

ENGINEERING CONNECTION ASSESSMENT

Engineering Connection Assessment

P2102 EPC SS-37 Substation Upgrade

ENMAX Power Corporation (EPC)

Date: June 14th, 2022

Version: V1

Classification: Public



Mahmoud Ahmed
June 16th, 2022
APEGA ID # 280036

Role	Name	Date	Signature
Prepared	Mahmoud Ahmed, P. Eng.	June 14th, 2022	Mahmoud Ahmed
Reviewed	Myron Jin-Li, P.Eng.	June 14th, 2022	Myr J.
Approved	Pravin Koshti, P.Eng.	June 16th, 2022	Pravin Koshti

NOTE:

The conclusions and recommendations in this report are based on the results presented in *Attachment A: Engineering Connection Assessment: Study Results*, which was prepared by a third party consultant in accordance with the AESO Connection Process.

The AESO has reviewed the *Engineering Connection Assessment: Study Results*, and finds it acceptable for the purpose of assessing the potential impacts of the proposed connection on the performance of the Alberta interconnected electric system.

Contents

1	Introduction	3
1.1	Project Overview.....	3
2	Assessment Scope	4
2.1	Objectives	4
2.2	Existing System	4
2.3	Study Area	4
3	Connection Alternatives	5
3.1	Overview	5
3.2	Connection Alternatives Examined.....	5
3.3	Connection Alternatives Selected for Further Study.....	7
3.4	Connection Alternatives Not Selected for Further Study	7
4	Assessment Approach	8
4.1	Standards, Criteria and Assumptions	8
4.2	Studies Performed	8
4.2.1	<i>Power Flow Studies</i>	8
4.2.2	<i>Voltage Stability Studies</i>	9
4.2.3	<i>Short-Circuit Current Level Studies</i>	9
5	Results.....	10
5.1	Overview	10
6	Project Dependencies.....	11
7	Conclusions and Recommendations	12

Tables

Table 4-1: Connection Study Scenarios.....	8
--	---

Attachments

Attachment A: Engineering Connection Assessment Results

1 Introduction

This AESO Engineering Connection Assessment describes the engineering studies that were completed to assess the impact of the Project (as defined below) on the performance of the Alberta interconnected electric system (AIES). This report also provides the AESO's conclusions and recommendations based on the results of the engineering studies.

Attached to this Engineering Connection Assessment are the results of the engineering studies (see Attachment A) and the scope and methodology used to perform the studies (see Attachment A1 to Attachment A). These attachments provide details regarding the technical criteria, assumptions, and methods for performing these engineering studies, and the results of the engineering studies.

1.1 Project Overview

ENMAX Power Corporation (EPC) (Market Participant), in its capacity as the legal owner of an electric distribution system (DFO), has submitted a request for system access service to the Alberta Electric System Operator (AESO) to improve the reliability of the electrical service in the Southeast area of Calgary.

The Market Participant's request includes a request for a Rate DTS, *Demand Transmission Service*, contract capacity increase of 26 MW, from 40 MW to 66 MW, for the system access service provided at SS-37 substation and a request for transmission development (collectively, the Project).

The scheduled in-service date (ISD) for the Project is October 28, 2024.

2 Assessment Scope

2.1 Objectives

The objectives of the AESO Engineering Connection Assessment are as follows:

- Assess the impact of the Project on the performance of the AIES.
- Evaluate Project connection alternatives and identify the AESO's preferred alternative.
- Recommend mitigation measures, if required, to reliably connect the Project to the AIES.
- Identify Project dependencies, including any TFO projects or AESO plans to expand or enhance the transmission system that must be completed prior to connection.

2.2 Existing System

Geographically, the Project is located in the AESO planning area of Calgary (Area 6), which is part of the AESO Calgary planning region. Calgary (Area 6) is surrounded by the planning areas of High River (Area 46), Strathmore (Area 45), Seebe (Area 44), and Airdrie (Area 57).

From a transmission system perspective, Calgary (Area 6) consists primarily of a 240 kV and 138 kV transmission system. Calgary (Area 6) is connected to High River (Area 46), Strathmore (Area 45), and Airdrie (Area 57), Seebe (Area 44), Brooks (Area 47), and Red Deer (Area 35).

Existing constraints in the Calgary planning region are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, Real Time Transmission Constraint Management (TCM Rule).

2.3 Study Area

The Study Area for the Project consists of the AESO Planning area of Calgary (Area 6), including the tie lines connecting this planning area to the rest of the AIES. All transmission facilities within the Study Area will be studied and monitored for violations of the Reliability Criteria (defined in Section 3.1 of Attachment A1).

3 Connection Alternatives

3.1 Overview

The AESO, in consultation with the TFO in the Study Area and the Market Participant, examined five alternatives to meet the DFO's request for system access service, as detailed in Section 3.2.¹

3.2 Connection Alternatives Examined

Below is a description of the developments associated with the transmission alternatives that were examined for the Project.

Alternative 1 – Distribution Load Transfer

EPC has determined that load transfer to adjacent substations doesn't meet the EPC Distribution System Performance Standard requirements. Therefore, this alternative is not acceptable as it would not address the reliability concerns over the planning horizon.

Alternative 2 – Upgrade the existing SS-37 substation

This alternative includes the following developments:

- Upgrade the existing SS-37 substation, including replacing the existing 13/25 kV transformer with one 138/25 kV transformer, adding one 138 kV circuit breaker; and
- Add or modify associated equipment as required for the above transmission developments

Alternative 3 –Upgrade the existing SS-38 substation

This alternative includes the following developments:

- Upgrade the existing SS-38 substation including adding one 138/25 kV transformer, one 138 kV bus-tie breaker;
- Discontinue from use for transmission purposes the existing 13/25 kV 10.13.3 MVA autotransformer at SS-37 substation; and
- Add or modify associated equipment as required for the above transmission developments.

Alternative 4 –Upgrade the existing SS-24 substation

This alternative includes the following developments:

¹ These alternatives reflect more up-to-date engineering design than the alternatives identified in EPC's Statement of Need (SON), which is filed under a separate cover.

- Upgrade the existing SS-24 substation including adding one 138/25 kV transformer and one 25 kV feeder breaker; and;
- Add or modify associated equipment as required for the above transmission developments.

Alternative 5 –New POD with an in-and-out connection to the existing 240 kV transmission line 765L

This alternative includes the following developments:

- Add one new 138/25 kV POD substation, including one 138/25 kV transformer;
- Add two 138 kV circuits, approximately 1 km long each, to connect the new substation to the existing 138 kV transmission line 765L (between the existing Janet 74S and Strathmore 151S substations) using an in-and-out configuration.
- Discontinue from use for transmission purposes the existing 13/25 kV 10/13.3 MVA autotransformer at SS-37 substation; and
- Add or modify associated equipment as required for the above transmission developments.

Alternative 6 –Upgrade the existing Chestermere 419S substation

This alternative includes the following developments:

- Upgrade the existing Chestermere 419S substation, including adding one 138/25 kV transformer dedicated for EPC load; ;
- Discontinue from use for transmission purposes the existing 13/25 kV 10/13.3 MVA autotransformer at SS-37 substation; and
- Add or modify associated equipment as required for the above transmission developments.

3.3 Connection Alternatives Selected for Further Study

Alternative 2 is considered technically feasible and therefore, it is selected for further study.

3.4 Connection Alternatives Not Selected for Further Study

Alternative 1 would not address the reliability concerns over the planning horizon, therefore it will not be considered.

Alternative 3 and Alternative 6 are considered technical feasible; however, they require additional distribution feeders to be constructed, which would result in greater losses, greater impact and significantly higher costs compared to Alternative 2 and 4. Therefore, Alternative 3 and Alternative 6 will not be studied.

Alternative 4 is considered technically feasible; however, it has higher transmission and distribution costs as compared to Alternative 2. Therefore, it will be ruled out.

Alternative 5 is also technical feasible; however, it requires the construction of a new substation, which has significantly higher costs compared to alternative 2. Therefore, it will not be studied.

4 Assessment Approach

4.1 Standards, Criteria and Assumptions

A detailed description of the standards, criteria, and assumptions that were used for the connection assessment is provided in Attachment A (see Attachment A1).

4.2 Studies Performed

At the time of study, the scheduled ISD for the Project is May 30, 2025. Therefore, studies were performed using scenarios for 2025 Summer Peak (SP) and 2025 Winter Peak (WP). As the ISD has since shifted to October 2024, the studies herein remain valid for the revised ISD.

Short-circuit studies were performed using the 2025 WP pre-Project scenario, 2025 WP and 2031 WP post-Project scenarios.

Table 4-1 lists the study scenarios. Post-Project scenarios reflect the final requested Rate DTS contract capacity increase of 26 MW at the ENMAX No. 37 Substation (SS-37).

Table 4-1: Connection Study Scenarios

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
Pre-Project					
1A	2025 Summer Peak (SP)	Moderate generation in Calgary Area with one Sheppard Energy Centre (SEP) unit offline (N-G)	2025 SP Pre-Project A	0	0
2A	2025 Winter Peak (WP)		2025 WP Pre-Project A	0	0
1B	2025 SP	High Flow South-North	2025 SP Pre-Project B	0	0
Post-Project					
3A	2025 SP	Moderate generation in Calgary Area with one Sheppard Energy Centre (SEP) unit offline (N-G)	2025 SP Post-Project A	26	0
4A	2025 WP		2025 WP Post-Project A	26	0
3B	2025 SP	High Flow South-North	2025 SP Post-Project B	26	0
5	2031 WP	All generation in the Study Area ON	2031 WP Post-Project	26	0

The AESO Planning Region load forecasts used for the connection studies were based on the AESO's 2021 Long-term Outlook (2021 LTO).

4.2.1 Power Flow Studies

The purpose of the power flow studies is to identify and quantify any thermal and voltage criteria violations in the Study Area.

In addition, power flow studies are also used to identify POD low voltage bus voltage deviations beyond the limits listed in Table 3-1 of Attachment A1.²

Power flow studies were performed for 2025 Summer Peak (SP)-A, 2025 Summer Peak (SP)-B and 2025 Winter Peak (WP)-A Pre-Project scenarios, and for 2025 SP-A, 2025 SP-B, and 2025 WP-A post-Project scenarios.

4.2.2 Voltage Stability Studies

The purpose of the voltage stability studies is to determine the ability of the transmission system to maintain voltage stability at the busses in the Study Area.

Voltage stability studies were performed for 2025 WP-A and 2025 SP-A post-Project scenarios.

4.2.3 Short-Circuit Current Level Studies

The purpose of short-circuit current level studies is to determine the expected system short-circuit current levels in the vicinity of the Project.

Short circuit studies were performed for the 2025 WP pre-Project scenario, 2025 WP and 2031 WP post-Project scenarios.

² The AESO's desired post-contingency voltage deviations for low voltage busses represent guidelines rather than criteria. A POD bus voltage deviation that exceeds the desired limits shown in Table 3-1 of Attachment A1 does not represent a Reliability Criteria violation. Mitigation measures would not be developed to specifically address POD bus voltage deviations that exceed the desired values in Table 3-1 of Attachment A1.

5 Results

5.1 Overview

Under Category A and Category B conditions, no Reliability Criteria violations or POD bus voltage deviations were observed.

The short-circuit current levels were found to be within the typical capability of the nearby facilities.

Detailed study results are provided in Attachment A.

6 Project Dependencies

The Project does not require the completion of any other AESO plans to expand or enhance the transmission system prior to connection.

7 Conclusions and Recommendations

Based on the study results, Alternative 2 is technically viable and will not adversely affect the performance of the transmission system. The connection assessment did not identify any system performance issues in the pre-Project and post-Project scenarios studied.

The AESO recommends proceeding with the Project using Alternative 2 as the preferred alternative to respond to the DFO's request for system access service.

Alternative 2 involves upgrading the existing SS-37 substation, replacing the existing 13/25 kV transformer with one 138/25 kV transformer, and adding one 138 kV circuit breaker. The DFO has advised that this alternative will also require the addition of 11 25 kV circuit breakers.

It is recommended that the 138/25 kV transformer at SS-37 substation have a transformation capability of 50 MVA, based on the requested Rate DTS contract capacity increase and the DFO's distribution system performance standard for their substations.

Attachment A: Engineering Connection Assessment Results

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

ENMAX Power Corporation (EPC)

Date: April 25, 2022

Version: V1D2



Role	Name	Date	Signature
Prepared	Busayo Akinloye, P. Eng	26-May-2022	
Reviewed	Kevin Neithercut, P. Eng.	26-May-22	
Approved	Igor Prelevic, P. Eng	26-May-2022	

PERMIT TO PRACTICE ENMAX POWER CORPORATION	
RM SIGNATURE:	
RM APEGA ID #:	80449
DATE:	May 26/22
PERMIT NUMBER: P006756	
The Association of Professional Engineers and Geoscientists of Alberta (APEGA)	

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

Contents

1	Introduction	1
2	Pre-Project Study Results	2
2.1	Power Flow Studies	2
2.1.1	Scenario 1: 2025 SP Pre-Project A.....	2
2.1.2	Scenario 2: 2025 WP Pre-Project A.....	2
2.1.3	Scenario 3: 2025 SP Pre-Project B.....	3
3	Post-Project Study Results	4
3.1	Power Flow Studies	4
3.1.1	Scenario 5: 2025 SP Post-Project A.....	4
3.1.2	Scenario 6: 2025 WP Post-Project A.....	4
3.1.3	Scenario 7: 2025 SP Post-Project B.....	4
3.2	Voltage Stability Studies	6
3.2.1	Scenario 5: 2025 SP Post-Project A.....	6
3.2.2	Scenario 6: 2025 WP Post-Project A.....	6
4	Short Circuit Studies.....	8
4.1	Pre-Project Results	8
4.2	Post-Project Results	8
4.2.1	Scenario 5: 2025 WP Post-Project B.....	8
4.2.2	Scenario 5: 2031 WP Post-Project	9

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

Tables

Table 3-1: Voltage Stability Study Results under Category B Conditions for Scenario 5.....	6
Table 3-2: Voltage Stability Study Results under Category B Conditions for Scenario 6.....	7
Table 4-1: Pre-Project Short-Circuit Current Levels for 2025 WP Pre-Project B.....	8
Table 4-2: Post-Project Short-Circuit Current Levels for 2025 WP Post-Project B.....	8
Table 4-3: Post-Project Short-Circuit Current Levels for 2031 WP Post-Project.....	9

Attachments

Attachment A1 Engineering Connection Assessment: Study Scope

Attachment A2 Pre-Project Power Flow Diagrams

Attachment A3 Post-Project Power Flow Diagrams

Attachment A4 Post-Project Voltage Stability Diagram

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

1 Introduction

This report presents the results of the engineering studies that were completed by ENMAX Power Corporation (EPC) (the Studies Consultant) to assess the impact of the Project (as defined in Attachment A1: AESO Engineering Connection Assessment Scope) on the performance of the Alberta interconnected electric system (AIES). The studies were performed in accordance with Attachment A1: AESO Engineering Connection Assessment: Study Scope, which was prepared by the AESO.

The power system network analysis tool that was used for the studies in this connection assessment was PSS/E version 34.

2 Pre-Project Study Results

This section describes the results of the pre-Project power flow studies.

2.1 Power Flow Studies

Power flow diagrams illustrating the pre-Project power flow studies results for Category A and Category B conditions are provided in Attachment A2.

2.1.1 Scenario 1: 2025 SP Pre-Project A

Category A Conditions

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.

2.1.2 Scenario 2: 2025 WP Pre-Project A

Category A Conditions

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

2.1.3 Scenario 3: 2025 SP Pre-Project B

Category A Conditions

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.

3 Post-Project Study Results

This section describes the results of the post-Project power flow studies and voltage stability studies.

3.1 Power Flow Studies

Power flow diagrams illustrating the post-Project power flow studies results for Category A and Category B conditions are provided in Attachment A3.

3.1.1 Scenario 5: 2025 SP Post-Project A

Category A Conditions

No Reliability Criteria violations were observed under Category A conditions.

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

3.1.2 Scenario 6: 2025 WP Post-Project A

Category A Conditions

No Reliability Criteria violations were observed under Category A conditions.

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

3.1.3 Scenario 7: 2025 SP Post-Project B

Category A Conditions

No Reliability Criteria violations were observed under Category A conditions.

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.

Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

3.2 Voltage Stability Studies

3.2.1 Scenario 5: 2025 SP Post-Project A

Voltage stability analysis was performed for the 2025 SP Post-Project A scenario. The reference load level for the Study Area is 1,605 MW. For Category B contingencies, the minimum incremental load transfer is 5% of the reference load, or 80.25 MW ($0.05 \times 1,605 \text{ MW} = 80.25 \text{ MW}$), to meet the voltage stability criteria.

Table 3-1 provides the voltage stability study results under the Category A condition and for the five worst contingencies under Category B conditions. The voltage stability diagrams are provided in Attachment A4.

The voltage stability margin was met for all studied conditions

Table 3-1: Voltage Stability Study Results under Category B Conditions for Scenario 5

Contingency (System Element Lost)	From	To	Maximum Incremental Transfer (MW)	Maximum Incremental Transfer (%)	Meets Criteria?
N-0	System Normal		810	52.1	Yes
906L	155	161	740	47.6	Yes
928L	155	161	740	47.6	Yes
918L	187	639	770	49.5	Yes
37.82L	207	574	770	49.5	Yes
PCE02L	198	290	750	48.2	Yes

3.2.2 Scenario 6: 2025 WP Post-Project A

Voltage stability analysis was performed for the 2025 WP Post-Project A scenario. The reference load level for the Study Area is 1,618 MW. For Category B contingencies, the minimum incremental load transfer is 5% of the reference load, or 80.9 MW ($0.05 \times 1,618 \text{ MW} = 80.9 \text{ MW}$), to meet the voltage stability criteria.

Table 3-1 provides the voltage stability study results under the Category A condition and for the five worst contingencies under Category B conditions. The voltage stability diagrams are provided in Attachment A4.

The voltage stability margin was met for all studied conditions

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

Table 3-2: Voltage Stability Study Results under Category B Conditions for Scenario 6

Contingency (System Element Lost)	From	To	Maximum Incremental Transfer (MW)	Maximum Incremental Transfer (%)	Meets Criteria?
N-0		System Normal	970	62.6	Yes
906L	155	161	900	58.1	Yes
928L	155	161	900	58.1	Yes
918L	187	639	930	60.1	Yes
37.82L	207	574	910	58.8	Yes
WATL	159	485	880	56.8	Yes

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

4 Short Circuit Studies

4.1 Pre-Project Results

Pre-Project short-circuit current levels are provided in Table 4-1¹.

Table 4-1: Pre-Project Short-Circuit Current Levels for 2025 WP Pre-Project B

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3-Φ Fault (kA)	Positive Sequence Thevenin Source Impedance (R_1+jX_1) (pu)	1-Φ Fault (kA)	Zero Sequence Thevenin Source Impedance (R_0+jX_0) (pu)
ENMAX No. 23	138.0	139.804	21.888	0.924+3.679j	14.960	1.553+8.969j
ENMAX No. 24	138.0	139.669	24.429	0.802+3.304j	19.641	0.901+5.857j
ENMAX No. 37	138.0	139.987	22.636	0.923+3.554j	15.652	1.473+8.503j
ENMAX No. 38	138.0	140.068	29.372	0.653+2.756j	26.604	0.449+3.733j
ENMAX No. 39	138.0	140.339	25.930	1.219+5.596j	25.624	0.994+5.978j
JANET 74S	240.0	249.657	5.120	0.278+3.009j	5.430	0.072+2.507j
	138.0	140.156	5.312	0.328+2.885j	5.611	0.08+2.444j

4.2 Post-Project Results

4.2.1 Scenario 5: 2025 WP Post-Project B

Post-Project short-circuit current levels for 2025 WP Post-Project B are provided in Table 4-2.

Table 4-2: Post-Project Short-Circuit Current Levels for 2025 WP Post-Project B

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3-Φ Fault (kA)	Positive Sequence Thevenin Source Impedance (R_1+jX_1) (pu)	1-Φ Fault (kA)	Zero Sequence Thevenin Source Impedance (R_0+jX_0) (pu)
ENMAX No. 23	138.0	140.079	21.971	0.931+3.667j	14.996	1.553+8.969j
ENMAX No. 24	138.0	139.928	24.542	0.811+3.288j	19.697	0.901+5.857j
ENMAX No. 37	138.0	140.044	22.717	0.928+3.546j	15.692	1.473+8.503j
ENMAX No. 38	138.0	140.191	29.502	0.659+2.746j	26.693	0.449+3.733j
ENMAX No. 39	138.0	140.524	26.044	1.227+5.584j	25.722	0.994+5.978j

¹ Short-circuit current studies were based on modeling information provided to the AESO by third parties. The authenticity of the modeling information has not been validated. Fault levels could change as a result of system developments, new customer connections, or additional generation in the area. It is recommended that these changes be monitored and fault levels reviewed to ensure that the fault levels are within equipment operating limits. The information provided in this study should not be used as the sole source of information for electrical equipment specifications or for the design of safety-grounding systems.

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

JANET 74S	240.0	250.296	5.082	0.28+3.005j	5.389	0.072+2.507j
	138.0	140.339	5.323	0.327+2.885j	5.623	0.08+2.444j

4.2.2 Scenario 5: 2031 WP Post-Project

Post-Project short-circuit current levels for 2031 WP Post-Project are provided in Table 4-3.

Table 4-3: Post-Project Short-Circuit Current Levels for 2031 WP Post-Project

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3-Φ Fault (kA)	Positive Sequence Thevenin Source Impedance (R_1+jX_1) (pu)	1-Φ Fault (kA)	Zero Sequence Thevenin Source Impedance (R_0+jX_0) (pu)
ENMAX No. 23	138.0	139.226	21.845	0.891+3.607j	14.829	1.535+8.897j
ENMAX No. 24	138.0	138.998	24.492	0.765+3.22j	19.583	0.879+5.771j
ENMAX No. 37	138.0	139.596	22.567	0.892+3.494j	15.515	1.458+8.441j
ENMAX No. 38	138.0	139.795	29.647	0.608+2.67j	26.743	0.43+3.646j
ENMAX No. 39	138.0	140.191	26.498	1.113+5.415j	26.036	0.967+5.871j
JANET 74S	240.0	252.130	4.927	0.313+3.007j	5.227	0.072+2.507j
	138.0	139.777	5.205	0.309+2.887j	5.517	0.079+2.415j

Engineering Connection Assessment: Study Results

P2102 EPC East Calgary Area Load

V1D2

Attachment A1

Engineering Connection Assessment: Study Scope

Engineering Connection Assessment: Study Scope


P2102 EPC East Calgary Area Load

ENMAX Power Corporation (EPC)

Date: May 16, 2022

Version: V1

Classification: Public

Company Name	Name and Credentials	Date	Signature
Enmax Power Corporation (Studies Consultant and Transmission Facility Owner)	Busayo Akinloye P.Eng.	May 17, 2022	
AESO	Mahmoud Ahmed, P. Eng.	May 18, 2022	
Enmax Power Corporation (DFO, Market Participant)			

Contents

1	Introduction	1
1.1	Project Overview.....	1
1.2	Existing System Overview	1
1.2.1	Study Area.....	1
1.2.2	Existing Constraints.....	4
2	Connection Alternative for Stage 3 to be Studied	5
2.1	Alternative 2 – Addition of 25 kV capacity at SS-37	5
3	Criteria, Standards and Requirements.....	6
3.1	AESO Reliability Criteria.....	6
3.2	ISO Rules and Information Documents	7
4	Scenarios and Assumptions	8
4.1	Scenarios	8
4.2	Assumptions	8
4.2.1	<i>System Project Assumptions</i>	8
4.2.2	<i>Connection Project Assumptions</i>	8
4.2.3	<i>Load Assumptions</i>	9
4.2.4	<i>Generation Assumptions</i>	9
4.2.5	<i>Intertie Flow Assumptions</i>	14
4.2.6	<i>HVDC Power Order Assumptions</i>	14
4.2.7	<i>Transmission Facility Ratings</i>	15
4.2.8	<i>Voltage Profile Assumption</i>	17
5	Study Methodology	18
5.1	Power Flow Studies	18
5.1.1	<i>Contingencies to be Studied</i>	19
5.2	Voltage Stability Studies	19
5.2.1	<i>Contingencies to be Studied</i>	19
5.3	Short-Circuit Current Level Studies	19
6	Mitigation Measures.....	21
6.1	Development.....	21
6.2	Evaluation	21
6.2.1	<i>Post-Mitigation Studies</i>	21
6.2.2	<i>Constraint Effective Factor Studies</i>	21
7	Changes to Study Assumptions	22

Tables

Table 1-1: Project Load and Generation Details	1
Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses	7

Table 4-1: Connection Study Scenarios.....	8
Table 4-2: Forecast Load (at AESO Calgary Planning Region Peak)	9
Table 4-3: Existing Generation (excluding Wind and Solar) Dispatch Conditions	10
Table 4-4: Dispatch Conditions for Existing and Under Construction Wind Generation Facilities.....	10
Table 4-5: Dispatch Conditions for Existing and Under Construction Solar Generation Facilities	11
Table 4-6: Dispatch Conditions for Planned Wind Generation Projects	12
Table 4-7: Dispatch Conditions for Planned Solar Generation Projects	13
Table 4-8: Intertie Flows for by Scenario	14
Table 4-9: HVDC Power Order by Scenario	14
Table 4-10: HVDC to Adjacent AC System MVar Exchange Limits	15
Table 4-11: Thermal Rating Assumptions for Key Transmission Lines in the Study Area	15
Table 4-12: Summary of Key Transformer Ratings in the Study Area.....	16
Table 4-13: Summary of Key Shunt Elements in the Study Area	17
Table 5-1: Summary of the Studies to be Performed.....	18

Figures

Figure 1-1: Transmission System in the Study Area.....	3
Figure 2-1: Connection Alternative 1.....	5

Attachments

Attachment A: Transmission Planning Criteria – Basis and Assumptions

1 Introduction

This Study Scope provides an overview of the engineering studies to be completed by ENMAX Power Corporation (EPC, the Studies Consultant) to assess the impact of the Project (as defined in section 1.1) on the performance of the Alberta interconnected electric system (AIES). Technical criteria, assumptions and methods for performing these engineering studies are provided in this document.

1.1 Project Overview

EPC, in its capacity as the legal owner of an electric distribution system (DFO), has submitted a request for system access service to the Alberta Electric System Operator (AESO) to increase the capacity at ENMAX No. 37 Substation (SS-37) located in the Calgary planning area.

The DFO's request includes a request for a Rate DTS, Demand Transmission Service, contract capacity increase of 26 MW, from 40 MW to 66 MW, for the system access service provided at SS-37 and a request for transmission development (collectively, the Project). Details on the need for the enhancement can be found in the DFO's Statement of Need (SON).

The Project in-service date (ISD) used for the purpose of the studies is October 28, 2024.

There are no generation components of the Project.

Table 1-1: Project Load and Generation Details

Project Component		Description
Load	Existing Rate DTS, <i>Demand Transmission Service</i> , contract capacity	40 MW at SS-37
	Requested Rate DTS	An increase of 26 MW at SS-37 to 66 MW
	Type	residential, commercial, industrial
	Motors (number and size)	N/A
	Power factor	0.9 pf
	Future load expansion plans	No

Note:

MARP and MC are defined in the AESO's *Consolidated Authoritative Document Glossary*, which can be found on the AESO's website.

1.2 Existing System Overview

1.2.1 Study Area

Geographically, the Project is located in the AESO planning area of Calgary (Area 6), which is part of the AESO Calgary planning region.

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



The Study Area consists of Calgary Area (Area 6), including the tie lines connecting this planning area to the rest of the AIES.

The existing transmission system in the Study Area is shown in Figure 1-1.


Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Figure 1-1: Transmission System in the Study Area



1.2.2 Existing Constraints

Existing constraints in the Study Area are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management* (TCM Rule).

There are a number of constraints in the Study Area that are mitigated by existing remedial action schemes (RASs) and/or other protection schemes.

The following existing RASs and/or other protection schemes are used to manage constraints in the area:

- RAS 11. Bennett 520S Underfrequency And Power Scheme
- RAS 12. Bennett 520S Undervoltage & Power Scheme
- RAS 133. Beddington 162S Overload Mitigation Scheme
- RAS 136. Direct Transfer Trip to MATL on Loss of 1201L
- RAS 145. Shepard RAS - Mitigation of 138 kV Thermal Constraints on ENMAX System
- RAS 153. Mitigation of 138 kV Thermal Constraints on ENMAX System at SS-65
- RAS 157. Chestermere 419S Overload and Voltage Stability Mitigation

2 Connection Alternative for Stage 3 to be Studied

The following alternative will be studied:


2.1 Alternative 2 –Upgrade the existing SS-37 substation

This alternative includes the following developments:

- Upgrade the existing SS-37 substation, including replacing the existing 13/25 kV transformer with one 138/25 kV transformer, adding one 138 kV circuit breaker and eleven 25 kV circuit breakers; and
- Add or modify associated equipment as required for the above transmission developments

The proposed connection configuration is shown in Figure 2-1.

Figure 2-1: Connection Alternative 2



3 Criteria, Standards and Requirements

3.1 AESO Reliability Criteria

The Transmission Planning (TPL) Standards, which are included in the Alberta Reliability Standards, and *Transmission Planning Criteria – Basis and Assumptions* (see Attachment A), (collectively, the Reliability Criteria) will be applied to evaluate system performance under Category A system conditions (i.e., all elements in-service) and following Category B contingencies (i.e., single element outage), prior to and following the studied alternatives. Below is a summary of Category A and Category B system conditions.

Category A, often referred to as the N-0 condition, represents a normal system with no contingencies and all facilities in service. Under this condition, the system must be able to supply all firm load and firm transfers to other areas. All equipment must operate within its applicable rating, voltages must be within their applicable range, and the system must be stable with no cascading outages.

Category B events, often referred to as an N-1 or N-G-1 with the most critical generator out of service, result in the loss of any single specified system element under specified fault conditions with normal clearing. These elements are a generator, a transmission circuit, a transformer, or a single pole of a DC transmission line. The acceptable impact on the system is the same as Category A. Planned or controlled interruptions of electric supply to radial customers or some local network customers, connected to or supplied by the faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted firm (non-recallable reserved) transmission service electric power transfers.

The TPL standards, TPL-001-AB-0 and TPL-002-AB1-0, have referenced Applicable Ratings when specifying the required system performance under Category A and Category B events. For the purpose of applying the TPL standards to the studies documented in this report, Applicable Ratings are defined as follows:

- Normal thermal rating of the line's loading limits for each season;
- The highest specified loading limits for transformers;
- For Category A conditions: Voltage range under normal operating condition per AESO Information Document #2010-007RS, *General Operating Practices – Voltage Control* (ID #2010-007RS). For the busses not listed in ID #2010-007RS, Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions* applies;
- For Category B conditions: The extreme voltage range values per Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions*; and
- Desired post-contingency voltage deviation limits for three defined post-event timeframes as provided in Table 3-1.

Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses

Parameter and reference point	Time Period		
	Post Transient (up to 30 sec)	Post Auto Control (30 sec to 5 min)	Post Manual Control (Steady State)
Voltage deviation from steady state at point of delivery (POD) low voltage bus.	±10%	±7%	±5%

3.2 ISO Rules and Information Documents

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for the Study Area.

The TCM Rule will be followed to set up the study scenarios and assess the impact of the Project. In addition, due regard will be given to the following:

- The AESO's *Connection Study Requirements*;
- Section 502.7 of the ISO rules, *Load Facility Technical Requirements*;

4 Scenarios and Assumptions

4.1 Scenarios

The following section describes the scenarios to be studied and the assumptions to be used in the studies.

Connection scenarios must be studied as outlined in Table 4-1.

Table 4-1: Connection Study Scenarios

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
Pre-Project					
1A	2025 Summer Peak (SP)	Moderate generation in Calgary Area with one Sheppard Energy Centre (SEP) unit offline (N-G)	2025 SP Pre-Project A	0	0
2A	2025 Winter Peak (WP)		2025 WP Pre-Project A	0	0
1B	2025 SP	High Flow South-North	2025 SP Pre-Project B	0	0
Post-Project					
3A	2025 SP	Moderate generation in Calgary Area with one Sheppard Energy Centre (SEP) unit offline (N-G)	2025 SP Post-Project A	26	0
4A	2025 WP		2025 WP Post-Project A	26	0
3B	2025 SP	High Flow South-North	2025 SP Post-Project B	26	0
5	2031 WP	All generation in the Study Area ON	2031 WP Post-Project	26	0

4.2 Assumptions

4.2.1 System Project Assumptions

The pre-Project and post-Project connection assessment will not include any system transmission projects because there are no planned system transmission developments in the Study Area that are expected to be in service before the scheduled Project ISD.

4.2.2 Connection Project Assumptions

The pre-Project and post-Project connection assessment will not include any other connection projects in the Study Area.

4.2.3 Load Assumptions

The load forecast to be used for the studies is shown in Table 4-2 and is a forecast for the AESO Calgary Planning Region peak based on the *AESO 2021 Long-term Outlook* (2021 LTO)¹ with modifications to incorporate the latest forecast intelligence. For the post-Project studies, when the Study Area loads are modified to align with the regional load forecast, the active power to reactive power ratio in the base case scenarios shall be maintained.

Table 4-2: Forecast Load (at AESO Calgary Planning Region Peak)

AESO Planning Region Name	Forecast Peak Load by Year/Season (MW)	
	2025 SP	2025 WP
Calgary Planning Region ¹	1,605	1,618

Note:

¹The Calgary Region comprises the following AESO planning areas: Calgary (Area 6) and Airdrie (Area 57)

IDEV files contain non-motor loads in zones 34, 36, and 351. These loads are not accounted for in the forecasted peak loads shown above and should not be considered when scaling load. The AESO engineer will provide guidance to load scaling procedures as required.

4.2.4 Generation Assumptions

The generation forecast to be used for the studies is based on the 2021 LTO with modifications to incorporate the latest forecast intelligence. The generation assumptions for the studies will assume Economic generation dispatch condition. Additional studies may be required in the event of changes to the AESO's corporate forecast.

The existing generation (excluding wind and solar) dispatch conditions for the study scenarios are described in Table 4-3.

Sheppard Energy Centre (SEP) unit 3 was determined to be the critical generator and shall be modelled as being offline to simulate the N-G condition in the corresponding study scenarios.

The wind and solar generation dispatch for the High South to North Flow scenarios is shown in Table 4-4, Table 4-5, Table 4-6, and Table 4-7².

¹ The 2021 LTO is available on the AESO website.

² To re-adjust the intertie, scale generation in the Edmonton and North-East Regions.

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Table 4-3: Existing Generation (excluding Wind and Solar) Dispatch Conditions

Facility	Unit	Bus Number	Area	Pmax (MW)	Unit Net Generation (MW)			
					N-G Dispatch		High South to North Flow	
					2025 SP	2025 WP	2025 SP	
Shepard Energy Centre	GT2	774	6	276	N-G	N-G	767	
	GT1	775	6	276	477	492		
	ST1	773	6	318				
Calgary Energy Centre	GT1	4187	6	190	210	235	210	
	ST1	3187	6	135				
Balzac	GT1	3290	6	64.1	40	47	40	
	GT2	4290	6	64.1				
	ST1	4290	6	26.5				
University of Calgary	GT1	2556	6	15	11	13	11	

Notes:

a "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

b "N-G" indicates the critical generating unit that is assumed by the AESO to be offline to test the N-G contingency condition

Table 4-4: Dispatch Conditions for Existing and Under Construction Wind Generation Facilities

Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generations (MW)
				2025 SP
Ardenville Wind (ARD1)	53	4735, 4740	68	54.4
Blackspring Ridge (BSR1)	49	61736, 61737	300	240.0
Blue Trail Wind (BTR1)	53	66328, 67328	66	52.8
Bull Creek (BUL1 & BUL2)	37	550003, 550004	29.5	23.6
Castle River #1 (CR1)	53	2234, 3234	39	31.2
Castle Rock Ridge 2 (CRR2)	53	567221	30.6	24.5
Castle Rock Wind Farm (CRR1)	53	67221	77	61.6
Cowley Ridge (CRE3)	53	4264	20	16.0
Enmax Taber (TAB1)	52	15343, 16343	81	64.8
Ghost Pine (NEP1)	42	2621, 2622, 2623, 2624, 2625	82	65.6
Halkirk Wind Power Facility (HAL1)	42	66435, 67435	150	120.0
Kettles Hill (KHW1)	53	2402, 3402	63	50.4
McBride Lake Windfarm (AKE1)	53	2901, 3901, 4901	73	58.4

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generations (MW)
				2025 SP
Old Man River(OWF1)	53	61543	46	36.8
Riverview Wind Farm (RIV1)	53	69221	115	92.0
Soderglen Wind (GWW1)	53	12358, 13358	71	56.8
Summerview 1 (IEW1)	53	2338, 3338	66	52.8
Summerview 2 (IEW2)	53	4339, 5337	66	52.8
Suncor Chin Chute (SCR3)	54	2389	30	24.0
Suncor Magrath (SCR2)	53	11002	30	24.0
Suncor Wintering Hills (SCR4)	43	60789, 60791, 60793, 60846, 60848, 60850	88	70.4
Whitla Wind Power Facility (WHT1)	4	60990	201.6	161.3
Whitla Wind Power Facility (WHT2)	4	61990, 64990	151.2	121.0
Windrise (WRW1)	53	567031	207	165.6

Note:

a "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

Table 4-5: Dispatch Conditions for Existing and Under Construction Solar Generation Facilities

Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generations (MW)
				2025 SP
Brooks Solar (BSC1)	47	553257	15	12.0
Hull DER Solar (HUL1)	52	2401	24.5	19.6
Vauxhall Solar (VXH1)	52	4274	22	17.6
Suffield Solar (SUF1)	4	3270	23	18.4
Claresholm Solar (CLR1)	49	60894	58	46.4
Claresholm Solar (CLR2)	49	61894	75	60.0
Burdett (BRD1)	52	2269	11	8.8
Westfield Yellow Lake (WEF1)	52	557277	19	15.2
Burdett (BUR1)	52	557269	20	16.0
Hays Solar	52	554401	24	19.2
Jenner Solar DER	48	554986	23	18.4
Innisfail Solar (INF1)	39	557120	22	17.6

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generations (MW)
				2025 SP
P2362 Fortis Enchant 447S DER Solar	52	993287	22	17.6
P2363 Fortis Enchant 447S DER Solar	52	993289	18	14.4
P2364 Fortis Enchant 447S DER Solar	52	994287	9	7.2
P2365 Fortis Enchant 447S DER Solar	52	994289	23	18.4

Note:

^a "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

Table 4-6: Dispatch Conditions for Planned Wind Generation Projects

Facility Name and Code	Bus No.	Planned ISD	Planning Area No.	AESO Stage	MC (MW)	Unit Net Generations (MW)
						2025 SP
P1892 Fortis Buffalo Atlee Cluster 3 WAGF	552260	1-Dec-21	47	3	17.3	13.8
P1853 Fortis Buffalo Atlee Cluster 1 WAGF	553260	1-Dec-21	47	3	17.3	13.8
P2199 Buffalo Atlee Wind Farm 2	557261	1-Dec-21	47	3	13.8	11.0
P1719 Stirling WAGF Project	61630	1-Nov-22	54	5	113	90.4
P2122 EDF Cypress Wind	560003	1-Nov-22	4	5	201.6	161.3
P1533 Joss MPC WAGF	60798, 60799	30-Jun-22	47	5	122	97.6
P1698 Joss Jenner WAGF - Phase 2	61798, 61799	30-Jun-22	47	3	71.4	57.1
P1812 Suncor Forty Mile Granlea WAGF	61994, 62994	16-Nov-21	4	5	200	160.0
P2212 RES Rattlesnake Ridge	60873	30-Jul-21	4	5	117.6	94.1
P1718 Wheatland WAGF Project	60632, 61632	30-Jun-22	43	5	120	96.0
P1909 TransAlta Garden Plain Wind	565002	1-Jul-22	42	4	130	104.0
P2234 Jenner Wind Phase 3	61799	30-Jun-22	48	3	109.2	87.4
P1898 Pattern Lanfine North Wind	60996	30-Sep-22	42	5	145	116.0

Note:

^a "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Table 4-7: Dispatch Conditions for Planned Solar Generation Projects

Facility Name and Code	Bus No.	Planned ISD	Planning Area No.	AESO Stage	MC (MW)	Unit Net Generation s (MW)
						2025 SP
P2009 Greengate Travers MPC Solar & P2341 Travers Solar Phase 2	560026, 561026, 562026	Dec 10, 2021& Apr 1, 2022	49	5	465	372.0
P1831 Fortis 255S Vulcan Faribault Farms DG PV	4244	44340	49	5	22	17.6
P1850 Fortis Coaldale 254S DER Solar 3	554691	May. 24, 2021	54	5	22	17.6
P1851 Fortis Monarch 492S DER Solar	2005	May. 24, 2021	54	5	23.6	18.9
P1862 Fortis Spring Coulee 385S Solar DG	553246 554246	Oct. 15, 2021	55	5	29.5	23.6
P1870 Fortis Stavely 349S DER Solar	2004	1-Feb-22	49	5	18.5	14.8
P1918 FortisAlberta Conrad DER Solar 1	554291	21-Dec-21	52	5	23.4	18.7
P1932 FortisAlberta Namaka DER Solar	552340	3-Sep-21	45	5	20.1	16.1
P1959 FortisAlberta Conrad DER Solar 2	553291	21-Dec-21	52	5	22.5	18.0
P2029 FortisAlberta Strathmore 151S DER Solar 1	557259	8-Nov-21	45	5	19.5	15.6
P2030 FortisAlberta Strathmore 151S DER Solar 2	558259	8-Nov-21	45	5	25	20.0
P2195 FortisAlberta Bassano 435S DER Solar	557399	1-Feb-23	47	3	9.25	7.4
P2249 FortisAlberta Empress 394S DER Solar 1	558316	1-Nov-21	48	5	22	17.6
P2250 FortisAlberta Empress 394S DER Solar 2	558016	1-Nov-21	48	5	16	12.8
P2300 RESC Enterprise MPC Solar	563070	31-Aug-22	49	4	65	52.0
2335 Fortis Vulcan 255S DER Solar	990002	1-May-22	49	3	13	10.4
P2337 Dunmore Solar	560044	1-Apr-23	4	3	216	172.8

Note:

^a "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

4.2.5 Intertie Flow Assumptions

The intertie flow assumptions for the Alberta-British Columbia (AB-BC), Alberta-Saskatchewan (AB-SK), and Alberta-Montana (MATL) interties are shown in Table 4-8.

For the 2031 WP scenario, the intertie flow values should be set to the AESO planning base cases.

Table 4-8: Intertie Flows for by Scenario

Scenario Number	Scenario Name	Import (-) / Export (+) (MW) by Intertie		
		AB-BC	AB-SK	MATL
1A, 1B, 3A, 3B	2025 SP	-516	0	0
2A, 4A	2025 WP	-460	0	0

4.2.6 HVDC Power Order Assumptions

The Western Alberta Transmission Line (WATL) and the Eastern Alberta Transmission Line (EATL) are high-voltage direct current (HVDC) transmission lines. The HVDC power order assumptions for the studies will be set to minimize losses for the pre-Project and post-Project study scenarios.

For the 2031 WP scenario, the HVDC power order should be as per the AESO base cases and will not be adjusted.

Table 4-9: HVDC Power Order by Scenario

Scenario Number	Scenario Name	WATL (MW)*	EATL (MW)*
1A	2025 SP	100.0 N -> S	100.0 S -> N
2A	2025 WP	450.0 N -> S	100.0 S -> N
1B	2025 SP	250.0 S -> N	1000.0 S -> N
3A	2025 SP	100.0 N -> S	100.0 S -> N
4A	2025 WP	450.0 N -> S	100.0 S -> N
3B	2025 SP	250.0 S -> N	1000.0 S -> N

Notes:

N → S: HVDC flow direction is North to South

S → N: HVDC flow direction is South to North

The reactive power limits of the MVar exchanges between the HVDC terminals (WATL and EATL) and the connected alternating current (AC) transmission systems are shown in Table 4-10. These limits must be maintained when performing the studies.

Table 4-10: HVDC to Adjacent AC System MVAr Exchange Limits

HVDC Facility	North Terminal Reactive Power Limit (MVAr)	South Terminal Reactive Power Limit (MVAr)
EATL	-85 to 75	-35 to 35
WATL	-75 to 75	-35 to 35

4.2.7 Transmission Facility Ratings

The legal owners of transmission facilities (TFOs) provided the thermal ratings assumptions for the existing transmission lines in the Study Area. Table 4-11 shows the normal ratings and emergency ratings for the key transmission lines in the Study Area, which will be used to perform the engineering studies.

Table 4-11: Thermal Rating Assumptions for Key Transmission Lines in the Study Area

Line ID	Line Description	Voltage Class (kV)	Normal Rating (MVA)		Emergency Rating (MVA)	
			Summer	Winter	Summer	Winter
1064L	Janet 74S - Langdon 102S	240	974	1039 M	1039 M	1039 M
1065L	Janet 74S - Langdon 102S	240	974	1208	1169	1247 M
985L	Janet 74S - Shepard SS-25	240	973	1039 M	1017	1039 M
1003L	Janet 74S - Shepard SS-25	240	973	1039 M	1017	1039 M
932L	Janet 74S - Beddington SS-162	240	481	581	577	648 M
929L	Janet 74S - Hazelwood 287S	240	441 LTD-L	581	529 LTD-L	648 M
925L	Janet 74S - Red Deer 63S	240	476 M	571 M	524 M	619 M
901L	Janet 74S - Red Deer 63S	240	408	494	490	593
765L	Janet 74S - Strathmore 151S	138	85	90	94	99
23.80L	Janet 74S - SS-23	138	285	287	285	350
2.80L	SS-2 - SS-23	138	285	350	285	350
9.80L	SS-9 - SS-31	138	287	287	316	316
24.81L	SS-24 - SS-31	138	287	287	316	316
24.82L	SS-24 - SS-65	138	285	350	285	350
24.83L	Janet 74S - SS-24	138	322	408	354	430
37.82L	Janet 74S - SS-37	138	287	287	352	430
37.81L	SS-37 - SS-38	138	287	287	316	316
38.83L	SS-38 - SS-39	138	287	287	316	316
22.81L	SS-22 - SS-39	138	285	287	285	316
13.82L	SS-13 - SS-22	138	161	204	177	225

Engineering Connection Assessment: Study Scope

P2102 EPC East Calgary Area Load

V1



Line ID	Line Description	Voltage Class (kV)	Normal Rating (MVA)		Emergency Rating (MVA)	
			Summer	Winter	Summer	Winter
39.82L	SS-39 - SS-162	138	322	408	354	449
2.83L	SS-5 – 2.83 Tap point	138	322	408	354	449
2.83L	SS-13 – 2.83 Tap point	138	287	287	316	316
2.83L	SS-2 – 2.83 Tap point	138	338	343	342	343
2.82L	SS-2 - SS-5	138	322	328	327	328
11.81L	SS-11 - SS-13	138	287	287	316	316
11.83L	SS-11 - SS-162	138	330	398	330	398
26.83L	SS-26 - SS-65	138	285	350	285	350
26.81L	SS-26 - SS-32	138	285	287	285	316
31.84L	SS-31 - SS-32	138	161	191	177	210
2.81L	SS-2 - SS-9	138	287	287	316	316

Note:

"M" indicates that the transmission line rating is limited for reasons other than protection equipment, transformer, current transformer, line, ganged switch, circuit breaker, or regulator.

"LTD-L" indicates that the transmission line rating is long-term derated from LiDAR surveys

The TFOs provided the details of the substation transformers in the Study Area. The key transformers in the Study Area are shown in Table 4-12.

Table 4-12: Summary of Key Transformer Ratings in the Study Area

Substation Name and Number	Transformer ID	Transformer Voltages* (kV)	Transformer Rating (MVA)
Janet 74S	74ST1	240/138	341.8 (Summer) 400.0 (Winter)
	74ST2	240/138	341.8 (Summer) 400.0 (Winter)
SS-162	162.1TR	240/138	400
	162.2TR	240/138	400
East Calgary 5S	5ST1	240/138	400
	5ST2	240/138	400
SS-38	38.1TR	138/13.8	30
	38.2TR	138/13.8	30
	38.3TR	138/13.8	30
SS-37	37.1TR	138/13.8	50
	37.2TR	138/13.8	50
SS-24	24.1TR	138/25	50
	24.2TR	138/25	50

* System nominal voltage. May differ from rated bushing voltage.

The TFOs provided the details of the shunt elements in the Study Area. The key shunt elements in the Study Area are shown in Table 4-13.

Table 4-13: Summary of Key Shunt Elements in the Study Area

Substation Name and Number	Voltage Class (kV)	Capacitors	
		Number of Switched Shunt Blocks	Total at Nominal Voltage (MVA)
Janet 74S	240	2	268.8
	138	2	146.74
Sarcee 42S	240	2	201.6
	138	1	48.92
Langdon 102S	240	SVC (Continuous)	+216.28 to -296.2
SS-2	138	2	160.00
SS-14	138	2	48.91
SS-21	138	1	48.91
SS-31	138	1	48.11
SS-38	138	1	48.11
SS-41	138	1	53.96

4.2.8 Voltage Profile Assumption

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for key area busses prior to commencing any studies. Table 2-1 of the *Transmission Planning Criteria – Basis and Assumptions* applies for the busses not included in ID #2010-007RS. These voltages will be used to set the voltage profile for the study base cases prior to the power flow studies.

5 Study Methodology

The studies to be performed for this connection assessment are identified in Table 5-1.

Table 5-1: Summary of the Studies to be Performed

Scenario No. and Name	Power Flow		Voltage Stability		Transient Stability		Motor Starting		Short Circuit
	Category		Category		Category		Category		Category A
	A	B	A	B	A	B	A	B	
Pre-Project									
1A	2025 SP	X	X						
2A	2025 WP	X	X						X
1B	2025 SP	X	X						
Post-Project									
3A	2025 SP	X	X	X	X				
4A	2025 WP	X	X	X	X				X
3B	2025 SP	X	X						
5	2031 WP								X

For the engineering studies, all transmission facilities 69 kV and above, within the Study Area and the transmission lines connecting this planning area to neighbouring planning areas will be studied and monitored to assess the impact of the Project on the performance of the AIES, including any violations of the Reliability Criteria (as defined in Section 3.1).

5.1 Power Flow Studies

Power flow studies will be performed to identify thermal and voltage criteria violations as per the Reliability Criteria, and any deviations from the limits listed in Table 3-1.

For information purposes, the Studies Consultant must also provide, as a separate file, a list of any transmission elements where the thermal loading exceeds 95% of the element's normal rating under Category A and Category B conditions.

For the Category B power flow studies, the transformer taps and switched shunt reactive compensating devices such as shunt capacitors and reactors will be locked and continuous shunt devices will be enabled.

Voltage deviations at point-of-delivery (POD) low voltage busses will also be assessed for both the pre-Project and post-Project networks by first locking all tap changers and area shunt reactive compensating devices to identify any post-transient voltage deviations above 10%. Second, tap changers will be allowed

to move while shunt reactive compensating devices remained locked to determine if any voltage deviations above 7% would occur in the area. Third, all the taps and shunt reactive compensating devices will be allowed to adjust, and voltage deviations above 5% will be reported.

The scenarios to be studied are shown in Table 5-1.

5.1.1 Contingencies to be Studied

Power flow studies will be performed for the Category A and all Category B conditions in the Study Area.

5.2 Voltage Stability Studies

The objective of the voltage stability studies is to determine the ability of the transmission system to maintain voltage stability margin at all busses under Category A and Category B conditions. The power-voltage (PV) curve is a representation of voltage change as a result of increased power transfer between two systems. The incremental transfers will be reported at the collapse point.

Voltage stability studies will be performed for the post-Project scenarios. For load connection projects, the load level modeled in post-Project scenarios is the same as, or higher than, in pre-Project scenarios. Therefore, voltage stability studies for pre-Project scenarios will only be performed if post-Project scenarios show voltage stability criteria violations.

Voltage stability studies will be performed according to the Western Electricity Coordinating Council (WECC) Voltage Stability Assessment Methodology. WECC voltage stability criteria states, for load areas, post-transient voltage stability margin is required for the area modeled at a minimum of 105% of the reference load level for Category A conditions and for Category B conditions. For this standard, the reference load level is the maximum established planned load.

Typically, voltage stability studies are carried out assuming the worst case scenarios in terms of loading. In this connection assessment, the voltage stability studies will be performed by increasing load in Calgary Area (Area 6) and increasing generation in Wabamun (Area 40) and Fort McMurray (Area 25).

The scenarios and cases to be studied are shown in Table 5-1.

5.2.1 Contingencies to be Studied

Voltage stability studies will be performed for all Category B contingencies in the Study Area. The Category A condition and the five contingencies with the smallest stability margin will be presented in the results.

5.3 Short-Circuit Current Level Studies

A maximum fault level must be provided for the substations in the vicinity of the Project assuming normal system operation with all transmission elements in service and generation dispatched. Three-phase faults and single line-to-ground faults will be simulated. Polar coordinates and per-unit values will be used for reporting the results.

Winter peak scenarios will be used for the short-circuit studies because winter peak scenarios generally produce higher short-circuit current levels than summer peak scenarios.

Estimated maximum three-phase faults and single line-to-ground short-circuit current levels will be reported for the following substations:

- Janet 74S
- SS-37
- SS-38
- SS-23
- SS-24
- SS-39

Further sensitivity studies, in consultation with the TFO, may be required if the primary short-circuit analysis indicates a potential to exceed or approach the existing fault rating of the transmission facilities.

The scenarios to be studied are as shown in Table 5-1.

6 Mitigation Measures

6.1 Development

Mitigation measures may be required if the post-Project study results identify system performance issues. Mitigation measures for the Project may involve modifying or adding real-time operational practices and/or remedial action schemes (RASs).

The Studies Consultant must notify the AESO of any system performance issues in a timely manner, following which the AESO Studies Engineer may instruct the Studies Consultant as follows:

- Develop tables showing the constraint effective factors³ for generation or load based on thermal criteria violations that are observed.
- Collaborate with the AESO to propose changes, if any, to the connection alternatives that could remove the requirement for a RAS.
- Collaborate with the AESO to study modifications to existing and/or planned RASs, proposed by the AESO, to ensure the coordination of existing protection schemes with the addition of any proposed protection schemes.
- Collaborate with the AESO to identify and study new RASs, if any, that may be required to ensure system reliability is maintained after connecting the Project to the AIES.

The AESO Studies Engineer will work closely with the Studies Consultant and guide the development and/or modifications of the proposed mitigation measures to ensure system reliability, security and compliance with AESO ID #2018-018T, *Provision of System Access Service and the Connection Process*.

6.2 Evaluation

6.2.1 Post-Mitigation Studies

Studies to evaluate the effectiveness of mitigation measures, if required, will be performed in accordance with the technical criteria, assumptions, and methods provided in this Study Scope and in accordance with further instructions from the AESO.

6.2.2 Constraint Effective Factor Studies

Constraint effective factor analysis are used to determine the generator- and load- constraint effective factors and to identify the most effective generators or loads to manage the thermal criteria violations, if any, that are observed under Category B conditions.

³ Constraint effective factor studies are performed to determine the generator- and load- constraint effective factors. Constraint effective factors are used to estimate the ability of generators and loads to manage transmission constraints. A generator's or load's constraint effective factor is defined as the change in power flow over a specific transmission line following a change in the generator's energy production or in the load's energy consumption. The greater the constraint effective factor, the more effective a generator or load can be in managing a thermal criteria violation on the specific transmission line.

7 Changes to Study Assumptions

This study will utilize the AESO's planning base cases, which are based on the AESO's current corporate forecast (2021 LTO) with modifications to incorporate the latest forecast intelligence. Sensitivity studies or restudy may be required in the event of revisions to the AESO's corporate forecast, forecast intelligence, or other study assumptions. Additional engineering studies may also be required to assess new connection alternatives, changes to project ISD, or delays in proposed system developments. Any additional or revised study requirements shall be captured in a signed Study Scope Amendment document.

Attachment A:

Transmission Planning Criteria – Basis and Assumptions

Engineering Connection Assessment: Study Results


P2102 EPC East Calgary Area Load

V1D2


Attachment A2

Pre-Project Power Flow Diagrams


Cat A: 2025_SP_Pre-Project_A




22.81L Outage: 2025_SP_Pre-Project_A




37.81L Outage: 2025_SP_Pre-Project_A




37.82L Outage: 2025_SP_Pre-Project_A




38.83L Outage: 2025_SP_Pre-Project_A




39.82L Outage: 2025_SP_Pre-Project_A




Cat A: 2025_SP_Pre-Project_B




22.81L Outage: 2025_SP_Pre-Project_B




37.81L Outage: 2025_SP_Pre-Project_B




37.82L Outage: 2025_SP_Pre-Project_B




38.83L Outage: 2025_SP_Pre-Project_B




39.82L Outage: 2025_SP_Pre-Project_B




Cat A: 2025_WP_Pre-Project_A




22.81L Outage: 2025_WP_Pre-Project_A




37.81L Outage: 2025_WP_Pre-Project_A




37.82L Outage: 2025_WP_Pre-Project_A



38.83L Outage: 2025_WP_Pre-Project_A



39.82L Outage: 2025_WP_Pre-Project_A



Engineering Connection Assessment: Study Results


P2102 EPC East Calgary Area Load

V1D2


Attachment A3

Post-Project Power Flow Diagrams


Cat A: 2025_SP_Post-Project_A




22.81L Outage: 2025_SP_Post-Project_A




37.81L Outage: 2025_SP_Post-Project_A




37.82L Outage: 2025_SP_Post-Project_A




38.83L Outage: 2025_SP_Post-Project_A




39.82L Outage: 2025_SP_Post-Project_A




Cat A: 2025_SP_Post-Project_B




22.81L Outage: 2025_SP_Post-Project_B




37.81L Outage: 2025_SP_Post-Project_B




37.82L Outage: 2025_SP_Post-Project_B




38.83L Outage: 2025_SP_Post-Project_B




39.82L Outage: 2025_SP_Post-Project_B




Cat A: 2025_WP_Post-Project_A




22.81L Outage: 2025_WP_Post-Project_A




37.81L Outage: 2025_WP_Post-Project_A




37.82L Outage: 2025_WP_Post-Project_A



38.83L Outage: 2025_WP_Post-Project_A



39.82L Outage: 2025_WP_Post-Project_A



Engineering Connection Assessment: Study Results


P2102 EPC East Calgary Area Load

V1D2


Attachment A4

Post-Project Voltage Stability Diagram

Bus Voltage (pu) Contingency: Pre-Contingency




Bus Voltage (pu) Contingency: 906L



2021RC_2025WP_CALGARY-LOW_TIE-ECON_WIND-0_P

transfer_file

Bus Voltage (pu) Contingency: 928L




Powertech VSAT 17.0 21-MAR-22 13:20

2021RC_2025WP_CALGARY-LOW_TIE-ECON_WIND-0_P

transfer_file

Bus Voltage (pu) Contingency: WATL




Powertech VSAT 17.0 21-MAR-22 13:20

2021RC_2025WP_CALGARY-LOW_TIE-ECON_WIND-0_P

transfer_file

Bus Voltage (pu) Contingency: 918L




Powertech VSAT 17.0 21-MAR-22 13:20

2021RC_2025WP_CALGARY-LOW_TIE-ECON_WIND-0_P


transfer_file

Bus Voltage (pu) Contingency: 37.82L



Powertech VSAT 17.0 21-MAR-22 13:20


Bus Voltage (pu) Contingency: Pre-Contingency



Powertech

VSAT 17.0 21-MAR-22 18:03

Bus Voltage (pu) Contingency: 906L




Powertech

VSAT 17.0 21-MAR-22 18:03

2021RC_2025SP_CALGARY-LOW_TIE-ECON_WIND-0_P

transfer_file


Bus Voltage (pu) Contingency: 928L




2021RC_2025SP_CALGARY-LOW_TIE-ECON_WIND-0_P

transfer_file

Bus Voltage (pu) Contingency: 918L




Bus Voltage (pu) Contingency: PCE02L



Powertech 
VSAT 17.0 21-MAR-22 18:03

Bus Voltage (pu) Contingency: 37.82L



Powertech 
VSAT 17.0 21-MAR-22 18:03