

Ensuring Grid Reliability and Operational Preparedness

October 7, 2021

In accordance with its mandate to operate in the public interest, the AESO will be audio recording this session and making the session recording available to the general public at www.aeso.ca. The accessibility of these discussions is important to ensure the openness and transparency of this AESO process, and to facilitate the participation of stakeholders. Participation in this session is completely voluntary and subject to the terms of this notice.

The collection of personal information by the AESO for this session will be used for the purpose of capturing stakeholder input for the Ensuring Grid Reliability and Operational Preparedness stakeholder information session. This information is collected in accordance with Section 33(c) of the *Freedom of Information and Protection of Privacy Act*. If you have any questions or concerns regarding how your information will be handled, please contact the Director, Information and Governance Services at 2500, 330 – 5th Avenue S.W., Calgary, Alberta, T2P 0L4, by telephone at 403-539-2528, or by email at privacy@aesocanada.com.

- Two ways to ask questions if you are accessing the webinar using your computer or smartphone
 - Click “Raise Hand” and the host will be notified that you would like to ask a question. The host will unmute your microphone, you in turn will need to unmute your microphone and then you can ask your question. Your name will appear on the screen, but your camera will remain turned off.
 - Click “Lower Hand” to lower it if needed.
 - You can also ask questions by tapping the “Q&A” button and typing them in. You’re able to up-vote questions that have been already asked.
- If you are accessing the webinar via conference call
 - If you would like to ask a question during the Q&A portion, on your phone’s dial pad, hit *9 and the host will see that you have raised your hand. The host will unmute your microphone, you in turn will need to unmute your microphone by hitting *6 and then you can ask your question. Your number will appear on the screen.

OUR ENGAGEMENT PRINCIPLES

Inclusive and Accessible

Strategic and Coordinated

Transparent and Timely

Customized and Meaningful

- Purpose and session objectives
- Overview of recent system events
 - Impact of generation pullback and distributed energy resources (DERs) loss during events
- Plans to ensure grid reliability and operational preparedness
 - Short, medium, and long-term plans
 - Achievements and work in progress
- Frequency response capability next steps
- Most Severe Single Contingency (MSSC) implications
- Q & A



- Changing supply mix creating frequency response capability challenges on our system
- Increasing importance of consistent, predictable and expected frequency response
- Generation pullback and loss of distributed energy resources during frequency events exacerbating the challenge
- AESO has taken—and is planning—more action to improve frequency response capability across the key time horizons




Overview of Recent System Events

June 7, 2020

- AB-BC Intertie Trip
- Frequency dropped to 59.15 Hz
- Under-Frequency Load Shed (UFLS) activated (235 MW)
- Load Shed Service for imports (LSSi) activated (188 MW)

February 21, 2021

- AB-BC Intertie Trip
- Frequency dropped to 59.44 Hz
- UFLS activated (125 MW)
- No LSSi activated



October 16, 2020

- Islanded Mode of Operation, Internal Generation (267 MW) trip
- Frequency dropped to 59.57 Hz for such a small disturbance
- No UFLS or LSSi triggered

February 22, 2021

- AB-BC Intertie Trip
- Frequency dropped to 59.48 Hz
- No UFLS activated
- LSSi activated (208 MW)

June 3, 2021


- AB-BC Intertie Trip
- Frequency dropped to 59.42 Hz
- UFLS activated (177 MW)
- LSSi activated (93 MW)
- 60 MW of DERs tripped

- Prior to the event:
 - Alberta Internal Load (AIL): 10,577 MW
 - Scheduled BC&MT flow: 660 MW
 - Actual BC&MT import prior to the trip: 708 MW
 - Wind generation: 1,025 MW
 - Solar generation: 259 MW
 - System Inertia: 55.3 GVA.S
 - 103 MW dispatched LSSi per the normal LSSi table
- Post event:
 - Total load of 270 MW shed including 93 MW LSSi response
 - UFLS Block D2 was activated
 - Gen response (A-B period): 78 MW/0.1Hz
 - Load Response (A-B period): 38.1 MW/0.1 Hz (2.16% damping)

System Response – June 3, 2021

System Response

Freq. Net Gen AIL




Impact of DERs on frequency response capability


- 2021 Long Term Outlook (LTO) - DERs:
 - 2,500 MW in the Reference case
 - 4,500 MW in the Clean-Tech scenario
- Tripping of DERs during system events can exacerbate the impact of an event on grid reliability
 - About 60 MW of DERs tripped during the June 3, 2021 event
 - Working with impacted DERs and distribution facility owners (DFOs) in the province to enable the implementation of the reliability standard (IEEE 1547) – frequency and voltage ride-through requirements
- Tripping of DERs as part of the province's UFLS service is a concern
 - Working with DFOs on identifying DERs on UFLS feeders and the potential of employing strategies such as sectionalizing



Two UFLS events due to larger generation pullback



80 MW of fast supply would have mitigated June 3, 2021 load shed event





Key drivers impacting frequency response capability from recent events

- Declining system inertia
 - Low system inertia during high imports and high renewable resources
- Declining primary frequency response from generators
 - Inconsistency in performance during events
 - Generation pull-back after initial response (lack of sustained response)
- Limited interconnection with WECC to access inertie support during system events
- Increasing penetration of renewable resources
 - Do not currently contribute to system inertia or frequency response

Plans to Ensure Grid Reliability and Operational Preparedness



Assessing action plans across the frequency control spectrum



Targeted action plans for each mode of control

Control	Type of Response	Timeframe
Primary Control	<ul style="list-style-type: none">• Inertia• Fast Frequency Response• Governor and Load Response	Milliseconds – 60 seconds
Secondary Control	Regulation / Automatic Generation Control (AGC)	1 – 10 minutes
Tertiary Control	Contingency Reserves Activation and dispatch of the energy market merit order (EMMO) for system rebalancing	10 minutes - hour

Primary Frequency Control – Inertia

Short Term

2021

Medium Term

2021 - 2022

Long Term

2021 - 2023

- ✓ Use of real-time system inertia and severe weather parameters on the AB-BC tie-line in determining allowable power flows
- ✓ Use of system inertia as a third parameter to develop arming tables for fast frequency response

- If need determined, implement Synthetic Inertia for IBRs

- Assess feasibility and effectiveness of Synthetic inertia for inverter-based resources (IBRs)
- Stakeholder engagement based on Synthetic Inertia studies and outcomes

- ✓ Action completed
- Work in progress
- Work yet to be started

Primary Frequency Control – Fast Frequency Response (FFR)

Short Term

2021

Medium Term

2021 - 2022

Long Term

2021 - 2023

- ✓ Work with current LSSi, a FFR product, to improve compliance to system events
- ✓ Develop technical rules for participation of energy storage resources (ESRs)

- Develop and implement ISO rules to enable technology-agnostic participation in FFR services

- ✓ Pilot project for FFR to enable participation of new technologies such as energy storage resources (ESRs)

- ✓ Action completed
- Work in progress
- Work yet to be started

Primary Frequency Control – Generator Primary Frequency Response (PFR)



Short Term

2021

Medium Term


2021 - 2022

Long Term

2021 - 2023

- ✓ Analyze the impact of generator characteristics, ambient temperature and lack of headroom on system performance
- ✓ Work collaboratively with Generation Facility Owners (GFOs) to help improve PFR from their assets
- ✓ Situational awareness in the control room on expected PFR (in MW/0.1Hz)
 - Provide clarity on PFR expectation from generators during system events, through an information document (ID)

- Implement ISO rule changes to address qualification standards and performance metrics



- ✓ Continue collaborative approach with GFOs including ensuring outer control loops and AGC controls do not impede PFR from generators
 - Assess need and approach to mitigate risks associated with generation pull-back
- ✓ Modify AESO modeling and operating assumptions
 - Develop and engage stakeholders in modifications to generator interconnection standards


✓	Action completed
➤	Work in progress
•	Work yet to be started

Secondary Frequency Control – Automatic Generation Control (AGC)



- ✓ Analyze the contribution of resources on AGC during system events
- Provide clarity on role of AGC during system events through an information document (ID)

- Study the technical impacts of ESR participation and Dynamic AGC on system performance (Fast versus Slow AGC)



- ✓ Work with GFOs to ensure AGC controls do not impede natural frequency response of generators
- Enable AGC blocking during system events to ensure recovery and grid reliability

✓	Action completed
➤	Work in progress
•	Work yet to be started

Tertiary Frequency Control – Contingency Reserves (CR)

Short Term

2021

Medium Term

2021 - 2022

Long Term

2021 - 2023

- ✓ Analyze the performance impact of CR resources during system events
- ✓ Work with GFOs to help improve performance of CR resources during system events

- Finalize stakeholder engagement and implement revisions to ISO technical rules for CR qualification and compliance processes, as required

- Identify improvements to the OR qualification process
- Proactively monitor performance of CR providers during system events and follow-up as required
- Develop and engage stakeholders in any proposed revisions to CR qualification requirements

- ✓ Action completed
- Work in progress
- Work yet to be started

Net Demand Variability (NDV)



Short Term

2021

Medium Term


2021 - 2022

Long Term

2021 - 2023

- ✓ Optimize the volume of regulating reserves
- ✓ Provide system controllers with daily forecast and ramp event reports to support decision making

- Implement changes to wind and solar forecast data rule (ISO Rule 304.9)
- Continued Optimization of regulating reserves to better manage NDV
- Improve system dispatch practices to proactively manage NDV
- Initiate any required market design initiatives



- Support dispatch decision making in the control room using ultra short-term forecasts (one-minute wind and solar forecasts)
- Stakeholder engagement on ISO Rule 304.9 to help improve forecast data quality and accuracy
- Forecast and analyze long-term NDV implications

✓	Action completed
➤	Work in progress
•	Work yet to be started


Frequency Response Capability Next Steps

- Continued Collaboration
 - Continue to work with GFOs to improve generator response during system events
- Transparency
 - Regular updates to the industry on plans, progress, and impact of actions on improving grid reliability
- Engagement
 - Engage stakeholders proactively on identified plans to support grid reliability and operational preparedness
- Compliance
 - Proactive approach to compliance to ensure adherence to ISO technical rules and reliability standards
- Improvements
 - Implement short-term bridging solution to address generation pullback and DER tripping risk


Most Severe Single Contingency (MSSC) Implications

Islanded operation event on Oct. 16, 2020

System Response



Oct. 16, 2020 event and simulation results for reduced MSSC levels




- Islanded operation event indicates system currently challenged to handle 466 MW MSSC loss
- Studies indicated 425 MW is the MSSC limit while islanded
- Any increase in MSSC will only exacerbate the reliability risk of customer load shed
- Assessing reliability risk increases at higher MSSC levels
- Assessing costs of additional reliability services required to enable higher MSSC levels
- Assessing benefits to increasing MSSC levels in Alberta
- MSSC-specific session will be planned for late October/early November to share results and engage stakeholders

Questions

Thank you

Appendix

Historical Events – System Response



Historical Events – Rate of Change of Frequency (RoCoF)

