

Applicability

- **1** Section 304.9 applies to:
 - (a) the legal owner of a wind or solar aggregated generating facility connected to the interconnected electric system or an electric system within the service area of the City of Medicine Hat, including a wind or solar aggregated generating facility situated within an industrial complex that is directly connected to the interconnected electric system or to an electric system within the service area of the City of Medicine Hat and that has a gross real power capability equal to or greater than 5 MW; and
 - (b) the ISO.

Requirements

Functional Specification

2 The **ISO** must, in accordance and generally consistent with this Section 304.9, approve a written functional specification containing details, work requirements, and specifications for the design, construction, and operation of an **aggregated generating facility** and associated **transmission facility** connection facilities.

Successor to Prior Requirements and Compliance Timeframe

3(1) The provisions of this Section 304.9 succeed all previous forecasting requirements for **aggregated generating facilities**, whether in an **ISO rule** or other document, and those requirements will no longer be in force and effect as of September 1, 2018.

Meteorological Data Collection Equipment and Availability Requirements

4(1) The **legal owner** of a wind or solar **aggregated generating facility** must ensure that the facility is equipped with meteorological data collection equipment and related devices that are installed and maintained in accordance with the provisions of subsections 4 and 5.

(2) The legal owner of a wind aggregated generating facility must ensure that it is equipped with one set of instruments for each meteorological parameter in accordance with the requirements in Table 1.

(3) The legal owner of a solar aggregated generating facility must ensure that the facility is equipped with meteorological data collection equipment and related devices in accordance with the following:

- (a) one (1) set of instruments for each meteorological parameter in accordance with the requirements in Table 1 per 49 square kilometers of surface area within the facility;
- (b) each set of instruments, if required by subsection 4(3)(a), must be less than 8 kilometers apart; and
- (c) measurements must be taken at not less than 2 meters and not greater than 10 meters above ground.

(4) The legal owner of a wind or solar aggregated generating facility must ensure that the meteorological data collection equipment and related devices described in subsections 4(2) and 4(3) take measurements of instantaneous values at interval of 15 seconds or less.

(5) The legal owner of a wind or solar aggregated generating facility must measure, collect and submit to the ISO the meteorological data in Table 1.



(6) The legal owner of a wind or solar aggregated generating facility must determine, at 30 minute intervals, and submit to the **ISO**, the gross real power capability with a precision to the nearest 2.0 MW.

(7) The legal owner of a wind or solar aggregated generating facility must determine and submit to the ISO, the following data:

- (a) any real power limits in megawatts (MW), with a precision for instantaneous measurements to the nearest 0.1 MW; and
- (b) actual net to grid real power production in megawatts (MW), with a precision for instantaneous measurements to the nearest 0.1 MW.

Data Transfer Technical Specification

5(1) The **legal owner** of a wind or solar **aggregated generating facility** must submit to the **ISO** the data specified in subsection 4(5) using one **minute** average data.

(2) The legal owner of a wind or solar aggregated generating facility must submit to the ISO the data specified in subsection 4 in the method and format the ISO specifies.

(3) The legal owner of a wind or solar aggregated generating facility must ensure that its meteorological data collection equipment and related devices including its data transfer equipment is designed and maintained with an availability of 98.0% in accordance with Table 1 and a mean time to repair of forty-eight (48) hours or less.

(4) The legal owner of a wind or solar aggregated generating facilities must keep seven (7) days of back up data for any data that has been submitted in accordance with this subsection 5 and must provide it to the **ISO** upon request within thirty (30) days.

Notification of Unavailability, Suspected Failure or Data Error

6(1) The **legal owner** of a wind or solar **aggregated generating facility** must, if any component in the meteorological data collection equipment and related devices including data transfer equipment becomes unavailable due to an unplanned event, is suspected to have failed, or to be providing erroneous data, notify the **ISO** as soon as practicable, in writing, after identifying the unavailability, suspected failure or data error.

(2) The legal owner of a wind or solar aggregated generating facility must provide the ISO as soon as practicable, in writing:

- (a) a description of the cause of any unavailability, suspected failure or data error reported pursuant to subsection 6(1);
- (b) in the event of an equipment failure, a plan acceptable to the **ISO** to repair the failed equipment, including testing; and
- (c) in the event of an equipment failure, the expected date when the equipment will be repaired and the required measurements will be restored.

(3) The **legal owner** of a wind or solar **aggregated generating facility** must, if an equipment failure described in subsection 6(2) is not repaired and required measurements are not restored by the expected date, notify the **ISO** as soon as practicable, in writing, of the revised date and the reason the component in the equipment was not repaired by the expected date.

(4) The **legal owner** of a wind or solar **aggregated generating facility** must notify the **ISO** as soon as practicable in writing after an equipment failure described in subsection 6(2) is repaired and the required measurements are restored.



Exceptions

7 Notwithstanding subsections 4 and 5, the **legal owner** of a wind or solar **aggregated generating facility** is not required to comply with the requirements of this Section 304.9 relating to meteorological data collection equipment and related devices including data transfer equipment when:

- (a) such equipment is being repaired or replaced in accordance with a plan acceptable to the **ISO** under subsection 6; and
- (b) the **legal owner** is using reasonable efforts to complete such repair or replacement in accordance with that plan.

Pre-Commissioning Facility Data and Records Requirements

8(1) The **legal owner** of a wind **aggregated generating facility** must provide to the **ISO** the pre-**commissioning** data and records referred to in this subsection 8 in a method and format the **ISO** specifies.

(2) The legal owner of a solar aggregated generating facility must provide to the ISO, in a method and format the ISO specifies, either:

- (a) the pre-commissioning data and records referred to in this subsection 8; or
- (b) an industry standard model that is approved by the ISO.

(3) Subject to the provisions of this subsection 8, the **legal owner** of a wind or solar **aggregated generating facility** must retain and provide within sixty (60) **days** of the **ISO**'s written request the following averaged meteorological data and records at ten (10) minute intervals or less, covering the two (2) calendar years prior to the **commissioning** of the wind or solar **aggregated generating facility**:

- (a) details on the height of the measurements;
- (b) wind speed;
- (c) wind direction;
- (d) temperature;
- (e) barometric pressure; and
- (f) for solar aggregated generating facilities only, global horizontal irradiance.

(4) The legal owner of a wind aggregated generating facility must, in response to a request by the ISO under subsection 8(3), provide the following facility data:

- (a) meteorological tower data collection height in meters (m), with a precision for instantaneous measurements to the nearest 1 m;
- (b) turbine model name;
- (c) turbine model capacity in megawatts (MW), with a precision to the nearest 0.1 MW;
- (d) turbine wind speed cut-in in meters per second (m/s), with a precision to the nearest 0.1 m/s;
- (e) turbine wind speed cut-out in meters per second (m/s), with a precision to the nearest 0.1 m/s;
- (f) turbine temperature cut-out lower in degrees Celsius (°C), with a precision for instantaneous measurements to the nearest 1 °C and an indicator is required to confirm that the numbers are ambient temperature within the rotor or air temperature;



- (g) turbine temperature cut-out upper in degrees Celsius (°C), with a precision for instantaneous measurements to the nearest 1 °C and an indicator is required to confirm that the numbers are ambient temperature within the rotor or air temperature;
- (h) site latitude and longitude in degrees; and
- (i) turbine power curves.

(5) The legal owner of a solar aggregated generating facility must in response to a request by the ISO under subsection 8(3), provide the following solar array data and records, including:

- (a) site latitude and longitude in degrees;
- (b) direct current (DC) real power rating;
- (c) alternating current (AC) real power rating;
- (d) inverter manufacturer and model;
- (e) mounting height from ground in meters (m);
- (f) tilt angle or range of tilt angles to horizontal plane in degrees;
- (g) azimuth angle in degrees;
- (h) alternating current (AC) real power capacity per solar array in megawatts (MW);
- (i) mounting type, tracking (fixed, single or dual axis); and
- (j) module type (crystalline, thin-film etc.).

Revision History

Date	Description
xxxx-xx-xx	Updated to align with current AESO drafting principles.
2019-12-11	"Removed duplication with new Section 103.14, Waivers and Variances; standardized functional specifications language; capitalized references to "Section"."
2018-09-01	Initial release.



Table 1								
Wind and Solar Aggregated Generating Facility Meteorological Data Requirements								

W	ind Aggregated Ger	nerating Fac	ility Mete	orological Data	a Requirements	
Measurement	Units	Precision	Range	Accuracy	Height of I	nstrument
Туре			-	_	Set-1	Set-2
Wind Speed	Meters/Second (m/s)	0.1 m/s	0 to 50	±1m/s	At Hub Height	At 35 Meters
Wind Direction	Degrees from True North	1 degree	0 to 360	±5°	At Hub Height	At 35 Meters
Barometric Pressure	HectoPascals (HPa)	1 hPa	800 to 1000	±1.0 hPa at -20 to 50°C; and ±1.5 hPa at below -20°C	At Convenient location	At Convenien location
Ambient Temperature	Degree Celsius (°C)	0.1° C	-50 to +50	±0.2°C	At Hub Height	At 35 Meters
Dewpoint	Degrees Celsius (°C)	0.1° C	-50 to +50	±0.2°C	At Convenient location	At Convenient
Relative Humidity	Percentage (%)	1.00%	0 to 100 %	±2%	At Convenient location	At Convenient
Ice-up Parameter Measured with an Icing Sensor	Scale 0.0 to1.0	0.1	0 to 1	n/a	At Convenient location	At Convenient location
Precipitation	Millimeters/minute (mm/min)	0.1	0 to11	2% up to 0.417 mm/mon 3% over 0.417 mm/min	At Convenient location	At Convenien location
S	olar Aggregated Gei	nerating Fac	ility Mete	orological Data	a Requirements	
Measurement	Units	Precision	Range	Accuracy	Height of Instrument	
Туре					Set-1 per 49 km²	Set-2 for each subsequent 49 km ²
Wind Speed	Meters/Second (m/s)	0.1 m/s	0 to 50	±1m/s	Between 2-10 meters	Between 2-10 meters
Wind Direction	Degrees from True North	1 degree	0 to 360	±5°	Between 2-10 meters	Between 2-10 meters
Barometric Pressure	HectoPascals (HPa)	1 hPa	800 to 1000	±1.0 hPa at -20 to 50°C; and ±1.5 hPa at below -20°C	Between 2-10 meters	Between 2-10 meters



			•			
Ambient	Degree Celsius	0.1° C	-50 to	±0.2°C	Between 2-10	Between 2-10
Temperature	(°C)		+50		meters	meters
Dewpoint	Degrees Celsius	0.1° C	-50 to	±0.2°C	Between 2-10	Between 2-10
	(°C)		+50		meters	meters
Relative	Percentage (%)	1.00%	0 to	±2%	Between 2-10	Between 2-10
Humidity			100 %		meters	meters
Precipitation	Millimeters/minute	0.1	0 to11	2% up to	Between 2-10	Between 2-10
-	(mm/min)			0.417	meters	meters
				mm/mon 3%		
				over 0.417		
				mm/min		
Back panel	Degree Celsius	0.1° C	-50 to	±0.15°C	Between 2-10	Between 2-10
Temperature	(°C)		+50	at -27 to	meters	meters
				+50°C; and		
				±0.2°C at		
				below -27°C		
Global	Watts/Square	0.1	0 to	±3%	Between 2-10	Between 2-10
Horizontal	Meter (W/m ²)		4000		meters	meters
Irradiance						
Diffused	Watts/Square	0.1	0 to	±3%	Between 2-10	Between 2-10
Horizontal	Meter (W/m ²)		4000		meters	meters
Irradiance						
Direct Normal	Watts/Square	0.1	0 to	±3%	Between 2-10	Between 2-10
Irradiance ¹	Meter (W/m ²)		2000		meters	meters

¹ The requirement to provide this parameter will be determined by the AESO based on solar technology used in the project. Blackline Issued for Stakeholder Consultation with AESO Replies: 2023-01-1703-06 Page 6 of 6