

# Engineering Connection Assessment

## P1828 Alderson Solar Power Project




### Connection

hep Canada SPV 1 Ltd

**Date:** Nov. 8, 2023

**Version:** V1

**Classification:** Public

Role	Name	Date	Signature
Prepared	Omid Ghoreishi, P. Eng.	Nov. 8, 2023	
Reviewed	Myron Jin-Li, P. Eng.	Nov. 10, 2023	
Approved	Pravin Koshti, P.Eng.	Nov10,2023	



ID No. 75906

*Nov. 8, 2023*

**PERMIT TO PRACTICE  
INDEPENDENT SYSTEM OPERATOR**

RM SIGNATURE: *Pravin Koshti*

RM APEGA ID #: 110749

DATE: Nov 10, 2023

**PERMIT NUMBER: P008200**

The Association of Professional Engineers and  
Geoscientists of Alberta (APEGA)

**NOTE:**

The conclusions and recommendations in this report are based on the results presented in *Attachment A: Engineering Connection Assessment: Study Results*, which was prepared by a third party consultant in accordance with the AESO Connection Process.

The AESO has reviewed the *Engineering Connection Assessment: Study Results* and finds it acceptable for the purpose of assessing the potential impacts of the proposed connection on the performance of the Alberta interconnected electric system.

# Contents

<b>1</b>	<b>Introduction</b> .....	<b>1</b>
1.1	Project Overview .....	1
<b>2</b>	<b>Assessment Scope</b> .....	<b>2</b>
2.1	Objectives .....	2
2.2	Existing System .....	2
2.3	Study Area .....	2
<b>3</b>	<b>Connection Alternatives</b> .....	<b>3</b>
3.1	Overview .....	3
3.2	Connection Alternatives Examined .....	3
3.3	Connection Alternatives Selected for Further Study .....	13
3.4	Connection Alternatives Not Selected for Further Study .....	13
<b>4</b>	<b>Assessment Approach</b> .....	<b>14</b>
4.1	Standards, Criteria and Assumptions .....	14
4.2	Studies Performed .....	14
4.2.1	<i>Power Flow Studies</i> .....	14
4.2.2	<i>Transient Stability Studies</i> .....	15
4.2.3	<i>Short-Circuit Current Level Studies</i> .....	15
4.3	Mitigation Measure Development and Evaluation .....	15
4.3.1	<i>Post-Mitigation Studies</i> .....	15
4.3.2	<i>Constraint Effective Factor Studies</i> .....	15
<b>5</b>	<b>Interpretation of Results</b> .....	<b>16</b>
5.1	Results Overview .....	16
5.2	Pre-Project Study Results .....	19
5.2.1	<i>Category A Conditions</i> .....	19
5.2.2	<i>Category B Conditions</i> .....	19
5.3	Post-Project Study Results .....	19
5.3.1	<i>Category A Conditions</i> .....	19
5.3.2	<i>Category B Conditions</i> .....	20
5.4	Mitigation Measures .....	20
5.4.1	<i>Pre-Project</i> .....	20
5.4.2	<i>Post-Project</i> .....	21
<b>6</b>	<b>Project Dependencies</b> .....	<b>22</b>
<b>7</b>	<b>Conclusions and Recommendations</b> .....	<b>23</b>

## Tables

Table 4-1: Connection Study Scenarios.....	14
Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures .....	17
Table 5-2: Thermal Criteria Category A violations in the SP post-Project scenarios .....	19

## Figures

Figure 3-1: Connection Alternative 1 .....	4
Figure 3-2: Connection Alternative 2.....	6
Figure 3-3: Connection Alternative 3.....	8
Figure 3-4: Connection Alternative 4.....	10
Figure 3-5: Connection Alternative 5.....	12

## Attachments

Attachment A: Engineering Connection Assessment Results



# 1 Introduction

This AESO Engineering Connection Assessment describes the engineering studies that were completed to assess the impact of the Project (as defined below) on the performance of the Alberta interconnected electric system (AIES). This report also provides the AESO's conclusions and recommendations based on the results of the engineering studies.

Attached to this Engineering Connection Assessment are the results of the engineering studies (see Attachment A) and the scope and methodology used to perform the studies (see Attachment A1 to Attachment A). These attachments provide details regarding the technical criteria, assumptions, and methods for performing these engineering studies, and the results of the engineering studies.

## 1.1 Project Overview

Hep Canada SPV 1 Ltd. (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its proposed Alderson Solar Power Project (Facility) to the AIES. The Facility includes a proposed collector substation, to be designated the Alderson Park 1061S substation.

The Market Participant's request includes: a request for a new system access service in the area, with a Rate STS, *Supply Transmission Service*, contract capacity of 100 MW and a Rate DTS, *Demand Transmission Service*, contract capacity of 0.5 MW; and a request for transmission development (collectively, the Project).

The scheduled in-service date (ISD) for the Project is Dec. 2, 2024.

## 2 Assessment Scope

### 2.1 Objectives

The objectives of the AESO Engineering Connection Assessment are as follows:

- Assess the impact of the Project on the performance of the AIES.
- Evaluate Project connection alternatives and identify the AESO's preferred alternative.
- Recommend mitigation measures, if required, to reliably connect the Project to the AIES.
- Identify Project dependencies, including any TFO projects or AESO plans to expand or enhance the transmission system that must be completed prior to connection.

### 2.2 Existing System

Geographically, the Project is located in the AESO planning area of Vauxhall (Area 52), which is part of the AESO South planning region. The Vauxhall area (Area 52) is electrically connected to the neighbouring planning areas of Medicine Hat (Area 4), Brooks (Area 47), and Lethbridge (Area 54).

From a transmission system perspective, the Vauxhall Area (Area 52) consists primarily of 138 kV transmission systems. The Vauxhall Area (Area 52) is connected to the Medicine Hat Area (Area 4) with one 138 kV transmission line, the Brooks Area (Area 47) with two 138 kV transmission lines, and the Lethbridge Area (Area 54) with one 138 kV transmission line.

Existing constraints in the South planning region are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management* (TCM Rule).

### 2.3 Study Area

The Study Area for the Project consists of the AESO Planning areas of Empress (Area 48), Medicine Hat (Area 4), Brooks (Area 47), and Vauxhall (Area 52), including the tie lines connecting these planning areas to the rest of the AIES. All transmission facilities within the Study Area will be studied and monitored for violations of the Reliability Criteria (defined in Section 3.1 of Attachment A1).

## 3 Connection Alternatives

### 3.1 Overview

The AESO, in consultation with the TFO in the Study Area and the Market Participant, examined five transmission alternatives to meet the Market Participant's request for system access service, as detailed in Section 3.2.

### 3.2 Connection Alternatives Examined

Below is a description of the developments associated with the transmission alternatives that were examined for the Project.

#### **Alternative 1 – In-and-out connection to 240 kV transmission line 1034L**

This alternative includes the following developments:


- Add a substation, including three 240 kV circuit breakers, connected to the existing 240 kV transmission line 1034L (between the Bowmanton 244S and Cassils 324S substations) using an in-and-out configuration;
- Add one 240 kV circuit, approximately 3 km<sup>1</sup> in length, to connect the Facility to the proposed substation; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-1.

---

<sup>1</sup> Exact line length for all connection alternatives listed are to be determined by the TFO and Market Participant, as applicable.

Figure 3-1: Connection Alternative 1



### **Alternative 2 – In-and-out connection to 240 kV transmission line 1035L**

This alternative includes the following developments:

- Add a substation, including three 240 kV circuit breakers, connected to the existing 240 kV transmission line 1035L (between the Bowmanton 244S and Newell 2075S substations) using an in-and-out configuration;
- Add one 240 kV circuit, approximately 3 km<sup>2</sup> in length, to connect the Facility to the proposed substation, which would require crossing the 240 kV transmission line 1034L; and
- Add or modify associated equipment as required for the above transmission developments.


The proposed connection configuration is shown in Figure 3-2.

---

<sup>2</sup> Exact line length for all connection alternatives listed are to be determined by the TFO and Market Participant, as applicable.



Figure 3-2: Connection Alternative 2



**Alternative 3 – T-tap connection to 138 kV transmission line 100L**

This alternative includes the following developments:


- Add one 138 kV circuit, approximately 3.5 km<sup>3</sup> in length, to connect the Facility to the existing 138 kV transmission line 100L using a T-tap configuration; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-3.

---

<sup>3</sup> Exact line length for all connection alternatives listed are to be determined by the TFO and Market Participant, as applicable.

Figure 3-3: Connection Alternative 3





**Alternative 4 – T-tap connection to 240 kV transmission line 1034L**

This alternative includes the following developments:


- Add one 240 kV circuit, approximately 3 km<sup>4</sup> in length, to connect the Facility to the existing 240 kV transmission line 1034L using a T-tap configuration; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-4.

---

<sup>4</sup> Exact line length for all connection alternatives listed are to be determined by the TFO and Market Participant, as applicable.

Figure 3-4: Connection Alternative 4



### **Alternative 5 – T-tap connection to 240 kV transmission line 1035L**

This alternative includes the following developments:


- Add one 240 kV circuit, approximately 3 km<sup>5</sup> in length, to connect the Facility to the existing 240 kV transmission line 1035L using a T-tap configuration, which would require crossing the 240 kV transmission line 1034L; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-5.

---

<sup>5</sup> Exact line length for all connection alternatives listed are to be determined by the TFO and Market Participant, as applicable.

Figure 3-5: Connection Alternative 5



### **3.3 Connection Alternatives Selected for Further Study**

Alternative 3 is considered technically feasible and was selected for further study.

### **3.4 Connection Alternatives Not Selected for Further Study**

Alternatives 1, 2, 4, and 5 would involve increased transmission development and hence, increased cost, compared with Alternative 3. Therefore, Alternatives 1, 2, 4 and 5 were ruled out.

## 4 Assessment Approach

### 4.1 Standards, Criteria and Assumptions

A detailed description of the standards, criteria, and assumptions that were used for the connection assessment is provided in Attachment A (see Attachment A1).

### 4.2 Studies Performed

The scheduled ISD for the Project is Dec. 2, 2024; therefore, studies were performed using scenarios for 2025 Summer Light and Summer Peak.

Short-circuit studies were performed using the 2031 Winter Peak scenario.

Table 4-1 lists the study scenarios. Post-Project scenarios reflect the requested Rate STS contract capacity of 100 MW at the Alderson Park 1061S substation.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
<b>Pre-Project</b>					
1	2025 Summer Peak (2025 SP)	High South generation, high solar generation	2025 SP Pre-Project-HG	0	0
2	2025 Summer Light (2025 SL)		2025 SL Pre-Project-HG	0	0
<b>Post-Project</b>					
3	2025 SP	High South generation, high solar generation	2025 SP Post -Project- HG	0	100
4	2025 SL		2025 SL Post -Project- HG	0	100
5	2031 WP	All study area generation in-service	2031 WP Post-Project- HG	0	100

The AESO Planning Region load forecasts used for the connection studies were based on the AESO’s 2021 Long-term Outlook (2021 LTO).

#### 4.2.1 Power Flow Studies

The purpose of the power flow studies is to identify and quantify any thermal and voltage criteria violations in the Study Area.



In addition, power flow studies are also used to identify point of delivery (POD) low voltage bus voltage deviations beyond the limits listed in Table 3-1 of Attachment A1.<sup>6</sup>

Power flow studies were performed for the 2025 Summer Light and 2025 Summer Peak pre-Project scenarios, and for 2025 Summer Light and 2025 Summer Peak post-Project scenarios.

#### **4.2.2 Transient Stability Studies**

The purpose of the transient stability studies is to assess the post-Project stability of the transmission system after three-phase to ground faults are applied on select transmission lines in the Study Area.

Transient stability studies were performed for the 2025 Summer Light and 2025 Summer Peak post-Project scenarios.

#### **4.2.3 Short-Circuit Current Level Studies**

The purpose of short-circuit current level studies is to determine the expected system short-circuit current levels in the vicinity of the Project.

Short circuit studies were performed for the 2025 Summer Peak pre-Project scenario and for the 2025 Summer Peak and 2031 Winter Peak post-Project scenarios.

### **4.3 Mitigation Measure Development and Evaluation**

As explained in Section 6 of Attachment A1, mitigation measures were developed to address system performance issues that were identified in the post-Project scenarios. Studies performed to assess the effectiveness of mitigation measures are briefly outlined below.

#### **4.3.1 Post-Mitigation Studies**

Power flow, transient stability, and short-circuit current level studies were performed to assess the impact of the Project on the performance of the AIES following implementation of the AESO's proposed mitigation measures.

#### **4.3.2 Constraint Effective Factor Studies**

Constraint effective factor studies were used to determine the generator and load constraint effective factors and to identify the most effective generators or loads to manage thermal criteria violations that were observed under Category B conditions.

---

<sup>6</sup> The AESO's desired post-contingency voltage deviations for low voltage busses represent guidelines rather than criteria. A POD bus voltage deviation that exceeds the desired limits shown in Table 3-1 of Attachment A1 does not represent a Reliability Criteria violation. Mitigation measures would not be developed to specifically address POD bus voltage deviations that exceed the desired values in Table 3-1 of Attachment A1.

## 5 Interpretation of Results

### 5.1 Results Overview

This section provides an assessment of the impact of the Project on the performance of the AIES. The Reliability Criteria violations observed during the connection assessment studies, and the proposed mitigation measures are summarized in Table 5-1.

- Section 5.2 includes an overview of the pre-Project studies results.
- Section 5.3 includes an overview of the post-Project studies results.
- Section 5.4 includes a description of the proposed mitigation measures to address observed Reliability Criteria violations.

Detailed study results are provided in Attachment A.



Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures

Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures	
	Pre-Project	Post-Project						
2025 Summer Peak	Thermal - above emergency rating	Thermal - above emergency rating	System Normal	Line 610L (Fincastle 336S to Taber 83S)	Materially increased violation	Real-time operational practices and system project P7075	Real-time operational practices and system project P7075	
	Thermal - above normal rating	Thermal - above emergency rating		Line 612L (Fincastle 336S to Suffield 895S)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above emergency rating	Thermal - above emergency rating		Line 172L (Taber 83S to 172EL Tap)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above normal rating	Thermal - above normal rating		Line 760L (Oyen 394S to P2421 Tap)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	None	Thermal - above emergency rating		Line 100L (P1828 Tap to Tilley 498S)	New violation	None	Increase the thermal rating of 100L (P1828 tap point – Tilley 498S)	
	Thermal - above emergency rating	Thermal - above emergency rating		Line 924L (Milo 356s to Langdon 102s)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above emergency rating	Thermal - above emergency rating		Line 927L (Milo 356s to Langdon 102s)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	None	Thermal - above normal rating		612L (Burdett 368S to Fincastle 336S)	Line 100L (P1828 Tap to Tilley 498S)	New violation	None	Real-time operational practices
	None	Thermal - above normal rating		610L (Taber 83S to Fincastle 336S)	Line 100L (P1828 Tap to Tilley 498S)	New violation	None	Real-time operational practices
	None	Thermal - above normal rating		871L (Amoco Empress 163S to Sand Hills 341S)	Line 924L (Milo 356s to Langdon 102s)	New violation	None	Real-time operational practices
	None	Thermal - above normal rating	763L (Vauxhall 158S to Hull 257S)	Line 610L (Fincastle 336S to Taber 83S)	New violation	None	Real-time operational practices	
	None	Thermal - above emergency rating	666L (Tilley 498S to West Brooks 28S)	Line 610L (Fincastle 336S to Taber 83S)	New violation	None	Existing RAS 181	
	Thermal - above normal rating	Thermal - above normal rating	1051L (West Brooks 28S to Cassils 324S)	Line 1052L (West Brooks 28S to Cassils 324S)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above normal rating	Thermal - above normal rating	1052L (West Brooks 28S to Cassils 324S)	Line 1051L (West Brooks 28S to Cassils 324S)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above normal rating	Thermal - above normal rating	935L (Milo 356S to Cassils 324S)	Line 1087L (Cassils 324S to Newwell 2075S)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	Thermal - above normal rating	Thermal - above normal rating		Line 923L (Milo 356s to Newwell 2075s)	Materially increased violation	Real-time operational practices	Real-time operational practices	
	None	Thermal - above normal rating	923L (Milo 356S to Newwell 2075S)	Line 935L (Milo 356s to Cassils 324s)	New violation	None	Real-time operational practices	
	Thermal - above emergency rating	Thermal - above emergency rating	924L (Langdon 102S to Milo 356S)	Line 927L (Milo 356s to Langdon 102s)	Materially increased violation	Existing RAS 175	Existing RAS 175	
	Thermal - above emergency rating	Thermal - above emergency rating	927L (Langdon 102S to Milo 356S)	Line 924L (Milo 356s to Langdon 102s)	Materially increased violation	Existing RAS 175	Existing RAS 175	
	None	Thermal - above normal rating	831L (Brooks 121S to Duchess 339S)	Line 924L (Milo 356s to Langdon 102s)	New violation	None	Real-time operational practices	
	None	Thermal - above normal rating	498ST1T2 (Tilley 498S Transformer T1/T2)	Line 612L (Fincastle 336S to Suffield 895S)	New violation	None	New RAS 209	
	None	Thermal - above emergency rating		Line 610L (Fincastle 336S to Taber 83S)	New violation	None		
	None	Thermal - above emergency rating		Line 892L (Suffield 895S to Bowmanton 244S)	New violation	None		
	None	Thermal - above emergency rating		Line 100L (Suffield 895S to P1828 Tap)	New violation	None		
	None	Thermal - above normal rating	163ST5 (Amoco Empress 163S Transformer T5)	Line 924L (Milo 356s to Langdon 102s)	Materially increased violation	None	Real-time operational practices	
	None	Thermal - above normal rating	1088L (Cassils 324S to Newwell 2075S)	Line 760L (Oyen 394S to P2421 Tap)	No impact	Real-time operational practices	Real-time operational practices	
	Thermal - above emergency rating	Thermal - above emergency rating	1088L (Cassils 324S to Newwell 2075S)	Line 1087L (Cassils 324S to Newwell 2075S)	Materially increased violation	Planned RAS 197 and real time operational practices	Planned RAS 197 and real time operational practices	
	Thermal - above normal rating	Thermal - above emergency rating	1035L (Bowmanton 244S to Newwell 2075S)	Line 1087L (Cassils 324S to Newwell 2075S)	Marginally increased violation	Real-time operational practices	Existing RAS 164	
Thermal - above normal rating	Thermal - above normal rating	EATL	Line 935L (Milo 356s to Cassils 324s)	Materially increased violation	Real-time operational practices	Real-time operational practices		
Thermal - above emergency rating	Thermal - above emergency rating		Line 924L (Milo 356s to Langdon 102s)	Materially increased violation				
Thermal - above emergency rating	Thermal - above emergency rating		Line 927L (Milo 356s to Langdon 102s)	Materially increased violation				
Thermal - above normal rating	Thermal - above normal rating		Line 923L (Milo 356s to Newwell 2075s)	Materially increased violation				
Thermal - above normal rating	Thermal - above normal rating		Line 760L (Oyen 394S to P2421 Tap)	Materially increased violation				
2025 Summer Light	None	Thermal - above normal rating	System Normal	Line 610L (Fincastle 336S to Taber 83S)	New violation	None	Real-time operational practices and system project P7075	
	None	Thermal - above emergency rating		Line 100L (P1828 Tap to Tilley 498S)	New violation	None	Increase the thermal rating of 100L (P1828 tap point – Tilley 498S)	
	None	Thermal - above normal rating	610L (Taber 83S to Fincastle 336S)	Line 100L (P1828 Tap to Tilley 498S)	New violation	None	Real-time operational practices	
	None	Thermal - above emergency rating	666L (Tilley 498S to West Brooks 28S)	Line 610L (Fincastle 336S to Taber 83S)	New violation	None	New RAS 209	
	None	Thermal - above normal rating		Line 892L (Suffield 895S to Bowmanton 244S)	New violation	None		
	None	Thermal - above normal rating		Line 100L (Suffield 895S to P1828 Tap)	New violation	None		
	None	Thermal - above emergency rating	498ST1T2 (Tilley 498S Transformer T1/T2)	Line 610L (Fincastle 336S to Taber 83S)	New violation	None	New RAS 209	
	None	Thermal - above emergency rating		Line 892L (Suffield 895S to Bowmanton 244S)	New violation	None		
	None	Thermal - above emergency rating	1088L (Cassils 324S to Newwell 2075S)	Line 100L (Suffield 895S to P1828 Tap)	New violation	None	Planned RAS 197 and real time operational practices	
	Thermal - above emergency rating	Thermal - above emergency rating		Line 1087L (Cassils 324S to Newwell 2075S)	Materially increased violation	Planned RAS 197 and real time operational practices		
None	Thermal - above normal rating	1035L (Bowmanton 244S to Newwell 2075S)	Line 1087L (Cassils 324S to Newwell 2075S)	New violation	None	Real-time operational practices		

- Notes:
- Marginally increased (or marginally decreased) refers to a percent loading difference (post-Project percent loading minus pre-Project percent loading) between 0% and 3% (or -3%).

## Engineering Connection Assessment

P1828 Alderson Solar Power Project Connection



- Materially increased (or materially decreased) refers to a percent loading difference (post-Project percent loading minus pre-Project percent loading) above or equal to 3% (or below or equal to -3%).
- RAS 197 was proposed for the approved P1927 Solar Krafte Utilities Inc project in the *Brooks Solar Farm Connection NID*. This RAS is referred to herein as "Planned RAS 197."
- RAS 209 is a new proposed RAS for P1828 to mitigate overload on 100L and 892L.

## 5.2 Pre-Project Study Results

### 5.2.1 Category A Conditions

The pre-Project power flow studies identified a number of thermal criteria violations under the Category A condition (i.e. all elements in service). As study assumptions did not account for the Vauxhall Area Transmission Development,<sup>7</sup> pre-Project Category A thermal criteria violations were observed on the 138 kV transmission line 610L. Category A thermal criteria violations were also observed on 612L, 172L, and 760L, and 240 kV transmission lines 924L and 927L prior to connection of the project. These Category A thermal criteria violations are predicted to arise following the connection of additional generation projects in the Study Area, with the exception of 610L, where congestion is presently occurring in real time.<sup>8</sup> The short-circuit fault levels were found to be within the typical capabilities of the nearby facilities.

### 5.2.2 Category B Conditions

The pre-Project power flow studies identified a number of thermal violations under Category B conditions (i.e., loss of a single system element).

## 5.3 Post-Project Study Results

### 5.3.1 Category A Conditions

With the addition of the Project, power flow studies identified a number of thermal criteria violations under the Category A condition (i.e. all elements in service). Category A thermal criteria violations were observed on the 138 kV transmission lines 610L, 612L, 172L, 760L, and 100L, and 240 kV transmission lines 924L and 927L. The short-circuit fault levels were found to be within the typical capabilities of the nearby facilities.

A summary of thermal criteria violations observed under N-0 system conditions in the Summer Peak scenarios are shown in Table 5-2.

**Table 5-2: Thermal Criteria Category A violations in the SP post-Project scenarios**

Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
			Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
612L (Fincastle 336S to Suffield 895S)	85.10	94.00	91.74	107.80	102.21	120.10	12.30

<sup>7</sup> Decision 27776-D01-2023, Alberta Electric System Operator, Needs Identification Document Application, Vauxhall Area Transmission Development and Section 15(2) Application, September 19, 2023. Approval 27776-D02-2023, Appendix 1 to Decision 27776-D01-2023.

<sup>8</sup> *ibid*

610L (Fincastle 336S to Taber 83S)	85.10	94.00	158.37	186.10	169.35	199.00 (after P7075, % loading = 97.89%)	12.90
172L (Taber 83S to 172EL Tap)	119.00	131.00	140.42	118.00	152.20	127.90	9.90
100L (Tilley 498S to P1828 Tap)	78.00	86.00	53.40	68.40	121.52	155.80	87.40
924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00	782.76	143.10	4.10
927L (Milo 356s to Langdon 102s)	576.00	691.00	763.20	132.50	785.66	136.40	3.90
760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.59	105.80	123.20	111.80	6.00

### 5.3.2 Category B Conditions

Post-Project studies identified a number of thermal criteria violations under Category B conditions.

Results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied.

## 5.4 Mitigation Measures

This section discusses the AESO’s proposed mitigation measures to address the system performance issues that were identified in the pre-Project and post-Project scenarios.

### 5.4.1 Pre-Project

The thermal criteria violations observed under Category A conditions on the 240 kV transmission lines 924L and 927L and 138 kV transmission lines 612L, 172L, and 760L can be managed by applying the TCM Rule to curtail generation as required until such a time that system developments are in place to alleviate congestion. If necessary, the AESO will file an application for an “exception” under Section 15(2) of the *Transmission Regulation* (TReg).

The approved Vauxhall Area Transmission Development, will address congestion on transmission line 610L and is expected to be fully energized by Q3 2024. The Alberta Utilities Commission also approved, pursuant to Section 15(2) of the TReg, a specific and limited exception to the matters described in Section 15(1)(f) of the TReg, thereby allowing for congestion to occur on 610L, until the Vauxhall Area Transmission Development Project is energized.<sup>9</sup>

Prior to connection of the Project, most of the observed Category B thermal criteria violations can be managed using real-time operational practices (RTOPs). In some cases, this could include applying the TCM Rule to dispatch down effective generation, and re-dispatching HVDC power levels. The remaining thermal criteria violations can be mitigated by the existing RAS 175 and planned RAS 197.

<sup>9</sup> Commission Decision 27776-D01-2023, Alberta Electric System Operator, Needs Identification Document Application, Vauxhall Area Transmission Development and Section 15(2) Application, September 19, 2023. Approval 27776-D02-2023, Appendix 1 to Decision 27776-D01-2023.

### 5.4.2 Post-Project

The post-connection assessment identified the same system performance issues that were identified in the pre-connection assessment, under certain Category A conditions. These thermal criteria violations on the 240 kV transmission lines 924L and 927L and 138 kV transmission lines 612L, 172L, and 760L can be managed by applying the TCM Rule to curtail generation as required until such a time that system developments are in place to alleviate congestion. If necessary, the AESO will file an application for an “exception” under Section 15(2) of the TReg.

The Category A thermal criteria violations observed on 138 kV transmission line 610L can be mitigated in the near term by applying the TCM Rule to dispatch down effective generation. The approved Vauxhall Area Transmission Development, will address congestion on transmission line 610L and is expected to be fully energized by Q3 2024. The Alberta Utilities Commission also approved, pursuant to Section 15(2) of the TReg, a specific and limited exception to the matters described in Section 15(1)(f) of the TReg, thereby allowing for congestion to occur on 610L, until the Vauxhall Area Transmission Development Project is energized.

The post-connection assessment identified an additional Category A violation on the 138 kV transmission line 100L. This violation will be mitigated by increasing the line rating on a section of the transmission line 100L from the Project T-tap point to the existing Tilley 498S substation to a minimum rating of 120 MVA or higher. This line rating increase will be completed as part of the Alderson Solar Power Project connection.

After connection of the Project, some the thermal criteria violations observed under Category B conditions can be mitigated by using RTOPs, existing RAS 164, existing RAS 175, existing RAS 181, and Planned RAS 197. A new RAS is required to mitigate the observed new thermal criteria violations under Category B conditions. A new RAS, hereafter referred to as RAS 209, is required to mitigate thermal criteria violations on the 138 kV transmission lines 100L and 892L under certain Category B conditions with the Project included in the RAS logic.

## **6 Project Dependencies**

The Project does not require the completion of any other AESO plans to expand or enhance the transmission system prior to connection.

## 7 Conclusions and Recommendations

Based on the study results, Alternative 3 (including the 100L rating increase) is technically viable. The connection assessment identified pre-Project and post-Project system performance issues.

The connection assessment uses credible worst-case conditions to assess the impact of the Facility connection on the Alberta interconnected electric system. Category A thermal criteria violations were observed (exacerbating pre project violations on 138 kV transmission lines 610L, 612L, 172L, 760L, 240 kV transmission lines 924L and 927L and new violation on 138 kV transmission line 100L) under these credible worst-case load and generation forecast conditions.

Study results identified a new Category A criteria violation on the 138 kV transmission line 100L and showed that the Project has a material impact on the existing Category A criteria violations. The Category A violation on 100L can be mitigated by increasing the line rating on a section of 100L to 120 MVA or higher. In addition, the observed Category A violation on the 138kV transmission line 610L can be mitigated by the approved Vauxhall Area Transmission Development, which will increase the rating of 610L once it is energized. The Alberta Utilities Commission also approved, pursuant to Section 15(2) of the TReg, a specific and limited exception to the matters described in Section 15(1)(f) of the TReg, thereby allowing for congestion to occur on 610L, until the Vauxhall Area Transmission Development Project is energized.

The remaining Category A violations will be mitigated through the use of real-time operational practices. The probability of Category A thermal criteria violations materializing is highly dependent upon the production profile of the Facility and other generation facilities in the area. The AESO will continue to monitor the pace of generation development and will notify Market Participants if it determines that it is necessary to obtain approval for a Section 15(2) exception for 924L, 927L, 612L, 172L and 760L.

The thermal criteria violations observed under Category B conditions can be mitigated through the use of existing RASs 164, 175, and 181, planned RAS 197, new RAS 209, and real-time operational practices, alone or in combination, as appropriate.

With implementation of these mitigation measures, connecting the project with the preferred alternative does not adversely affect the performance of the AIES.

The AESO recommends proceeding with the Project using Alternative 3 as the preferred alternative to respond to the Market Participant's request for system access service. Alternative 3 involves adding a 138 kV circuit to connect the Facility to the existing 138 kV transmission line 100L in a T-tap configuration, and increasing the line rating of 100L between the Project T-tap point and Tilley 498S.

The conductor used for the 138 kV circuit connecting the Facility to 100L should have a minimum capacity of 112 MVA to meet the Market Participant's requested STS contract capacity. The conductor used for the 100L line upgrade should have a minimum rating of 120 MVA.

# Attachment A: Engineering Connection Assessment Results



# Engineering Connection Assessment


## P1828 HEP Alderson Solar Park

HEP Canada SPV 1 Ltd.

**Date:** September 25, 2023


**Version:** V1

**Classification:** Public

Role	Name	Date	Signature
Prepared	Anees Khan E.I.T.	2023-09-25	
Reviewed	Rafae Malik P.Eng., M.Eng.	2023-09-25	
Approved	Yani Jazayeri P.Eng.	2023-09-25	



Sep 25, 2023  
ID # 74277

<b>PERMIT TO PRACTICE</b> <b>HARDLINE ENGINEERING LTD.</b>	
Signature	
Date	2023-09-26
ID#	92969
<b>PERMIT NUMBER: P 14024</b>	
The Association of Professional Engineers and Geoscientists of Alberta	

# Contents

<b>1</b>	<b>Executive Summary .....</b>	<b>1</b>
<b>2</b>	<b>Introduction .....</b>	<b>4</b>
<b>3</b>	<b>Connection Alternatives .....</b>	<b>4</b>
3.1	Connection Alternatives Studied.....	4
<b>4</b>	<b>Pre-Project Study Results .....</b>	<b>6</b>
4.1	Power Flow Studies .....	6
	4.1.1 <i>Alternative 3</i> .....	6
<b>5</b>	<b>Post-Project Study Results .....</b>	<b>20</b>
5.1	Power Flow Studies .....	20
	5.1.1 <i>Alternative 3</i> .....	20
5.2	Transient Stability Studies .....	46
	5.2.1 <i>Alternative 3</i> .....	46
<b>6</b>	<b>Short Circuit Studies.....</b>	<b>48</b>
6.1	Pre-Project Results .....	48
6.2	Post-Project Results .....	49
	6.2.1 <i>Scenario 3: 2025 SP Post-Project</i> .....	49
	6.2.2 <i>Scenario 5: 2031 WP Post-Project</i> .....	49
<b>7</b>	<b>Mitigation Measure Development and Evaluation .....</b>	<b>51</b>
7.1	Pre-Project.....	51
7.2	Post-Project .....	52
7.3	Evaluation of Mitigation Measures.....	55
	7.3.1 <i>Scenario 3: 2025 SP</i> .....	55
	7.3.2 <i>Scenario 4: 2025 SL</i> .....	56
	7.3.3 <i>Scenario 8: 2025 SP - Sensitivity including P2418</i> .....	57
	7.3.4 <i>Scenario 9: 2025 SL - Sensitivity including P2418</i> .....	60
	7.3.5 <i>Scenario 12: 2025 SP - Sensitivity including P2446</i> .....	61
	7.3.6 <i>Scenario 13: 2025 SL - Sensitivity including P2446</i> .....	62
7.4	Constraint Effective Factor Studies .....	63
<b>8</b>	<b>Project Interdependencies .....</b>	<b>63</b>

## Tables

Table 4-1: Thermal Criteria Violations under Category B Conditions for Scenario 1 .....	8
Table 4-2: Thermal Criteria Violations under Category B Conditions for Scenario 2 .....	9
Table 4-3: Thermal Criteria Violations under Category B Conditions for Scenario 6 .....	12
Table 4-4: Thermal Criteria Violations under Category B Conditions for Scenario 7 .....	14
Table 4-5: Thermal Criteria Violations under Category B Conditions for Scenario 10 .....	17
Table 4-6: Thermal Criteria Violations under Category B Conditions for Scenario 11 .....	19
Table 5-1: Thermal Criteria Violations under Category B Conditions for Scenario 3 .....	22
Table 5-2: Thermal Criteria Violations under Category B Conditions for Scenario 4 .....	26
Table 5-3: Thermal Criteria Violations under Category B Conditions for Scenario 8 .....	29
Table 5-4: Thermal Criteria Violations under Category B Conditions for Scenario 9 .....	36
Table 5-5: Thermal Criteria Violations under Category B Conditions for Scenario 12 .....	40
Table 5-6: Thermal Criteria Violations under Category B Conditions for Scenario 13 .....	44
Table 5-7: Transient Stability Study Results under Category B Conditions for Scenario 3 .....	46
Table 5-8: Transient Stability Study Results under Category B Conditions for Scenario 4 .....	47
Table 6-1: Pre-Project Short-Circuit Current Levels for Scenario 1 .....	48
Table 6-2: Post-Project Short-Circuit Current Levels for Scenario 3 .....	49
Table 6-3: Post-Project Short-Circuit Current Levels for Scenario 5 .....	50
Table 7-1: Pre-Project Mitigation Measures .....	51
Table 7-2: Post-Project Mitigation Measures .....	52
Table 7-3: Post-RAS Power Flow Study Results for Scenario 3 .....	56
Table 7-4: Post-RAS Power Flow Study Results for Scenario 4 .....	57
Table 7-5: Post-RAS Power Flow Study Results for Scenario 8 .....	58
Table 7-6: Post-RAS Power Flow Study Results for Scenario 9 .....	60
Table 7-7: Post-RAS Power Flow Study Results for Scenario 12 .....	61
Table 7-8: Post-RAS Power Flow Study Results for Scenario 13 .....	62

## Figures

Figure 1 Alternative 3 .....	5
------------------------------	---

## Attachments

**Attachment A: Engineering Connection Assessment: Study Scope**

**Attachment B: Pre-Project Power Flow Diagrams (Scenarios 1 to 2, 6 to 7, 10 to 11)**

**Attachment C: Pre-Project Transient Stability Diagrams (Scenarios 1 to 2)- Not Required**

**Attachment D: Post-Project Power Flow Diagrams (Scenarios 3 to 4, 8 to 9, 12 to 13)**

**Attachment E: Post-Project Transient Stability Diagrams (Scenarios 3 to 4)**

**Attachment F: Constraints Summary Tables (Scenarios 3 to 4, 8 to 9, 12 to 13)**

**Attachment G: Constraint Effective Factors Tables**

**Attachment H: Post-Project Post-Mitigation Power Flow Diagrams (Scenarios 3 to 4, 8 to 9, 12 to 13)**

**Attachment I: Dynamic Data and Assumptions**

# 1 Executive Summary

## Project Overview

HEP Canada SPV 1 Ltd. has submitted a System Access Service Request (SASR) to the Alberta Electric System Operator for a connection of the proposed HEP Alderson Solar Park project. The Market Participant (MP) has requested for a Supply Transmission Service (STS) of 100MW and a Demand Transmission Service (DTS) of 0.5 MW connection to the 138kV transmission line south-east of Tilley.

The requested In-Service Date for the Project is December 02, 2024.

### Study Area for the Project

The Study Area for the Project consists of the AESO Planning areas of Medicine Hat (Area 4), Vauxhall (Area 52), Empress (Area 48), and Brooks (Area 47), including the tie lines connecting these planning areas to the rest of the AIES. All transmission facilities within the Study Area were studied and monitored for violations of the Reliability Criteria.

## Connection alternatives studied

Alternative 3 – T-tap connection onto 138kV line 100L.

## Studies Performed for the Project

High south generation in combination with high solar were studied for mitigation as these were found to provide the most stressed scenarios for the studies.

Power flow analysis was performed for the 2025 summer light (SL) and summer peak (SP) pre-Project and post-Project scenarios, with the 2025 AIES topology in the South Planning Region, to determine the impact of the connection of the Project on the AIES.

Short-circuit analysis was performed for the 2025 SP pre-Project scenario and for the 2025 SP and 2031 WP post-Project scenarios to determine the short-circuit levels in the vicinity of the project.

A sensitivity analysis for system normal conditions was performed for the 2025 SL and 2025 SP pre-Project and post-Project scenarios for the condition when additional generation projects (P2418 or P2446) are online.

Transient stability analysis was performed for the 2025 SL and 2025 SP post-Project scenarios to identify violations, if any, of the transient stability criteria.

## Results of the Pre-Project Studies

### Category A Conditions

The power flow studies identified thermal violations under Category A conditions (i.e., no lost system element). The most effective generators were scaled down to mitigate the observed Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

### Category B Conditions

Category A curtailments were performed prior to the Category B studies.

## **Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

The pre-Project power flow studies identified a number of thermal violations under Category B conditions (i.e., loss of a single system element).

No Reliability Criteria violations or voltage deviations were observed that were beyond the limits listed in Table 3-1 of the AESO's Study Scope (hereafter referred to as point of delivery (POD) bus voltage deviations) under Category B conditions.

### **Results of the Post-Project Studies**

#### Category A Conditions

The power flow studies identified thermal violations under Category A conditions (i.e., no lost system element). The most effective generators were scaled down to mitigate the observed Category A overloads.

The long-term short circuit levels were found to be within the designed capabilities of the nearby facilities.

#### Category B Conditions

Category A curtailments were conducted prior to the Category B studies.

Post-Project power flow studies and voltage stability studies identified a number of system performance issues under Category B conditions, namely: thermal criteria violations.

Results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied.

### **Mitigation Strategy and Sensitivity Analysis**

Thermal violations, above normal ratings but below the emergency ratings, will be mitigated using real time operational practices.

The main study scenarios identified the requirement of a new Remedial Action Scheme (RAS), namely RAS 209, to mitigate the thermal violations observed under the 498ST1T2 (Tilley 498S Transformer T1/T2) and 666L (Tilley 498S to West Brooks 28S) contingencies.

The sensitivity study scenarios identified the requirement of three new Remedial Action Schemes (RASs), namely New RAS No. 1, New RAS No.2 and New RAS No. 3, to mitigate the thermal violations observed under certain contingencies.

The following Table shows the summary of RASs for the observed thermal violations in the main study cases and in the sensitivity studies for the mitigation of overloads under various contingencies:

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

RAS Number/Name	RAS Description
New RAS No.209	To mitigate overloads under 498ST1T2 and 666L contingency.
Planned RAS No.164	To mitigate 1087L overload under 498ST1T2 and 1035L contingency.
Existing RAS No.175	To mitigate overloads under 924L and 927L contingency.
Existing RAS No.181	To mitigate overloads under 763L and 666L contingency.
Existing RAS No.197	To mitigate 1087L overload under 1088L contingency.
Planned RAS No.607**	To mitigate overloads under 163ST5 and 760L contingency.
New RAS No.1*	To mitigate 100L, 760L, and 666L overloads under 610L, 612L, 879L or 368ST1 contingency.
New RAS No.2*	To mitigate 1051L and 1052L overloads under 1051L or 1052L contingency.
New RAS No.3*	To mitigate 610L, 923L, 935L, and 1087L overloads under 923L or 935L contingency.

### Notes:

\* New RAS considered for the sensitivity scenarios only.

\*\* Planned RAS considered for the sensitivity scenarios only.

## **2 Introduction**

This report presents the results of the engineering studies that were completed by Hardline Engineering Ltd. (the Studies Consultant) to assess the impact of the Project (as defined in the AESO's Study Scope) on the performance of the Alberta interconnected electric system (AIES). The studies were performed in accordance with the AESO's Connection Study Scope (CSS) titled "P1828 ECA Study Scope V2".

The power system network analysis tool that was used for the studies in this connection assessment was PSS/E version 33.

## **3 Connection Alternatives**

### **3.1 Connection Alternatives Studied**

One connection alternative was examined in this report. A description of the developments associated with the alternative is provided below.

**Alternative 3:**

- Add one 138 kV circuit, approximately 3km in length, to connect the Facility to the existing 138 kV transmission line 100L (Suffield 985S to Tilley 498S) in a T-tap configuration.
- Add or modify associated equipment as required for the above transmission developments.



Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1




Figure 1 Alternative 3

## 4 Pre-Project Study Results

This section describes the results of the pre-Project power flow studies.

### 4.1 Power Flow Studies

Power flow diagrams illustrating the pre-Project power flow studies results for Category A and Category B conditions are provided in Attachment B.

#### 4.1.1 Alternative 3

##### 4.1.1.1 Scenario 1: 2025 Summer Peak Pre-Project

###### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 1 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)	
				Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	91.74	107.80
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	158.37	186.10
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	140.42	118.00
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	763.20	132.50
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.59	105.80

###### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to commencing Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments for this scenario were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 1 are shown in the table below:

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1) -	60873	130.00	78.00	0.00
Enmax Taber (TAB1) - 15343, 16343	15343, 16343	81.00	48.60	0.00
P2247	560041, 560042	465.00	279.60	0.00
P1927	60434, 61434	360.00	342.00	0.00
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 1 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)		Pre-Project Results (Post-Curtailment)	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	91.74	107.80	48.57	57.07
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	158.37	186.10	67.33	79.12
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	140.42	118.00	54.16	45.51
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00	518.12	94.72
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	763.20	132.50	520.01	90.28
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.59	105.80	81.74	74.17

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-1.

**Table 4-1: Thermal Criteria Violations under Category B Conditions for Scenario 1**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738	635.7032	103.4
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738	635.7032	103.4
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547	656	582.008	106.4
	923L (Milo 356s to Newell 2075s)	547	656	563.957	103.1
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547	656	572.709	104.7
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576	691	759.744	131.9
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547	656	757.595	138.5
163ST5 (Amoco Empress 163S Transformer T5)	760L (Oyen 394S to P2421 Tap)	110.2	131	116.0406	105.3
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	871.371	159.3
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	654.212	119.6
EATL	935L (Milo 356s to Cassils 324s)	547	656	600.059	109.7
	924L (Milo 356s to Langdon 102s)	547	656	740.091	135.3
	927L (Milo 356s to Langdon 102s)	576	691	742.464	128.9
	923L (Milo 356s to Newell 2075s)	547	656	626.862	114.6
	760L (Oyen 394S to P2421 Tap)	110.2	131	111.302	101

Notes:

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No voltage deviations beyond the limits listed in Table 3-1 of the AESO's Study Scope (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.

## 4.1.1.2 Scenario 2: 2025 Summer Light Pre-Project

### Category A Conditions

No Reliability Criteria (as defined in the AESO's Study Scope) violations were observed under Category A conditions.

### Category B Conditions

Thermal criteria violations were observed under Category A conditions in the 2025 SL post-Project scenario. Hence, Category A curtailments were conducted prior to the Category B studies. The generation adjustments were performed based on the post-Project Category A violations and were applied to the pre-Project scenario accordingly. The most effective generators were scaled down to mitigate Category A overloads.

Updated generation dispatch values for Scenario 2 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1) -	60873	130.00	26.00	0.00

### Thermal Criteria Violations

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-2.

**Table 4-2: Thermal Criteria Violations under Category B Conditions for Scenario 2**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
1088L (Cassils 324S to	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	790.415	144.5

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Newell 2075S)					
------------------	--	--	--	--	--

### Notes:

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 4.1.1.3 Scenario 6: 2025 Summer Peak Pre-Project Sensitivity With P2418

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 6 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)	
				Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	102.72	120.70
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	169.43	199.10
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	155.41	130.60
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	802.45	146.70
Base Case	927L (Milo 356s to Langdon 102s)	547.00	656.00	764.71	139.80
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	150.86	136.90

### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 6 are shown in the table below:

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
P2421	560051	140.00	133.00	83.00
P2247	560041, 560042	465.00	279.60	0.00
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	78.00	0.00
Enmax Taber (TAB1)	15343, 16343	81.00	48.60	0.00
"Westfield Yellow Lake (WEF1)	557277	19.00	18.05	0.00
P1927	60434, 61434	360.00	342.00	0.00
Travers Solar	560026, 561026, 562026	465.00	441.75	260.75
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 6 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)		Pre-Project Results (Post-Curtailment)	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	102.72	120.70	49.96	58.71
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	169.43	199.10	71.62	84.16
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	155.41	130.60	56.23	47.25
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	802.45	146.70	509.15	93.08
Base Case	927L (Milo 356s to Langdon 102s)	547.00	656.00	764.71	139.80	485.30	88.72
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	150.86	136.90	83.07	75.38

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-3.

**Table 4-3: Thermal Criteria Violations under Category B Conditions for Scenario 6**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
610L (Taber 83S to Fincastle 336S)	100L (Suffield 895S to P1828 Tap)	78	86	79.40	101.80
760L (Amoco Empress 163S to Empress 394S)	668L (Empress 394S to Cypress 562S)	121	133	166.62	137.70
892L (Suffield 895S to Bowmanton 244S)	610L (Fincastle 336S to Taber 83S)	85.1	94	86.46	101.60
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738	702.72	114.30
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738	702.72	114.30
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547	656	626.32	114.50
	923L (Milo 356s to Newell 2075s)	547	656	647.10	118.30
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547	656	656.40	120.00
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576	691	747.07	129.70
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547	656	745.01	136.20
498ST1T2 (Tilley 498S)	610L (Fincastle 336S to Taber 83S)	85.1	94	87.14	102.40



## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Transformer T1/T2)					
100L (Suffield 895S to Tilley 498S)	610L (Fincastle 336S to Taber 83S)	85.1	94	87.40	102.70
163ST5 (Amoco Empress 163S Transformer T5)	668L (Empress 394S to Cypress 562S)	121	133	167.83	138.70
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	923.34	168.80
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	684.84	125.20
EATL	935L (Milo 356s to Cassils 324s)	547	656	650.93	119.00
	924L (Milo 356s to Langdon 102s)	547	656	731.34	133.70
	927L (Milo 356s to Langdon 102s)	576	691	734.40	127.50
	923L (Milo 356s to Newell 2075s)	547	656	678.28	124.00
	760L (Oyen 394S to P2421 Tap)	110.2	131	112.51	102.10

### Notes:

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 4.1.1.4 Scenario 7: 2025 Summer Light Pre-Project Sensitivity With P2418

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 7 are shown in the table below:

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)	
				Power Flow (MVA)	% Loading
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	87.31	102.60

**Category B Conditions**

Thermal criteria violations were observed under Category A conditions. Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 7 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	26.00	0.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 7 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)		Pre-Project Results (Post-Curtailment)	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	87.31	102.60	72.75	85.49

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-4.

**Table 4-4: Thermal Criteria Violations under Category B Conditions for Scenario 7**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
562ST1 (Cypress 562S)	760L (EMPRESS 394S to AMOCO EMPRESS 163S)	119	131	120.19	101.00

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Transformer T1)					
562ST1 (Cypress 562S Transformer T2)	760L (EMPRESS 394S to AMOCO EMPRESS 163S)	119	131	120.07	100.90
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	822.14	150.30
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	554.11	101.30
EATL	924L (Milo 356s to Langdon 102s)	547	656	550.83	100.70
	760L (Oyen 394S to P2421 Tap)	110.2	131	121.77	110.50

### Notes:

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 4.1.1.5 Scenario 10: 2025 Summer Peak Pre-Project Sensitivity With P2446

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 10 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)	
				Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	93.01	109.30
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	162.54	191.00

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	138.64	116.50
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00
Base Case	927L (Milo 356s to Langdon 102s)	547.00	656.00	724.78	132.50
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.04	105.30

### Category B Condition

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 10 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
P2421	560051	140.00	133.00	83.00
P2247	560041, 560042	465.00	279.60	0.00
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	78.00	0.00
Enmax Taber (TAB1)	15343, 16343	81.00	48.60	0.00
"Westfield Yellow Lake (WEF1)	557277	19.00	18.05	0.00
P1927	60434, 61434	360.00	342.00	0.00
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 10 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results (Pre-Curtailment)		Pre-Project Results (Post-Curtailment)	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	93.01	109.30	46.59	54.75

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	162.54	191.00	67.88	79.77
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	138.64	116.50	46.52	39.09
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00	512.87	93.76
Base Case	927L (Milo 356s to Langdon 102s)	547.00	656.00	724.78	132.50	488.80	89.36
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.04	105.30	67.30	61.07

### Thermal Criteria Violations

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-5.

**Table 4-5: Thermal Criteria Violations under Category B Conditions for Scenario 10**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738	634.4736	103.2
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738	634.4736	103.2
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547	656	580.367	106.1
	923L (Milo 356s to Newell 2075s)	547	656	554.658	101.4
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547	656	563.41	103
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576	691	751.104	130.4
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547	656	748.843	136.9
1088L (Cassils)	1087L (Cassils 324S to Newell 2075S)	547	656	873.012	159.6

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

324S to Newell 2075S)					
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	657.494	120.2
EATL	935L (Milo 356s to Cassils 324s)	547	656	593.495	108.5
	924L (Milo 356s to Langdon 102s)	547	656	735.715	134.5
	927L (Milo 356s to Langdon 102s)	576	691	738.432	128.2
	923L (Milo 356s to Newell 2075s)	547	656	620.845	113.5

**Notes:**

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as  $MVA$  (i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

*Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

*POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

**4.1.1.6 Scenario 11: 2025 Summer Light Pre-Project Sensitivity With P2446**

**Category A Conditions**

No Reliability Criteria violations were observed under Category A conditions.

**Category B Conditions**

Thermal criteria violations were observed under Category A conditions in the 2025 SL sensitivity scenario which included P2446. Category A curtailments were conducted prior to the Category B studies. The generation adjustments were performed based on the post-Project Category A violations and were applied to the pre-Project scenario accordingly. The most effective generators were scaled down to mitigate Category A overloads.

Updated generation dispatch values for Scenario 11 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	26.00	0.00

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

### Thermal Criteria Violations

Thermal criteria violations were observed under certain Category B conditions as shown in Table 4-6.

**Table 4-6: Thermal Criteria Violations under Category B Conditions for Scenario 11**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	794.791	145.3

**Notes:**

<sup>a</sup> The facility ratings shown in the AESO's Study Scope have been adjusted from a [72/144] kV voltage base to a [69/138] kV voltage base, as is used by the power system network analysis tool.

<sup>b</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{\text{base}} \times I_{\text{actual}}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in the AESO's Study Scope.

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 5 Post-Project Study Results

This section describes the results of the post-Project power flow studies and transient stability studies.

As described in Section 2 of the AESO's Study Scope, the post-Project studies were performed using Alternative 3.

### 5.1 Power Flow Studies

Power flow diagrams illustrating the post-Project power flow studies results for Category A and Category B, conditions are included in Attachment D.

#### 5.1.1 Alternative 3

##### 5.1.1.1 Scenario 3: 2025 Summer Peak Post-Project

###### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 3 and it's corresponding pre-Project scenario (Scenario 1) are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	91.74	107.80	102.21	120.10	12.30
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	158.37	186.10	169.35	199.00	12.90
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	140.42	118.00	152.20	127.90	9.90
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	53.4	68.4	121.52	155.80	87.4
Base Case	924L (Milo 356s to	547.00	656.00	760.33	139.00	782.76	143.10	4.10



## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	Langdon 102s)							
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	763.20	132.50	785.66	136.40	3.90
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.59	105.80	123.20	111.80	6.00

### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 3 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1) -	60873	130.00	78.00	0.00
Enmax Taber (TAB1) - 15343, 16343	15343, 16343	81.00	48.60	0.00
P2247	560041, 560042	465.00	279.60	0.00
P1927	60434, 61434	360.00	342.00	0.00
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 3 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to	85.10	94.00	102.21	120.10	58.06	68.23

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

	Suffield 895S)						
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	169.35	199.00	76.53	89.93
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	152.20	127.90	66.60	55.97
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	121.52	155.80	66.46	85.21
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	782.76	143.10	541.26	98.95
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	785.66	136.40	543.23	94.31
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	123.20	111.80	86.08	78.11

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-1.

**Table 5-1: Thermal Criteria Violations under Category B Conditions for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
612L (Burdett 368S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	61.8	51.5	124.1	103.4	51.9
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	68.1	56.8	129.2	107.7	51.0
871L (Amoco Empress 163S to Sand Hills 341S)	924L (Milo 356s to Langdon 102s)	547.0	656.0	525.4	96.0	548.6	100.3	4.3
763L (Vauxhall	610L (Fincastle	85.1	94.0	75.7	88.9	85.6	100.6	11.7

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

158S to Hull 257S)	336S to Taber 83S)							
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	70.6	83.0	100.4	118.0	35.0
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738.0	635.7	103.4	691.0	112.4	9.0
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738.0	635.7	103.4	691.0	112.4	9.0
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	582.0	106.4	606.6	110.9	4.5
	923L (Milo 356s to Newell 2075s)	547.0	656.0	564.0	103.1	610.5	111.6	8.5
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547.0	656.0	572.7	104.7	619.2	113.2	8.5
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.0	691.0	759.7	131.9	793.7	137.8	5.9
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.0	656.0	757.6	138.5	792.1	144.8	6.3
831L (Brooks 121S to Duchess 339S)	924L (Milo 356s to Langdon 102s)	547.0	656.0	524.0	95.8	547.0	100.0	4.2
498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.1	94.0	61.3	72.1	89.9	105.6	33.6
	610L (Fincastle 336S to Taber 83S)	85.1	94.0	80.1	94.2	108.4	127.4	33.2
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	18.6	23.2	96.2	120.2	97.0
	100L (Suffield	78.0	86.0	1.1	1.4	92.8	119.0	117.6

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	895S to P1828 Tap)							
163ST5 (Amoco Empress 163S Transformer T5)	924L (Milo 356s to Langdon 102s)	547.0	656.0	526.1	96.2	549.2	100.4	4.2
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	116.0	105.3	116.0	105.3	0.0
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	871.4	159.3	900.4	164.6	5.3
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	654.2	119.6	667.9	122.1	2.5
EATL	935L (Milo 356s to Cassils 324s)	547.0	656.0	600.1	109.7	628.0	114.8	5.1
	924L (Milo 356s to Langdon 102s)	547.0	656.0	740.1	135.3	765.3	139.9	4.6
	927L (Milo 356s to Langdon 102s)	576.0	691.0	742.5	128.9	767.8	133.3	4.4
	923L (Milo 356s to Newell 2075s)	547.0	656.0	626.9	114.6	654.8	119.7	5.1
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	111.3	101.0	116.2	105.4	4.4

### *Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

### *POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

## 5.1.1.2 Scenario 4: 2025 Summer Light Post-Project

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 4 and it's corresponding pre-Project scenario (Scenario 2) are shown in the table below:

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	81.2	95.4	90.89	106.80	11.4
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	32.4	41.5	101.32	129.90	88.4

**Category B Conditions**

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The generation adjustments were performed based on the post-project Category A violations. The most effective generators were scaled down to mitigate Category A overloads.

Updated generation dispatch values for Scenario 4 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1) -	60873	130.00	26.00	0.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 4 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	90.89	106.80	74.35	87.37
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	101.32	129.90	62.35	79.94

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-2.

**Table 5-2: Thermal Criteria Violations under Category B Conditions for Scenario 4**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	51.7	66.3	124.6	103.8	37.5
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	67.1	78.9	95.7	112.4	33.6
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	28.0	35.0	85.8	107.2	72.2
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	24.9	31.9	80.7	103.4	71.5
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	74.1	87.1	101.8	119.6	32.5
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	13.7	17.2	106.6	133.3	116.2
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	0.0	0.0	102.3	131.2	131.2
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	790.4	144.5	815.0	149.0	4.5
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	537.0	98.2	550.3	100.6	2.4

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 5.1.1.3 Scenario 8: 2025 Summer Peak Post-Project Sensitivity With P2418

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 8 and its corresponding pre-Project scenario (Scenario 6) are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	102.72	120.7	112.67	132.40	11.70
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	169.43	199.1	180.58	212.20	13.10
Base Case	879L (Burdett 368S to 879AL_Tap)	85.00	94.00	75.6	89.0	85.51	100.60	11.6
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	155.41	130.6	163.51	137.40	6.80
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	66.7	85.6	133.85	171.60	86
Base Case	935L (Milo 356s to Cassils 324s)	547.00	656.00	545.9	99.8	568.33	103.90	4.1
Base Case	924L (Milo 356s to)	547.00	656.00	802.45	146.7	826.52	151.10	4.40

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	Langdon 102s)							
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	805.25	139.8	829.44	144.00	4.20
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	150.86	136.9	157.48	142.90	6.00

### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 8 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
P2421	560051	140.00	133.00	83.00
P2247	560041, 560042	465.00	279.60	0.00
RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	78.00	0.00
Enmax Taber (TAB1)	15343, 16343	81.00	48.60	0.00
"Westfield Yellow Lake (WEF1)	557277	19.00	18.05	0.00
P1927	60434, 61434	360.00	342.00	0.00
Travers Solar	560026, 561026, 562026	465.00	441.75	260.75
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 8 are shown in the table below:



**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	112.67	132.40	60.17	70.71
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	180.58	212.20	81.42	95.68
Base Case	879L (Burdett 368S to 879AL Tap)	85.00	94.00	85.51	100.60	49.86	58.66
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	163.51	137.40	69.17	58.13
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	133.85	171.60	77.60	99.49
Base Case	935L (Milo 356s to Cassils 324s)	547.00	656.00	568.33	103.90	419.33	76.66
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	826.52	151.10	529.88	96.87
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	829.44	144.00	531.82	92.33
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	157.48	142.90	89.48	81.20

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-3.

**Table 5-3: Thermal Criteria Violations under Category B Conditions for Scenario 8**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
612L (Burdett 368S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	72.1	60.1	141.8	118.2	58.1
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	78.8	65.7	147.5	122.9	57.2

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

871L (Amoco Empress 163S to Sand Hills 341S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.4	46.2	121.3	101.1	54.9
931L (Ware Junction 132S to West Brooks 28S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	57.4	47.8	122.9	102.4	54.6
1075L (Ware Junction 132S to West Brooks 28S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	57.4	47.8	122.9	102.4	54.6
1053L (Ware Junction 132S to Cassils 324S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	56.7	47.2	122.3	101.9	54.7
1002L (Jenner 275S to Amoco Empress 163S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	57.2	47.6	123.5	102.9	55.3
945L (Jenner 275S to Cypress 562S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	57.7	48.1	124.1	103.4	55.3
163ST1 (Amoco Empress 163S Transformer T5)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.6	46.4	121.7	101.4	55.1
760L (Amoco Empress 163S to Empress 394S)	668L (Empress 394S to Cypress 562S)	121.0	133.0	166.6	137.7	167.5	138.4	0.7
722L (Burdett 368S to Westfield 107S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	79.8	93.8	90.0	105.7	11.9
	100L (Tilley 498S to P1828 Tap)	120.0	132.0	54.4	45.3	120.8	100.7	55.4
892L (Suffield 895S to Bowmanton 244S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	86.5	101.6	86.3	101.4	-0.2
507L (Taber 83S to Hull 257S)	610L (Fincastle)	85.1	94.0	78.9	92.7	89.8	105.5	12.8

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	336S to Taber 83S)							
763L (Vauxhall 158S to Hull 257S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	83.9	98.5	94.6	111.2	12.7
666L (Tilley 498S to West Brooks 28S)	612L (Fincastle 336S to Suffield 895S)	85.1	94.0	56.2	66.1	87.2	102.5	36.4
	610L (Fincastle 336S to Taber 83S)	85.1	94.0	77.8	91.5	108.2	127.1	35.6
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738.0	702.7	114.3	756.8	123.1	8.8
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738.0	702.7	114.3	756.8	123.1	8.8
1148L (Whitla 251S to Shamrock 1018S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	54.9	45.7	121.8	101.5	55.8
562ST1 (Cypress 562S Transformer T1)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.7	46.4	121.8	101.5	55.1
562ST1 (Cypress 562S Transformer T2)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.7	46.4	121.8	101.5	55.1
935L (Milo 356S to Cassils 324S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	78.0	91.7	88.2	103.7	12.0
	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	626.3	114.5	649.8	118.8	4.3
	923L (Milo 356s to Newell 2075s)	547.0	656.0	647.1	118.3	688.1	125.8	7.5
1087L (Cassils 324S to Newell 2075S)	1088L (Cassils 324S to Newell A2075S)	931.0	1024.0	923.5	99.2	952.4	102.3	3.1
923L (Milo 356S to	610L (Fincastle	85.1	94.0	77.4	91.0	87.7	103.1	12.1

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Newell 2075S)	336S to Taber 83S)							
	935L (Milo 356s to Cassils 324s)	547.0	656.0	656.4	120.0	696.9	127.4	7.4
336ST1 (Fincastle 336S Transformer T1)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	76.1	89.5	86.1	101.2	11.7
895ST2 (Suffield 895S Transformer T2)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	54.6	45.5	121.7	101.4	55.9
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.0	691.0	747.1	129.7	777.0	134.9	5.2
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.0	656.0	745.0	136.2	775.1	141.7	5.5
853L (Queenstow n 504S to West Brooks 28S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.2	46.0	121.4	101.2	55.2
498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.1	94.0	65.7	77.3	95.4	112.1	34.9
	610L (Fincastle 336S to Taber 83S)	85.1	94.0	87.1	102.4	116.1	136.4	34.0
	879L (Burdett 368S to 879AL Tap)	85.0	94.0	55.7	65.6	86.3	101.5	35.9
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	17.1	21.4	103.0	128.8	107.4
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	1.1	1.4	97.7	125.3	123.9
	879L (Bowmanto n 244S to 879AL Tap)	85.0	94.0	61.1	71.9	91.1	107.2	35.3
100L (Suffield 895S to Tilley 498S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	87.4	102.7	87.9	103.3	0.6

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

760L/7L60 (Amoco Empress 163S to Oyen 767S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	54.3	45.2	120.7	100.6	55.4
163ST5 (Amoco Empress 163S Transformer T5)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	78.1	91.8	88.4	103.9	12.1
	668L (Empress 394S to Cypress 562S)	121.0	133.0	167.8	138.7	168.4	139.2	0.5
	100L (Tilley 498S to P1828 Tap)	120.0	132.0	61.8	51.5	126.8	105.7	54.2
944L (Jenner 275S to Ware Junction 132S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	56.7	47.3	124.0	103.3	56.1
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	923.3	168.8	951.8	174.0	5.2
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	684.8	125.2	701.3	128.2	3.0
964L (Bowmanton 244S to Whitla 251S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	55.5	46.3	122.9	102.4	56.1
676L (Bowmanton 244S to Bullshead 523S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	54.7	45.6	121.6	101.3	55.7
763L (West Brooks 28S to Vauxhall 158S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.3	88.5	85.6	100.6	12.1
368ST1 (Burdett 368S Transformer T1)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	68.4	57.0	138.6	115.5	58.5
257ST1 (Hull 257S Transformer T1)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	78.9	92.7	89.8	105.5	12.8
158ST2 (Vauxhall 158S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	81.5	95.7	92.2	108.4	12.7

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Transformer T2)								
879L (Burdett 368S to Bullshead 523S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	69.9	58.3	138.8	115.7	57.4
172L (Taber 83S to Coaldale 254S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	57.5	47.9	124.4	103.7	55.8
EATL	610L (Fincastle 336S to Taber 83S)	85.1	94.0	77.8	91.4	87.8	103.2	11.8
	935L (Milo 356s to Cassils 324s)	547.0	656.0	650.9	119.0	676.6	123.7	4.7
	924L (Milo 356s to Langdon 102s)	547.0	656.0	731.3	133.7	754.3	137.9	4.2
	927L (Milo 356s to Langdon 102s)	576.0	691.0	734.4	127.5	757.4	131.5	4.0
	923L (Milo 356s to Newell 2075s)	547.0	656.0	678.3	124.0	704.5	128.8	4.8
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	112.5	102.1	119.8	108.7	6.6

*Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

*POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

**5.1.1.4 Scenario 9: 2025 Summer Light Post-Project Sensitivity With P2418**

**Category A Conditions**

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 9 and it's corresponding pre-Project scenario (Scenario 7) are shown in the table below:

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	87.31	102.6	99.57	117.00	14.40
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	40.6	52	110.68	141.90	89.9

### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 9 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	26.00	0.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 9 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	99.57	117.00	82.72	97.20
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	110.68	141.90	68.52	87.84

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-4.

**Table 5-4: Thermal Criteria Violations under Category B Conditions for Scenario 9**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
612L (Burdett 368S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	51.4	65.9	124.7	103.9	38.0
610L (Taber 83S to Fincastle 336S)	666L (Tilley 498S to West Brooks 28S)	120.0	108.0	49.7	41.4	120.2	100.2	58.8
	100L (Tilley 498S to P1828 Tap)	120.0	132.0	63.9	81.9	137.2	114.3	32.4
1002L (Jenner 275S to Amoco Empress 163S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.3	88.5	85.5	100.5	12.0
945L (Jenner 275S to Cypress 562S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.7	88.9	85.9	100.9	12.0
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	104.7	95.0	110.5	100.3	5.3
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	76.9	90.4	106.3	124.9	34.5
	892L (Suffield 895S to Bowman 244S)	80.0	88.0	28.0	35.0	85.4	106.8	71.9
	100L (Suffield 895S to)	78.0	86.0	24.9	31.9	80.5	103.2	71.3



## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	P1828 Tap)							
935L (Milo 356S to Cassils 324S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	76.1	89.5	86.5	101.6	12.1
923L (Milo 356S to Newell 2075S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.4	88.6	85.7	100.7	12.1
336ST1 (Fincastle 336S Transformer T1)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.7	89.0	85.7	100.7	11.7
Burdett 368S Transformer T2	610L (Fincastle 336S to Taber 83S)	85.1	94.0	75.8	89.1	85.8	100.8	11.7
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	84.1	98.8	112.4	132.1	33.3
	892L (Suffield 895S to Bowmant on 244S)	80.0	88.0	13.7	17.2	106.4	133.0	115.8
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	0.0	0.0	102.3	131.1	131.1
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	100.8	91.5	111.4	101.1	9.6
163ST5 (Amoco Empress 163S Transformer T5)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	78.4	92.1	89.0	104.6	12.5
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	822.1	150.3	844.6	154.4	4.1
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	554.1	101.3	566.7	103.6	2.3
EATL	610L (Fincastle	85.1	94.0	80.5	94.6	90.3	106.1	11.5

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

	336S to Taber 83S)							
	924L (Milo 356s to Langdon 102s)	547.0	656.0	550.8	100.7	568.9	104.0	3.3
	760L (Oyen 394S to P2421 Tap)	110.2	131.0	121.8	110.5	127.3	115.5	5.0

*Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

*POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

**5.1.1.5 Scenario 12: 2025 Summer Peak Post-Project Sensitivity With P2446**

**Category A Conditions**

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 12 and it's corresponding pre-Project scenario (Scenario 10) are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	93.01	109.30	103.82	122.00	12.70
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	162.54	191.00	172.58	202.80	11.80
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	138.64	116.50	150.06	126.10	9.60
Base Case	100L (Tilley 498S to	78.00	86.00	49.9	64	109.12	139.90	75.9

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	P1828 Tap)							
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	760.33	139.00	782.21	143.00	4.00
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	763.20	132.50	785.09	136.30	3.80
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	116.04	105.30	121.88	110.60	5.30

### Category B Conditions

Thermal criteria violations were observed under Category A conditions. Hence, Category A curtailments were conducted prior to the Category B studies. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 12 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
P2421	560051	140.00	133.00	103.00
P2247	560041, 560042	465.00	279.60	0.00
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	78.00	0.00
Enmax Taber (TAB1)	15343, 16343	81.00	48.60	0.00
"Westfield Yellow Lake (WEF1)	557277	19.00	18.05	0.00
P1927	60434, 61434	360.00	342.00	0.00
Area 4 Wind	60990, 61990, 61994, 62994, 65994, 560003, 561003, 3462, 3463, 60608, 61608, 560044, 567034		1075.64	800.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 12 are shown in the table below:

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	103.82	122.00	54.86	64.47
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	172.58	202.80	76.09	89.41
Base Case	172L (Taber 83S to 172EL Tap)	119.00	131.00	150.06	126.10	57.94	48.69
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	109.12	139.90	62.53	80.17
Base Case	924L (Milo 356s to Langdon 102s)	547.00	656.00	782.21	143.00	532.61	97.37
Base Case	927L (Milo 356s to Langdon 102s)	576.00	691.00	785.09	136.30	534.59	92.81
Base Case	760L (Oyen 394S to P2421 Tap)	110.20	131.00	121.88	110.60	72.97	66.22

*Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-5.

**Table 5-5: Thermal Criteria Violations under Category B Conditions for Scenario 12**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
763L (Vauxhall 158S to Hull 257S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	77.6	91.2	86.8	102.0	10.8

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	77.0	90.5	104.2	122.4	31.9
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	22.7	28.4	89.1	111.4	83.0
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	13.7	17.6	85.7	109.9	92.3
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.8	738.0	634.5	103.2	684.3	111.3	8.1
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.8	738.0	634.5	103.2	684.3	111.3	8.1
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	580.4	106.1	600.6	109.8	3.7
	923L (Milo 356s to Newell 2075s)	547.0	656.0	554.7	101.4	592.4	108.3	6.9
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547.0	656.0	563.4	103.0	601.7	110.0	7.0
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.0	691.0	751.1	130.4	779.9	135.4	5.0
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.0	656.0	748.8	136.9	777.8	142.2	5.3
498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.1	94.0	57.7	67.8	85.7	100.7	32.9
	610L (Fincastle 336S to Taber 83S)	85.1	94.0	78.8	92.6	106.3	124.9	32.3
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	17.0	21.2	95.9	119.9	98.7

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	100L (Suffield 895S to P1828 Tap)	78.0	86.0	1.1	1.4	92.9	119.1	117.7
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	873.0	159.6	896.5	163.9	4.3
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	657.5	120.2	670.6	122.6	2.4
EATL	935L (Milo 356s to Cassils 324s)	547.0	656.0	593.5	108.5	617.6	112.9	4.4
	924L (Milo 356s to Langdon 102s)	547.0	656.0	735.7	134.5	759.2	138.8	4.3
	927L (Milo 356s to Langdon 102s)	576.0	691.0	738.4	128.2	762.0	132.3	4.1
	923L (Milo 356s to Newell 2075s)	547.0	656.0	620.8	113.5	644.4	117.8	4.3

### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

## 5.1.1.6 Scenario 13: 2025 Summer Light Post-Project Sensitivity With P2446

### Category A Conditions

Thermal criteria violations were observed under Category A conditions. Thermal criteria violations under Category A Conditions prior to generation curtailment for Scenario 13 and its corresponding pre-Project scenario (Scenario 11) are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results (Pre-curtailment)		Post-Project Results (Pre-curtailment)		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Base Case	610L (Fincastle)	85.10	94.00	80.5	54	85.70	100.70	46.70

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	336S to Taber 83S)							
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	30	38.4	94.85	121.60	83.20

### Category B Conditions

Category A curtailments were conducted prior to the Category B studies. Thermal criteria violations were observed under Category A conditions. The most effective generators were scaled down to mitigate Category A overloads. The generation adjustments were performed based on the post-project Category A violations.

Updated generation dispatch values for Scenario 13 are shown in the table below:

Generator Name	Bus Number	MC (MW)	CSS (MW)	Dispatch (MW)
"RESC Rattlesnake Ridge MPC Wind (RTL1)	60873	130.00	26.00	0.00

Thermal criteria violations under Category A Conditions prior to and after generation curtailment for Scenario 13 are shown in the table below:

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Post-Project Results (Pre-curtailment)		Post-Project Results (Post-curtailment)	
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading
Base Case	610L (Fincastle 336S to Taber 83S)	85.10	94.00	85.70	100.70	73.76	86.68
Base Case	100L (Tilley 498S to P1828 Tap)	78.00	86.00	94.85	121.60	60.57	77.66

### Thermal Criteria Violations

Thermal criteria violations were observed under certain Category B conditions as shown in Table 5-6.

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

**Table 5-6: Thermal Criteria Violations under Category B Conditions for Scenario 13**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.0	132.0	49.0	62.8	121.9	101.6	38.8
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	68.2	80.1	98.0	115.1	35.0
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	20.5	25.6	99.0	123.8	98.2
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	11.8	15.1	94.5	121.2	106.1
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.1	94.0	70.7	83.1	100.2	117.8	34.7
	892L (Suffield 895S to Bowmanton 244S)	80.0	88.0	13.7	17.1	106.7	133.4	116.3
	100L (Suffield 895S to P1828 Tap)	78.0	86.0	0.0	0.0	102.3	131.2	131.2
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	794.8	145.3	817.8	149.5	4.2
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.0	656.0	539.4	98.6	551.9	100.9	2.3
EATL	924L (Milo 356s to Langdon 102s)	547.0	656.0	530.1	96.9	547.5	100.1	3.2

**Voltage Criteria Violations**

No voltage criteria violations were observed under Category B conditions.



**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

*POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

## 5.2 Transient Stability Studies

### 5.2.1 Alternative 3

#### 5.2.1.1 Scenario 3: 2025 SP Post-Project

Transient stability studies were completed for Scenario 3.

If there were no transient stability issues, use the following explanation. The results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied, as shown in Table 5-7. The post-Project transient stability plots are provided in Attachment E. The dynamic data and assumptions of all equipment proposed for the Facility are provided in Attachment I.

**Table 5-7: Transient Stability Study Results under Category B Conditions for Scenario 3**

Studied Contingency	Fault Description and Location	Results
666L (West Brooks 28S - Tilley 498S)	3-phase fault at Tilley 498S	Stable
	3-phase fault at West Brooks 28S	Stable
892L (Suffield 895S – Bowmanton 244S)	3-phase fault at Suffield 895S	Stable
	3-phase fault at Bowmanton 244S	Stable
763L (West Brooks 28S - Vauxhall 158S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Vauxhall 158S	Stable
853L (West Brooks 28S – Queenstown 504S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Queenstown 504S	Stable
814L (Brooks 121S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Brooks 121S	Stable
827L (Brooks 121S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Brooks 121S	Stable
1051L (West Brooks 28S – Cassils 324S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Cassils 324S	Stable
1052L (West Brooks 28S – Cassils 324S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Cassils 324S	Stable
931L (Ware Junction 132S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Ware Junction 132S	Stable
1075L (Ware Junction 132S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Ware Junction 132S	Stable
675L (Bowmanton 244S – Medicine Hat 41S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Medicine Hat 41S	Stable
674L (Bowmanton 244S- Chappice Lake 649S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Chappice Lake 649S	Stable

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

879L (Bowmanton 244S – Burdett 368S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Burdett 368S	Stable

### 5.2.1.2 Scenario 4: 2025 SL Post-Project

Transient stability studies were completed for Scenario 4.

If there were no transient stability issues, use the following explanation. The results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied, as shown in Table 5-8. The post-Project transient stability plots are provided in Attachment E. The dynamic data and assumptions of all equipment proposed for the Facility are provided in Attachment I.

**Table 5-8: Transient Stability Study Results under Category B Conditions for Scenario 4**

Studied Contingency	Fault Description and Location	Results
666L (West Brooks 28S - Tilley 498S)	3-phase fault at Tilley 498S	Stable
	3-phase fault at West Brooks 28S	Stable
892L (Suffield 895S – Bowmanton 244S)	3-phase fault at Suffield 895S	Stable
	3-phase fault at Bowmanton 244S	Stable
763L (West Brooks 28S - Vauxhall 158S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Vauxhall 158S	Stable
853L (West Brooks 28S – Queenstown 504S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Queenstown 504S	Stable
814L (Brooks 121S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Brooks 121S	Stable
827L (Brooks 121S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Brooks 121S	Stable
1051L (West Brooks 28S – Cassils 324S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Cassils 324S	Stable
1052L (West Brooks 28S – Cassils 324S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Cassils 324S	Stable
931L (Ware Junction 132S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Ware Junction 132S	Stable
1075L (Ware Junction 132S – West Brooks 28S)	3-phase fault at West Brooks 28S	Stable
	3-phase fault at Ware Junction 132S	Stable
675L (Bowmanton 244S – Medicine Hat 41S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Medicine Hat 41S	Stable
674L (Bowmanton 244S- Chappice Lake 649S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Chappice Lake 649S	Stable
879L (Bowmanton 244S – Burdett 368S)	3-phase fault at Bowmanton 244S	Stable
	3-phase fault at Burdett 368S	Stable

## 6 Short Circuit Studies

### 6.1 Pre-Project Results

Pre-Project short-circuit current levels are provided in Table 6-1<sup>1</sup>.

**Table 6-1: Pre-Project Short-Circuit Current Levels for Scenario 1**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
895S SUFFIELD	138	138.30	3.3731	0.057367+j0.130791	2.1309	0.108204+j0.377077
498S TILLEY	138	139.75	5.0661	0.037240+j0.090210	3.6613	0.048966+j0.203788
28S WEST BROOKS	138	139.93	15.5857	0.006342+j0.031440	17.1661	0.001822+j0.021792
649S CHAPPICE LAKE	138	140.43	4.1567	0.042554+j0.106308	2.6016	0.082919+j0.307309
28S WEST BROOKS	240	243.67	13.9687	0.004278+j0.020251	14.2325	0.002721+j0.018543
244S BOWMANTON (Bus 645)	138	140.43	4.155	0.042622+j0.106343	2.6032	0.082700+j0.306956
244S BOWMANTON (Bus 659)	138	140.61	9.3089	0.005551+j0.051562	8.9208	0.008372+j0.054496
244S BOWMANTON	240	247.32	7.3699	0.004606+j0.038596	7.3943	0.007619+j0.036227
562S CYPRESS	138	140.47	10.5576	0.005258+j0.044115	8.2996	0.011145+j0.077514
562S CYPRESS	240	257.30	6.92	0.005865+j0.040900	5.4666	0.010864+j0.070752
394S CASSILS	240	243.65	13.9981	0.004263+j0.020220	14.1402	0.002965+j0.019003
321S AL ROTHBAUER	138	139.28	7.8332	0.008299+j0.058831	7.5477	0.007917+j0.060067
840S MCNEILL STATION	138	141.56	7.0038	0.007583+j0.067062	4.8597	0.028738+j0.151917

**Notes:**

\* MEDICINE HAT 41S does not exist anymore, therefore AL ROTHBAUER 321S will be considered for the short circuit studies.

<sup>1</sup> Short-circuit current studies were based on modeling information provided to the AESO by third parties. The authenticity of the modeling information has not been validated. Fault levels could change as a result of system developments, new customer connections, or additional generation in the area. It is recommended that these changes be monitored and fault levels reviewed to ensure that the fault levels are within equipment operating limits. The information provided in this study should not be used as the sole source of information for electrical equipment specifications or for the design of safety-grounding systems.

## 6.2 Post-Project Results

### 6.2.1 Scenario 3: 2025 SP Post-Project

Post-Project short-circuit current levels for Scenario 3 are provided in Table 6-2.

**Table 6-2: Post-Project Short-Circuit Current Levels for Scenario 3**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance ( $R1+jX1$ ) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance ( $R0+jX0$ ) (pu)
895S SUFFIELD	138	142.39	3.4782	0.057584+j0.131376	3.0092	0.064521+j0.199100
498S TILLEY	138	141.68	5.1568	0.037342+j0.090474,	4.3993	0.038237+j0.142499
28S WEST BROOKS	138	139.42	15.599	0.006351+j0.031452	17.2515	0.001895+j0.021416
649S CHAPPICE LAKE	138	142.17	4.2179	0.042594+j0.106425	2.8258	0.076538+j0.271703
28S WEST BROOKS	240	242.93	13.9781	0.004285+j0.020258	14.281	0.002727+j0.018375
244S BOWMANTON (Bus 645)	138	142.17	4.2165	0.042663+j0.106461	2.83	0.076176+j0.271006
244S BOWMANTON (Bus 659)	138	140.51	9.3214	0.005554+j0.051563	8.9348	0.008328+j0.054465
244S BOWMANTON	240	247.06	7.3808	0.004609+j0.038598	7.407	0.007597+j0.036203
562S CYPRESS	138	140.79	10.6205	0.005254+j0.044040	8.3845	0.011144+j0.076657
562S CYPRESS	240	258.62	6.9592	0.005881+j0.040956	5.5143	0.010877+j0.070365
394S CASSILS	240	242.88	14.0068	0.004270+j0.020226	14.1857	0.002971+j0.018842
321S AL ROTHBAUER	138	139.21	7.8421	0.008302+j0.058829	7.5557	0.007907+j0.060080,
840S MCNEILL STATION	138	141.86	7.0416	0.007598+j0.066980	4.897	0.028734+j0.151062
ALDRSNPK	138	143.53	3.7659	0.053193+j0.123595	4.1045	0.034139+j0.093612

**Notes:**

\* MEDICINE HAT 41S does not exist anymore, therefore AL ROTHBAUER 321S will be considered for the short circuit studies.

### 6.2.2 Scenario 5: 2031 WP Post-Project

Post-Project short-circuit current levels for Scenario 5 are provided in Table 6-3.

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

**Table 6-3: Post-Project Short-Circuit Current Levels for Scenario 5**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3-Φ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1-Φ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
895S SUFFIELD	138	144.56	3.1943	0.056336+j0.131482	2.7541	0.069002+j0.199334
498S TILLEY	138	140.18	4.7419	0.034469+j0.087465	4.0478	0.036894+j0.137292
28S WEST BROOKS	138	139.81	15.1794	0.004719+j0.028952	17.2494	0.001104+j0.018181
649S CHAPPICE LAKE	138	146.34	3.9059	0.044133+j0.108585	2.6352	0.079129+j0.274672
28S WEST BROOKS	240	251.40	14.5992	0.003136+j0.017886	15.9419	0.001526+j0.013470
244S BOWMANTON (Bus 645)	138	146.36	3.9055	0.044184+j0.108608	2.6386	0.078841+j0.274102
244S BOWMANTON (Bus 659)	138	138.83	8.1826	0.004796+j0.053151	8.3355	0.006523+j0.050018
244S BOWMANTON	240	249.17	6.5004	0.004118+j0.039879,	7.0646	0.005492+j0.030042
562S CYPRESS	138	142.93	9.8145	0.007097+j0.044706	8.4593	0.006728+j0.066383
562S CYPRESS	240	256.08	6.7814	0.006153+j0.038373	6.0503	0.005625+j0.052414
394S CASSILS	240	251.42	14.6323	0.003122+j0.017852	15.7898	0.001750+j0.014010
321S AL ROTHBAUER	138	137.78	7.0017	0.006762+j0.061023	6.902	0.007592+j0.063582
840S MCNEILL STATION	138	142.93	6.5712	0.012782+j0.066392	4.7813	0.024357+j0.141094
ALDRSNPK	138	142.83	3.4154	0.051332+j0.122365	3.6946	0.039960+j0.093549

**Notes:**

\* MEDICINE HAT 41S does not exist anymore, therefore AL ROTHBAUER 321S will be considered for the short circuit studies.

## 7 Mitigation Measure Development and Evaluation

The Studies Consultant, in consultation with the AESO, developed mitigation measures to address the system performance issues that were identified in the post-Project scenarios. Existing remedial action schemes (RASs) are described in the AESO’s Connection Study Scope. Further mitigation measures were considered to address system performance issues observed in the sensitivity studies.

As part of this Project, mitigation measures will not be specifically developed for the POD bus voltage deviations observed under certain Category B conditions during pre-Project and post-Project scenarios.<sup>2</sup>

### 7.1 Pre-Project

Pre-Project mitigation measures are summarized in Table 7-1.

**Table 7-1: Pre-Project Mitigation Measures**

Mitigation Measure	Location of Observed Violation	Contingency
Planned RAS No. 164	1087L (Cassils 324S to Newell 2075S)	1035L (Bowmanton 244S to Newell 2075S)
Existing RAS No.175	927L (Milo 356s to Langdon 102s)	924L (Langdon 102S to Milo 356S)
	924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)
Existing RAS No.197 and real time operational practices	1087L (Cassils 324S to Newell 2075S)	1088L (Cassils 324S to Newell 2075S)
Real time operational practices	1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)
	1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)
	1087L (Cassils 324S to Newell 2075S)	935L (Milo 356S to Cassils 324S)
	923L (Milo 356s to Newell 2075s)	
	935L (Milo 356s to Cassils 324s)	923L (Milo 356S to Newell 2075S)
	760L (Oyen 394S to P2421 Tap)	163ST5 (Amoco Empress 163S Transformer T5)
	610L (Fincastle 336S to Taber 83S)	892L (Suffield 895S to Bowmanton 244S)
		100L (Suffield 895S to Tilley 498S)
	935L (Milo 356s to Cassils 324s)	EATL
	924L (Milo 356s to Langdon 102s)	
	927L (Milo 356s to Langdon 102s)	
923L (Milo 356s to Newell 2075s)		

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	760L (Oyen 394S to P2421 Tap)	
	610L (Fincastle 336S to Taber 83S)	
	1087L (Cassils 324S to Newell 2075S)	1035L (Bowmanton 244S to Newell 2075S)
Planned RAS No. 607*	668L (Empress 394S to Cypress 562S)	760L (Amoco Empress 163S to Empress 394S)
		163ST5 (Amoco Empress 163S Transformer T5)

### Notes:

\* Planned RAS considered for the sensitivity scenarios only.

## 7.2 Post-Project

Post-Project mitigation measures are summarized in Table 7-2.

**Table 7-2: Post-Project Mitigation Measures**

Mitigation Measure	Location of Observed Violation	Contingency
New RAS No.209	612L (Fincastle 336S to Suffield 895S)	498ST1T2 (Tilley 498S Transformer T1/T2)
	610L (Fincastle 336S to Taber 83S)	
	892L (Suffield 895S to Bowmanton 244S)	
	100L (Suffield 895S to P1828 Tap)	
	879L (Burdett 368S to 879AL_Tap)	
	879L (Bowmanton 244S to 879AL Tap)	
	760L (Oyen 394S to P2421 Tap)	666L (Tilley 498S to West Brooks 28S)
	610L (Fincastle 336S to Taber 83S)	
	892L (Suffield 895S to Bowmanton 244S)	
	100L (Suffield 895S to P1828 Tap)	
Planned RAS No.164	1087L (Cassils 324S to Newell 2075S)	1035L (Bowmanton 244S to Newell 2075S)
Existing RAS No.175	927L (Milo 356s to Langdon 102s)	924L (Langdon 102S to Milo 356S)
	924L (Milo 356s to Langdon 102s)	927L (Langdon 102S to Milo 356S)
Existing RAS No.181	610L (Fincastle 336S to Taber 83S)	763L (Vauxhall 158S to Hull 257S)
	612L (Fincastle 336S to Suffield 895S)	666L (Tilley 498S to West Brooks 28S)
	610L (Fincastle 336S to Taber 83S)	



## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	892L (Suffield 895S to Bowmanton 244S)	
	100L (Suffield 895S to P1828 Tap)	
Existing RAS No.197 and real time operational practices	1087L (Cassils 324S to Newell 2075S)	1088L (Cassils 324S to Newell 2075S)
Real time operational practices	924L (Milo 356s to Langdon 102s)	871L (Amoco Empress 163S to Sand Hills 341S)
	924L (Milo 356s to Langdon 102s)	831L (Brooks 121S to Duchess 339S)
	924L (Milo 356s to Langdon 102s)	163ST5 (Amoco Empress 163S Transformer T5)
	760L (Oyen 394S to P2421 Tap)	
	100L (Tilley 498S to P1828 Tap)	871L (Amoco Empress 163S to Sand Hills 341S)
		931L (Ware Junction 132S to West Brooks 28S)
		1075L (Ware Junction 132S to West Brooks 28S)
		1053L (Ware Junction 132S to Cassils 324S)
		1002L (Jenner 275S to Amoco Empress 163S)
		945L (Jenner 275S to Cypress 562S)
		163ST1 (Amoco Empress 163S Transformer T5)
		1148L (Whitla 251S to Shamrock 1018S)
		562ST1 (Cypress 562S Transformer T1)
		562ST1 (Cypress 562S Transformer T2)
		895ST2 (Suffield 895S Transformer T2)
		853L (Queenstown 504S to West Brooks 28S)
		760L/7L60 (Amoco Empress 163S to Oyen 767S)
		944L (Jenner 275S to Ware Junction 132S)
	964L (Bowmanton 244S to Whitla 251S)	
	676L (Bowmanton 244S to Bullshead 523S)	
172L (Taber 83S to Coaldale 254S)		
610L (Fincastle 336S to Taber 83S)	722L (Burdett 368S to Westfield 107S)	
100L (Tilley 498S to P1828 Tap)		

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	1088L (Cassils 324S to Newell A2075S)	1087L (Cassils 324S to Newell 2075S)	
	610L (Fincastle 336S to Taber 83S)	892L (Suffield 895S to Bowmanton 244S)	
		507L (Taber 83S to Hull 257S)	
		336ST1 (Fincastle 336S Transformer T1)	
		100L (Suffield 895S to Tilley 498S)	
		763L (West Brooks 28S to Vauxhall 158S)	
		257ST1 (Hull 257S Transformer T1)	
		158ST2 (Vauxhall 158S Transformer T2)	
		1002L (Jenner 275S to Amoco Empress 163S)	
		Burdett 368S Transformer T2	
		610L (Fincastle 336S to Taber 83S)	945L (Jenner 275S to Cypress 562S)
	760L (Oyen 394S to P2421 Tap)	1011L (Amoco Empress 163S to Cypress 562S)	
			669L (Cypress 562S to Amoco Empress 163S)
			562ST1 (Cypress 562S Transformer T1)
			562ST1 (Cypress 562S Transformer T2)
		EATL	
	935L (Milo 356s to Cassils 324s)	924L (Milo 356s to Langdon 102s)	
	927L (Milo 356s to Langdon 102s)		
	923L (Milo 356s to Newell 2075s)		
	760L (Oyen 394S to P2421 Tap)		
610L (Fincastle 336S to Taber 83S)			
New RAS No.1 *	100L (Tilley 498S to P1828 Tap)		612L (Burdett 368S to Fincastle 336S)
			610L (Taber 83S to Fincastle 336S)
		368ST1 (Burdett 368S Transformer T1)	
		879L (Burdett 368S to Bullshead 523S)	
		610L (Taber 83S to Fincastle 336S)	
666L (Tilley 498S to West Brooks 28S)			
New RAS No.2 *	1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

	1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)
New RAS No.3 *	610L (Fincastle 336S to Taber 83S)	935L (Milo 356S to Cassils 324S)
	1087L (Cassils 324S to Newell 2075S)	
	923L (Milo 356s to Newell 2075s)	
	610L (Fincastle 336S to Taber 83S)	923L (Milo 356S to Newell 2075S)
	935L (Milo 356s to Cassils 324s)	
Planned RAS No.607 **	668L (Empress 394S to Cypress 562S)	760L (Amoco Empress 163S to Empress 394S)
	610L (Fincastle 336S to Taber 83S)	163ST5 (Amoco Empress 163S Transformer T5)
	668L (Empress 394S to Cypress 562S)	
	100L (Tilley 498S to P1828 Tap)	

### Notes:

\* New RAS considered for the sensitivity scenarios only.

\*\* Planned RAS considered for sensitivity scenarios only.

## 7.3 Evaluation of Mitigation Measures

This section describes the results of the power flow studies that were performed to assess the impact of the Project on the performance of the AIES following the implementation of proposed mitigation measures.

The post-mitigation measures studies were performed under Category B conditions for Scenario 3, Scenario 4, Scenario 8, Scenario 9, Scenario 12, and Scenario 13 using Alternative 3 and the RASs described in the previous section.

The post-mitigation power flow diagrams for selected Category B conditions are provided in Attachment H. Post-mitigation power flow diagrams present only those contingencies that result in thermal criteria violations that require RAS mitigation. Contingencies that result in thermal criteria violations that can be mitigated by real-time operational practices or TFO capital maintenance projects were not studied.

### 7.3.1 Scenario 3: 2025 SP

#### Category B Conditions

Thermal criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-3.

After RAS actions were complete, real-time operational practices are required to fully alleviate certain thermal criteria violations observed on 927L, 924L, and 1087L.

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

**Table 7-3: Post-RAS Power Flow Study Results for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	100.42	118.00	65.51	76.98
	612L (Burdett 368S to Fincastle 336S)	85.1	94.0	79	96.6	85	104.7 <sup>a</sup>
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.00	691.00	793.73	137.80	632.22	109.76 <sup>a</sup>
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.00	656.00	792.06	144.80	630.80	115.32 <sup>a</sup>
498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	89.87	105.60	60.91	71.57
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	108.42	127.40	79.66	93.61
498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	96.16	120.20	12.74	15.93
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828)	78.00	86.00	92.82	119.00	4.15	5.32
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	900.36	164.60	648.20	118.50 <sup>a</sup>
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	667.89	122.10	608.81	111.30 <sup>a</sup>

**Notes:**

<sup>a</sup> Violation remained after RAS actions were complete and real-time operational practices will mitigate the overload.

### 7.3.2 Scenario 4: 2025 SL

#### Category B Conditions

The thermal criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-4.

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

**Table 7-4: Post-RAS Power Flow Study Results for Scenario 4**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	95.65	112.40	65.61	77.10
666L (Tilley 498S to West Brooks 28S)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	85.76	107.20	27.39	34.24
666L (Tilley 498S to West Brooks 28S)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	80.65	103.40	23.64	30.31
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	101.78	119.60	72.45	85.13
498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	106.64	133.30	9.26	11.57
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	102.34	131.20	4.22	5.41
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	815.03	149.00	497.22	90.90

### 7.3.3 Scenario 8: 2025 SP - Sensitivity including P2418

#### Category B Conditions

The thermal and voltage criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-5.

After RAS actions were complete, real-time operational practices are required to fully alleviate certain thermal criteria violations observed on 610L, 612L, 924L, 927L, 1051L, 1052L, and 1087L.

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

**Table 7-5: Post-RAS Power Flow Study Results for Scenario 8**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
612L (Burdett 368S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.00	132.00	141.84	118.20	70.91	59.09
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.00	132.00	147.48	122.90	77.52	64.60
760L (Amoco Empress 163S to Empress 394S)	668L (Empress 394S to Cypress 562S)	121.00	133.00	167.46	138.40	18.17	15.02
763L (Vauxhall 158S to Hull 257S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	94.63	111.20	64.41	75.69
666L (Tilley 498S to West Brooks 28S)	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	87.23	102.50	94.00	110.46 <sup>a</sup>
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	108.16	127.10	74.23	87.23
1051L (West Brooks 28S to Cassils 324S)	1052L (West Brooks 28S to Cassils 324S)	614.80	738.00	756.82	123.10	729.95	118.73 <sup>a</sup>
1052L (West Brooks 28S to Cassils 324S)	1051L (West Brooks 28S to Cassils 324S)	614.80	738.00	756.82	123.10	729.95	118.73 <sup>a</sup>
935L (Milo 356S to Cassils 324S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	88.25	103.70	82.33	96.74
935L (Milo 356S to Cassils 324S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	649.84	118.80	620.46	113.43 <sup>a</sup>
935L (Milo 356S to Cassils 324S)	923L (Milo 356s to Newell 2075s)	547.00	656.00	688.13	125.80	441.21	80.66
923L (Milo 356S to Newell 2075S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	87.74	103.10	81.55	95.83
923L (Milo 356S to Newell 2075S)	935L (Milo 356s to Cassils 324s)	547.00	656.00	696.88	127.40	454.06	83.01

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

Newell 2075S)							
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.00	691.00	777.02	134.90	685.15	118.95 <sup>a</sup>
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.00	656.00	775.10	141.70	683.64	124.98 <sup>a</sup>
498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	95.40	112.10	65.88	77.42
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	116.08	136.40	87.52	102.84 <sup>a</sup>
498ST1T2 (Tilley 498S Transformer T1/T2)	879L (Burdett 368S to 879AL_Tap)	85.00	94.00	86.28	101.50	55.47	65.26
498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	103.04	128.80	15.61	19.51
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	97.73	125.30	4.09	5.24
498ST1T2 (Tilley 498S Transformer T1/T2)	879L (Bowmanton 244S to 879AL Tap)	85.00	94.00	91.12	107.20	60.80	71.53
163ST5 (Amoco Empress 163S Transformer T5)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	88.42	103.90	73.72	86.63
163ST5 (Amoco Empress 163S Transformer T5)	668L (Empress 394S to Cypress 562S)	121.00	133.00	168.43	139.20	18.66	15.42
163ST5 (Amoco Empress 163S Transformer T5)	100L (Tilley 498S to P1828 Tap)	120.00	132.00	126.84	105.70	112.56	93.80
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	951.78	174.00	654.21	119.60 <sup>a</sup>

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	701.25	128.20	639.17	116.85 <sup>a</sup>
368ST1 (Burdett 368S Transformer T1)	100L (Tilley 498S to P1828 Tap)	120.00	132.00	138.60	115.50	67.18	55.98
879L	100L (Tilley 498S to P1828 Tap)	120.00	132.00	138.84	115.70	68.59	57.16

### Notes:

<sup>a</sup> Violation remained after RAS actions were complete and real-time operational practices will mitigate the overload.

## 7.3.4 Scenario 9: 2025 SL - Sensitivity including P2418

### Category B Conditions

The thermal and voltage criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-6.

After RAS actions were complete, real-time operational practices are required to fully alleviate certain thermal criteria violations observed on 100L, 760L, and 892L.

**Table 7-6: Post-RAS Power Flow Study Results for Scenario 9**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
610L (Taber 83S to Fincastle 336S)	666L (Tilley 498S to West Brooks 28S)	120.00	108.00	120.24	100.20	47.59	39.66
610L (Taber 83S to Fincastle 336S)	100L (Tilley 498S to P1828 Tap)	120.00	132.00	137.16	114.30	61.90	51.58
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	106.29	124.90	81.93	96.27
666L (Tilley 498S to West Brooks 28S)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	85.44	106.80	85.27	106.59 <sup>a</sup>
666L (Tilley 498S to West Brooks 28S)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	80.50	103.20	80.43	103.12 <sup>a</sup>
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	112.42	132.10	83.68	98.33



## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	106.40	133.00	9.32	11.65
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	102.26	131.10	4.21	5.40
498ST1T2 (Tilley 498S Transformer T1/T2)	760L (Oyen 394S to P2421 Tap)	110.20	131.00	111.41	101.10	101.14	91.78
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	844.57	154.40	531.68	97.20

### Notes:

<sup>a</sup> Violation remained after RAS actions were complete and real-time operational practices will mitigate the overload.

## 7.3.5 Scenario 12: 2025 SP - Sensitivity including P2446

### Category B Conditions

The thermal and voltage criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-7.

After RAS actions were complete, real-time operational practices are required to fully alleviate certain thermal criteria violations observed on 924L, 927L, and 1087L.

**Table 7-7: Post-RAS Power Flow Study Results for Scenario 12**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	104.16	122.40	76.62	90.03
666L (Tilley 498S to West Brooks 28S)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	89.12	111.40	17.51	21.89
666L (Tilley 498S to West Brooks 28S)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	85.72	109.90	11.22	14.38
924L (Langdon 102S to Milo 356S)	927L (Milo 356s to Langdon 102s)	576.00	691.00	779.90	135.40	619.83	107.61 <sup>a</sup>
927L (Langdon 102S to Milo 356S)	924L (Milo 356s to Langdon 102s)	547.00	656.00	777.83	142.20	618.44	113.06 <sup>a</sup>

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

498ST1T2 (Tilley 498S Transformer T1/T2)	612L (Fincastle 336S to Suffield 895S)	85.10	94.00	85.70	100.70	56.88	66.84
498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	106.29	124.90	78.35	92.07
498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	95.92	119.90	11.33	14.16
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	92.90	119.10	3.99	5.11
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	896.53	163.90	642.73	117.50 <sup>a</sup>
1035L (Bowmanton 244S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	670.62	122.60	610.51	111.61 <sup>a</sup>

### Notes:

<sup>a</sup> Violation remained after RAS actions were complete and real-time operational practices will mitigate the overload.

## 7.3.6 Scenario 13: 2025 SL - Sensitivity including P2446

### Category B Conditions

The thermal and voltage criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 7-8.

**Table 7-8: Post-RAS Power Flow Study Results for Scenario 13**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
666L (Tilley 498S to West Brooks 28S)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	97.95	115.10	68.68	80.70
666L (Tilley 498S to West Brooks 28S)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	99.04	123.80	17.94	22.42
666L (Tilley 498S to West Brooks 28S)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	94.54	121.20	9.27	11.88

## Engineering Connection Assessment

P1828 HEP Alderson Solar Park

V1

498ST1T2 (Tilley 498S Transformer T1/T2)	610L (Fincastle 336S to Taber 83S)	85.10	94.00	100.25	117.80	71.08	83.52
498ST1T2 (Tilley 498S Transformer T1/T2)	892L (Suffield 895S to Bowmanton 244S)	80.00	88.00	106.72	133.40	9.24	11.55
498ST1T2 (Tilley 498S Transformer T1/T2)	100L (Suffield 895S to P1828 Tap)	78.00	86.00	102.34	131.20	4.23	5.42
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547.00	656.00	817.77	149.50	499.96	91.40

## 7.4 Constraint Effective Factor Studies

Constraint effective factor studies were conducted for all post-Project scenarios. The constraint effective factors were calculated for all Category B conditions when the loadings of the monitored transmission elements in the Study Area exceeded 100% (i.e., for all of the contingencies that resulted in thermal criteria violations). The results of the constraint effective factor studies are provided in Attachment G.

## 8 Project Interdependencies

The project is dependent on increasing the rating of the section of the 138 kV transmission line 100L from the Project T-tap point to Tilley 498S.

**Engineering Connection Assessment**

P1828 HEP Alderson Solar Park

V1

# Attachment A: Engineering Connection Assessment: Study Scope

# Study Scope




## P1828 HEP Energy Alderson MPC Solar

hep Canada SPV 1 Ltd

**Date:** Aug. 25, 2023

**Version:** V2

**Classification:** Public

Company Name	Name and Credentials	Date	Signature
Hardline Engineering Ltd.	Rafae Malik, P.Eng., M.Eng.	2023-09-25	
AESO	Omid Ghoreishi, P. Eng.	2023-09-26	
hep Canada SPV 1 Ltd.	Pamela Pelletier	<a href="#">2023-09-25</a>	

# Contents

<b>1</b>	<b>Introduction</b>	<b>1</b>
1.1	Project Overview	1
1.2	Existing System Overview	2
1.2.1	Study Area	2
1.2.2	Existing Constraints	2
<b>2</b>	<b>Connection Alternative to be Studied</b>	<b>4</b>
2.1	Alternative 3 – T-tap onto 138kV line 100L	4
<b>3</b>	<b>Criteria, Standards and Requirements</b>	<b>6</b>
3.1	AESO Reliability Criteria	6
3.2	ISO Rules and Information Documents	7
<b>4</b>	<b>Scenarios and Assumptions</b>	<b>8</b>
4.1	Scenarios	8
4.2	Assumptions	9
4.2.1	System Project Assumptions	9
4.2.2	Connection Project Assumptions	9
4.2.3	Load Assumptions	9
4.2.4	Generation Assumptions	10
4.2.5	Intertie Flow Assumptions	16
4.2.6	HVDC Power Order Assumptions	16
4.2.7	Transmission Facility Ratings	16
4.2.8	Protection Fault Clearing Times	20
4.2.9	Project Dynamic Data	21
4.2.10	Voltage Profile Assumption	22
<b>5</b>	<b>Study Methodology</b>	<b>23</b>
5.1	Study Case Validation	24
5.2	Power Flow Studies	24
5.2.1	Contingencies to be Studied	24
5.3	Transient Stability Studies	25
5.3.1	Contingencies to be Studied	25
5.4	Short-Circuit Current Level Studies	25
<b>6</b>	<b>Mitigation Measures</b>	<b>27</b>
6.1	Development	27
6.2	Evaluation	27
6.2.1	Post-Mitigation Studies	27
6.2.2	Constraint Effective Factor Studies	27
<b>7</b>	<b>Changes to Study Assumptions</b>	<b>28</b>

## Tables

Table 1-1: Project Load and Generation Details .....	1
Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses .....	7
Table 4-1: Connection Study Scenarios.....	8
Table 4-2: Planned Connection Projects Included in the Sensitivity Studies.....	9
Table 4-3: Forecast Load (at AESO Northeast Planning Region Peak) .....	10
Table 4-4: Key Existing Generation (excluding Wind and Solar) Dispatch Conditions .....	10
Table 4-5: Dispatch Conditions for Existing and Under-Construction Wind Generation Projects .....	11
Table 4-6: Dispatch Conditions for Existing and Under-Construction Solar Generation Projects .....	12
Table 4-7: Dispatch Conditions for Planned Wind Generation Projects .....	13
Table 4-8: Dispatch Conditions for Planned Solar Generation Projects .....	14
Table 4-9: Dispatch Conditions for Planned Generation Projects for Sensitivity Study.....	15
Table 4-10: Intertie Flows by Scenario.....	16
Table 4-11: HVDC to Adjacent AC System MVar Exchange Limits .....	16
Table 4-12: Thermal Rating Assumptions for Key Transmission Lines in the Study Area .....	17
Table 4-13: Summary of Key Transformer Ratings in the Study Area.....	19
Table 4-14: Summary of Key Shunt Elements in the Study Area .....	19
Table 4-15: Protection Fault Clearing Times.....	21
Table 5-1: Summary of the Studies to be Performed.....	23

## Figures

Figure 1-1: Transmission System in the Study Area.....	3
Figure 2-1: Connection Alternative 1 .....	5

## Attachments

Attachment A: Transmission Planning Criteria – Basis and Assumptions

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



# 1 Introduction

This Study Scope provides an overview of the engineering studies to be completed by Hardline Engineering Ltd. (the Studies Consultant) to assess the impact of the Project (as defined in section 1.1) on the performance of the Alberta interconnected electric system (AIES). Technical criteria, assumptions and methods for performing these engineering studies are provided in this document.

## 1.1 Project Overview

Hep Canada SPV 1 Ltd. (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its proposed Alderson Park 1061S (Facility) to the AIES.

The Market Participant's request includes: a request for a new system access service in the area, with a Rate STS, Supply Transmission Service, contract capacity of 100 MW and a Rate DTS, Demand Transmission Service, contract capacity of 0.5 MW; and a request for transmission development (collectively, the Project).

The Project in-service date (ISD) used for the purpose of the studies is Dec. 2, 2024.

Load and generation components of the Project are listed in Table 1-1.

**Table 1-1: Project Load and Generation Details**

Project Component		Description
Generation	Generation type	Solar
	Existing Rate STS, <i>Supply Transmission Service</i> , contract capacity	0 MW
	Requested Rate STS	100 MW
	Number and size of generating units	Not Available
	Maximum authorized real power (MARP)	100 MW
	Maximum capability (MC)	100 MW
	Reactive power capability	0.95 pf absorbing
		0.9 pf producing
Future generation expansion plans	No	
Load	Existing Rate DTS, <i>Demand Transmission Service</i> , contract capacity	0 MW
	Requested Rate DTS	0.5 MW
	Type	Station service
	Motors (number and size)	None
	Power factor	0.9 pf



## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



Project Component		Description
	Future load expansion plans	No

### Note:

MARP and MC are defined in the AESO's *Consolidated Authoritative Document Glossary*, which can be found on the AESO's website.

## 1.2 Existing System Overview

### 1.2.1 Study Area

Geographically, the Project is located in the AESO planning area of Vauxhall, Area 52.

The Study Area consists of the AESO planning areas of Empress (Area 48), Medicine Hat (Area 4), Brooks (Area 47), and Vauxhall (Area 52), including the tie lines connecting these planning areas to the rest of the AIES.

The existing transmission system in the Study Area is shown in Figure 1-1.

### 1.2.2 Existing Constraints

Existing constraints in the Study Area are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management* (TCM Rule).

There are a number of constraints in the Study Area that are mitigated by existing remedial action schemes (RASs) and/or other protection schemes.

The following existing RASs and/or other protection schemes are used to manage constraints in the area:

- RAS 27: 562S Cypress McNeil Power and Undervoltage Scheme
- RAS 28: 163S Amoco Empress Reverse Power and Undervoltage Scheme
- RAS 29: McNeil 840S Under Voltage Runback Scheme
- RAS 33: Cypress T562S Reverse Power and Undervoltage Scheme
- RAS 112: Cypress 562S - Power/Under & Over Frequency Scheme
- RAS 141: Tilley 498S voltage instability mitigation
- RAS 164: 1034L and 1035L Contingency Mitigation
- RAS 168: 172L-83S Overload Mitigation
- RAS 173: 880L-321S Overload Mitigation Scheme
- RAS 175: Milo 356S – 924L/927L Overload Mitigation Scheme
- RAS 197: 1087L Overload Mitigation
- RAS 181: 610L Overload Mitigation Scheme


**Study Scope**

P1828 HEP Energy Alderson MPC Solar

V2



**Figure 1-1: Transmission System in the Study Area**



**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



## 2 Connection Alternative to be Studied

The following alternative is to be studied:

### 2.1 Alternative 3 – T-tap onto 138kV line 100L

This alternative included the following developments:

- Add one 138 kV circuit, approximately 3 km in length<sup>1</sup>, to connect the Facility to the existing 138 kV transmission line 100L (Suffield 895S to Tilley 498S) in a T-tap configuration;
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 2-1

---

<sup>1</sup> The exact line length to be determined by the MP.


**Study Scope**

P1828 HEP Energy Alderson MPC Solar

V2



**Figure 2-1: Connection Alternative 1**



## 3 Criteria, Standards and Requirements

### 3.1 AESO Reliability Criteria

The Transmission Planning (TPL) Standards, which are included in the Alberta Reliability Standards, and *Transmission Planning Criteria – Basis and Assumptions* (see Attachment A), (collectively, the Reliability Criteria) will be applied to evaluate system performance under Category A system conditions (i.e., all elements in-service) and following Category B contingencies (i.e., single element outage), prior to and following the studied alternatives. Below is a summary of Category A and Category B system conditions.

**Category A**, often referred to as the N-0 condition, represents a normal system with no contingencies and all facilities in service. Under this condition, the system must be able to supply all firm load and firm transfers to other areas. All equipment must operate within its applicable rating, voltages must be within their applicable range, and the system must be stable with no cascading outages.

**Category B** events, often referred to as an N-1 or N-G-1 with the most critical generator out of service, result in the loss of any single specified system element under specified fault conditions with normal clearing. These elements are a generator, a transmission circuit, a transformer, or a single pole of a DC transmission line. The acceptable impact on the system is the same as Category A. Planned or controlled interruptions of electric supply to radial customers or some local network customers, connected to or supplied by the faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted firm (non-recallable reserved) transmission service electric power transfers.

The TPL standards, TPL-001-AB-0 and TPL-002-AB1-0 have referenced Applicable Ratings when specifying the required system performance under Category A and Category B events. For the purpose of applying the TPL standards to the studies documented in this report, Applicable Ratings are defined as follows:

- Normal thermal rating of the line's loading limits for each season;
- The highest specified loading limits for transformers;
- For Category A conditions: Voltage range under normal operating condition per AESO Information Document #2010-007RS, *General Operating Practices – Voltage Control* (ID #2010-007RS). For the busses not listed in ID #2010-007RS, Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions* applies;
- For Category B and Category C5 conditions: The extreme voltage range values per Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions*; and
- Desired post-contingency voltage deviation limits for three defined post-event timeframes as provided in Table 3-1.

**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



**Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses**

Parameter and reference point	Time Period		
	Post Transient (up to 30 sec)	Post Auto Control (30 sec to 5 min)	Post Manual Control (Steady State)
Voltage deviation from steady state at point of delivery (POD) low voltage bus.	±10%	±7%	±5%

### 3.2 ISO Rules and Information Documents

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for the Study Area.

The TCM Rule will be followed to set up the study scenarios and assess the impact of the Project. In addition, due regard will be given to the following:

- The AESO's *Connection Study Requirements*;
- Section 502.1 of the ISO rules, *Aggregated Generating Facilities Technical Requirements*;
- Section 502.16 of the ISO rules, *Aggregated Generating Facilities Operating Requirements*;

## 4 Scenarios and Assumptions

### 4.1 Scenarios

The following section describes the scenarios to be studied and the assumptions to be used in the studies. Connection scenarios must be studied as outlined in Table 4-1.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
<b>Pre-Project</b>					
1	2025 Summer Peak (2025 SP)	High South generation, high solar generation	2025 SP Pre-Project-HG	0	0
2	2025 Summer Light (2025 SL)		2025 SL Pre-Project-HG	0	0
<b>Post-Project</b>					
3	2025 SP	High South generation, high solar generation	2025 SP Post -Project- HG	0	100
4	2025 SL		2025 SL Post -Project- HG	0	100
5	2031 WP	All study area generation in-service	2031 WP Post-Project- HG	0	100
<b>Pre-Project – Sensitivity Study including P2418</b>					
6	2025 SP	High South generation, high solar generation	2025 SP Pre-Project-HG	0	0
7	2025 SL		2025 SL Pre-Project-HG	0	0
<b>Post-Project – Sensitivity Study including P2418</b>					
8	2025 SP	High South generation, high solar generation	2025 SP Post -Project- HG	0	100
9	2025 SL		2025 SL Post -Project- HG	0	100
<b>Pre-Project – Sensitivity Study including P2446</b>					
10	2025 SP	High South generation, high solar generation	2025 SP Pre-Project-HG	0	0
11	2025 SL		2025 SL Pre-Project-HG	0	0
<b>Pre-Project – Sensitivity Study including P2446</b>					
12	2025 SP	High South generation, high solar generation	2025 SP Post -Project- HG	0	100

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
13	2025 SL		2025 SL Post -Project- HG	0	100

## 4.2 Assumptions

### 4.2.1 System Project Assumptions

The pre-Project and post-Project connection assessment will not include any system transmission projects because there are no planned system transmission developments in the Study Area that are expected to be in service before the scheduled Project ISD.

### 4.2.2 Connection Project Assumptions

Table 4-2 summarizes the connection projects in the Study Area that should be included in the sensitivity studies only.

**Table 4-2: Planned Connection Projects Included in the Sensitivity Studies**

AESO Project No.	AESO Project Name	AESO Planning Area No.	Generation (MW)	Load (MW)	Scheduled ISD	AUC NID Decision No.
P2418	Greencells Estuary Solar	48	200	2	3-Sep-24	N/A
P2446	Fortis Tilley 498S DER Solar	47	20	0	29-Feb-24	N/A

### 4.2.3 Load Assumptions

The load forecast to be used for the studies is shown in Table 4- and is a forecast for the AESO

South Planning Region peak based on the AESO *2021 Long-Term Outlook (2021 LTO)*<sup>2</sup> with modifications to incorporate the latest forecast intelligence. For the post-Project studies, when the Study Area loads are modified to align with the regional load forecast, the active power to reactive power ratio in the base case scenarios shall be maintained.

<sup>2</sup> The 2021 LTO is available on the AESO website.



## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



**Table 4-3: Forecast Load (at AESO Northeast Planning Region Peak)**

AESO Planning Region Name	Forecast Peak Load by Year/Season (MW)	
	2025 SL	2025 SP
South Planning Region	891	1,614

**Note:**

<sup>1</sup> The South Region comprises the following AESO planning areas: 44, 46, 53, 45, 49, 54, 55, 43, 47, 52, 48, 4

IDEV files contain non-motor loads in zones 34, 36, and 351. These loads are not accounted for in the forecasted peak loads shown above and should not be considered when scaling load. The AESO engineer will provide guidance to load scaling procedures as required.

### 4.2.4 Generation Assumptions

The generation forecast to be used for the studies is based on the 2021 LTO with modifications to incorporate the latest forecast intelligence. The generation assumptions for the studies will assume high Northeast generation. Additional studies may be required in the event of changes to the AESO's corporate forecast.

The existing generation (excluding wind and solar) dispatch conditions for the study scenarios are described in Table 4-.

**Table 4-4: Key Existing Generation (excluding Wind and Solar) Dispatch Conditions**

Facility Name	Unit No.	Bus No.	MC (MW)	AESO Planning Area No.	Unit Net Generation <sup>a</sup> (MW) by Scenario	
					2025 SL	2025 SP
Chin Chute (CHIN)		407	15	54	10	9
Irrican Hydro (ICP1)		450	7	54	7	6
Parkland (ALP2)		4235	10	49	0	9
Lethbridge Taber (ME02)		3272	8	52	0	7
Lethbridge Burdett (ME03)		4269	7	52	0	7
Lethbridge Coaldale (ME04)		557690	6	54	0	6
Coaldale (COD1)		2690	5	54	4	5
Cavalier (EC01)		3247,4247	120	45	100	85
Carseland Cogen (TC01)		3251,4251	95	45	79	71
Oldman River (OMRH)		2230	32	53	31	26
Summerview (SUM1)		61336	10	53	-10	10

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



Using this value, the wind and solar generation facilities will be dispatched to yield the credible worst-case power flow conditions for the Study Area. Pre-Project dispatch levels for the existing and under-construction wind and solar generation facilities are shown in Table 4- and Table 4-.

**Table 4-5: Dispatch Conditions for Existing and Under-Construction Wind Generation Projects**

Facility Name and Code	Bus No.	AESO Planning Area No.	MC (MW)	Unit Net Generation Dispatch <sup>a</sup> (MW)	
				2025 SL	2025 SP
Ardenville Wind (ARD1)	4735, 4740	53	68	13.6	40.8
Blue Trail Wind (BTR1)	66328, 67328	53	66	13.2	39.6
Castle River #1 (CR1)	2234, 3234	53	39	7.8	23.4
Castle Rock Wind Farm (CRR1)	67221	53	77	15.4	46.2
Cowley Ridge (CRE3)	4264	53	20	4.0	12.0
Enmax Taber (TAB1)	15343, 16343	52	81	16.2	48.6
Kettles Hill (KHW1)	2402, 3402	53	63	12.6	37.8
McBride Lake Windfarm (AKE1)	2901, 3901, 4901	53	73	14.6	43.8
Soderglen Wind (GWW1)	12358, 13358	53	71	14.2	42.6
Summerview 1 (IEW1)	2338, 3338	53	66	13.2	39.6
Summerview 2 (IEW2)	4339, 5337	53	66	13.2	39.6
Suncor Chin Chute (SCR3)	2389	54	30	6.0	18.0
Suncor Magrath (SCR2)	11002	53	30	6.0	18.0
Suncor Wintering Hills (SCR4)	60789, 60791, 60793, 60846, 60848, 60850	43	88	17.6	52.8
Old Man River(OWF1)	61543	53	46	9.2	27.6
Blackspring Ridge(BSR1)	61736, 61737	49	300	60.0	180.0
Castle Rock Ridge 2 (CRR2)	567221	53	30.6	6.1	18.4
Enel Riverview Wind Farm (RIV1)	69221	53	115	23.0	69.0
Capital Power Whitla Wind Power Facility (WHT1)	60990	4	201.6	40.3	121.0
Capital Power Whitla Wind Power Facility Phase 2	61990	4	97.2	19.4	58.3
Capital Power Whitla Wind Power Facility Phase 3	64990	4	54	10.8	32.4
TransAlta Windrise (WRW1)	567031	53	207	41.4	124.2

**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



Rattlesnake Ridge Wind (RTL1)	60873	4	130	26.0	78.0
Ghost Pine (NEP1)	2621, 2622, 2623, 2624, 2625	42	82	16.4	49.2
Halkirk (HAL1)	66435, 67435	42	150	30.0	90.0
Fortis Bull Creek Phases 1 and 2(Bul1 & BUL2)	550003, 550004	37	29.5	5.9	17.7

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

**Table 4-6: Dispatch Conditions for Existing and Under-Construction Solar Generation Projects**

Facility Name and Code	Bus No.	AESO Planning Area No.	MC (MW)	Unit Net Generation Dispatch <sup>a</sup> (MW)	
				2025 SL	2025 SP
Brooks Solar (BSC1)	553257	47	15	10.5	14.25
Hull DER Solar (HUL1)	2401	52	24.5	17.15	23.275
Vauxhall Solar (VXH1)	4274	52	22	15.4	20.9
Suffield Solar (SUF1)	3270	4	23	16.1	21.85
Claresholm Solar (CLR1)	60894	49	58	40.6	55.1
Claresholm Solar (CLR2)	61894	49	75	52.5	71.25
Burdett (BRD1)	2269	52	11	7.7	10.45
Westfield Yellow Lake (WEF1)	557277	52	19	13.3	18.05
Burdett (BUR1)	557269	52	20	14	19
Hays Solar (HYS1)	554401	52	24	16.8	22.8
Jenner Solar DER (JER1)	554986	48	23	16.1	21.85
Innisfail Solar (INF1)	557120	39	22	15.4	20.9
Brooks Solar 1 (BRK1)	553256	47	13	9.1	12.35
Brooks Solar 2 (BRK2)	554257	47	14	9.8	13.3
Coaldale Solar (COL1)	554691	54	22	15.4	20.9
Strathmore 1 (STR1)	557259	45	18	12.6	17.1
Strathmore 2 (STR2)	558259	45	23	16.1	21.85
Travers (TVS1)	560026, 561026, 562026	49	465	325.5	441.75

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



Pre-Project dispatch levels for the planned wind and solar generation facilities are shown in Table 4- and Table 4-.

**Table 4-7: Dispatch Conditions for Planned Wind Generation Projects**

Project Number	Project Name	Planned ISD	Bus No.	AESO Planning Area No.	MC (MW)	Unit Net Generation Dispatch <sup>a</sup> (MW)	
						2025 SL	2025 SP
P1892	Fortis Buffalo Atlee Cluster 3 WAGF	1-Dec-21	552260	47	17.3	3.5	10.4
P1853	Fortis Buffalo Atlee Cluster 1 WAGF	1-Dec-21	553260	47	17.3	3.5	10.4
P2199	Buffalo Atlee Wind Farm 2	1-Dec-21	557261	47	13.8	2.8	8.3
P1719	Stirling WAGF Project	1-Nov-22	61630	54	113	22.6	67.8
P2122	EDF Cypress Wind	1-Nov-22	560003	4	201.6	40.3	121.0
P1533	Joss MPC WAGF	30-Jun-22	60798, 60799	47	122	24.4	73.2
P1698	Joss Jenner WAGF - Phase 2	30-Jun-22	61798, 61799	47	71.4	14.3	42.8
P1812	Suncor Forty Mile Granlea WAGF	16-Nov-21	61994, 62994	4	200	40.0	120.0
P1718	Wheatland WAGF Project	30-Jun-22	60632, 61632	43	120	24.0	72.0
P1909	TransAlta Garden Plain Wind	1-Jul-22	565002	42	130	26.0	78.0
P2234	Jenner Wind Phase 3	30-Jun-22	61799	48	109.2	21.8	65.5
P1898	Pattern Lanfine North Wind	30-Sep-22	60996	42	145	29.0	87.0
P2263	BER Hand Hills MPC Wind	1-Sep-22	560045	42	151	30.2	90.6
P1800	Capital Power Whitla Wind Power Facility	15-Sep-21	60990, 61990	4	299	59.8	179.4
P2041	TransAlta Windrise MPC Wind	10-Jun-21	567031	53	207	41.4	124.2
P2247	Buffalo Plains MPC Wind	17-Apr-23	560041, 560042	47	466	93.2	279.6
P2254	RESC Hilda MPC Wind	7-Oct-22	567004	48	100	20.0	60.0
P2338	Capital Power Whitla Wind Phase 3	15-Sep-21	64990	4	54	10.8	32.4
P2412	Fortis Buffalo Atlee Cluster 4 DER Wind	4-Apr-23	990082	48	11	2.2	6.6
P2413	EDF Cypress 2 Wind	31-Aug-22	560003, 561003	4	46	9.2	27.6
P1250&P2065	Wild Run Grizzly Bear Wind & Phase 2	15-Nov-22	67308	13	154	30.8	92.4
P1567	EDPR Sharp Hills Wind Farm	16-Dec-22	60831, 60832	42	297	59.4	178.2
P1704	Paintearth Wind Power	28-Jul-23	61418	42	150	30.0	90.0

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



P2137	Enerfin Winnifred MPC Wind	17-Mar-23	567034	4	90	18.0	54.0
P2237	RESC Forty Mile MPC Wind	15-Sep-23	60608, 61608	4	266	53.2	159.6

### Notes:

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

**Table 4-8: Dispatch Conditions for Planned Solar Generation Projects**

Project Number	Project Name	Planned ISD	Bus No.	AESO Planning Area No.	MC (MW)	Unit Net Generation Dispatch <sup>a</sup> (MW)	
						2025 SL	2025 SP
P1831	Fortis 255S Vulcan Faribault Farms DG PV	24-May-21	4244	49	22	15.4	20.9
P1850	Fortis Coaldale 254S DER Solar 3	May. 24, 2021	554691	54	22	15.4	20.9
P1851	Fortis Monarch 492S DER Solar	May. 24, 2021	2005	54	23.6	16.52	22.42
P1862	Fortis Spring Coulee 385S Solar DG	Oct. 15, 2021	553246 554246	55	29.5	20.65	28.025
P1870	Fortis Stavely 349S DER Solar	1-Feb-22	2004	49	18.5	12.95	17.575
P1918	FortisAlberta Conrad DER Solar 1	21-Dec-21	554291	52	23.4	16.38	22.23
P1932	FortisAlberta Namaka DER Solar	3-Sep-21	552340	45	20.1	14.07	19.095
P1959	FortisAlberta Conrad DER Solar 2	21-Dec-21	553291	52	22.5	15.75	21.375
P2195	FortisAlberta Bassano 435S DER Solar	1-Feb-23	557399	47	9.25	6.475	8.7875
P2249	FortisAlberta Empress 394S DER Solar 1	1-Nov-21	558316	48	22	15.4	20.9
P2250	FortisAlberta Empress 394S DER Solar 2	1-Nov-21	558016	48	16	11.2	15.2
P2300	RESC Enterprise MPC Solar	31-Aug-22	563070	49	65	45.5	61.75
P2335	Fortis Vulcan 255S DER Solar	1-May-22	990092	49	13	9.1	12.35
P2337	Dunmore Solar	1-Apr-23	560044	4	216	151.2	205.2
P2362	Fortis Enchant 447S DER Solar	30-Nov-21	993287	52	23	16.1	21.85
P2363	Fortis Enchant 447S DER Solar	30-Nov-21	993289	52	17.9	12.53	17.005
P2364	Fortis Enchant 447S DER Solar	30-Nov-21	994287	52	10	7	9.5
P2365	Fortis Enchant 447S DER Solar	30-Nov-21	994289	52	24	16.8	22.8

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



P1838	Fortis 895S Suffield DG PV	30-Jun-20	3270	4	23	16.1	21.85
P1839	Fortis 421S Hays DG PV	24-Jun-21	554401	52	23	16.1	21.85
P1840	Fortis 275S Jenner Solar DER	23-Jun-21	554986	48	23	16.1	21.85
P1849	Fortis Burdett 368S DG P/V	18-Feb-21	2269	52	11	7.7	10.45
P1879	Claresholm Solar Connection	25-Jan-21	60894	49	150	105	142.5
P1927	Solar Krafte Brooks	1-Dec-23	60434, 61434	47	360	252	342
P2241	FortisAlberta 368S Burdett DER Solar	25-Feb-21	558269	52	20	14	19
P2347	Forty Mile Granlea Solar Phase 2	17-Nov-23	5994	4	220	154	209
P2216	FortisAlberta Chappice Lake 649S DER Solar	15-Dec-22	557320	4	11	7.7	10.45
P2059	ATCO Three Hills 770S DER Solar 1	1-May-22	552433	42	14	9.8	13.3
P2061	ATCO Michichi Creek 802S DER Solar	1-May-22	554448	42	11	7.7	10.45
P1978	ATCO Michichi DER Solar	1-Nov-22	552448, 553448, 552450	42	75	52.5	71.25
P2424	ATCO Oyen 767S DER Solar	14-Apr-23	88888	42	15	10.5	14.25
P1831	Fortis 255S Vulcan Faribault Farms DG PV	24-May-21	4244	49	22	15.4	20.9
P2334	TCE Saddlebrook Solar Storage	1-Jun-23	562240, 563240	46	109	76.3	103.55
P2348	BluEarth Wheatcrest MPC Solar	15-Mar-23	557051	52	50	35	47.5
P2361	ATCO Youngstown 772S DER Solar	1-Apr-23	990072	42	6	4.2	5.7
P2421	RESC Big Sky Solar	1-Jan-24	560051	48	140	98	133
P2411	Greengate Jurassic MPC Solar Battery	31-Dec-23	567072, 568072	48	300	210	285

### Notes:

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

Pre-Project dispatch levels for the planned generation facilities for the sensitivity study are shown in Table 4-9.

**Table 4-9: Dispatch Conditions for Planned Generation Projects for Sensitivity Study**

Project Number	Project Name	Planned ISD	Bus No.	AESO Planning Area No.	MC (MW)	Unit Net Generation Dispatch <sup>a</sup> (MW)	
						2025 SL	2025 SP
P2418	Greencells Estuary Solar	3-Sep-24	562418	48	200	140	190

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



2446	Fortis Tilley 498S DER Solar	29-Feb-24	994276	47	20	14	19
------	------------------------------	-----------	--------	----	----	----	----

### Note:

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

The post-Project scenario wind and solar generation dispatch levels were identical to the pre-Project scenario dispatch levels shown in Table 4-5 through Table 4-9.

## 4.2.5 Intertie Flow Assumptions

The intertie flow assumptions for the Alberta-British Columbia (AB-BC), Alberta-Saskatchewan (AB-SK), and Alberta-Montana (MATL) interties are shown in Table 4-2.

For the 2031 WP scenario, the intertie flow values should be set to the AESO planning base cases.

**Table 4-2: Intertie Flows by Scenario**

Scenario Number	Scenario Name	Import (-) / Export (+) (MW) by Intertie		
		AB-BC	AB-SK	MATL
1, 3, 6, 8, 10, 12	2025 SP HS Pre (Post)-Project	527	-150	0
2, 4, 7, 9, 11, 13	2025 SL HS Pre (Post)-Project	527	-150	0

## 4.2.6 HVDC Power Order Assumptions

The Western Alberta Transmission Line (WATL) and the Eastern Alberta Transmission Line (EATL) are high-voltage direct current (HVDC) transmission lines. The HVDC power order assumptions for the studies will be set to minimize losses for the pre-Project and post-Project study scenarios.

The reactive power limits of the MVar exchanges between the HVDC terminals (WATL and EATL) and the connected alternating current (AC) transmission systems are shown in Table 4-. These limits must be maintained when performing the studies.

**Table 4-3: HVDC to Adjacent AC System MVar Exchange Limits**

HVDC Facility	North Terminal Reactive Power Limit (MVar)	South Terminal Reactive Power Limit (MVar)
EATL	-85 to 75	-35 to 35
WATL	-75 to 75	-35 to 35

## 4.2.7 Transmission Facility Ratings

The legal owner of transmission facilities (TFO) provided the thermal ratings assumptions for the existing transmission lines in the Study Area. Table 4-12 shows the normal ratings and emergency ratings for the key transmission lines in the Study Area, which will be used to perform the engineering studies.

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



**Table 4-12: Thermal Rating Assumptions for Key Transmission Lines in the Study Area**

Line ID	Line Description	Voltage Class (kV)	Normal Summer Rating (MVA)	Emergency Summer Rating (MVA)
1002L	JENNER 275S – AMOCO EMPRESS 163S	240	333 CT	499 CT
945L	JENNER 275S – CYPRESS 562S	240	550	660
1011L	CYPRESS 562S – AMOCO EMPRESS 163S	240	333 CT	499 CT
964L	BOWMANTON 244S - WHITLA 251S	240	952 M	1047 M
983L	BOWMANTON 244S – WHITLA 251S	240	952 M	1047 M
1034L	BOWMANTON 244S – CASSILS 324S	240	931 M	1024 M
1035L	BOWMANTON 244S – NEWELL 2075S	240	952 M	1047 M
1087L	NEWELL 2075S - CASSILS 324S	240	547	656
1088L	NEWELL 2075S - CASSILS 324S	240	931 M	1024 M
760AL	EMPRESS LIQUIDS 164S – 760AL TAP POINT	138	86 LTD-L	95 LTD-L
760L/7L760	7LA760 TAP POINT – 760AL TAP POINT	138	120	132
760L	AMOCO EMPRESS 163S – 760AL TAP POINT	138	120	132
760L	EMPRESS 394S – AMOCO EMPRESS 163S	138	119	131
871L	SAND HILLS SUB 341S – AMOCO EMPRESS 163S	138	120 CT	179 CT
869L	AMOCO EMPRESS 163S – SANDY POINT 204S	138	48 CT	72 CT
669L	AMOCO EMPRESS 163S – CYPRESS 562S	138	177	195
668L	EMPRESS 394S – CYPRESS 562S	138	121	133
830L	CYPRESS 562S – MCNEILL STATION 840S	138	177	195
658L	CYPRESS 562S – CHAPPICE LAKE 649S	138	121	133
674L	CHAPPICE LAKE 649S – BOWMANTON 244S	138	121	133
892L	SUFFIELD 895S - BOWMANTON 244S	138	80	88
100L	SUFFIELD 895S - TILLEY 498S	138	78	86
666L	WEST BROOKS 28S - TILLEY 498S	138	120 CT	133
675L	BOWMANTON 244S – AL ROTHBAUER 321S	138	368	405
676L	BOWMANTON 244S – BULLSHEAD 523S	138	369	406
879L	BOWMANTON 244S – BURDETT 368S	138	85	94
612L	BURDETT 368S – FINCASTLE 336S	138	85	94
722L	BURDETT 368S – WESTFIELD 107S	138	85	94
880L	AL ROTHBAUER 321S - BULLSHEAD 523S	138	121	133
600L	BULLSHEAD 523S – PEACE BUTTE 404S	138	121	133



## Study Scope

P1828 HEP Energy Alderson MPC Solar

V2



Line ID	Line Description	Voltage Class (kV)	Normal Summer Rating (MVA)	Emergency Summer Rating (MVA)
610L	FINCASTLE 336S – TABER 83S	138	85	94
507L	HULL 257S – TABER 83S	138	120	132
172L	COALDALE 254S – TABER 83S	138	119	131
9L20	Nevis 766S – Cordel 755S	240	429	501
9L46	Lanfine 959S – Pemukan 932S	240	755	831 CT
9L99	Sheerness 807S – Anderson 801S	240	470	499 GS
9L100	Sheerness 807S – Anderson 801S	240	470	499 GS
9L29	Oakland 946S - Coyote Lake 963S	240	740	831 GS
9L70	Anderson 801S – Oakland 946S	240	499 GS	499 GS
9L97	Anderson 801S – Oakland 946S	240	499 GS	499 GS
9L59	Anderson 801S – Tinchebray 972S	240	499 GS	499 GS
954L	Metiskow 648S - Hansman Lake 650S	240	333 CT	499 CT
7L127	Pemukan 932S – Monitor 774S	144	151 bus cond	194 bus cond
7I224	Hansman Lake 650S – ATCO Monitor 774S	138	287	376 M
7L110	Monitor 774S – Loyalist 903S	144	99 CT	99 CT
7L16	Nevis 766S – Heatburg 948S	144	112	125
7L116	Excel 910S – Lanfine 959S	144	99 CT	99 CT
7L25	Michichi Creek 802S – Rowley 768S	144	114	128
7L159	Heatburg 948S - tap	144	112	124
7L79	Pemukan 932S - Ribstone Creek 892S	144	114 L	129 L
7L137	Three Hills 770S – Rowley 768S	144	113	126
7L143	Nevis 766S – Stettler 769S	144	100 CT	100 CT
7L159	Three Hills 770S - tap	144	112	124
760L/7L760	Oyen 767S – Bindloss 914S tap point	144	115	128
6L09	Oyen 767S – tap	72	24 CT	24 CT
6L09	Hanna 763S - tap	72	24 CT	24 CT
6L02	Battle River 757S - Marion Lake 873S tap	72	59 L	67 L
6L02	Stettler 769S - Marion Lake 873S tap	72	59 L	66 CT
6L03	Battle River 757S - Castor tap	72	57 L	64 L
6L03	Sullivan Lake 775S – Castor tap	72	49 CT	49 CT
6L12	Monitor 774S – Coronation 773S tap	72	24 CT	24 CT
6L15	Hanna 763S - Sullivan Lake 775S	72	24 CT	24 CT
6L56	Hanna 763S - Michichi Creek 802S	72	37 L	37 CT

**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



Line ID	Line Description	Voltage Class (kV)	Normal Summer Rating (MVA)	Emergency Summer Rating (MVA)
1047L	Nilrem 574S - Hansman Lake 650S	240	499 CT	680
6L12	Sullivan Lake 775S – Coronation 773S tap	72	24 CT	24 CT

**Note:**

“CT” indicates that the transmission line is limited by current transformer.

“L” indicates that the transmission line rating is limited by the line

“M” indicates that the transmission line rating is limited for reasons other than protection equipment, transformer, current transformer, line, ganged switch, circuit breaker, or regulator.

The TFO provided the details of the substation transformers in the Study Area. The key transformers in the Study Area are shown in Table 4-.

**Table 4-13: Summary of Key Transformer Ratings in the Study Area**

Substation Name and Number	Transformer ID	Transformer Voltages (kV)	Transformer Rating (MVA)
AMOCO EMPRESS 163S	T5	240/138	191.2
CYPRESS 562S	T1	240/138	200
	T2	240/138	200
BOWMANTON 244S	T1	240/138	200
	T2	240/138	200
WEST BROOKS 28S	T1	240/138	400
	T2	240/138	400

The TFO provided the details of the shunt elements in the Study Area. The key shunt elements in the Study Area are shown in Table 4-.

**Table 4-14: Summary of Key Shunt Elements in the Study Area**

Substation Name and Number	Voltage Class (kV)	Capacitors		Reactors	
		Number of Switched Shunt Blocks	Total at Nominal Voltage (MVA <sub>r</sub> )	Number of Switched Shunt Blocks	Total at Nominal Voltage (MVA <sub>r</sub> )
BULLSHEAD 523S	138	1	18.3	-	-
WHITLA 251S	240	-	-	2	150
MCNEILL 840S	138	2	49.6		
AMOCO EMPRESS 163S	138	2	48.7		
WEST BROOKS 28S	240	-	-	1	50
TILLEY 498S	138	1	27.17	-	-
BURDETT 368S	138	1	24.46	-	-

## Study Scope

P1828 HEP Energy Alderson MPC Solar

V2



Substation Name and Number	Voltage Class (kV)	Capacitors		Reactors	
		Number of Switched Shunt Blocks	Total at Nominal Voltage (MVar)	Number of Switched Shunt Blocks	Total at Nominal Voltage (MVar)
		1	22.96	-	-
HAYS 421S	138	1	22.96	-	-
TABER 83S	138	1	24.46	-	-
		1	27.20	-	-

### 4.2.8 Protection Fault Clearing Times

The transient stability studies will be performed using the actual fault clearing times for the selected contingencies, as provided by the TFO and as shown in Table 4-4. Only those contingencies shown in Table 4-4 will be studied for transient stability studies. If the TFO did not specify the fault clearing times (e.g. for new transmission lines) for a selected contingency, then the studies for that contingency will be performed using the standard fault clearing times that are specified in Table 2-3 of the AESO's *Transmission Planning Criteria – Basis and Assumptions*.

**Study Scope**P1828 HEP Energy Alderson MPC Solar  
V2**Table 4-4: Protection Fault Clearing Times**

Contingency (System Element Lost)	Fault Location	Clearing Times (Cycles)	
		Near End	Far End
666L (West Brooks 28S - Tilley 498S)	Tilley 498S	6	27
	West Brooks 28S	6	27
892L (Suffield 895S – Bowmanton 244S)	Suffield 895S	6	27
	Bowmanton 244S	6	27
763L (West Brooks 28S - Vauxhall 158S)	West Brooks 28S	60	9
	Vauxhall 158S	9	60
853L (West Brooks 28S – Queenstown 504S)	West Brooks 28S	9	60
	Queenstown 504S	9	60
814L (Brooks 121S – West Brooks 28S)	West Brooks 28S	6	24
	Brooks 121S	6	24
827L (Brooks 121S – West Brooks 28S)	West Brooks 28S	6	24
	Brooks 121S	6	24
1051L (West Brooks 28S – Cassils 324S)	West Brooks 28S	6	6
	Cassils 324S	6	6
1052L (West Brooks 28S – Cassils 324S)	West Brooks 28S	6	6
	Cassils 324S	6	6
931L (Ware Junction 132S – West Brooks 28S)	West Brooks 28S	6.25	7.25
	Ware Junction 132S	7.25	6.25
1075L (Ware Junction 132S – West Brooks 28S)	West Brooks 28S	6.25	5
	Ware Junction 132S	5	6.25
675L (Bowmanton 244S – Medicine Hat 41S)	Bowmanton 244S	6	27
	Medicine Hat 41S	6	27
674L (Bowmanton 244S- Chappice Lake 649S)	Bowmanton 244S	6	27
	Chappice Lake 649S	6	27
879L (Bowmanton 244S – Burdett 368S)	Bowmanton 244S	30	9
	Burdett 368S	9	30

**4.2.9 Project Dynamic Data**

Dynamic data for the Project can be found in Attachment A7.

## Study Scope

P1828 HEP Energy Alderson MPC Solar

V2



### **4.2.10 Voltage Profile Assumption**

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for key area busses prior to commencing any studies. Table 2-1 of the *Transmission Planning Criteria – Basis and Assumptions* applies for the busses not included in ID #2010-007RS. These voltages will be used to set the voltage profile for the study base cases prior to the power flow studies.

## 5 Study Methodology

The studies to be performed for this connection assessment are identified in Table 5-1.

**Table 5-1: Summary of the Studies to be Performed**

Scenario No. and Name		Power Flow		Voltage Stability		Transient Stability		Motor Starting		Short Circuit
		Category		Category		Category		Category		Category A
		A	B	A	B	A	B	A	B	
<b>Pre-Project</b>										
1	2025 SP	X	X			X*	X*			X
2	2025 SL	X	X			X*	X*			
<b>Post-Project</b>										
3	2025 SP	X	X			X	X			X
4	2025 SL	X	X			X	X			
5	2031 WP									X
<b>Pre-Project – Sensitivity including P2418</b>										
6	2025 SP	X	X							
7	2025 SL	X	X							
<b>Post-Project – Sensitivity – Sensitivity including P2418</b>										
8	2025 SP	X	X							
9	2025 SL	X	X							
<b>Pre-Project – Sensitivity including P2446</b>										
10	2025 SP	X	X							
11	2025 SL	X	X							
<b>Post-Project – Sensitivity including P2446</b>										
12	2025 SP	X	X							
13	2025 SL	X	X							

\* Pre-project transient stability and voltage stability studies will be Only required if post-project studies identify potential performance issues.

For the engineering studies, all transmission facilities 69 kV and above, within the Study Area and the transmission lines connecting these planning areas to neighbouring planning areas will be studied and monitored to assess the impact of the Project on the performance of the AIES, including any violations of the Reliability Criteria (as defined in Section 3.1).

## Study Scope

P1828 HEP Energy Alderson MPC Solar  
V2



## 5.1 Study Case Validation

The study will be conducted on the AIES system model using the AESO's planning base cases. The seasonal light/peak scenarios will be studied as required. The base cases will be modified by the AESO to include the corresponding load and generation forecast information. The resulting cases, or seed cases, along with the project IDEVs, will be provided by the AESO to the Studies Consultant. These cases are provided in PSS/E v34 and/or v33 format. Upon request, the AESO can provide RAW and SEQ files. Software used by the Studies Consultant must be able to read and write these file types. Manual adjustments may be required to ensure full alignment with the details outlined in this Study Scope, as described in the process outlined below. The AESO will provide guidance to the Studies Consultant with regard to the setup of the study cases should any questions arise.

The expected process for the creation of acceptable study cases is as follows:

1. The AESO provides seed cases and the appropriate incremental IDEVs to use and any other applicable information required to the Studies Consultant.
2. The Studies Consultant applies the identified IDEVs to the seed cases to create the study cases. The Studies Consultant verifies and makes adjustments as required to ensure the study cases represent the assumptions outlined within the Study Scope.
3. Upon creating the study cases, all the study cases are forwarded to the AESO for approval.
4. The Studies Consultant proceeds with the required engineering studies only after the study cases are approved by the AESO.

## 5.2 Power Flow Studies

Power flow studies will be performed to identify thermal and voltage criteria violations as per the Reliability Criteria, and any deviations from the limits listed in Table 3-1.

For information purposes, the Studies Consultant must also provide, as a separate file, a list of any transmission elements where the thermal loading exceeds 95% of the element's normal rating under Category A and Category B conditions.

For the Category B power flow studies, the transformer taps and switched shunt reactive compensating devices such as shunt capacitors and reactors will be locked and continuous shunt devices will be enabled.

Voltage deviations at point-of-delivery (POD) low voltage busses will also be assessed for both the pre-Project and post-Project networks by first locking all tap changers and area shunt reactive compensating devices to identify any post-transient voltage deviations above 10%. Second, tap changers will be allowed to move while shunt reactive compensating devices remained locked to determine if any voltage deviations above 7% would occur in the area. Third, all the taps and shunt reactive compensating devices will be allowed to adjust, and voltage deviations above 5% will be reported.

The scenarios to be studied are shown in Table 5-1.

### 5.2.1 Contingencies to be Studied

Power flow studies will be performed for the Category A and all Category B conditions in the Study Area.

## 5.3 Transient Stability Studies

Genesee unit 3 in Wabamun (Area 40) will be used as the reference for the studies.

The report presenting the results of the transient stability studies must provide response plots for several variables, including rotor angle as applicable, and active and reactive power output for the generating units in the study area. The results report must also provide the 500 kV, 240 kV and 138 kV bus voltage levels for substations near the point of connection. Other busses will be monitored and will be reported as determined by the results. The results report must also provide the key branch active and reactive power flow surrounding the Facility.

Transient stability studies will be performed for the post-Project scenarios as shown in Table 5-1. If any transient stability issues are observed, transient stability analysis will be performed for the corresponding pre-Project scenarios.

### 5.3.1 Contingencies to be Studied

Transient stability studies will be performed for the contingencies shown in Table 4-4.

## 5.4 Short-Circuit Current Level Studies

A maximum fault level must be provided for the substations in the vicinity of the Project assuming normal system operation with all transmission elements in service and generation dispatched. Three-phase faults and single line-to-ground faults will be simulated. Polar coordinates and per-unit values will be used for reporting the results.

Winter peak scenarios will be used for the short-circuit studies because winter peak scenarios generally produce higher short-circuit current levels than summer peak scenarios.

Estimated maximum three-phase faults and single line-to-ground short-circuit current levels will be reported for the following substations:

- Tilley 498S
- Suffield 895S
- Cassils 324S
- West Brooks 28S
- Medicine Hat 41S
- Chappice Lake 649S
- Cypress 562S
- McNeil Station 840S
- Bowmanton 244S
- P1828 Facility

Further sensitivity studies, in consultation with the TFO, may be required if the primary short-circuit analysis indicates a potential to exceed or approach the existing fault rating of the transmission facilities.



**Study Scope**

P1828 HEP Energy Alderson MPC Solar

V2



The scenarios to be studied are as shown in Table 5-1.

## 6 Mitigation Measures

### 6.1 Development

Mitigation measures may be required if the post-Project study results identify system performance issues. Mitigation measures for the Project may involve modifying or adding real-time operational practices and/or remedial action schemes (RASs).

The Studies Consultant must notify the AESO of any system performance issues in a timely manner, following which the AESO Studies Engineer may instruct the Studies Consultant as follows:

- Develop tables showing the constraint effective factors<sup>3</sup> for generation or load based on thermal criteria violations that are observed.
- Collaborate with the AESO to propose changes, if any, to the connection alternatives that could remove the requirement for a RAS.
- Collaborate with the AESO to study modifications to existing and/or planned RASs, proposed by the AESO, to ensure the coordination of existing protection schemes with the addition of any proposed protection schemes.
- Collaborate with the AESO to identify and study new RASs, if any, that may be required to ensure system reliability is maintained after connecting the Project to the AES.

The AESO Studies Engineer will work closely with the Studies Consultant and guide the development and/or modifications of the proposed mitigation measures to ensure system reliability, security and compliance with AESO ID #2018-018T, *Provision of System Access Service and the Connection Process*.

### 6.2 Evaluation

#### 6.2.1 Post-Mitigation Studies

Studies to evaluate the effectiveness of mitigation measures, if required, will be performed in accordance with the technical criteria, assumptions, and methods provided in this Study Scope and in accordance with further instructions from the AESO.

#### 6.2.2 Constraint Effective Factor Studies

Constraint effective factor analysis are used to determine the generator- and load- constraint effective factors and to identify the most effective generators or loads to manage the thermal criteria violations, if any, that are observed under Category B conditions.

---

<sup>3</sup> Constraint effective factor studies are performed to determine the generator- and load- constraint effective factors. Constraint effective factors are used to estimate the ability of generators and loads to manage transmission constraints. A generator's or load's constraint effective factor is defined as the change in power flow over a specific transmission line following a change in the generator's energy production or in the load's energy consumption. The greater the constraint effective factor, the more effective a generator or load can be in managing a thermal criteria violation on the specific transmission line.

**Study Scope**

P1828 HEP Energy Alderson MPC Solar  
V2



## 7 Changes to Study Assumptions

This study will utilize the AESO's planning base cases, which are based on the AESO's current corporate forecast (2021 LTO) with modifications to incorporate the latest forecast intelligence. Sensitivity studies or restudy may be required in the event of revisions to the AESO's corporate forecast, forecast intelligence, or other study assumptions. Additional engineering studies may also be required to assess new connection alternatives, changes to project ISD, or delays in proposed system developments. Any additional or revised study requirements shall be captured in a signed Study Scope Amendment document.

# Attachment A: Transmission Planning Criteria – Basis and Assumptions

# Transmission Planning Criteria – Basis and Assumptions

**Date:** July 9, 2019

**Version:** V1.2

## 1. Introduction

This document presents the reliability standards, criteria, and assumptions to be used as the basis for planning the Alberta Transmission System. The criteria, standards and assumptions identified in this document supersede those previously established.

## 2. Transmission Reliability Standards and Criteria<sup>1</sup>

The AESO applies the following Alberta Reliability Standards to ensure that the transmission system is planned to meet applicable performance requirements under a defined set of system conditions and contingencies. A brief description of each of these standards is given below:

### 1. TPL-001-AB-0: System Performance Under Normal Conditions

Category A represents a normal system condition with all elements in service (N-0). All equipment must be within its applicable rating, voltages must be within their applicable ratings and the system must be stable with no cascading outages. Under Category A, electric supply to load cannot be interrupted and generating units cannot be removed from service.

### 2. TPL-002-AB1-0: System Performance Following Loss of a Single BES Element

Category B events result in the loss of any single element (N-1) under specified fault conditions with normal clearing. The specified elements are a generating unit, a transmission circuit, a transformer or a single pole of a direct current transmission line. The acceptable impact on the system is the same as Category A with the exception that radial customers or some local network customers, including loads or generating units, are allowed to be disconnected from the system if they are connected through the faulted element. The loss of opportunity load or opportunity interchanges is allowed. No cascading can occur.

### 3. TPL-003-AB-0: System Performance Following Loss of Two or More BES Elements

Category C events result in the loss of two or more bulk electric system elements (sequential, N-1-1 or concurrent, N-2) under specified fault conditions and include both normal and delayed fault clearing. All of the system limits for Category A and B events apply with the exception that planned and controlled loss of firm load, firm transfers and/or generation is acceptable provided there is no cascading.

### 4. TPL-004-AB-0: System Performance Following Extreme BES Events

Category D represents a wide variety of extreme, rare and unpredictable events, which may result in the loss of load and generation in widespread areas. The system may not be able to reach a new stable steady state, which means a blackout is a possible outcome. The AESO needs to evaluate these events, at its discretion, for risks and consequences prior to creating mitigation plans.

### 5. FAC-014-AB1-2: Establishing and Communicating System Operating Limits

The AESO is required to establish system operating limits where a contingency is not mitigated through construction of transmission facilities

---

<sup>1</sup> A complete description of the *Alberta Reliability Standards* can be found on the AESO's website: <https://www.aeso.ca/rules-standards-and-tariff/alberta-reliability-standards/>

## 2.1 Thermal Loading Criteria

The AESO Thermal Loading Criteria require that the continuous thermal rating of any transmission element is not exceeded under normal and post-contingency operating conditions. Thermal limits are assumed to be 100% of the respective normal summer and winter ratings. Emergency limits are not considered in the planning evaluations.

## 2.2 Voltage Range and Voltage Stability Criteria

The normal minimum and maximum voltage limits as specified in the following table are used to identify Category A system voltage violations, while the extreme minimum and maximum limits are used to identify Category B and C system violations. Table 2-1 presents the acceptable steady state and contingency state voltage ranges for the AIES. Table 2-2 provides voltage stability criteria used to test the system performance.

**Table 2-1: Acceptable Range of Steady State Voltage (kV)**

Nominal Voltage	Extreme Minimum	Normal Minimum	Normal Maximum	Extreme Maximum
500	475	500	525	550
240	216	234	252	264
260 (Northeast & Northwest)*	234	247	266	275
144	130	137	151	155
138	124	135	145	150
72	65	68.5	75.5	79
69	62	65.5	72.5	76

**Table 2-2: Voltage Stability Criteria**

Performance Level	Disturbance (1)(2)(3)(4) Initiated by: Fault or No Fault DC Disturbance	MW Margin (P-V method) (5)(6)(7)	MVAr Margin (V-Q method) (6)(7)
A	Any element such as: One Generator One Circuit One Transformer One Reactive Power Source One DC Monopole	$\geq 5\%$	Worst Case Scenario(8)
B	Bus Section	$\geq 5\%$	50% of Margin Requirement in Level A
C	Any combination of two elements such as: A Line and a Generator A Line and a Reactive Power Source Two Generators Two Circuits Two Transformers Two Reactive Power Sources DC Bipole	$\geq 2.5\%$	50% of Margin Requirement in Level A
D	Any combination of three or more elements such as: Three or More Circuits on ROW Entire Substation Entire Plant Including Switchyard	$> 0$	$> 0$

## 2.3 Transient Stability Analysis Assumptions

Standard fault clearing times as shown in Table 2-3 are used for the new facilities or when the actual clearing times are not available for the existing facilities. Double line-to-ground faults are applied for the Category C5 events with normal clearing times. Single line-to-ground faults are applied for Category C6 to C9 events with delayed clearing times as depicted in Table 2-4 and Table 2-5.

**Table 2-3: Fault Clearing Times**

Nominal (kV)	Near End (Cycles)	Far End (Cycles)
500	4	5
240	5	6
144/138 with telecommunications	6	8
144/138 without telecommunications	6	30

**Table 2-4: Stuck Breaker Clearing Times for Lines**


Voltage (kV)	Fault Clearing Times (Cycles)		
	Near End	Far End	2 <sup>nd</sup> Ckt (C5 and C7 only)
138/144	15	24	24
240	12	6	14
500	9	5	11

**Table 2-5: Stuck Breaker Clearing Times for Transformers**

Voltage (kV)	Fault Location	Fault Clearing Times (Cycles)		
		High Side	Low Side	2 <sup>nd</sup> Ckt (breaker fail)
240/138	240 kV side	12	6	14
	138 kV side	5	15	24
500/240	500 kV side	9	5	11
	240 kV side	4	12	14



# Attachment B: Pre-Project Power Flow Diagrams (Scenarios 1 to 2, 6 to 7, 10 to 11)




DRAWING NOTE:  
 1) These portions of 172L and 172EL are outside of the study area. Provided for reference only. Typical for all preceding SLDs in this appendix.

### P1828 HEP Alderson Solar Project

BC Import: -516.689 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A0-1-N-0: NORMAL OPERATION (PRE-CURTALMENT)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 FRI, SEP 08 2023 09:17**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 100.0%Rate B  
 100.0%Rate C  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



### P1828 HEP Alderson Solar Project

BC Import: -521.312 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW


**FIGURE A1-1-N-0: NORMAL OPERATION  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:55**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>> 500.000</math>








**P1828 HEP Alderson Solar Project**

BC Import: -545.101 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-4-N-1: 871L (AMOCO EMPRESS 163S TO SAND HILLS 341S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:55**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate/A  
 kv: <math>V < 25,000</math> <math>25,000 < V < 69,000</math> <math>69,000 < V < 138,000</math> <math>138,000 < V < 240,000</math> <math>V > 240,000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -543.799 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-5-N-1: 763L(VAUXHALL 158S TO HULL 257S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:55**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kV: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>> 500.000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -545.462 MW      Sask Import: -175.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-6-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:55**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -544.841 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-7-N-1: 1051L(WEST BROOKS 28S TO CASSISL 324S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:56**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -544.841 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-8-N-1: 1052L(WEST BROOKS 28S TO CASSISL 324S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:56**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -525.152 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-9-N-1: 935L(MILO 3565 TO CASSILS 3245)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:56**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -527.409 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-10-N-1: 923L(MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:56**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -493.410 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-11-N-1: 924L(LANGDON 102S TO MIL0 356S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:56**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -488.797 MW      Sask Import: -175.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-12-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -563.514 MW	Sask Import: -150.000 MW
EATL: -1000.000 MW	WATL: -800.000 MW

**FIGURE A1-13-N-1: 831L(BROOKS 121S TO DUCHESS 339S)  
2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
TUE, AUG 22 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -583.174 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-14-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kV: <math>V < 25.000</math> <math>25.000 < V < 69.000</math> <math>69.000 < V < 138.000</math> <math>138.000 < V < 240.000</math> <math>240.000 < V < 500.000</math> <math>V > 500.000</math>






**P1828 HEP Alderson Solar Project**

BC Import: -550.577 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-15-N-1: 163ST5(AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -546.318 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-16-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>> 500.000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -520.292 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A1-17-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 1 (PRE PROJECT)  
 TUE, AUG 22 2023 10:58**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -239.093 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE A1-18-N-1: EATL 2025 SUMMER PEAK - SCN 1 (PRE PROJECT) TUE, AUG 22 2023 12:00**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -521.080 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A0-2-N-0: NORMAL OPERATION (PRE-CURTALMENT)  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 FRI, SEP 08 2023 9:18**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -521.053 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-1-N-0: NORMAL OPERATION  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -513.839 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-2-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -520.857 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -540.609 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-4-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2) 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT) TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -517.928 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-5-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -512.136 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A2-6-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 2 (PRE PROJECT)  
 TUE, AUG 22 2023 11:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -516.145 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A0-3-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 9:31**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.825 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-1-N-0: NORMAL OPERATION  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:14**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -516.158 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-2-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:03**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -518.926 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-3-N-1: 760L (AMOCO EMPRESS 163S TO EMPRESS 394S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:04**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**


BC Import: -519.083 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-4-N-1: 892L (SUFFIELD 895S TO BOWMANTON 244S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -519.658 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-5-N-1: 1051L (WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.658 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-6-N-1: 1052L (WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -495.554 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-7-N-1: 935L (MILO 365S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -497.965 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-8-N-1: 923L (MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -472.170 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-9-N-1: 924L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -467.811 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-10-N-1: 927L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -539.776 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-11-N-1: 498ST1T2 (TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:12**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**


BC Import: -518.528 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-12-N-1: 100L (SUFFIELD 895S TO TILLEY 498S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -546.305 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-13-N-1: 163ST5(AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:14**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -515.167 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-14-N-1: 1088L(CASSILS 3245 TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -488.047 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C1-15-N-1: 103SL(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -239.508 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE C1-16-N-1: EATL  
 2025 SUMMER PEAK - SCN 6 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 12:02**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -520.984 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A0-4-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 9:41**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -521.146 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C2-1-N-0: NORMAL OPERATION  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -520.565 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C2-2-N-1: 562ST1 (CYPRESS 562S TRANSFORMER T1)  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -520.562 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C2-3-N-1: 562ST1 (CYPRESS 562S TRANSFORMER T2)  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -517.761 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C2-4-N-1: 1088L(CASSISL 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -512.917 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C2-5-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -408.405 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE C2-6-N-1: EATL  
 2025 SUMMER LIGHT - SCN 7 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 12:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -516.568 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE A0-5-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 9:54**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




### P1828 HEP Alderson Solar Project

BC Import: -518.879 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-1-N-0: NORMAL OPERATION  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:29**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.770 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-2-N-1: 1051L(WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:29**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.770 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-3-N-1: 1052L(WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:29**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -500.673 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-4-N-1: 935L(MILO 3565 TO CASSILS 3245)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:29**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -502.882 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-5-N-1: 923L(MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:29**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -469.009 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-6-N-1: 924L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -464.635 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-7-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -514.360 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C3-8-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**

BC Import: -486.695 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW


**FIGURE C3-9-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 10 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000







**P1828 HEP Alderson Solar Project**


BC Import: -521.224 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C4-1-N-0: NORMAL OPERATION  
 2025 SUMMER LIGHT - SCN 11 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:35**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**





**P1828 HEP Alderson Solar Project**


BC Import: -518.054 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE C4-2-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 11 (PRE SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:35**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000

# Attachment C: Pre-Project Transient Stability Diagrams (Scenarios 1 to 2)- Not Required

# Attachment D: Post-Project Power Flow Diagrams (Scenarios 3 to 4, 8 to 9, 12 to 13)




### P1828 HEP Alderson Solar Project

BC Import: -516.398 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B0-1-N-0: NORMAL OPERATION (PRE-CURTALMENT)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 FRI, SEP 08 2023 10:28**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <math>V < 25,000</math> <math>25,000 < V < 69,000</math> <math>69,000 < V < 138,000</math> <math>138,000 < V < 240,000</math> <math>V > 240,000</math>




DRAWING NOTE:  
 1) These portions of 172L and 172EL are outside of the study area. Provided for reference only. Typical for all preceding SLDs in this appendix.

### P1828 HEP Alderson Solar Project

BC Import: -592.579 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

### FIGURE B1-1-N-0: NORMAL OPERATION 2025 SUMMER PEAK - SCN 3 (POST PROJECT) TUE, AUG 22 2023 9:05

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -589.173 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-2-N-1: 612L (BURDETT 368S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -585.693 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-3-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -616.334 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-4-N-1: 871L (AMOCO EMPRESS 163S TO SAND HILLS 341S 2025 SUMMER PEAK - SCN 3 (POST PROJECT) TUE, AUG 22 2023 9:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -591.427 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-5-N-1: 763L(VAUXHALL 158S TO HULL 257S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -585.832 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-6-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -591.805 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-7-N-1: 1051L(WEST BROOKS 285 TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -591.841 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-8-N-1: 1052L(WEST BROOKS 285 TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>V < 25,000</math> <math>25,000 < V < 69,000</math> <math>69,000 < V < 138,000</math> <math>138,000 < V < 240,000</math> <math>V > 240,000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -569.915 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-9-N-1: 935L(MILO 356S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -572.280 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-10-N-1: 923L(MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -536.952 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-11-N-1: 924L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate/A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -531.660 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-12-N-1: 927L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -611.017 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-13-N-1: 831L (BROOKS 121S TO DUCHESS 339S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -599.951 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-14-N-1: 498ST1T2 (TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -621.102 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-15-N-1: 163ST5 (AMOCO EMPRESS 163S TRANSFORMER T5) 2025 SUMMER PEAK - SCN 3 (POST PROJECT) TUE, AUG 22 2023 9:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -563.016 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-17-N-1: 103SL (BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)  
 TUE, AUG 22 2023 9:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -295.754 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE B1-18-N-1: EATL 2025 SUMMER PEAK - SCN 3 (POST PROJECT) TUE, AUG 22 2023 11:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A/W  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000





**P1828 HEP Alderson Solar Project**


BC Import: -520.977 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-1-N-0: NORMAL OPERATION  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -511.029 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-2-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -514.126 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -527.343 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-4-N-1: 498ST1T2 (TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:35**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -517.704 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-5-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:12**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -511.720 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-6-N-1: 1035L (BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)  
 TUE, AUG 22 2023 9:12**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -515.643 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B0-3-N-0: NORMAL OPERATION (PRE-CURTALMENT)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 10:45**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.403 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-1-N-0: NORMAL OPERATION  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -516.963 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-2-N-1: 612L (BURDETT 368S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -514.272 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-3-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -542.450 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-4-N-1: 871L (AMOCO EMPRESS 163S TO SAND HILLS 341S 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT) TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -513.251 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-5-N-1: 931L (WARE JUNCTION 132S TO WEST BROOKS 28S 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT) TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -513.251 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-6-N-1: 1075L (WARE JUNCTION 132S TO WEST BROOKS 28 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT) TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -510.167 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-7-N-1: 1053L (WARE JUNCTION 132S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:15**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -516.481 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-8-N-1: 1002L (JENNER 275S TO AMOCO EMPRESS 163S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:16**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



### P1828 HEP Alderson Solar Project


BC Import: -516.133 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-9-N-1: 945L (JENNER 275S TO CYPRESS 562S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 13:16**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -518.479 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-10-N-1: 163ST1 (AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:50**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -518.503 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-11-N-1: 760L (AMOCO EMPRESS 163S TO EMPRESS 394S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:42**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -531.429 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-12-N-1: 722L (BURDETT 368S TO WESTFIELD 107S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:42**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.937 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-13-N-1: 892L (SUFFIELD 895 TO BOWMANTON 244S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:42**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -517.563 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-15-N-1: 763L (VAUXHALL 158S TO HULL 257S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:42**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -512.496 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-16-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:42**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.436 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-17-N-1: 1051L(WEST BROOKS 228S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -519.436 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-18-N-1: 1052L(WEST BROOKS 228S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -402.229 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-19-N-1: 1148L(WHITLA 251S TO SHAMROCK 1018S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.538 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-20-N-1: 562ST1(CYPRESS 562S TRANSFORMER T1)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.541 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-21-N-1: 562ST1(CYPRESS 562S TRANSFORMER T2)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:43**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -491.730 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-22-N-1: 935L(MILO 356S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 14:44**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -517.438 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-23-N-1: 1087(CASSILLS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -494.332 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-24-N-1: 923L(MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -526.707 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-25-N-1: 336ST1(FINCASTLE 336S TRANSFORMER T1)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -522.382 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-26-N-1: 895ST2(SUFFIELD 895S TRANSFORMER T2)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -466.822 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-27-N-1: 924L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -462.111 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-28-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.304 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-29-N-1: 853L(QUEENSTOWN 504S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -525.635 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-30-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -450.338 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-31-N-1: 100L(SUFFIELD 895S TO TILLEY 498S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000





**P1828 HEP Alderson Solar Project**

BC Import: -545.222 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW


**FIGURE D1-33-N-1: 163ST5(AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 15:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000










**P1828 HEP Alderson Solar Project**

BC Import: -514.421 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-35-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:21**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math><= 69.000</math> <math><= 138.000</math> <math><= 240.000</math> <math><= 500.000</math> >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -487.788 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-36-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 THU, AUG 24 2023 17:58**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -250.070 MW  
 SASK Import: -150.000 MW  
 EATL: -1000.000 MW  
 WATL: -800.000 MW

**FIGURE D1-37-N-1: 964L(BOWMANTON 244S TO WHITLA 251S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -409.265 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-38-N-1: 676L(BOWMANTON 244S TO BULLSHED 523S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -448.962 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-39-N-1: 763L(WEST BROOKS 28S TO VAUXHALL 158S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -500.152 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-40-N-1: 368ST1(BURDETT 368S TRANSFORMER T1)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 18:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -526.526 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-41-N-1: 257ST1(HULL 257S TRANSFORMER)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 18:16**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000





### P1828 HEP Alderson Solar Project


BC Import: -527.329 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-42-N-1: 158ST2(VAUXHALL 158S TRANSFORMER T2)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 18:19**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -518.057 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-43-N-1: 879L  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:40**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -263.915 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE D1-45-N-1: EATL  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 17:41**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**


BC Import: -520.908 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B0-4-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 10:44**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000








**P1828 HEP Alderson Solar Project**

BC Import: -510.187 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-3-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:05**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -519.238 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-4-N-1: 1002L (JENNER 275S TO AMOCO EMPRESS 163S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -518.963 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-5-N-1: 945L (JENNER 275S TO CYPRESS 562S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -521.009 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-6-N-1: 1011L(AMOCO EMPRESS 163S TO CYPRESS 562S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -521.264 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-7-N-1: 669L(CYPRESS 562S TO AMOCO EMPRESS 163S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -513.753 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-8-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:06**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -520.596 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-10-N-1: 562ST1(CYPRESS 562S TRANSFORMER T2)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:17**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**


BC Import: -515.986 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-11-N-1: 935L(MILO 356S TO CASSILS 324S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000








**P1828 HEP Alderson Solar Project**

BC Import: -525.969 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-13-N-1: 336ST1(FINCASTLE 336S TRANSFORMER T1)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:07**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -526.266 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-14-N-1: BURDETT 368S TRANSFORMER T2  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -526.495 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-15-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -550.359 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-16-N-1: 163ST5(AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -517.658 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-17-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -512.029 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-18-N-1: 103SL(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -392.602 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW      WATL: -800.000 MW

**FIGURE D2-19-N-1: EATL 2025 SUMMER LIGHT - SCN 9 (POST SENSITIVITY PROJECT) TUE, AUG 22 2023 11:49**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -516.496 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B0-5-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 10:49**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math><= 69.000</math> <math><= 138.000</math> <math><= 240.000</math> <math>> 500.000</math> >500.000






### P1828 HEP Alderson Solar Project

BC Import: -518.757 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-1-N-0: NORMAL OPERATION  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -517.074 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-2-N-1: 763L(VAUXHALL 158S TO HULL 257S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -509.591 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:25**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25</math> <math>< 69</math> <math>\leq 138</math> <math>< 240</math> <math>\leq 500</math> <math>> 500</math> 000




**P1828 HEP Alderson Solar Project**

BC Import: -518.614 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-4-N-1: 1051L(WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -518.614 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-5-N-1: 1052L(WEST BROOKS 28S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -497.675 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-6-N-1: 935L(MILO 3565 TO CASSILS 3245)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -499.992 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-7-N-1: 923L(MILO 356S TO NEWELL2075S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -466.070 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-8-N-1: 924L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -461.312 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-9-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -513.832 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-10-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:30**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -514.375 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-11-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:27**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -486.793 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-12-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:27**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -193.010 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE D3-13-N-1: EATL 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT) TUE, AUG 22 2023 10:27**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -520.992 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B0-6-N-0: NORMAL OPERATION (PRE-CURTAILMENT)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 FRI, SEP 08 2023 10:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25</math> <math>25 < V \le 69</math> <math>69 < V \le 138</math> <math>138 < V \le 240</math> <math>240 < V < 500</math> <math>500 < V < 1000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -521.009 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-1-N-0: NORMAL OPERATION  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:37**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -510.983 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-2-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:37**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <math>\leq 25</math> <math>25 < V \leq 69</math> <math>69 < V \leq 138</math> <math>138 < V \leq 240</math> <math>V > 240</math>






**P1828 HEP Alderson Solar Project**

BC Import: -511.050 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:37**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -515.993 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-4-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:38**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**




**P1828 HEP Alderson Solar Project**

BC Import: -517.710 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-5-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:38**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -511.740 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-6-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 10:38**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000







**P1828 HEP Alderson Solar Project**







BC Import: -412.634 MW      Sask Import: -150.000 MW  
 EATL: 0.000 MW              WATL: -800.000 MW

**FIGURE D4-7-N-1: EATL  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)  
 TUE, AUG 22 2023 11:56**





Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 >500.000





# Attachment E: Post-Project Transient Stability Diagrams (Scenarios 3 to 4)







































































































































































































































































































































































































































































































































































































































































































































































































































































































































































































































# Attachment F: Constraints Summary Tables (Scenarios 3 to 4, 8 to 9, 12 to 13)








# Attachment G: Constraint Effective Factors Tables





# Attachment H: Post-Project Post-Mitigation Power Flow Diagrams (Scenarios 3 to 4, 8 to 9, 12 to 13)






### P1828 HEP Alderson Solar Project

BC Import: -553.828 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-6-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)-RAS181  
 TUE, AUG 22 2023 12:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -190.737 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-11-N-1: 927L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)-RAS175  
 TUE, AUG 22 2023 12:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -193.958 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-12-N-1: 924L (LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)-RAS175  
 TUE, AUG 22 2023 12:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -541.727 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B1-14-N-1: 498ST1T2 (TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)-RAS209  
 TUE, AUG 22 2023 12:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -522.906 MW      Sask Import: -150.000 MW  
 EATL: -600.000 MW      WATL: -800.000 MW

**FIGURE B1-16-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 3 (POST PROJECT)-RAS197  
 TUE, AUG 22 2023 12:23**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000</math> >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -441.650 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)-RAS209  
 TUE, AUG 22 2023 12:28**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**


BC Import: -461.658 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE B2-4-N-1: 498ST1T2 (TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)-RAS209  
 TUE, AUG 22 2023 12:31**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

**kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000**






**P1828 HEP Alderson Solar Project**

BC Import: -296.942 MW      Sask Import: -150.000 MW  
 EATL: -600.000 MW      WATL: -800.000 MW

**FIGURE B2-5-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 4 (POST PROJECT)-RAS197  
 TUE, AUG 22 2023 12:28**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -449.750 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-2-N-1: 612L (BURDETT 368S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS 1  
 TUE, AUG 22 2023 21:08**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -444.283 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-3-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS 1  
 TUE, AUG 22 2023 21:26**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000</math> >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -391.517 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-11-N-1: 760L (AMOCO EMPRESS 163S TO EMPRESS 394S) 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS607 TUE, AUG 22 2023 21:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>> 500.000</math> <math>> 500.000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -483.418 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-15-N-1: 763L (VAUXHALL 158S TO HULL 257S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS181  
 TUE, AUG 22 2023 21:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.00 <=69.00 <=138.00 <=240.00 >500.00




**P1828 HEP Alderson Solar Project**

BC Import: -480.304 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-16-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS181  
 TUE, AUG 22 2023 21:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -488.490 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-17-N-1: 1051L(WEST BROOKS 228S TO CASSILS 324S) 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS2 TUE, AUG 22 2023 20:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00 >500.00






**P1828 HEP Alderson Solar Project**

BC Import: -488.501 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-18-N-1: 1052L(WEST BROOKS 228S TO CASSILS 324S) 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS2 TUE, AUG 22 2023 20:59**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00 >500.00






### P1828 HEP Alderson Solar Project

BC Import: -200.965 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-22-N-1: 935L(MILO 356S TO CASSILS 324S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS3  
 TUE, AUG 22 2023 21:09**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -203.654 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-24-N-1: 923(L)(MILO 356S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS3  
 TUE, AUG 22 2023 21:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -260.231 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-27-N-1: 924L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS175  
 TUE, AUG 22 2023 21:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000 > 500.000</math>




**P1828 HEP Alderson Solar Project**

BC Import: -256.434 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-28-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS175  
 TUE, AUG 22 2023 21:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -470.850 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-30-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 21:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -422.196 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-33-N-1: 163ST5(AMOCO EMPRESS 163S TRANSFORMER T5)  
 2025 SUMMER PEAK- SCN 8(POST SENSITIVITY PROJECT)-RAS607  
 TUE, AUG 22 2023 21:10**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -211.717 MW      Sask Import: -150.000 MW  
 EATL: -500.000 MW      WATL: -800.000 MW

**FIGURE D1-35-N-1: 1088L(CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS197  
 TUE, AUG 22 2023 21:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>> 500.000</math> >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -281.394 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-36-N-1: 1035L(BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS164  
 TUE, AUG 22 2023 21:11**

Bus - Voltage (kV/pu)  
 Branch - M/Mvar  
 Equipment - M/Mvar  
 100.0%Rate A  
 kv: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000</math> >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -425.531 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-40-N-1: 368ST1(BURDETT 368S TRANSFORMER T1)  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS1  
 TUE, AUG 22 2023 21:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -450.422 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D1-43-N-1: 879L  
 2025 SUMMER PEAK - SCN 8 (POST SENSITIVITY PROJECT)-RAS1  
 TUE, AUG 22 2023 21:11**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -435.699 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-3-N-1: 610L (TABER 83S TO FINCASTLE 336S)  
 2025 SUMMER PEAK - SCN 9 (POST SENSITIVITY PROJECT)-RAS1  
 TUE, AUG 22 2023 12:50**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -488.507 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-8-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 9 (POST SENSITIVITY PROJECT)-RAS181)  
 TUE, AUG 22 2023 12:50**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -463.068 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D2-15-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 9 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 12:51**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -291.666 MW      Sask Import: -150.000 MW  
 EATL: -600.000 MW      WATL: -800.000 MW

**FIGURE D2-17-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 9 (POST SENSITIVITY PROJECT)-RAS197  
 TUE, AUG 22 2023 12:51**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -450.237 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 12:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -119.969 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-8-N-1: 924L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS175  
 TUE, AUG 22 2023 12:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000






**P1828 HEP Alderson Solar Project**

BC Import: -116.867 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-9-N-1: 927L(LANGDON 102S TO MILO 356S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS175  
 TUE, AUG 22 2023 12:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -455.241 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-10-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 12:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




### P1828 HEP Alderson Solar Project

BC Import: -202.209 MW      Sask Import: -150.000 MW  
 EATL: -600.000 MW      WATL: -800.000 MW

**FIGURE D3-11-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS197  
 TUE, AUG 22 2023 12:57**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A

kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -282.409 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D3-12-N-1: 103SL (BOWMANTON 244S TO NEWELL 2075S)  
 2025 SUMMER PEAK - SCN 12 (POST SENSITIVITY PROJECT)-RAS164  
 TUE, AUG 22 2023 12:58**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -442.065 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-3-N-1: 666L(TILLEY 498S TO WEST BROOKS 28S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 13:03**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000




**P1828 HEP Alderson Solar Project**

BC Import: -450.042 MW      Sask Import: -150.000 MW  
 EATL: -1000.000 MW      WATL: -800.000 MW

**FIGURE D4-4-N-1: 498ST1T2(TILLEY 498S TRANSFORMER T1/T2)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)-RAS209  
 TUE, AUG 22 2023 13:03**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
 kV: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000



**P1828 HEP Alderson Solar Project**

BC Import: -296.449 MW      Sask Import: -150.000 MW  
 EATL: -600.000 MW      WATL: -800.000 MW

**FIGURE D4-5-N-1: 1088L (CASSILS 324S TO NEWELL 2075S)  
 2025 SUMMER LIGHT - SCN 13 (POST SENSITIVITY PROJECT)-RAS19  
 TUE, AUG 22 2023 13:03**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate A  
  
 kv: <=25.000 <=69.000 <=138.000 <=240.000 <=500.000 >500.000

# Attachment I: Dynamic Data and Assumptions



```

/***** PV GENERATION GENERIC MODELS *****/
/*****P1828 HEP Alderson Park 100 MW Solar(G1), T-tap on 100L*****/
/
/STAGE-3
/
560111 'USRMDL' G1 'REGCAU1' 101 1 1 14 3 4 1 0.2000E-01 10.000 0.90000
0.500 1.2200 1.2000 0.80000 0.40000 -1.3000 0.2000E-01 0.70000
9999.0 -9999.0 1.0000 / Inverter

560111 'USRMDL' G1 'RECAU1' 102 0 6 45 6 9
0 0 1 0 0 0
0.90 1.1 0.01 -0.10 0.10 1 1.0 -1.0 1.00 0 0 0
0.01 0.60 -0.60 1.10 0.9 0.3 5.0 0.5 0.0 0
0.01 99 -99 1 0 1.0 0.01
0.00 0.01 0.49 0.01 0.5 1 1.2 1
0.00 0.01 0.49 0.01 0.5 1 1.2 1/ Electrical control

560111 'USRMDL' G1 'REPCAU1' 107 0 7 27 7 9
560311 560311 560211 'L1' 1 1 1
0.020000 18.000 5.0000 0.0000 0.75000E-01 0.0000 0.0000 0.0000 0.2000E-01 0.1000
-0.10000 0.0000 0.0000 0.43600 -0.43600 0.10000 0.50000E-01 0.25000 0.00
0.0000 999.00 -999.00 999.00 -999.00 0.10000 20.000 0.0000 / Power plant controller

```