

APPENDIX A

Existing System Power Flow Plots


2009 Load Flow Diagrams

2009 Winter Peak

Figure Number	2009 WP Contingency	Overloaded Element	Transmission Voltage Violation
A-2009-11	Many Area Contingencies. Worst overload contingency is 702L/7L702 Battle River 757S to Hardisty 377S	7L50 Battle River 757S to Jarrow tap	NONE
A-2009-8	Vegreville 144-72kV tie transformer	6L82 Bonnyville 700S to St. Paul 707S	Voltage drops below 90% at Willingdon 711S
A-2009-2	6L82 Bonnyville 700S to St. Paul 707S	6L79 Vegreville 709S to Willingdon 711S	Voltage collapse (below 85%) at St. Paul 707S and below 90% at Willingdon 711S
A-2009-45	6L79 Vegreville 709S to Willingdon 711S	6L82 Bonnyville 700S to St. Paul 707S	Voltage below 90% at St. Paul 707S and Willingdon 711S
A-2009-65	Marguerite Lake 240-144kV 901T	Marguerite Lake 240-144kV 902T	NONE
	Marguerite Lake 240-144kV 902T	Marguerite Lake 240-144kV 901T	
A-2009-20	Ethel Lake 601T	Ethel Lake 602T	
	Ethel Lake 602T	Ethel Lake 601T	
A-2009-51	7L83 Mahihkan 837S to Leming Lake 715S	7L87 Marguerite Lake 826S to Wolf Lake 822S	
		7L74 Wolf Lake 822S to Primrose tap	
A-2009-52	7L89 Marguerite Lake 826S to La Corey 721S	7L74 Wolf Lake 822S to Primrose tap	
		7L87 Marguerite Lake 826S to Wolf Lake 822S	
		7L50 Battle River 757S to Jarrow tap	
A-2009-60	7L91 Marguerite Lake 826S to Leming Lake 715S	7L74 Wolf Lake 822S to Primrose tap	
		7L87 Marguerite Lake 826S to Wolf Lake 822S	
A-2009-16	7L95 Leming Lake 715S to Makeses 889S	7L74 Wolf Lake 822S to Primrose tap	
A-2009-12	7L14 Vermilion 710S to Hill 751S	Vermilion 144-72-25kV 701T (Worst overload)	
A-2009-44		6L06 Vermilion 710S to Kitscoty 705S	
A-2009-25	Vermilion 144-25kV 703T	Vermilion 144-72-25kV 701T	
A-2009-4	749L Metiskow 648S to Edgerton 899S	Vermilion 144-72-25kV 701T	
A-2009-59	7L749 Lloydminster 716S to Edgerton 899S	Vermilion 144-72-25kV 701T	
A-2009-17	954L Hansman Lake 650S to Metiskow 648S	Hansman 240-138kV transformer	
A-2009-22	Metiskow 240-138kV transformer	Hansman 240-138kV transformer	
A-2009-24	Hansman 240-138kV transformer	Metiskow 240-138kV transformer	
A-2009-7	Battle River 144-72kV 701T		Voltage below 90% at Heisler 764S, Bigknife Creek 843S, Mannix Mine 765S and Bigfoot 756S.

NOTE: BLACK text indicates N-1 violations;
RED text indicates additional violations under Battle River N-G-1;
BLUE text indicates additional violations under Primrose N-G-1;
MAROON text indicates additional violations under Battle River or Primrose N-G-1.

COLD LAKE AREA



VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-2-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 10:38

By: [unreadable]
 Date: [unreadable]
 Project: [unreadable]
 Rev: [unreadable]

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2009-2-b



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2009-4-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 THU, MAR 26 2009 16:33


By: [unreadable]
 Date: [unreadable]
 Project: [unreadable]
 Revision: [unreadable]

VEGREVILLE AREA

WAINWRIGHT AREA



COLD LAKE AREA



VEGREVILLE AREA

LOYDMINSTER AREA


Figure A-2009-7-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 13:34

BY: VEGREVILLE
 DATE: 03/27/09
 PROJECT: SWINGBUS 1520

VEGREVILLE AREA

WAINWRIGHT AREA




TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 13:34

Figure A-2009-7-b

Bus - VOLTAGE (KV) [Color Legend]
 Branch - MVA (KV) [Color Legend]
 Equipment - MVA (KV) [Color Legend]
 [Color Legend]
 [Color Legend]

COLD LAKE AREA



VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2009-8-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 10:33

By: VEGREVILLE
 Date: 03/27/09
 Project: SWINGBUS 1520
 Revision: 1.0

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA




Figure A-2009-8-b





Figure A-2009-11-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 11:55

BY: POLINA DUTKA
 ENGINEER: M. BROWN
 CHECKED: M. BROWN
 REV: 0000-000000

VEGREVILLE AREA


WAINWRIGHT AREA



TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 12:00

Figure A-2009-11-b

Bus - VOLTAGE (KV) [Color key]
 Branch - CURRENT (A) [Color key]
 Equipment - LOSS (KW) [Color key]
 Loss - LOSS (KW) [Color key]
 Max - MAX (KV) [Color key]



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-12-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 13:07

By: [unreadable]
 Date: [unreadable]
 Project: [unreadable]

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2009-12-b

COLD LAKE AREA




VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-16-a

VEGREVILLE AREA

WAINWRIGHT AREA




TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 12:53

Figure A-2009-16-b

Bus - VOLTAGE (KV) [Color key for voltage levels]

COLD LAKE AREA



VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-17-a

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2009-17-b

COLD LAKE AREA



VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-20-a

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA




Figure A-2009-20-b

COLD LAKE AREA




Figure A-2009-22-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 13:30


BY: T. V. P. (TVP)
 DATE: 03/27/09
 PROJECT: SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 REV: 0001

VEGREVILLE AREA


WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



COLD LAKE AREA



VEGREVILLE AREA

LOYDMINSTER AREA


Figure A-2009-24-a

VEGREVILLE AREA


WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



COLD LAKE AREA



VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2009-25-a

VEGREVILLE AREA

WAINWRIGHT AREA




Figure A-2009-25-b

Bus - VOLTAGE (kV) [COLOR]
 Branch - MVA (kVA) [COLOR]
 Equipment - 1000 MVA [COLOR]
 MW - 10000 [COLOR]
 MVA - 10000 [COLOR]

VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA

BATTLE RIVER AREA

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
SWINGBUS 1520 FOR FC-2007-4:2010-04-02:18:44-1-1-0-0
FRI, MAR 27 2009 13:09


Figure A-2009-44-a

See Appendix 2009-44-a
Appendix 2009-44-a
Appendix 2009-44-a



VEGREVILLE AREA


WAINWRIGHT AREA



TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
SWINGBUS 1520 FOR FC-2007-4:2010-04-02:18:44-1-1-0-0
FRI, MAR 27 2009 13:09

Figure A-2009-44-b

Bus - VOLTAGE (KV) (KV)
Branch - MVA (MVA)
Equipment - (MVA)
Voltage - (KV)
MVA - (MVA)
MVA - (MVA)



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2009-45-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 10:44

By: [unreadable]
 Date: [unreadable]
 Project: [unreadable]
 Revision: [unreadable]





Figure A-2009-51-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 10:56

By: VIZAGE CONSULTANTS
 10000-100th Street, Edmonton, Alberta
 T5A 0K6
 Tel: 780-443-8888
 Fax: 780-443-8889
 Email: info@vzage.com

COLD LAKE AREA



LLOYDMINSTER AREA

Figure A-2009-52-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 12:04

By: TASC
 Date: 03/27/09
 Project: SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 File: TSMO-08-11-15:22:22

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA




Figure A-2009-52-b

COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2009-59-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 13:24

SW - SWINGBUS
 FC - FLOW CONTROL
 PV - PUMP VALVE
 TV - TRIP VALVE
 CV - CONTROL VALVE
 MV - MOTOR VALVE
 HV - HEAVY VALVE
 LV - LIGHT VALVE
 BV - BURNER VALVE
 DV - DRAIN VALVE
 EV - EXHAUST VALVE
 FV - FLOW VALVE
 GV - GATE VALVE
 IV - ISOLATION VALVE
 JV - JUNCTION VALVE
 KV - KEY VALVE
 LV - LOCK VALVE
 MV - MOTOR VALVE
 NV - NORM VALVE
 OV - OPEN VALVE
 PV - PUMP VALVE
 RV - RESET VALVE
 SV - STOP VALVE
 TV - TRIP VALVE
 UV - UNDER VALVE
 VV - VALVE VALVE
 WV - WASTE VALVE
 XV - X-RAY VALVE
 YV - YIELD VALVE
 ZV - ZONE VALVE




Figure A-2009-60-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02:18:44-1-1-0-0
 FRI, MAR 27 2009 12:08

BY: T. V. P. ENGINEERING
 10000 10000 10000 10000
 10000 10000 10000 10000
 10000 10000 10000 10000

VEGREVILLE AREA

WAINWRIGHT AREA




Figure A-2009-60-b

COLD LAKE AREA





Figure A-2009-65-a

TASMO MODEL; OUTPUT GENERATED 2008-08-11 15:22:22
 SWINGBUS 1520 FOR FC-2007-4-2010-04-02-18:44-1-1-0-0
 FRI, MAR 27 2009 10:24

By: [unreadable]
 Date: [unreadable]
 Project: [unreadable]
 Revision: [unreadable]

VEGREVILLE AREA

WAINWRIGHT AREA




2012 Load Flow Diagrams

2012 Summer Peak

2012 Winter Peak

Figure Number	2012sp Contingency	Overloaded Element	Transmission Voltage Violation
	NOTE: RED lettering indicates additional violation under N-G-1		
	NOTE: Italized print means new or changed from winter peak listing		
A-2012-08	Base Case	7L53 Bonnyville 700S to tap (PR-out)	
A-2012-10	7L50 Battle River 757S to Buffalo Creek 526S	Multiple line overloads including 9L27 Cordel 755S to Paintearth 863S and 7L53 Bonnyville (700S) to Irish Creek (706S)	Voltage drops more than 90% from nominal on the 144kV buses at Irish Creek 706S, Vermilion 710S, Vermilion tap sub.
VOLTAGE COLLAPSE	Bonnyville 144-72kV tie transformer	* Non-converged contingency due to voltage collapse on the 72kV network between Bonnyville and Vegreville affecting the towns of St. Paul 707S and	
A-2012-14	6L82 Bonnyville 700S to St. Paul 707S	6L79 Vegreville 709S to Willingdon 711S	(NOTE: With all 25kV capacitors on at St. Paul, no voltage violations.)
A-2012-12	6L79 Vegreville 709S to Willingdon 711S	6L82 Bonnyville 700S to St. Paul 707S Bonnyville 144-72kV tie transformer	Voltage below 90% at Willingdon 711S and borderline at St. Paul 707S with all 25kV capacitors on
A-2012-17	7L24 Bonnyville 700S to Grande Centre 846S	7L89 Marguerite Lake 826S to La Corey 721S	
A-2012-18	7L28 Ethel Lake 717S to Grande Centre 846S	7L89 Marguerite Lake 826S to La Corey 721S	
A-2012-20	7L66 Leming Lake 715S to Ethel Lake 717S	7L89 Marguerite Lake 826S to La Corey 721S and La Corey 721S to Bonnyville 700S	
A-2012-24	7L89 Marguerite Lake 826S to La Corey 721S	7L28 Ethel Lake 717S to Grande Centre 846S 7L66 Leming Lake 715S to Ethel Lake 717S	
A-2012-79	7L14 Vermilion 710S to Hill 751S	Vermilion 144-72kV Tie transformer 701T 6L06 Vermilion 710S to Kitscoty 705S	
A-2012-76	7L701 Battle River 757S to Strome 223S	7L89 Marguerite Lake 826S to La Corey 721S	
A-2012-16	749L Metiskow 648S to Edgerton 899S	7L14 Vermilion 710S to Hill 751S	
A-2012-70	9L27 Cordel 755S to Paintearth Creek 863S	7L53 Bonnyville 700S to Vermillion 710S	
A-2012-33	Vegreville 144-72kV tie transformer	6L82 Bonnyville 700S to St. Paul 707S Bonnyville 144-72kV tie transformer	Voltage drops more than 90% from nominal at at St. Paul 707S and Willingdon 711S

NOTE: BLACK text indicates N-1 violations;
RED text indicates additional violations under Battle River N-G-1;
BLUE text indicates additional violations under Primrose N-G-1;
MAROON text indicates additional violations under Battle River or Primrose N-G-1.



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2012-08-a

VEGREVILLE AREA

WAINWRIGHT AREA




Figure A-2012-08-b




Figure A-2012-10-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:08


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:07

Figure A-2012-10-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




Figure A-2012-12-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:12


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:11

Figure A-2012-12-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.100OV0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-14-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:14

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LUV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA




Figure A-2012-14-b





Figure A-2012-15-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:14

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LUV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:14

Figure A-2012-15-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2012-16-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:15

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:15

Figure A-2012-16-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




Figure A-2012-17-a

CENTRAL AREA STUDY
2012 SUMMER PEAK BASE CASE REVISION 7.2.1
WED, MAR 18 2009 18:18

Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0% RATE A
1.00KV 0.950UV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2012-17-b



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2012-18-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:18

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2012-18-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-20-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:20

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LUV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2012-20-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-24-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 WED, MAR 18 2009 18:24

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2012-24-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-70-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, MAR 20 2009 16:01

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <<69.000 <=138.000 <<240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2012-70-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-76-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, MAR 20 2009 16:09

Bus - VOLTAGE (KV/PU)
 Branch - MV% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.000V 0.950V
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2012-76-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-79-a

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, MAR 20 2009 16:11

Bus - VOLTAGE (KV/PU)
 Branch - MV% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE
 1.000V 0.950UV
 KV: >0.000 <=35.000 <<69.000 <=138.000 <<240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2012-79-b



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2012-33-a

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1
 THU, MAR 19 2009 11:30


Bus - VOLTAGE (KV/PU)
 Branch - MV/A% OF RATE B
 Equipment - MW/MVAR
 100.0% RATES
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
2012 WINTER PEAK BASE CASE REVISION 7.2.1
THU, MAR 19 2009 11:30

Figure A-2012-33-b

Bus - VOLTAGE (KV/PU)
Branch - MVA/% OF RATE B
Equipment - MW/MVAR
100.0% RATE B
1.1000V 0.950UV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017 Load Flow Diagrams

2017 Summer Peak

2017 Winter Peak

Figure Number	2017sp Contingency	Overloaded Element	Transmission Voltage Violation
NOTE: RED lettering indicates additional violation under N-G-1			
NOTE: Italized print means new or changed from winter peak listing.			
A-2017-13	Vegreville 144-72kV tie transformer	6L82 Bonnyville 700S to St. Paul 707S Bonnyville 144-72kV Tie Transformer	Voltage collapse (below 85%) at Willingdon 711S. Voltage below 90% at St. Paul 707S
A-2017-9	6L79 Vegreville 709S to Willingdon 711S	6L82 Bonnyville 700S to St. Paul 707S Bonnyville 144-72kV Tie Transformer	Voltage collapse (below 85%) at Willingdon 711S. Voltage below 90% at St. Paul 707S
A-2017-106	<i>7L24 Bonnyville 700S to Grande Centre 846S</i>	<i>7L89 Marguerite Lake 826S to La Corey 721S</i>	
A-2017-107	<i>7L28 Ethel Lake 717S to Grande Centre 846S</i>	<i>7L89 Marguerite Lake 826S to La Corey 721S and 7L89 Bonnyville 700S to La Corey 721S</i>	
A-2017-22	7L66 Leming Lake 715S to Ethel Lake 717S	7L89 Marguerite Lake 826S to La Corey 721S	
A-2017-27	7L89 Marguerite Lake 826S to La Corey 721S	7L28 Ethel Lake 717S to Grande Centre 846S 7L66 Leming Lake 715S to Ethel Lake 717S	
A-2017-95	<i>7L53 Bonnyville 700S to Irish Creek 706S</i>		<i>Voltage drops below 90% at Irish Creek 706S and Vermilion 710S. Borderline voltages at 90% for Vermilion tanned sub</i>
A-2017-12	Hill 144-72-25kV Tie Transformer		Voltage collapse (below 85%) at Kitscoty 705S
A-2017-91	<i>7L701 Battle River 757S to Strome 223S</i>		<i>Voltages below at 90% at Vegreville 709S and borderline at 90% for Kitscoty 705S and Hill 751S 72kV bus</i>
A-2017-19	<i>7L702 Battle River 757S to Hardisty 377S</i>	<i>Tucuman 240-138kV Tie Transformer</i>	
A-2017-171	<i>703L Metiskow 648S to Hardisty 377S (Primrose G out)</i>	<i>Tucuman 240-138kV Tie Transformer</i>	
A-2017-10	749L Metiskow 648S to Edgerton 899S		Voltages below 90% at Hill 751S (72kV) and Kitscoty 705S
A-2017-31	<i>Hansman Lake 240-138kV Tie Transformer</i>	<i>Metiskow 240-138kV Tie Transformer</i>	
A-2017-33	Metiskow 240-138kV Tie Transformer	Hansman Lake 240-138kV Tie Transformer	
A-2017-34	954L Metiskow 648S to Hansman Lake 650S	Hansman Lake 240-138kV Tie Transformer	
A-2017-98	<i>9L59 Cordel 755S to Halkirk</i>		<i>Voltage drops below 90% on 240kV at Battle River 757S</i>
A-2017-47	6L82 Bonnyville 700S to St. Paul 707S	6L79 Vegreville 709S to Willingdon 711S	(NOTE: With all 25kV capacitors on at St. Paul, no voltage violations.)

NOTE: For many 240kV contingencies (e.g. 9L20 Cordel to Nevis and Cordel to Halkirk, etc.) the future Hansman Lake Hansman Lake SVC is operating to prevent voltage collapse.

NOTE: BLACK text indicates N-1 violations;

RED text indicates additional violations under Battle River N-G-1;

BLUE text indicates additional violations under Primrose N-G-1;

MAROON text indicates additional violations under Battle River or Primrose N-G-1.




Figure A-2017-9-a

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
THU, MAR 19 2019 16:02

Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0% RATE A
1.100KV 0.950LV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA





Figure A-2017-9-b



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2017-10-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:03

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:03

Figure A-2017-10-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2017-12-a

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
THU, MAR 19 2009 16:12


Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0%RATE
1.1000V 0.9500V
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:13

Figure A-2017-12-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.100OV0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA

Figure A-2017-13-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2019 16:13


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500V
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:14

Figure A-2017-13-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000





Figure A-2017-19-a

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:18

Figure A-2017-19-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2017-22-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2019 16:27


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:27

Figure A-2017-22-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




Figure A-2017-27-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2019 16:31

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0%RATE
 1.00KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





Figure A-2017-27-b



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2017-31-a

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
THU, MAR 19 2009 16:35

Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0%RATE
1.1000V 0.9500V
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:36

Figure A-2017-31-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2017-33-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:37

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




Figure A-2017-33-b




Figure A-2017-34-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 16:38

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.100KV 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

BATTLE RIVER AREA

PROVOST AREA





Figure A-2017-34-b



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2017-91-a

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
SUN, MAR 22 2009 11:54

Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0%RATE
1.100KV 0.950LV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 11:54

Figure A-2017-91-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.1000V0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




Figure A-2017-95-a

VEGREVILLE AREA

WAINWRIGHT AREA




Figure A-2017-95-b




Figure A-2017-98-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 11:57


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0% RATE A
 1.1000V 0.9500V
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 11:57

Figure A-2017-98-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.100OV0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2017-106-a

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
SUN, MAR 22 2009 12:02


Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0% RATE A
1.100KV 0.950LV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
SUN, MAR 22 2009 12:02

Figure A-2017-106-b

Bus - VOLTAGE (KV/PU)
Branch - MVA% OF RATE A
Equipment - MW/MVAR
100.0%RATEA
1.100OV0.950UV
KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




Figure A-2017-107-a

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 12:03


Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0%RATE
 1.000V 0.950LV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 12:03

Figure A-2017-107-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.100OV0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

Figure A-2017-171-a

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 SUN, MAR 22 2009 13:06

Figure A-2017-171-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVAR
 100.0%RATEA
 1.100OV0.950UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000

COLD LAKE AREA



VEGREVILLE AREA

LLOYDMINSTER AREA


Figure A-2017-47-a

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, MAR 19 2009 17:59

Figure A-2017-47-b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/MVAR
 100.0% RATED
 1.1000V 0.9500UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000