

APPENDIX D

Steady State and Voltage Stability Analyses

1.0 Steady State Analysis

1.1 Category A and B Events Analysis

All three regional alternative option sets were tested under all Central East regions' Category B (N-1) contingencies as listed in Table 1 with generation dispatch scenario 3. (It should be noted that outages of load transformers at all substation were also investigated but are not listed in this Table.)

These three alternatives were also tested under the same Category B contingencies but with the critical generator out of service (Battle River unit 5), as well as both Primrose generators out of service (N-G-1) (Previous studies indicated the outage of Primrose generation also creates stress in that area.)

The load flow analysis revealed that there were neither voltage range violations nor thermal over loads for the category A (All elements in service) and B (N-1 and N-G-1) contingencies studied in the Central East region. The proposed alternatives thus met the Reliability Criteria. However, there were a total of three violations on customer owned facilities as listed below:

1. The customer owned line 7L105 (Mahihkan 837S to MahNo 909S) gets overloaded under summer peak and light load conditions in 2017). This customer has been informed about it.
2. The customer owned line 7L35 (Primrose tap to Primrose plant) will be overloaded under the following conditions: summer peak and light load conditions in 2017; loss of 7L87 line (Wolf Lake to Marguerite Lake) and Primrose's units in 2017 winter peak case.
3. The industrial load at Ethel Lake 717S will have to be curtailed if one of the dual 72/25 kV transformers (supplied via a single 144/72 kV tie transformer) goes out of service.
4. In all aforementioned circumstances the respective customer is responsible for mitigating the constraints

Table 1 Category B Contingency List

Category B Line and Tie Transformer Contingencies			
Faulted Element	To	From	Tapped sub
9L16	Cordel 755S	Tinchebray 972S	
9L953	Nilrem	Cordel 755S	
9L948	Paintearth Creek 863S	Hansman Lake 650S	
9L948	Hansman Lake 650S	Paintearth Creek 863S	
9L80	Battle River 757S	Cordel 755S	
9L79	Battle River 757S	Cordel 755S	
9L59	Cordel 755S	Tinchebray	
9L37	Whitefish Lake 825S	Marguerite Lake 826S	
9L36	Whitefish Lake 825S	Marguerite Lake 826S	
9L27	Cordel 755S	Paintearth Creek 25 kV	
9L20	Cordel 755S	Nevis 766S	
9Lnew	Hansman Lake 650S	Pemukan 932S	
954L	Metiskow 648S	Hansman Lake 650S	
953L	Nilrem	Hansman Lake 650S	
885L	Metiskow 648S	Hansman Lake 650S	
7newL	Wainwright 51S	Jarrow 252S	
7newL	Hardisty 377S	Nilrem	
7newL	Provost 545S	Hayter 277S	
7newL	Wainwright 51S	Edgerton 899S	
7L95	Mahkeses 889S	Leming Lake 715S	
7L92	Whitby Lake 819S	Vilna 777S	
7L92	Vegreville 709S	Vilna 777S	Watt Lake 956S (new Willingdon)
7L91	Marguerite Lake 826S	Leming Lake 715S	
7L89	Bonnyville 700S	La Corey 721S	
7L89	Marguerite Lake 826S	La Corey 721S	
7L87	Marguerite Lake 826S	Wolf Lake 822S	
7L86	Wolf Lake 822S	Foster Creek 877S	Tapped sub
7L83	Bourque 970S	Leming Lake 715S	
7L794	Whitby Lake 819S	Lac La Biche 157S	
7L77	Vegreville 709S	N. Holden 395S	
7L749	Lloydminster 716S	Edgerton 899S	Briker 880S

Table 1 Category B Contingency Listing (cont'd)

Category B Line and Tie Transformer Contingencies			
Faulted Element	To	From	Tapped sub
7L74	Wolf Lake 822S	Bourque 970S	Primrose 859S (two generators & plant)
7L70	Whitby Lake 819S	St. Paul 707S	
7L66	Leming Lake 715S	Ethel Lake 717S	
7L65	Vegreville 709S	Vermilion 710S	
7L53	Bonnyville 700S	Irish Creek 706S	Tapped sub
7L50	Battle River 757S	Buffalo Creek 526S	Jarrow 252S
7L42	Hill 751S	Lloydminster 716S	
7L28	Grande Centre 846S	Ethel Lake 717S	
7L24	Bonnyville 700S	Grande Centre 846S	Tapped sub
7L163	Marguerite Lake 826S	Bourque 970S	
7L160	Bourque 970S	Mahihkan 837S	
7L157	Bourque 970S	Mahihkan 837S	
7L146	Bonnyville 700S	Bourque 970S	
7L14	Vermilion 710S	Hill 751S	Kitscoty 705S
7L139	Bonnyville 700S	St. Paul 707S	
7L129	Vermilion 710S	Buffalo Creek 526S	Tapped sub
7L117	Vermilion 710S	Irish Creek 706S	
7L105	Mahihkan 837S	MahNo 909S	MahNo plant & 2 generators
7L701	Battle River 757S	Strome 223S	Heisler 764S
749L	Metiskow 648S	Killarney Lake 267S	
749L	Killarney Lake 267S	Edgerton 899S	
748L	Killarney Lake 267S	Hayter 277S	
715L	Hansman Lake 650S	Provost 545S	
704L	Wainwright 51S	Tucuman 478S	
704L	Hardisty 377S	Tucuman 478S	
	Nilrem	Tucuman 478S	
703L	Metiskow 648S	Hardisty 377S	several tapped subs
702L/7L702	Battle River 757S	Hardisty 377S	Sedgwick 137S
701L	Strome 223S	N Holden 395S	
6L08	Battle River 757S	Bigfoot 756S	
6L05	Battle River 757S	Bigknife Creek 843S	
6L02	Battle River 757S	Mannix Mine 765S	
61L	Wainwright 51S	Cochin	
174L	N Holden 395S	Bardo 197S	

Table 1 Category B Contingency Listing (cont'd)

Category B Line and Tie Transformer Contingencies			
Faulted Element	To	From	Tapped sub
Wainwright tie transformer	Wainwright 138kV	Wainwright 69 kV	
Vegreville tie transformer	Vegreville 144 kV	Vegreville 72 kV	
Nilrem tie transformer	Nilrem 240 kV	Nilrem 144 kV	
Nilrem tie transformer	Nilrem 240 kV	Nilrem 138 kV	
Metiskow tie transformer	Metiskow 240 kV	Metiskow 138 kV	
Hansman Lake tie transformer	Hansman Lake 240 kV	Hansman Lake 144 kV	
Hansman Lake tie transformer	Hansman Lake 240 kV	Hansman Lake 144 kV	
Marguerite Lake tie transformer	Marguerite Lake 240 kV	Marguerite Lake 144 kV	
Marguerite Lake tie transformer	Marguerite Lake 240 kV	Marguerite Lake 144 kV	
Heisler tie transformer	Heisler 144kV	Heisler 72kV	
Battle River tie transformer	Battle River 240 kV	Battle River 144 kV	
Battle River tie transformer	Battle River 144kV	Battle River 72 kV	
Battle River generator	Battle River 144kV	unit 3	
Battle River generator	Battle River 144kV	unit 4	
Battle River generator	Battle River 240 kV	unit 5	
Primrose generator	Primrose 144kV	G1 unit transformer	
Primrose generator	Primrose 144kV	G2 unit transformer	
MahNo generators	MahNo 144k V	G1 & G2 unit transformer	
Mahkeses generator	Mahkeses 138kV	G1 unit transformer	
Mahkeses generator	Mahkeses 144kV	G2 unit transformer	
Foster Creek generator	Foster Creek 144kV	G1 unit transformer	
Foster Creek generator	Foster Creek 144kV	G2 unit transformer	
Foster Creek generator	Foster Creek 144kV	G3 unit transformer	

Category A and B Events: Load Adequacy Power Flow Analysis for Alternatives 1, 2 and 3

There were no thermal overloads and voltage violations or system performance concerns for any regional Alternative under Category A or B contingencies. Thus the proposed regional alternatives met the requirements of AESO's Reliability Criteria.

This region is stressed the most when the critical generator is out of service (Battle River unit # 5). A set of sliders were chosen to illustrate system violations as discussed in Section 3 when the critical generator is out of service (see Figures referenced in Tables B-2012-1 to 3 and B-2017-1 to 3 Other sliders for Category B contingencies as listed in above Table 1 will be made available upon request.

Table B-2012-1 Summary of 2012 Summer Light Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out of Service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Contingency
2012SL-Alt 1-1.a 2012SL-Alt 1-1.b	2012SL-Alt 2-1.a 2012SL-Alt 2-1.b	2012SL-Alt 3-1.a 2012SL-Alt 3-1.b	Base Case - All Elements in Service
2012SL-Alt 1-2.a 2012SL-Alt 1-2.b	2012SL-Alt 2-2.a 2012SL-Alt 2-2.b		7L749 - Edgerton 899S to Lloydminster 716S -Briker 880S Tap
2012SL-Alt 1-3.a 2012SL-Alt 1-3.b	2012SL-Alt 2-3.a 2012SL-Alt 2-3.b	2012SL-Alt 3-2.a 2012SL-Alt 3-2.b	749L - Metiskow 648S to Killarney 267S*
2012SL-Alt 1-4.a 2012SL-Alt 1-4.b	2012SL-Alt 2-4.a 2012SL-Alt 2-4.b		715L Hansman Lake 650S to Provost 545S
2012SL-Alt 1-5.a 2012SL-Alt 1-5.b	2012SL-Alt 2-5.a 2012SL-Alt 2-5.b	2012SL-Alt 3-3.a 2012SL-Alt 3-3.b	748L - Killarney Lake 267S to Hayter 277S
2012SL-Alt 1-6.a 2012SL-Alt 1-6.b	2012SL-Alt 2-6.a 2012SL-Alt 2-6.b		749L - Edgerton 899S to Killarney Lake 267S

**Alternative 3 749L Contingency is from Metiskow to Edgerton with Killarney Lake and Hayter loads tapped off line*

Table B-2012-2 Summary of 2012 Summer Peak Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out Of Service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Contingency
2012SP-Alt 1-1.a 2012SP-Alt 1-1.b	2012SP-Alt 2-1.a 2012SP-Alt 2-1.b	2012SP-Alt 3-1.a 2012SP-Alt 3-1.b	Base Case - All Elements in Service
2012SP-Alt 1-2.a 2012SP-Alt 1-2.b	2012SP-Alt 2-2.a 2012SP-Alt 2-2.b	2012SP-Alt 3-2.a 2012SP-Alt 3-2.b	7L146 - Bonnyville 700S to Bourque 970S
2012SP-Alt 1-3.a 2012SP-Alt 1-3.b	2012SP-Alt 2-3.a 2012SP-Alt 2-3.b	2012SP-Alt 3-3.a 2012SP-Alt 3-3.b	7L87 - Marguerite Lake 826S to Wolf Lake 822S
2012SP-Alt 1-4.a 2012SP-Alt 1-4.b	2012SP-Alt 2-4.a 2012SP-Alt 2-4.b	2012SP-Alt 3-4.a 2012SP-Alt 3-4.b	7L66 - Leming Lake 715S to Ethel Lake 717S
2012SP-Alt 1-5.a 2012SP-Alt 1-5.b		2012SP-Alt 3-5.a 2012SP-Alt 3-5.b	7L53 - Bonnyville 700S to Irish Creek 706S
2012SP-Alt 1-6.a 2012SP-Alt 1-6.b	2012SP-Alt 2-5.a 2012SP-Alt 2-5.b	2012SP-Alt 3-6.a 2012SP-Alt 3-6.b	7L14 - Vermilion 710S to Hill 751S (Kitscoty 705S Tap)
2012SP-Alt 1-7.a 2012SP-Alt 1-7.b	2012SP-Alt 2-6.a 2012SP-Alt 2-6.b	2012SP-Alt 3-7.a 2012SP-Alt 3-7.b	7L89- Marguerite Lake 826S to Lacorey 721S
2012SP-Alt 1-8.a 2012SP-Alt 1-8.b	2012SP-Alt 2-7.a 2012SP-Alt 2-7.b	2012SP-Alt 3-8.a 2012SP-Alt 3-8.b	7L42 - Hill 751S to Lloydminster 716S
2012SP-Alt 1-9.a 2012SP-Alt 1-9.b	2012SP-Alt 2-8.a 2012SP-Alt 2-8.b		7L749 - Edgerton 899S to Lloydminster 716S (Briker 880S Tap)
2012SP-Alt 1-10.a 2012SP-Alt 1-10.b	2012SP-Alt 2-9.a 2012SP-Alt 2-9.b	2012SP-Alt 3-9.a 2012SP-Alt 3-9.b	7L50 - Battle River 757S to Buffalo Creek 526S (Jarrow 252S Tap)
2012SP-Alt 1-11.a 2012SP-Alt 1-11.b	2012SP-Alt 2-10.a 2012SP-Alt 2-10.b	2012SP-Alt 3-10.a 2012SP-Alt 3-10.b	7L701 - Battle River 757S to Strome 223S (Heisler 764S Tap)
2012SP-Alt 1-12.a 2012SP-Alt 1-12.b	2012SP-Alt 2-11.a 2012SP-Alt 2-11.b	2012SP-Alt 3-11.a 2012SP-Alt 3-11.b	749L - Metiskow 648S to Killarney 267S*
2012SP-Alt 1-13.a 2012SP-Alt 1-13.b	2012SP-Alt 2-12.a 2012SP-Alt 2-12.b		715L - Hansman Lake 650S to Provost 545S
2012SP-Alt 1-14.a 2012SP-Alt 1-14.b	2012SP-Alt 2-13.a 2012SP-Alt 2-13.b	2012SP-Alt 3-12.a 2012SP-Alt 3-12.b	9L20 - Cordel 755S to Nevis 766S
2012SP-Alt 1-15.a 2012SP-Alt 1-15.b	2012SP-Alt 2-14.a 2012SP-Alt 2-14.b	2012SP-Alt 3-13.a 2012SP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
2012SP-Alt 1-16.a 2012SP-Alt 1-16.b	2012SP-Alt 2-15.a 2012SP-Alt 2-15.b		749L - Edgerton 899S to Killarney Lake 267S
		2012SP-Alt 3-14.a 2012SP-Alt 3-14.b	Hansman Lake to Wind Collector Station
		2012SP-Alt 3-15.a 2012SP-Alt 3-15.b	749L - Edgerton 899S to Killarney Lake 267S

**Alternative 3 749L Contingency is from Metiskow to Edgerton with Killarney Lake and Hayter loads tapped off this line*

Table B-2012-3 Summary of 2012 Winter Peak Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out of Service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Description
2012WP-Alt 1-1.a 2012WP-Alt 1-1.b	2012WP-Alt 2-1.a 2012WP-Alt 2-1.b	2012WP-Alt 3-1.a 2012WP-Alt 3-1.b	Base Case - All Elements in Service
2012WP-Alt 1-2.a 2012WP-Alt 1-2.b	2012WP-Alt 2-2.a 2012WP-Alt 2-2.b	2012WP-Alt 3-2.a 2012WP-Alt 3-2.b	7L146 - Bonnyville 700S to Bourque 970S
2012WP-Alt 1-3.a 2012WP-Alt 1-3.b	2012WP-Alt 2-3.a 2012WP-Alt 2-3.b	2012WP-Alt 3-3.a 2012WP-Alt 3-3.b	7L87 -Marguerite Lake 826S to Wolf Lake 822S
2012WP-Alt 1-4.a 2012WP-Alt 1-4.b	2012WP-Alt 2-4.a 2012WP-Alt 2-4.b	2012WP-Alt 3-4.a 2012WP-Alt 3-4.b	7L66 - Leming Lake 715S to Ethel Lake 717S
2012WP-Alt 1-5.a 2012WP-Alt 1-5.b		2012WP-Alt 3-5.a 2012WP-Alt 3-5.b	7L53 - Bonnyville 700S to Irish Creek 706S
2012WP-Alt 1-6.a 2012WP-Alt 1-6.b	2012WP-Alt 2-5.a 2012WP-Alt 2-5.b	2012WP-Alt 3-6.a 2012WP-Alt 3-6.b	7L14 - Vermilion 710S to Hill 751S (Kitscoty 705S Tap)
2012WP-Alt 1-7.a 2012WP-Alt 1-7.b	2012WP-Alt 2-6.a 2012WP-Alt 2-6.b	2012WP-Alt 3-7.a 2012WP-Alt 3-7.b	7L89 - Marguerite Lake 826S to Lacorey 721S
2012WP-Alt 1-8.a 2012WP-Alt 1-8.b	2012WP-Alt 2-7.a 2012WP-Alt 2-7.b	2012WP-Alt 3-8.a 2012WP-Alt 3-8.b	7L42 - Hill 751S to Lloydminster 716S
2012WP-Alt 1-9.a 2012WP-Alt 1-9.b	2012WP-Alt 2-8.a 2012WP-Alt 2-8.b		7L749 - Edgerton 899S to Lloydminster 716S (Briker 880S Tap)
2012WP-Alt 1-10.a 2012WP-Alt 1-10.b	2012WP-Alt 2-9.a 2012WP-Alt 2-9.b	2012WP-Alt 3-9.a 2012WP-Alt 3-9.b	7L50 - Battle River 757S to Buffalo Creek 526S (Jarrow 252S Tap)
2012WP-Alt 1-11.a 2012WP-Alt 1-11.b	2012WP-Alt 2-10.a 2012WP-Alt 2-10.b	2012WP-Alt 3-10.a 2012WP-Alt 3-10.b	7L701 - Battle River 757S to Strome 223S (Heisler 764S Tap)
2012WP-Alt 1-12.a 2012WP-Alt 1-12.b	2012WP-Alt 2-11.a 2012WP-Alt 2-11.b	2012WP-Alt 3-11.a 2012WP-Alt 3-11.b	7L749 - Metiskow 648S to Killarney 267S
2012WP-Alt 1-13.a 2012WP-Alt 1-13.b	2012WP-Alt 2-12.a 2012WP-Alt 2-12.b	2012WP-Alt 3-12.a 2012WP-Alt 3-12.b	715L -Hansman Lake 650S to Provost 545S
2012WP-Alt 1-14.a 2012WP-Alt 1-14.b	2012WP-Alt 2-13.a 2012WP-Alt 2-13.b	2012WP-Alt 3-13.a 2012WP-Alt 3-13.b	9L20 - Cordel 755S to Nevis 766S
2012WP-Alt 1-15.a 2012WP-Alt 1-15.b	2012WP-Alt 2-14.a 2012WP-Alt 2-14.b		Battle River 144/72 kV Transformer 701T
2012WP-Alt 1-16.a 2012WP-Alt 1-16.b	2012WP-Alt 2-15.a 2012WP-Alt 2-15.b		749L -Edgerton 899S to Killarney Lake 267S
		2012WP-Alt 3-14.a 2012WP-Alt 3-14.b	Hansman Lake to Wind Collector Station
		2012WP-Alt 3-15.a 2012WP-Alt 3-15.b	749L - Edgerton 899S to Killarney Lake 267S

**Alternative 3 749L Contingency is from Metiskow to Edgerton with Killarney Lake and Hayter loads tapped off this line*

Table B-2017-1 Summary of 2017 Summer Light Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out of Service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Contingency
2017SL-Alt 1-1.a 2017SL-Alt 1-1.b	2017SL-Alt 2-1.a 2017SL-Alt 2-1.b	2017SL-Alt 3-1.a 2017SL-Alt 3-1.b	Base Case - All Elements in Service
2017SL-Alt 1-2.a 2017SL-Alt 1-2.b	2017SL-Alt 2-2.a 2017SL-Alt 2-2.b		7L749 - Edgerton 899S to Lloydminster 716S -Briker 880S Tap
2017SL-Alt 1-3.a 2017SL-Alt 1-3.b	2017SL-Alt 2-3.a 2017SL-Alt 2-3.b	2017SL-Alt 3-2.a 2017SL-Alt 3-2.b	749L - Metiskow 648S to Killarney 267S*
2017SL-Alt 1-4.a 2017SL-Alt 1-4.b	2017SL-Alt 2-4.a 2017SL-Alt 2-4.b		715L Hansman Lake 650S to Provost 545S
2017SL-Alt 1-5.a 2017SL-Alt 1-5.b	2017SL-Alt 2-5.a 2017SL-Alt 2-5.b	2017SL-Alt 3-3.a 2017SL-Alt 3-3.b	748L - Killarney Lake 267S to Hayter 277S
2017SL-Alt 1-6.a 2017SL-Alt 1-6.b	2017SL-Alt 2-6.a 2017SL-Alt 2-6.b		749L - Edgerton 899S to Killarney Lake 267S

**Alternative 3 749L Contingency is from Metiskow to Edgerton with Killarney Lake and Hayter loads tapped off this line*

Table B-2017-2 Summary of 2017 Summer Peak Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out of Service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Contingency
2017SP-Alt 1-1.a 2017SP-Alt 1-1.b	2017SP-Alt 2-1.a 2017SP-Alt 2-1.b	2017SP-Alt 3-1.a 2017SP-Alt 3-1.b	Base Case - All Elements in Service
2017SP-Alt 1-2.a 2017SP-Alt 1-2.b	2017SP-Alt 2-2.a 2017SP-Alt 2-2.b	2017SP-Alt 3-2.a 2017SP-Alt 3-2.b	7L146 - Bonnyville 700S to Bourque 970S
2017SP-Alt 1-3.a 2017SP-Alt 1-3.b	2017SP-Alt 2-3.a 2017SP-Alt 2-3.b	2017SP-Alt 3-3.a 2017SP-Alt 3-3.b	7L87 - Marguerite Lake 826S to Wolf Lake 822S
2017SP-Alt 1-4.a 2017SP-Alt 1-4.b	2017SP-Alt 2-4.a 2017SP-Alt 2-4.b	2017SP-Alt 3-4.a 2017SP-Alt 3-4.b	7L66 - Leming Lake 715S to Ethel Lake 717S
2017SP-Alt 1-5.a 2017SP-Alt 1-5.b		2017SP-Alt 3-5.a 2017SP-Alt 3-5.b	7L53 - Bonnyville 700S to Irish Creek 706S
2017SP-Alt 1-6.a 2017SP-Alt 1-6.b	2017SP-Alt 2-5.a 2017SP-Alt 2-5.b	2017SP-Alt 3-6.a 2017SP-Alt 3-6.b	7L14 - Vermilion 710S to Hill 751S (Kitscoty 705S Tap)
2017SP-Alt 1-7.a 2017SP-Alt 1-7.b	2017SP-Alt 2-6.a 2017SP-Alt 2-6.b	2017SP-Alt 3-7.a 2017SP-Alt 3-7.b	7L89- Marguerite Lake 826S to Lacorey 721S
2017SP-Alt 1-8.a 2017SP-Alt 1-8.b	2017SP-Alt 2-7.a 2017SP-Alt 2-7.b	2017SP-Alt 3-8.a 2017SP-Alt 3-8.b	7L42 - Hill 751S to Lloydminster 716S
2017SP-Alt 1-9.a 2017SP-Alt 1-9.b	2017SP-Alt 2-8.a 2017SP-Alt 2-8.b		7L749 - Edgerton 899S to Lloydminster 716S (Briker 880S Tap)
2017SP-Alt 1-10.a 2017SP-Alt 1-10.b	2017SP-Alt 2-9.a 2017SP-Alt 2-9.b	2017SP-Alt 3-9.a 2017SP-Alt 3-9.b	7L50 - Battle River 757S to Buffalo Creek 526S (Jarrow 252S Tap)
2017SP-Alt 1-11.a 2017SP-Alt 1-11.b	2017SP-Alt 2-10.a 2017SP-Alt 2-10.b	2017SP-Alt 3-10.a 2017SP-Alt 3-10.b	7L701 - Battle River 757S to Strome 223S (Heisler 764S Tap)
2017SP-Alt 1-12.a 2017SP-Alt 1-12.b	2017SP-Alt 2-11.a 2017SP-Alt 2-11.b	2017SP-Alt 3-11.a 2017SP-Alt 3-11.b	749L - Metiskow 648S to Killarney 267S*
2017SP-Alt 1-13.a 2017SP-Alt 1-13.b	2017SP-Alt 2-12.a 2017SP-Alt 2-12.b		715L - Hansman Lake 650S to Provost 545S
2017SP-Alt 1-14.a 2017SP-Alt 1-14.b	2017SP-Alt 2-13.a 2017SP-Alt 2-13.b	2017SP-Alt 3-12.a 2017SP-Alt 3-12.b	9L20 - Cordel 755S to Nevis 766S
2017SP-Alt 1-15.a 2017SP-Alt 1-15.b	2017SP-Alt 2-14.a 2017SP-Alt 2-14.b	2017SP-Alt 3-13.a 2017SP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
2017SP-Alt 1-16.a 2017SP-Alt 1-16.b	2017SP-Alt 2-15.a 2017SP-Alt 2-15.b		749L - Edgerton 899S to Killarney Lake 267S
	2017SP-Alt 2-16.a 2017SP-Alt 2-16.b		Vermilion 240/144 kV tie transformer
		2017SP-Alt 3-14.a 2017SP-Alt 3-14.b	Lloydminster to Wind Collector Station
		2017SP-Alt 3-15.a 2017SP-Alt 3-15.b	Hansman Lake to Wind Collector Station

**Alternative 3 749L Contingency is from Metiskow to Edgerton with Killarney Lake and Hayter loads tapped off this line*

Table B-2017-3 Summary of 2017 Winter Peak Base Case Sliders and Power Flow Analysis for Alternative 1 (Battle River Unit 5 Out of service)

Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Contingency
2017WP-Alt 1-1.a 2017WP-Alt 1-1.b	2017WP-Alt 2-1.a 2017WP-Alt 2-1.b	2017WP-Alt 3-1.a 2017WP-Alt 3-1.b	Base Case - All Elements in Service
2017WP-Alt 1-2.a 2017WP-Alt 1-2.b	2017WP-Alt 2-2.a 2017WP-Alt 2-2.b	2017WP-Alt 3-2.a 2017WP-Alt 3-2.b	7L146 - Bonnyville 700S to Bourque 970S
2017WP-Alt 1-3.a 2017WP-Alt 1-3.b	2017WP-Alt 2-3.a 2017WP-Alt 2-3.b	2017WP-Alt 3-3.a 2017WP-Alt 3-3.b	7L87 - Marguerite Lake 826S to Wolf Lake 822S
2017WP-Alt 1-4.a 2017WP-Alt 1-4.b	2017WP-Alt 2-4.a 2017WP-Alt 2-4.b	2017WP-Alt 3-4.a 2017WP-Alt 3-4.b	7L66 - Leming Lake 715S to Ethel Lake 717S
2017WP-Alt 1-5.a 2017WP-Alt 1-5.b		2017WP-Alt 3-5.a 2017WP-Alt 3-5.b	7L53 - Bonnyville 700S to Irish Creek 706S
2017WP-Alt 1-6.a 2017WP-Alt 1-6.b	2017WP-Alt 2-5.a 2017WP-Alt 2-5.b	2017WP-Alt 3-6.a 2017WP-Alt 3-6.b	7L14 - Vermilion 710S to Hill 751S (Kitscoty 705S Tap)
2017WP-Alt 1-7.a 2017WP-Alt 1-7.b	2017WP-Alt 2-6.a 2017WP-Alt 2-6.b	2017WP-Alt 3-7.a 2017WP-Alt 3-7.b	7L89- Marguerite Lake 826S to Lacorey 721S
2017WP-Alt 1-8.a 2017WP-Alt 1-8.b	2017WP-Alt 2-7.a 2017WP-Alt 2-7.b	2017WP-Alt 3-8.a 2017WP-Alt 3-8.b	7L42 - Hill 751S to Lloydminster 716S
2017WP-Alt 1-9.a 2017WP-Alt 1-9.b	2017WP-Alt 2-8.a 2017WP-Alt 2-8.b		7L749 - Edgerton 899S to Lloydminster 716S (Briker 880S Tap)
2017WP-Alt 1-10.a 2017WP-Alt 1-10.b	2017WP-Alt 2-9.a 2017WP-Alt 2-9.b	2017WP-Alt 3-9.a 2017WP-Alt 3-9.b	7L50 - Battle River 757S to Buffalo Creek 526S (Jarrow 252S Tap)
2017WP-Alt 1-11.a 2017WP-Alt 1-11.b	2017WP-Alt 2-10.a 2017WP-Alt 2-10.b	2017WP-Alt 3-10.a 2017WP-Alt 3-10.b	7L701 - Battle River 757S to Strome 223S (Heisler 764S Tap)
2017WP-Alt 1-12.a 2017WP-Alt 1-12.b	2017WP-Alt 2-11.a 2017WP-Alt 2-11.b	2017WP-Alt 3-11.a 2017WP-Alt 3-11.b	749L - Metiskow 648S to Killarney 267S*
2017WP-Alt 1-13.a 2017WP-Alt 1-13.b	2017WP-Alt 2-12.a 2017WP-Alt 2-12.b		715L - Hansman Lake 650S to Provost 545S
2017WP-Alt 1-14.a 2017WP-Alt 1-14.b	2017WP-Alt 2-13.a 2017WP-Alt 2-13.b	2017WP-Alt 3-12.a 2017WP-Alt 3-12.b	9L20 - Cordel 755S to Nevis 766S
2017WP-Alt 1-15.a 2017WP-Alt 1-15.b	2017WP-Alt 2-14.a 2017WP-Alt 2-14.b	2017WP-Alt 3-13.a 2017WP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
2017WP-Alt 1-16.a 2017WP-Alt 1-16.b	2017WP-Alt 2-15.a 2017WP-Alt 2-15.b		749L - Edgerton 899S to Killarney Lake 267S
	2017WP-Alt 2-16.a 2017WP-Alt 2-16.b		Vermilion 240/144 kV tie transformer
		2017WP-Alt 3-14.a 2017WP-Alt 3-14.b	Lloydminster to Wind Collector Station
		2017WP-Alt 3-15.a 2017WP-Alt 3-15.b	Hansman Lake to Wind Collector Station

1.2 Category C & D Contingency Analysis

A number of category C and D contingency events were analyzed as listed in Table 2. The worst Category C and D contingencies were selected for further analysis to illustrate the performance of the system under these conditions. Based on the results of N-1-1 analysis, the worst C contingencies were those which resulted in either thermal over loads or voltage violations, significant voltage deviation or non convergence of solution due to exceeding maximum no. of iterations.

The load flow results were shown for those contingencies that resulted in significant thermal overloads, voltage violations or the most voltage deviations. These are summarized in the Table 3 at the end of this section. Other slides will be made available upon request.

Table 2 Category C & D Contingency List

Faulted Element 1	To	From	Tapped Substation	Faulted Element 2	To	From	Tapped Substation
Category C3: N-1-1							
7L53	Bonnyville 700S	Irish Creek 706S	IPF Lindbergh	7L42	Hill 751S	Lloydminster 716S	
7L53	Bonnyville 700S	Irish Creek 706S	IPF Lindbergh	7L749	Lloydminster 716S	Edgerton 899S	Briker 880S
7L53	Bonnyville 700S	Irish Creek 706S	IPF Lindbergh	7L50	Battle River 757S	Buffalo Creek 526S	Jarrow 252S
7L53	Bonnyville 700S	Irish Creek 706S	IPF Lindbergh	7L14	Vermilion 710S	Kitscoty 705S	
7L53	Bonnyville 700S	Irish Creek 706S	IPF Lindbergh	7L14	Hill 751S	Kitscoty 705S	
7L50	Battle River 757S	Buffalo Creek 526S	Jarrow 252S	7L749	Lloydminster 716S	Edgerton 899S	Briker 880S
7L129	Vermilion 710S	Buffalo Creek 526S		7L749	Lloydminster 716S	Edgerton 899S	Briker 880S
703L	Metiskow 648S	Hardisty 377S	HRT Express, Hughenden, Sunken Lake	New	Hardisty 377S	Tucuman 478S	
703L	648S	Hardisty 377S	HRT Express, Hughenden, Sunken Lake	New	Nilrem	Hardisty 377S	
7L65	Vermilion 710S	Vegreville 709S		7L749	Lloydminster 716S	Edgerton 899S	Briker 880S
7L163	Marguerite Lake 826S	Bourque 970S		7L146	Bourque 970S	Bonnyville 700S	
7L87	Marguerite Lake 826S	Wolf Lake 822S		7L89	Marguerite Lake 826S	Lacorey 721S	
7L163	Marguerite Lake 826S	Bourque 970S		7L87	Marguerite Lake 826S	Wolf Lake 822S	
715L	Hansman Lake 650S	Provost 545S		749L	Metiskow 648S	Killarney Lake 267S	
7L89	Marguerite Lake 826S	La Corey 721S		7L66	Marguerite Lake 826S	Leming Lake 715S	

Table 2 Category C & D Contingency List (cont'd)

Faulted Element 1	To	From	Tapped Substation	Faulted Element 2	To	From	Tapped Substation
Category C5: N-2 Common Towers							
7L89	Marguerite Lake 826S	La Corey 721S		7L91	Marguerite Lake 826S	Leming Lake 715S	
7L66	Leming Lake 715S	Ethel Lake 717S		7L91	Marguerite Lake 826S	Leming Lake 715S	
9L27	Cordel 755S	Paintearth Creek 863S		9L953	Cordel 755S	Nilrem	
9L79	Battle River 757S	Cordel 755S		9L80	Battle River 757S	Cordel 755S	
9L36	Marguerite Lake 826S	Whitefish Lake 825S		9L37	Marguerite Lake 826S	Whitefish Lake 825S	-
New	Cordel 755S	Nilrem		New	Hansman Lake 650S	Nilrem	-

Faulted Element 1	To	From	Tapped Substation	Faulted Element 2	To	From	Tapped Substation
Category C7: Breaker Fail (only considered for non-radial buses with more than two transmission lines)							
7L83	Bourque	Leming Lake		7L157	Bourque	Mahihkan	
7L83	Bourque	Leming Lake		7L74	Bourque	Wolf Lake	Primrose plant (two Generators)
7L146	Bourque	Bonnyville		7L163	Bourque	Marguerite Lake	
7L146	Bourque	Bonnyville		7L160	Bourque	Mahihkan	
9L36	Marguerite Lake	Whitefish Lake		9L37	Marguerite Lake	Whitefish Lake	
7L89	Marguerite Lake	Bonnyville	La Corey	7L163	Marguerite Lake	Bourque	
7L91	Marguerite Lake	Leming Lake		7L163	Marguerite Lake	Bourque	
9L20	Cordel	Nevis		9L79	Cordel	Battle River	
9L27	Cordel	Paintearth		9L79	Cordel	Battle River	
9L27	Cordel	Paintearth		9L80	Cordel	Battle River	
9L59	Cordel	Halkirk		9L80	Cordel	Battle River	
9L59	Cordel	Halkirk		9L953	Cordel	Nilrem	
9L20	Cordel	Nevis		9L953	Cordel	Nilrem	

Table 2 Category C & D Contingency List (cont'd)

Substation Number	Substation Name	kV of Bus	Lines Taken Out of Service	Number of 240 kV Tie Transformers Taken out of service	Generators Lost
Category C7: Critical Area Bus Outages (only considered for substations with more than two transmission lines and radial bus configurations)					
715S	Leming Lake	144	7L83, 7L95, 7L91, 7L66	0	Both Mahkeses generators
700S	Bonnyville	144	7L24, 7L53, 7L89, 7L139		
710S	Vermilion	144	7L14, 7L65, 7L117, 7L129		
757S	Battle River	144	7L50, 7L701, 7L702		Battle River units 3 and 4
51S	Wainwright	138	New lines to Edgerton, Tucuman and Jarrow		
899S	Edgerton	138	7L749, 749L and new line to Wainwright		
648S	Metiskow	138	703L, 749L, 885L	1	
650S	Hansman Lake	138	715L, 885L, 7L224	1	
650S	Hansman Lake	240	954L, 948L, 953L	1	
478S	Tucuman	138	New lines to Nilrem, Hardisty and Wainwright		
	Nilrem	138	New lines to Tucuman and Hardisty	2	
	Nilrem	240	New lines to Cordel and Hansman Lake	2	
	Hardisty	138	702L, 703L, lines to IPL Hardisty, Tucuman and Nilrem		
Category D: Loss of a Switching Station or Generation plant					
755S	Cordel	240	9L80, 9L79, 9L20, 9L59, 9L27, 9L953		
826S	Marguerite Lake	240, 144	9L36, 9L37, 7L87, 7L89, 7L91, 7L163	2	
	Battle River Generating Station				Battle River units 3, 4 and 5

The following Table 3 presents the results of system performance for all three alternatives for the Category C & D contingencies analyzed.

Where an SPS scheme is tested, the thermal overloads and voltage violations in the Table are with the SPS scheme in place.

NOTE: In the following table, marginal voltages indicate buses where the steady state voltage is barely above the extreme minimum steady state voltage. LV means low voltages below the extreme minimum steady state voltages as per the AESO transmission reliability criteria. The results presented below did not take into account any generation re dispatch or load adjustments to show the impact of the N-1-1 contingencies. These infractions would be alleviated through Operational measures.

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives

Figure No.	Base Case	Faulted Lines	To	From	Overload Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: N-1-1								
2012 summer light base case violations - none								
2012 summer peak base case violations								
2012SP-Alt 1 BR #5 ON-2.a 2012SP-Alt 1 BR #5 ON-2.b	2012sp	7L53	Bonnyville 700S	Irish Creek 706S	7L65	102.2	Marginal voltage at Irish Creek	N/A
		7L50	Battle River 757S	Buffalo Creek 526S				
None - same as Alt 1 - no additional slider	2012sp	7L53	Bonnyville 700S	Irish Creek 706S	7L65	102.2	Marginal voltage at Irish Creek	N/A
		7L50	Battle River 757S	Buffalo Creek 526S				
2012SP-Alt 2 BR #5 ON-4.a 2012SP-Alt 2 BR #5 ON-4.b	2012sp	715L	Hansman Lake 650S	Provost 545S	None		LV at Provost and Hayter	N/A
		749L	Metiskow 648S	Killarney Lake 267S				
2012SP-Alt 3 BR #5 ON-3.a 2012SP-Alt 3 BR #5 ON-3.b	2012sp	7L53	Bonnyville 700S	Irish Creek 706S	7L749	103.6	LV at Irish Creek, Vermilion, Kitscoty and Vermilion tap sub.	N/A
		7L50	Battle River 757S	Buffalo Creek 526S				

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives (cont'd)

Figure No.	Base Case	Faulted Lines	To	From	Overload Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: N-1-1								
2012 winter peak base case violations								
2012WP-Alt 1 BR #5 ON-2.a 2012WP-Alt 1 BR #5 ON-2.b	2012wp	7L53	Bonnyville 700S	Irish Creek 706S	7L65	105.4	LV at Irish Creek, Vermilion and Vermilion tapped sub.	Curtail about 20 MW of load in and around Vermilion area.
		7L50	Battle River 757S	Buffalo Creek 526S				
No SPS: 2012SP-Alt 1 BR #5 ON-4.a 2012SP-Alt 1 BR #5 ON-4.b With SPS: 2012SP-Alt 1 BR #5 ON-5.a 2012SP-Alt 1 BR #5 ON-5.b	2012wp	7L749	Lloydminster 716S	Edgerton 899S	None		None	Curtail about 15 MW of load in and around Vermilion area. Requires an SPS (otherwise regional voltage collapse with 0 PV margin)
		7L50	Battle River 757S	Buffalo Creek 526S				
2012WP-Alt 2 BR #5 ON-2.a 2012WP-Alt 2 BR #5 ON-2.b	2012wp	7L53	Bonnyville 700S	Irish Creek 706S	7L65	105.7	LV at Irish Creek, Vermilion, and Vermilion tapped sub	Curtail about 20 MW of load in and around Vermilion area.
		7L50	Battle River 757S	Buffalo Creek 526S				
No SPS: 2012WP-Alt 2 BR #5 ON-3.a 2012WP-Alt 2 BR #5 ON-3.b	2012wp	7L749	Lloydminster 716S	Edgerton 899S	None		None	Curtail about 15 MW of load in and around Vermilion area. Requires an SPS (otherwise regional voltage collapse with 0 PV margin)
		7L50	Battle River 757S	Buffalo Creek 526S				
2012WP-Alt 3 BR #5 ON-2.a 2012WP-Alt 3 BR #5 ON-2.b	2012wp	7L53	Bonnyville 700S	Irish Creek 706S	7L65	122.2	Wide spread voltage collapse from Lloydminster through to Willingdon and Irish Creek.	Curtail about 20 MW of load in and around Vermilion area.
		7L50	Battle River 757S	Buffalo Creek 526S				
With SPS: 2012WP-Alt 3 BR #5 ON-7.a 2012WP-Alt 3 BR #5 ON-7.b	2012wp	7L749	Lloydminster 716S	Edgerton 899S	None		None	Curtail about 15 MW of load in and around Vermilion area. Requires an SPS (otherwise regional voltage collapse with 0 PV margin)
		7L50	Battle River 757S	Buffalo Creek 526S				

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives (cont'd)

Figure No.	Base Case	Faulted Lines	To	From	Overload Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: N-1-1								
2017 summer light base case violations - none								
2017 summer peak base case violations								
2017SP-Alt 1 BR #5 ON-2.a 2017SP-Alt 1 BR #5 ON-2.b	2017sp	7L53	Bonnyville 700S	Irish Creek 706S	None		LV at Irish Creek, Vermilion and Vermilion tapped sub	Curtail about 34 MW of load in and around Vermilion area.
		7L50	Battle River 757S	Buffalo Creek 526S				
No SPS: 2017SP-Alt 1 BR #5 ON-4.a 2017SP-Alt 1 BR #5 ON-4.b With SPS: 2017SP-Alt 1 BR #5 ON-5.a 2017SP-Alt 1 BR #5 ON-5.b	2017sp	7L749	Lloydminster 716S	Edgerton 899S	None		None	Curtail about 22 MW of load in and around Vermilion area. Requires an SPS (otherwise regional voltage collapse with 0 PV margin)
		7L50	Battle River 757S	Buffalo Creek 526S				
2017 winter peak base case violations								
2017WP-Alt 1 BR #5 ON-2.a 2017WP-Alt 1 BR #5 ON-2.b	2017wp	7L53	Bonnyville 700S	Irish Creek 706S	None		LV at Irish Creek, Vermilion, Vermilion tapped sub, Buffalo Creek and Kitscoty	Curtail about 34 MW of load in and around Vermilion area.
		7L50	Battle River 757S	Buffalo Creek 526S				
No SPS: 2017WP-Alt 1 BR #5 ON-4.a 2017WP-Alt 1 BR #5 ON-4.b With SPS: 2017WP-Alt 1 BR #5 ON-5.a 2017WP-Alt 1 BR #5 ON-5.b	2017wp	7L749	Lloydminster 716S	Edgerton 899S	None		None	Curtail about 22 MW of load in and around Vermilion area. Requires an SPS (otherwise regional voltage collapse with 0 PV margin)
		7L50	Battle River 757S	Buffalo Creek 526S				

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives (cont'd)

Figure No.	Base Case	Faulted Elements	To	From	Overloaded Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: N-2 Common Towers								
2012 summer base cases								
2012SP-Alt 1 BR #5 ON-7.a 2012SP-Alt 1 BR #5 ON-7.b	2012sp	9L27	Cordel 755S	Paintearth Creek 863S	7L702/702L	113/ 123.8	None	N/A
		9L953	Cordel 755S	Nilrem				
	2012sp	9L27	Cordel 755S	Paintearth Creek 863S	7L50	124.1	None	N/A
		9L953	Cordel 755S	Nilrem				
2012SP-Alt 2 BR #5 ON-5.a 2012SP-Alt 2 BR #5 ON-5.b	2012sp	9L27	Cordel 755S	Paintearth Creek 863S	702L	105.5	None	N/A
		9L953	Cordel 755S	Nilrem				
	2012sp	9L27	Cordel 755S	Paintearth Creek 863S	7L50	138/ 137 (252S to tap)	None	N/A
		9L953	Cordel 755S	Nilrem				
2012 winter base cases								
2012WP-Alt 1 BR #5 ON-7.a 2012WP-Alt 1 BR #5 ON-7.b	2012wp	9L27	Cordel 755S	Paintearth Creek 863S	7L50	106	None	N/A
		9L953	Cordel 755S	Nilrem				
2012WP-Alt 2 BR #5 ON-5.a 2012WP-Alt 2 BR #5 ON-5.b	2012wp	9L27	Cordel 755S	Paintearth Creek 863S	7L50	108.5/143 (252S to tap)	None	N/A
		9L953	Cordel 755S	Nilrem				
2012WP-Alt 3 BR #5 ON-13.a 2012WP-Alt 3 BR #5 ON-13.b	2012sp	9L953	Cordel 755S	Nilrem	703L	103.5 (377S to tap)	None	N/A
		953L	Hansman Lake 650S	Nilrem				
2017 summer base cases								
2017SP-Alt 1 BR #5 ON-7.a 2017SP-Alt 1 BR #5 ON-7.b	2017sp	9L27	Cordel 755S	Paintearth Creek 863S	7L702/702L	128.4 / 141.2	None	N/A
		9L953	Cordel 755S	Nilrem				
2017SP-Alt 2 BR #5 ON-5.a 2017SP-Alt 2 BR #5 ON-5.b	2017sp	9L27	Cordel 755S	Paintearth Creek 863S	7L702/702L	115.6/131	None	N/A
		9L953	Cordel 755S	Nilrem				
2017SP-Alt 3 BR #5 ON-7.a 2017SP-Alt 3 BR #5 ON-7.b	2017sp	9L27	Cordel 755S	Paintearth Creek 863S	7L702/702L	143.8/ 166.5	None	N/A
		9L953	Cordel 755S	Nilrem				
	2017sp	9L27	Cordel 755S	Paintearth Creek 863S	7L14	103.4	None	N/A
		9L953	Cordel 755S	Nilrem				
no slider	2017sp	9L79	Battle River 757S	Cordel 755S	702L	100.8	None	N/A
		9L80	Battle River 757S	Cordel 755S				
2017 winter base cases								
2017WP-Alt 3 BR #5 ON-7.a 2017WP-Alt 3 BR #5 ON-7.b	2017wp	9L27	Cordel 755S	Paintearth Creek 863S	7L702/702L	115/108	None	N/A
		9L953	Cordel 755S	Nilrem				

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives (cont'd)

Figure No.	Base Case	Bus or Substation Outage	Overloaded Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: Substation Bus Outages						
2012 summer base cases						
2012SP-Alt 1 BR #5 ON-6.a 2012SP-Alt 1 BR #5 ON-6.b	2012sp	Hansman Lake 650S - 240 kV bus	*703L	112.1 (377S to tap)	None	N/A
2012SP-Alt 2 BR #5 ON-9.a 2012SP-Alt 2 BR #5 ON-9.b	2012sp	Hansman Lake 650S - 240 kV bus	*703L	116.7 (377S to tap)	None	N/A
2012SP-Alt 2 BR #5 ON-11.a 2012SP-Alt 2 BR #5 ON-11.b	2012sp	Nilrem 240kV bus	7L50	102.8	None	N/A
2012 winter base cases						
2012WP-Alt 1 BR #5 ON-11.a 2012WP-Alt 1 BR #5 ON-11.b	2012wp	Hansman Lake 650S - 240 kV bus	*703L	110 (377S to tap)	None	N/A
2012WP-Alt 2 BR #5 ON-9.a 2012WP-Alt 2 BR #5 ON-9.b	2012wp	Hansman Lake 650S - 240 kV bus	*703L	115.6 (377S to tap)	None	N/A
2012WP-Alt 3 BR #5 ON-12.a 2012WP-Alt 3 BR #5 ON-12.b	2012wp	Hansman Lake 650S - 240 kV bus	*703L	None	None	N/A
2017 summer base cases						
NO SLIDER	2017sl	Nilrem 240kV bus	*703L	112.5 (377S to tap)	None	N/A
2017SP-Alt 1 BR #5 ON-13.a 2017SP-Alt 1 BR #5 ON-13.b	2017sp	Nilrem 240kV bus	702L	104	None	N/A
2017SP-Alt 3 BR #5 ON-14.a 2017SP-Alt 3 BR #5 ON-14.b	2017sp	Nilrem 240kV bus	7L702/ 702L	105/ 117	None	N/A
2017SP-Alt 1 BR #5 ON-11.a 2017SP-Alt 1 BR #5 ON-11.b	2017sp	Hansman Lake 650S - 240 kV bus	*703L	157(377S to tap)	None	N/A
2017SP-Alt 2 BR #5 ON-9.a 2017SP-Alt 2 BR #5 ON-9.b	2017sp	Hansman Lake 650S - 240 kV bus	*703L	148.8 (377S to tap)	None	N/A
2017SP-Alt 3 BR #5 ON-12.a 2017SP-Alt 3 BR #5 ON-12.b	2017sp	Hansman Lake 650S - 240 kV bus	*703L	176 (377S to tap)	None	N/A
2017 winter base cases						
2017WP-Alt 1 BR #5 ON-11.a 2017WP-Alt 1 BR #5 ON-11.b	2017wp	Hansman Lake 650S - 240 kV bus	*703L	168.9 (377S to tap)	None	N/A
2017WP-Alt 2 BR #5 ON-9.a 2017WP-Alt 2 BR #5 ON-9.b	2017wp	Hansman Lake 650S - 240 kV bus	*703L	161 (377S to tap)	None	N/A
2017WP-Alt 3 BR #5 ON-12.a 2017WP-Alt 3 BR #5 ON-12.b	2017wp	Hansman Lake 650S - 240 kV bus	*703L	191 (377S to tap)	None	N/A
2017WP-Alt 2 BR #5 ON-11.a 2017WP-Alt 2 BR #5 ON-11.b	2017wp	Nilrem 240kV bus	*703L	100 (377S to tap)	None	N/A
2017WP-Alt 3 BR #5 ON-14.a 2017WP-Alt 3 BR #5 ON-14.b	2017wp	Nilrem 240kV bus	*703L	132 (377S to tap)	None	N/A

* NOTE: Only the worst overloaded segment of 703L is shown in this table.

Table 3 Category C & D Contingencies: Summary of Results for All Alternatives (cont'd)

Figure No.	Base Case	Bus or Substation Outage	Overloaded Element	Percent Loading (%)	Other System Performance Concerns	SPS
Category C: Loss of Switching Station or Generation Plant						
2012 summer base cases						
2012SP-Alt 1 BR #5 ON-14.a 2012SP-Alt 1 BR #5 ON-14.b	2012sp	Cordel 240kV switching station	7L702	101.8	None	N/A
	2012sp	Cordel 240kV switching station	702L	114.3	None	N/A
	2012sp	Cordel 240kV switching station	7L50	108	None	N/A
2012SP-Alt 1 BR #5 ON-16.a 2012SP-Alt 1 BR #5 ON-16.b	2012sp	Battle River Generation Plant	174L	107.7	None	N/A
2012WP-Alt 1 BR #5 ON-16.a 2012WP-Alt 1 BR #5 ON-16.b	2012sp	Battle River Generation Plant	174L	107.7	None	N/A
2012SP-Alt 2 BR #5 ON-12.a 2012SP-Alt 2 BR #5 ON-12.b	2012sp	Cordel 240kV switching station	7L702	101.8	None	N/A
	2012sp	Cordel 240kV switching station	702L	114.3	None	N/A
	2012sp	Cordel 240kV switching station	7L50	118/147.5 (252S to tap)	None	N/A
2012 winter base cases						
2012WP-Alt 1 BR #5 ON-14.a 2012WP-Alt 1 BR #5 ON-14.b	2012wp	Cordel 240kV switching station	7L50	108 (252S to tap)	None	N/A
2012WP-Alt 2 BR #5 ON-12.a 2012WP-Alt 2 BR #5 ON-12.b	2012wp	Cordel 240kV switching station	7L50	130 (252S to tap)	None	N/A
2012WP-Alt 3 BR #5 ON-16.a 2012WP-Alt 3 BR #5 ON-16.b	2012wp	Cordel 240kV switching station	7L702	104	None	N/A
2017 summer base cases						
2017SP-Alt 1 BR #5 ON-14.a 2017SP-Alt 1 BR #5 ON-14.b	2017sp	Cordel 240kV switching station	7L702	105.6	None	N/A
	2017sp	Cordel 240kV switching station	702L	118.4	None	N/A
2017SP-Alt 2 BR #5 ON-12.a 2017SP-Alt 2 BR #5 ON-12.b	2017sp	Cordel 240kV switching station	702L	107	None	N/A
2017SP-Alt 3 BR #5 ON-15.a 2017SP-Alt 3 BR #5 ON-15.b	2017sp	Cordel 240kV switching station	7L14	103	None	N/A
	2017sp	Cordel 240kV switching station	7L702/702L	129.2/148.2	None	N/A
2017 winter base cases - no violations for these contingencies						

Table C-2012 List of Category C & D Sliders for 2012 Base Cases (Battle River Unit 5 ON)

Sliders for 2012 Summer and Winter Peak load conditions					
Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Faulted Elements	To	From
Category C: N-1-1					
2012SP-Alt 1 BR #5 ON-1.a 2012SP-Alt 1 BR #5 ON-1.b 2012WP-Alt 1 BR #5 ON-1.a 2012WP-Alt 1 BR #5 ON-1.b	2012SP-Alt 2 BR #5 ON-1.a 2012SP-Alt 2 BR #5 ON-1.b 2012WP-Alt 2 BR #5 ON-1.a 2012WP-Alt 2 BR #5 ON-1.b	2012SP-Alt 3 BR #5 ON-1.a 2012SP-Alt 3 BR #5 ON-1.b 2012WP-Alt 3 BR #5 ON-1.a 2012WP-Alt 3 BR #5 ON-1.b	Base Case		
		2012SP-Alt 3 BR #5 ON-2.a 2012SP-Alt 3 BR #5 ON-2.b 2012WP-Alt 3 BR #5 ON-2.a 2012WP-Alt 3 BR #5 ON-2.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L42	Hill 751S	Lloydminster 716S
2012SP-Alt 1 BR #5 ON-2.a 2012SP-Alt 1 BR #5 ON-2.b 2012WP-Alt 1 BR #5 ON-2.a 2012WP-Alt 1 BR #5 ON-2.b		2012SP-Alt 3 BR #5 ON-3.a 2012SP-Alt 3 BR #5 ON-3.b 2012WP-Alt 3 BR #5 ON-3.a 2012WP-Alt 3 BR #5 ON-3.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L50	Battle River 757S	Buffalo Creek 526S
		2012SP-Alt 3 BR #5 ON-4.a 2012SP-Alt 3 BR #5 ON-4.b 2012WP-Alt 3 BR #5 ON-4.a 2012WP-Alt 3 BR #5 ON-4.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L14	Vermilion 710S	Kitscoty 705S
2012SP-Alt 1 BR #5 ON-3.a 2012SP-Alt 1 BR #5 ON-3.b 2012WP-Alt 1 BR #5 ON-3.a 2012WP-Alt 1 BR #5 ON-3.b	2012SP-Alt 2 BR #5 ON-2.a 2012SP-Alt 2 BR #5 ON-2.b 2012WP-Alt 2 BR #5 ON-2.a 2012WP-Alt 2 BR #5 ON-2.b	2012SP-Alt 3 BR #5 ON-5.a 2012SP-Alt 3 BR #5 ON-5.b 2012WP-Alt 3 BR #5 ON-5.a 2012WP-Alt 3 BR #5 ON-5.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L14	Hill 751S	Kitscoty 705S
2012SP-Alt 1 BR #5 ON-4.a 2012SP-Alt 1 BR #5 ON-4.b 2012WP-Alt 1 BR #5 ON-4.a 2012WP-Alt 1 BR #5 ON-4.b	2012SP-Alt 2 BR #5 ON-3.a 2012SP-Alt 2 BR #5 ON-3.b 2012WP-Alt 2 BR #5 ON-3.a 2012WP-Alt 2 BR #5 ON-3.b	2012SP-Alt 3 BR #5 ON-6.a 2012SP-Alt 3 BR #5 ON-6.b 2012WP-Alt 3 BR #5 ON-6.a 2012WP-Alt 3 BR #5 ON-6.b	7L50	Battle River 757S	Buffalo Creek 526S
			7L749	Lloydminster 716S	Edgerton 899S
2012SP-Alt 1 BR #5 ON-5.a 2012SP-Alt 1 BR #5 ON-5.b 2012WP-Alt 1 BR #5 ON-5.a 2012WP-Alt 1 BR #5 ON-5.b		2012SP-Alt 3 BR #5 ON-7.a 2012SP-Alt 3 BR #5 ON-7.b 2012WP-Alt 3 BR #5 ON-7.a 2012WP-Alt 3 BR #5 ON-7.b	7L50	Battle River 757S	Buffalo Creek 526S
			7L749	Lloydminster 716S	Edgerton 899S
2012SP-Alt 1 BR #5 ON-6.a 2012SP-Alt 1 BR #5 ON-6.b 2012WP-Alt 1 BR #5 ON-6.a 2012WP-Alt 1 BR #5 ON-6.b	2012SP-Alt 2 BR #5 ON-4.a 2012SP-Alt 2 BR #5 ON-4.b 2012WP-Alt 2 BR #5 ON-4.a 2012WP-Alt 2 BR #5 ON-4.b		715L	Hansman Lake 650S	Provost 545S
			749L	Metiskow 648S	Killarney Lake 267S
	SPS Trip of load				
2012 Summer and Winter Sliders					
Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Faulted Elements	To	From
Category C: N-2 Common Towers					
2012SP-Alt 1 BR #5 ON-7.a 2012SP-Alt 1 BR #5 ON-7.b 2012WP-Alt 1 BR #5 ON-7.a 2012WP-Alt 1 BR #5 ON-7.b	2012SP-Alt 2 BR #5 ON-5.a 2012SP-Alt 2 BR #5 ON-5.b 2012WP-Alt 2 BR #5 ON-5.a 2012WP-Alt 2 BR #5 ON-5.b	2012SP-Alt 3 BR #5 ON-8.a 2012SP-Alt 3 BR #5 ON-8.b 2012WP-Alt 3 BR #5 ON-8.a 2012WP-Alt 3 BR #5 ON-8.b	9L27	Cordel 755S	Paintearth Creek 863S
			9L953	Cordel 755S	Nilrem

Table C-2012 List of Category C & D Sliders for 2012 Base Cases (Battle River Unit 5 ON) – cont'd

Sliders for 2012 Summer and Winter Peak load conditions					
Alternative 1 Figure No.	Alternative Figure 2 No.	Alternative Figure 3 No.	Substation Number	Substation Name	kV of Bus
			Category C: Critical Area Bus Outages (only considered for substations with more than two transmission lines and radial bus configurations)		
2012SP-Alt 1 BR #5 ON-8.a 2012SP-Alt 1 BR #5 ON-8.b 2012WP-Alt 1 BR #5 ON-8.a 2012WP-Alt 1 BR #5 ON-8.b	2012SP-Alt 2 BR #5 ON-6.a 2012SP-Alt 2 BR #5 ON-6.b 2012WP-Alt 2 BR #5 ON-6.a 2012WP-Alt 2 BR #5 ON-6.b	2012SP-Alt 3 BR #5 ON-9.a 2012SP-Alt 3 BR #5 ON-9.b 2012WP-Alt 3 BR #5 ON-9.a 2012WP-Alt 3 BR #5 ON-9.b	700S	Bonnyville	144
2012SP-Alt 1 BR #5 ON-9.a 2012SP-Alt 1 BR #5 ON-9.b 2012WP-Alt 1 BR #5 ON-9.a 2012WP-Alt 1 BR #5 ON-9.b	2012SP-Alt 2 BR #5 ON-7.a 2012SP-Alt 2 BR #5 ON-7.b 2012WP-Alt 2 BR #5 ON-7.a 2012WP-Alt 2 BR #5 ON-7.b	2012SP-Alt 3 BR #5 ON-10.a 2012SP-Alt 3 BR #5 ON-10.b 2012WP-Alt 3 BR #5 ON-10.a 2012WP-Alt 3 BR #5 ON-10.b	757S	Battle River	144
		2012SP-Alt 3 BR #5 ON-11.a 2012SP-Alt 3 BR #5 ON-11.b 2012WP-Alt 3 BR #5 ON-11.a 2012WP-Alt 3 BR #5 ON-11.b	648S	Metiskow	138
2012SP-Alt 1 BR #5 ON-10.a 2012SP-Alt 1 BR #5 ON-10.b 2012WP-Alt 1 BR #5 ON-10.a 2012WP-Alt 1 BR #5 ON-10.b	2012SP-Alt 2 BR #5 ON-8.a 2012SP-Alt 2 BR #5 ON-8.b 2012WP-Alt 2 BR #5 ON-8.a 2012WP-Alt 2 BR #5 ON-8.b	2012SP-Alt 3 BR #5 ON-12.a 2012SP-Alt 3 BR #5 ON-12.b 2012WP-Alt 3 BR #5 ON-12.a 2012WP-Alt 3 BR #5 ON-12.b	650S	Hansman Lake	138
2012SP-Alt 1 BR #5 ON-11.a 2012SP-Alt 1 BR #5 ON-11.b 2012WP-Alt 1 BR #5 ON-11.a 2012WP-Alt 1 BR #5 ON-11.b	2012SP-Alt 2 BR #5 ON-9.a 2012SP-Alt 2 BR #5 ON-9.b 2012WP-Alt 2 BR #5 ON-9.a 2012WP-Alt 2 BR #5 ON-9.b	2012SP-Alt 3 BR #5 ON-13.a 2012SP-Alt 3 BR #5 ON-13.b 2012WP-Alt 3 BR #5 ON-13.a 2012WP-Alt 3 BR #5 ON-13.b	650S	Hansman Lake	240
2012SP-Alt 1 BR #5 ON-12.a 2012SP-Alt 1 BR #5 ON-12.b 2012WP-Alt 1 BR #5 ON-12.a 2012WP-Alt 1 BR #5 ON-12.b	2012SP-Alt 2 BR #5 ON-10.a 2012SP-Alt 2 BR #5 ON-10.b 2012WP-Alt 2 BR #5 ON-10.a 2012WP-Alt 2 BR #5 ON-10.b	2012SP-Alt 3 BR #5 ON-14.a 2012SP-Alt 3 BR #5 ON-14.b 2012WP-Alt 3 BR #5 ON-14.a 2012WP-Alt 3 BR #5 ON-14.b	478S	Tucuman	138
2012SP-Alt 1 BR #5 ON-13.a 2012SP-Alt 1 BR #5 ON-13.b 2012WP-Alt 1 BR #5 ON-13.a 2012WP-Alt 1 BR #5 ON-13.b	2012SP-Alt 2 BR #5 ON-11.a 2012SP-Alt 2 BR #5 ON-11.b 2012WP-Alt 2 BR #5 ON-11.a 2012WP-Alt 2 BR #5 ON-11.b	2012SP-Alt 3 BR #5 ON-15.a 2012SP-Alt 3 BR #5 ON-15.b 2012WP-Alt 3 BR #5 ON-15.a 2012WP-Alt 3 BR #5 ON-15.b		Nilrem	240
			Category D: Loss of a Switching Station or generation plant		
2012SP-Alt 1 BR #5 ON-14.a 2012SP-Alt 1 BR #5 ON-14.b 2012WP-Alt 1 BR #5 ON-14.a 2012WP-Alt 1 BR #5 ON-14.b	2012SP-Alt 2 BR #5 ON-12.a 2012SP-Alt 2 BR #5 ON-12.b 2012WP-Alt 2 BR #5 ON-12.a 2012WP-Alt 2 BR #5 ON-12.b	2012SP-Alt 3 BR #5 ON-16.a 2012SP-Alt 3 BR #5 ON-16.b 2012WP-Alt 3 BR #5 ON-16.a 2012WP-Alt 3 BR #5 ON-16.b	755S	Cordel	240
2012SP-Alt 1 BR #5 ON-15.a 2012SP-Alt 1 BR #5 ON-15.b 2012WP-Alt 1 BR #5 ON-15.a 2012WP-Alt 1 BR #5 ON-15.b	2012SP-Alt 2 BR #5 ON-13.a 2012SP-Alt 2 BR #5 ON-13.b 2012WP-Alt 2 BR #5 ON-13.a 2012WP-Alt 2 BR #5 ON-13.b	2012SP-Alt 3 BR #5 ON-17.a 2012SP-Alt 3 BR #5 ON-17.b 2012WP-Alt 3 BR #5 ON-17.a 2012WP-Alt 3 BR #5 ON-17.b	826S	Marguerite Lake	240, 144
2012SP-Alt 1 BR #5 ON-16.a 2012SP-Alt 1 BR #5 ON-16.b 2012WP-Alt 1 BR #5 ON-16.a 2012WP-Alt 1 BR #5 ON-16.b	2012SP-Alt 2 BR #5 ON-14.a 2012SP-Alt 2 BR #5 ON-14.b 2012WP-Alt 2 BR #5 ON-14.a 2012WP-Alt 2 BR #5 ON-14.b	2012SP-Alt 3 BR #5 ON-18.a 2012SP-Alt 3 BR #5 ON-18.b 2012WP-Alt 3 BR #5 ON-18.a 2012WP-Alt 3 BR #5 ON-18.b		Battle River Generating Station	

Table C-2017 List of Category C & D Sliders for 2017 Base Cases (Battle River Unit 5 ON)

Sliders for 2017 Summer and Winter peak load conditions					
Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Faulted Elements	To	From
Category C: N-1-1					
2017SP-Alt 1 BR #5 ON-1.a 2017SP-Alt 1 BR #5 ON-1.b 2017WP-Alt 1 BR #5 ON-1.a 2017WP-Alt 1 BR #5 ON-1.b	2017SP-Alt 2 BR #5 ON-1.a 2017SP-Alt 2 BR #5 ON-1.b 2017WP-Alt 2 BR #5 ON-1.a 2017WP-Alt 2 BR #5 ON-1.b	2017SP-Alt 3 BR #5 ON-1.a 2017SP-Alt 3 BR #5 ON-1.b 2017WP-Alt 3 BR #5 ON-1.a 2017WP-Alt 3 BR #5 ON-1.b	Base Case		
		2017SP-Alt 3 BR #5 ON-2.a 2017SP-Alt 3 BR #5 ON-2.b 2017WP-Alt 3 BR #5 ON-2.a 2017WP-Alt 3 BR #5 ON-2.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L42	Hill 751S	Lloydminster 716S
2017SP-Alt 1 BR #5 ON-2.a 2017SP-Alt 1 BR #5 ON-2.b 2017WP-Alt 1 BR #5 ON-2.a 2017WP-Alt 1 BR #5 ON-2.b		2017SP-Alt 3 BR #5 ON-3.a 2017SP-Alt 3 BR #5 ON-3.b 2017WP-Alt 3 BR #5 ON-3.a 2017WP-Alt 3 BR #5 ON-3.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L50	Battle River 757S	Buffalo Creek 526S
		2017SP-Alt 3 BR #5 ON-4.a 2017SP-Alt 3 BR #5 ON-4.b 2017WP-Alt 3 BR #5 ON-4.a 2017WP-Alt 3 BR #5 ON-4.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L14	Vermilion 710S	Kitscoty 705S
2017SP-Alt 1 BR #5 ON-3.a 2017SP-Alt 1 BR #5 ON-3.b 2017WP-Alt 1 BR #5 ON-3.a 2017WP-Alt 1 BR #5 ON-3.b	2017SP-Alt 2 BR #5 ON-2.a 2017SP-Alt 2 BR #5 ON-2.b 2017WP-Alt 2 BR #5 ON-2.a 2017WP-Alt 2 BR #5 ON-2.b	2017SP-Alt 3 BR #5 ON-5.a 2017SP-Alt 3 BR #5 ON-5.b 2017WP-Alt 3 BR #5 ON-5.a 2017WP-Alt 3 BR #5 ON-5.b	7L53	Bonnyville 700S	Irish Creek 706S
			7L14	Hill 751S	Kitscoty 705S
2017SP-Alt 1 BR #5 ON-4.a 2017SP-Alt 1 BR #5 ON-4.b 2017WP-Alt 1 BR #5 ON-4.a 2017WP-Alt 1 BR #5 ON-4.b	2017SP-Alt 2 BR #5 ON-3.a 2017SP-Alt 2 BR #5 ON-3.b 2017WP-Alt 2 BR #5 ON-3.a 2017WP-Alt 2 BR #5 ON-3.b	2017SP-Alt 3 BR #5 ON-6.a 2017SP-Alt 3 BR #5 ON-6.b 2017WP-Alt 3 BR #5 ON-6.a 2017WP-Alt 3 BR #5 ON-6.b	7L50	Battle River 757S	Buffalo Creek 526S
			7L749	Lloydminster 716S	Edgerton 899S
2017SP-Alt 1 BR #5 ON-5.a 2017SP-Alt 1 BR #5 ON-5.b 2017WP-Alt 1 BR #5 ON-5.a 2017WP-Alt 1 BR #5 ON-5.b			7L50	Battle River 757S	Buffalo Creek 526S
			7L749	Lloydminster 716S	Edgerton 899S
2017SP-Alt 1 BR #5 ON-6.a 2017SP-Alt 1 BR #5 ON-6.b 2017WP-Alt 1 BR #5 ON-6.a 2017WP-Alt 1 BR #5 ON-6.b	2017SP-Alt 2 BR #5 ON-4.a 2017SP-Alt 2 BR #5 ON-4.b 2017WP-Alt 2 BR #5 ON-4.a 2017WP-Alt 2 BR #5 ON-4.b		715L	Hansman Lake 650S	Provost 545S
			749L	Metiskow 648S	Killarney Lake 267S
	SPS Trip of load				

Sliders for 2017 Summer and Winter peak load conditions					
Alternative 1 Figure No.	Alternative 2 Figure No.	Alternative 3 Figure No.	Faulted Elements	To	From
Category C: N-2 Common Towers					
2017SP-Alt 1 BR #5 ON-7.a 2017SP-Alt 1 BR #5 ON-7.b 2017WP-Alt 1 BR #5 ON-7.a 2017WP-Alt 1 BR #5 ON-7.b	2017SP-Alt 2 BR #5 ON-5.a 2017SP-Alt 2 BR #5 ON-5.b 2017WP-Alt 2 BR #5 ON-5.a 2017WP-Alt 2 BR #5 ON-5.b	2017SP-Alt 3 BR #5 ON-7.a 2017SP-Alt 3 BR #5 ON-7.b 2017WP-Alt 3 BR #5 ON-7.a 2017WP-Alt 3 BR #5 ON-7.b	9L27	Cordel 755S	Paintearth Creek 863S
			9L953	Cordel 755S	Nilrem

Table C-2017 List of Category C & D Sliders for 2017 Base Cases (Battle River Unit 5 ON) – cont'd

Sliders for 2017 Summer and Winter Load conditions					
Alternative 1 Figure No.	Alternative Figure 2 No.	Alternative Figure 3 No.	Substation Number	Substation Name	kV of Bus
			Category C: Critical Area Bus Outages (only considered for substations with more than two transmission lines and radial bus configurations)		
2017SP-Alt 1 BR #5 ON-8.a 2017SP-Alt 1 BR #5 ON-8.b 2017WP-Alt 1 BR #5 ON-8.a 2017WP-Alt 1 BR #5 ON-8.b	2017SP-Alt 2 BR #5 ON-6.a 2017SP-Alt 2 BR #5 ON-6.b 2017WP-Alt 2 BR #5 ON-6.a 2017WP-Alt 2 BR #5 ON-6.b	2017SP-Alt 3 BR #5 ON-8.a 2017SP-Alt 3 BR #5 ON-8.b 2017WP-Alt 3 BR #5 ON-8.a 2017WP-Alt 3 BR #5 ON-8.b	700S	Bonnyville	144
2017SP-Alt 1 BR #5 ON-9.a 2017SP-Alt 1 BR #5 ON-9.b 2017WP-Alt 1 BR #5 ON-9.a 2017WP-Alt 1 BR #5 ON-9.b	2017SP-Alt 2 BR #5 ON-7.a 2017SP-Alt 2 BR #5 ON-7.b 2017WP-Alt 2 BR #5 ON-7.a 2017WP-Alt 2 BR #5 ON-7.b	2017SP-Alt 3 BR #5 ON-9.a 2017SP-Alt 3 BR #5 ON-9.b 2017WP-Alt 3 BR #5 ON-9.a 2017WP-Alt 3 BR #5 ON-9.b	757S	Battle River	144
		2017SP-Alt 3 BR #5 ON-10.a 2017SP-Alt 3 BR #5 ON-10.b 2017WP-Alt 3 BR #5 ON-10.a 2017WP-Alt 3 BR #5 ON-10.b	648S	Metiskow	138
2017SP-Alt 1 BR #5 ON-10.a 2017SP-Alt 1 BR #5 ON-10.b 2017WP-Alt 1 BR #5 ON-10.a 2017WP-Alt 1 BR #5 ON-10.b	2017SP-Alt 2 BR #5 ON-8.a 2017SP-Alt 2 BR #5 ON-8.b 2017WP-Alt 2 BR #5 ON-8.a 2017WP-Alt 2 BR #5 ON-8.b	2017SP-Alt 3 BR #5 ON-11.a 2017SP-Alt 3 BR #5 ON-11.b 2017WP-Alt 3 BR #5 ON-11.a 2017WP-Alt 3 BR #5 ON-11.b	650S	Hansman Lake	138
2017SP-Alt 1 BR #5 ON-11.a 2017SP-Alt 1 BR #5 ON-11.b 2017WP-Alt 1 BR #5 ON-11.a 2017WP-Alt 1 BR #5 ON-11.b	2017SP-Alt 2 BR #5 ON-9.a 2017SP-Alt 2 BR #5 ON-9.b 2017WP-Alt 2 BR #5 ON-9.a 2017WP-Alt 2 BR #5 ON-9.b	2017SP-Alt 3 BR #5 ON-12.a 2017SP-Alt 3 BR #5 ON-12.b 2017WP-Alt 3 BR #5 ON-12.a 2017WP-Alt 3 BR #5 ON-12.b	650S	Hansman Lake	240
2017SP-Alt 1 BR #5 ON-12.a 2017SP-Alt 1 BR #5 ON-12.b 2017WP-Alt 1 BR #5 ON-12.a 2017WP-Alt 1 BR #5 ON-12.b	2017SP-Alt 2 BR #5 ON-10.a 2017SP-Alt 2 BR #5 ON-10.b 2017WP-Alt 2 BR #5 ON-10.a 2017WP-Alt 2 BR #5 ON-10.b	2017SP-Alt 3 BR #5 ON-13.a 2017SP-Alt 3 BR #5 ON-13.b 2017WP-Alt 3 BR #5 ON-13.a 2017WP-Alt 3 BR #5 ON-13.b	478S	Tucuman	138
2017SP-Alt 1 BR #5 ON-13.a 2017SP-Alt 1 BR #5 ON-13.b 2017WP-Alt 1 BR #5 ON-13.a 2017WP-Alt 1 BR #5 ON-13.b	2017SP-Alt 2 BR #5 ON-11.a 2017SP-Alt 2 BR #5 ON-11.b 2017WP-Alt 2 BR #5 ON-11.a 2017WP-Alt 2 BR #5 ON-11.b	2017SP-Alt 3 BR #5 ON-14.a 2017SP-Alt 3 BR #5 ON-14.b 2017WP-Alt 3 BR #5 ON-14.a 2017WP-Alt 3 BR #5 ON-14.b		Nilrem	240
			Category D: Loss of a Switching Station or generation plant		
2017SP-Alt 1 BR #5 ON-14.a 2017SP-Alt 1 BR #5 ON-14.b 2017WP-Alt 1 BR #5 ON-14.a 2017WP-Alt 1 BR #5 ON-14.b	2017SP-Alt 2 BR #5 ON-12.a 2017SP-Alt 2 BR #5 ON-12.b 2017WP-Alt 2 BR #5 ON-12.a 2017WP-Alt 2 BR #5 ON-12.b	2017SP-Alt 3 BR #5 ON-15.a 2017SP-Alt 3 BR #5 ON-15.b 2017WP-Alt 3 BR #5 ON-15.a 2017WP-Alt 3 BR #5 ON-15.b	755S	Cordel	240
2017SP-Alt 1 BR #5 ON-15.a 2017SP-Alt 1 BR #5 ON-15.b 2017WP-Alt 1 BR #5 ON-15.a 2017WP-Alt 1 BR #5 ON-15.b	2017SP-Alt 2 BR #5 ON-13.a 2017SP-Alt 2 BR #5 ON-13.b 2017WP-Alt 2 BR #5 ON-13.a 2017WP-Alt 2 BR #5 ON-13.b	2017SP-Alt 3 BR #5 ON-16.a 2017SP-Alt 3 BR #5 ON-16.b 2017WP-Alt 3 BR #5 ON-16.a 2017WP-Alt 3 BR #5 ON-16.b	826S	Marguerite Lake	240, 144
2017SP-Alt 1 BR #5 ON-16.a 2017SP-Alt 1 BR #5 ON-16.b 2017WP-Alt 1 BR #5 ON-16.a 2017WP-Alt 1 BR #5 ON-16.b	2017SP-Alt 2 BR #5 ON-14.a 2017SP-Alt 2 BR #5 ON-14.b 2017WP-Alt 2 BR #5 ON-14.a 2017WP-Alt 2 BR #5 ON-14.b	2017SP-Alt 3 BR #5 ON-17.a 2017SP-Alt 3 BR #5 ON-17.b 2017WP-Alt 3 BR #5 ON-17.a 2017WP-Alt 3 BR #5 ON-17.b		Battle River Generating Station	

2.0 Voltage Stability Criteria Analysis

Prior to proceeding with voltage stability analysis, the regional source and load (sink) areas must be defined. As mentioned in Section 6 of the need identification document, generation support from outside the Central East region comes mainly from Red Deer (area 35), Sheerness (area 43) and Wabamun (area 40) areas. These were used as the source subsystems throughout this analysis.

The load area for this analysis was the entire regional load which includes all the buses in the Lloydminster (area 13), Cold Lake (area 28), Wainwright (area 32), Alliance (area 36), Provost (area 37) and Vegreville (area 56) areas.

In the 2012 winter peak load case, the base load used was 1142 MW while in the 2017 winter peak load case, the base load used was 1307.3 MW. The incremental transfers under Category B contingencies (105% of base load) for 2012 and 2017 are 57.1 MW and 65.4 MW respectively. Similarly the incremental transfer for Category C contingencies (102.5% of base load) are 28.6 MW and 32.7 MW respectively and are applied in the PV and QV analysis

2.1 Power Voltage (P-V) Margin

The three proposed alternatives met the WECC voltage stability criteria for all Category B contingencies listed in Table 1.

A summary of the P-V analysis for the worst Category C & D contingencies is presented in the following Tables.

The worst category C contingency was found to be the loss of 7L50 (Battle River to Buffalo Creek) combined with loss of 7L749 (Edgerton to Lloydminster). Under such an event, the Vermilion area would experience voltage collapse unless a special protection scheme for load curtailment is strategically located in that area. This type of Category C event met the AESO Voltage Stability by curtailing load after the occurrence of first contingency. In real time Operations, this is not feasible and hence an automatic Special Protection Scheme (SPS) with back-up UVLS scheme needs to be devised to ensure the security of supplying the regional load.

Table PV-2012 Summary of 2012 PV Margin (MW)

(As per criteria, minimum incremental transfer required is 102.5% or >28.6 MW with BR5 On and >0 with BR5 OFF)

		2012wp					
Category C & D Event		Alternative 1		Alternative 2		Alternative 3	
Line 1	Line 2	BR5 ON	BR5 OFF	BR5 ON	BR5 OFF	BR5 ON	BR5 OFF
Base Case		280	280	280	280	280	280
7L53	7L42	280	256.25	280	280	216.88	182.5
7L53	7L749	191.25	162.5	225.63	191.25	116.88	96.25
7L53	7L50	115.63	90	101.25	78.13	32.5	15.63
7L50	7L749	83.75	80.63	83.13	80	84.38	81.25
7L129	7L749	243.75	238.13	243.13	236.88	245.63	241.25
7L65	7L749	254.38	226.88	280	254.38	196.25	178.13
715L	749L	86.88	60	45	21.25		
9L36	9L37	279.38	263.13	279.38	262.5	272.5	257.5
9L953	953L	280	280	280	280	280	241.25
Bonnyville 144kV Bus		280	280	280	280	280	277.5
Battle River 144kV Bus		280	280	280	266.25	280	227.5
Marguerite Substation		246.25	229.38	245.63	228.75	238.75	223.75

Yellow highlight is worst area contingency and PV margin indicated is with SPS

Blue Font = Contingency has same PV margin as base case.

Table PV-2017 Summary of 2017 PV Margin (MW)

(As per criteria, minimum incremental transfer required is 102.5% or >32.7 MW with BR5 On and >0 with BR5 OFF)

		2017wp					
Category C & D Event		Alternative 1		Alternative 2		Alternative 3	
Line 1	Line 2	BR5 ON	BR5 OFF	BR5 ON	BR5 OFF	BR5 ON	BR5 OFF
Base Case		320	320	320	320	320	320
7L53	7L42	320	270.63	320	320	138.13	87.5
7L53	7L749	217.5	169.38	320	320	320	320
7L53	7L50	73.75	55	320	320	320	320
7L50	7L749	34.38	36.25	320	320	320	320
7L129	7L749	237.5	234.38	320	320	320	320
7L65	7L749	288.75	250.63	320	320	320	320
715L	749L	81.25	39.38	103.13	89.38	320	320
9L27	9L953	320	320	320	320	289.38	319.38
9L36	9L37	161.88	150	209.38	198.13	184.38	175.63
9L953	953L	188.75	145.63	269.38	253.13	125.63	98.75
Edgerton 138 kV bus		320	315	320	320	320	320
Hansman Lake 240 kV Bus		242.5	145	301.88	169.38	168.13	71.88
Nilrem 240 kV Bus		191.25	147.5	225.63	181.88	126.88	100.63
Marguerite Substation		135.63	124.38	185.63	174.38	158.75	150.63

Yellow highlight is worst area contingency and PV margin indicated is with SPS

Blue Font = Contingency has same PV margin as base case.

Figure PV-2012-1 Worst Category C & D Contingencies – all generators on

PV Analysis: 2012 Winter Peak - Alternative 1 (BR5 ON)
At Bus: 144 kV Vermilion 710S




Figure PV-2012-2 Worst Category C & D Contingencies –critical generator OFF

PV Analysis: 2012 Winter Peak-Alternative 1 (BR 5 OFF)
At Bus: 144 kV Vermilion 710S




Figure PV-2017-1 Worst Category C & D Contingencies –all generators on





Figure PV-2017-2 Worst Category C & D Contingencies –critical generator OFF



2.2 Reactive Power (Q-V) Margin

2.2.1 Category B Contingencies

Low voltages were observed in the Vermilion area under several Category B N-1 and N-G-1 contingencies and Var support is required to improve the voltage profile.

The worst voltage violations occur on three substation buses: Vermilion 144kV, Irish Creek 144 kV and the Vermilion tapped substation 144kV bus. Since Vermilion is strongly connected to other sources and also a load centre, a properly sized capacitor bank at this location will help boost local the voltage profile. Hence the Vermilion substation was chosen for installing a capacitor bank.

The following Q-V curves show Var requirements at the three substation 144kV buses for the worst Category B contingencies with and without the critical generator, Battle River unit 5, in service.

Figure QV-2012-B1 Worst Category B Contingencies for Voltage Violations (all generation ON)




Figure QV-2012-B2 Worst Category B Contingencies for Voltage Violations—BR #5 OFF




Figure QV-2017-B1 Worst Category B Contingencies for Voltage Violations (all generation ON)





Figure QV-2017-B2 Worst Category B Contingencies for Voltage Violations-BR #5 OFF



Engineering judgment coupled with the above results concluded that a 25 MVAR capacitor bank would be sufficient to maintain the 144kV voltages above the extreme minimum during the worst contingencies. It was also determined that the worst category B contingency for further testing was with the 7L50 contingency with Battle River unit #5 out of service.

The Q-V analysis was repeated with a 25 MVAR capacitor bank at Vermilion to ensure that the preferred Alternative 1 has sufficient reactive power reserve.


All the Q-V curves show that under the worst Category B contingency conditions, the system has adequate voltage stability margin and also confirms the adequacy of the proposed reactive power support at all affected area buses.

Table QV Worst Category B Contingency: Summary of Q-V Analysis Results

Figure	Base Case	Worst Case Scenario	144kV Bus	Performance Level A	Performance Level C	Level C within 50% Level A
				Maximum Reactive Margin (100 % of base load) (MVar)	Maximum Reactive Margin 105% of base load) (MVar)	Met WECC voltage stability criteria
2012-QV-1	2012wp	Base Case with 7L50 out	Vermilion	-38.13	-36.91	Yes
		7L50 + BR5 off	Vermilion	-29.86	-28.29	Yes
2012-QV-2		Base Case with 7L50 out	Vermilion Tapped Substation	-24.88	-23.9	Yes
		7L50 + BR5 off	Vermilion Tapped Substation	-19.12	-17.74	Yes
2012-QV-3		Base Case with 7L50 out	Irish Creek	-35.13	-33.95	Yes
		7L50 + BR5 off	Irish Creek	-28.37	-26.75	Yes
2017-QV-1	2017wp	Base Case with 7L50 out	Vermilion	-33.79	-33.03	Yes
		7L50 + BR5 off	Vermilion	-30.66	-28.38	Yes
2017-QV-2		Base Case with 7L50 out	Vermilion Tapped Substation	-21.74	-21.13	Yes
		7L50 + BR5 off	Vermilion Tapped Substation	-18.7	-16.94	Yes
2017-QV-3		Base Case with 7L50 out	Irish Creek	-35.75	-34.88	Yes
		7L50 + BR5 off	Irish Creek	-31.89	-29.77	Yes

Figure 2012-QV-1 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2012 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVar Cap at Vermilion
At Bus: 144kV Vermilion 710S**



**QV Curves: 2012 Winter Peak Alternative 1 with BR5 OFF + 144kV 25 MVar Cap at Vermilion
Worst Category B At Bus: 144kV Vermilion 710S**





Figure 2012-QV-2 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2012 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVar Cap at Vermilion
At Bus: 144kV Vermilion Tapped Substation**



**QV Curves: 2012 Winter Peak Alternative 1 with BR5 OFF + 144kV 25 MVar Cap at Vermilion
Worst Category B At Bus: 144kV Vermilion Tapped Substation**





Figure 2012-QV-3 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2012 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVar Cap at Vermilion
At Bus: 144kV Irish Creek 706S**



**QV Curves: 2012 Winter Peak Alternative 1 with BR5 OFF + 144kV 25 MVar Cap at Vermilion
Worst Category B At Bus: 144kV Irish Creek 706S**





Figure 2017-QV-1 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2017 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVA Cap at Vermilion
At Bus: 144kV Vermilion 710S**



**QV Curves: 2017 Winter Peak Alternative 1 with BR5 OFF + 144kV 25MVA Cap at Vermilion
Worst Category B At Bus: 144kV Vermilion 710S**





Figure 2017-QV-2 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2017 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVA Cap at Vermilion
At Bus: 144kV Vermilion Tapped Substation**



**QV Curves: 2017 Winter Peak Alternative 1 with BR5 OFF + 144kV 25MVA Cap at Vermilion
Worst Category B At Bus: 144kV Vermilion Tapped Substation**






Figure 2017-QV-3 Load Adequacy with 7L50 Battle River to Buffalo Creek out

**QV Curves: 2017 Winter Peak Alternative 1 with 7L50 out + 144kV 25 MVA Cap at Vermilion
At Bus: 144kV Irish Creek 706S**



**QV Curves: 2017 Winter Peak Alternative 1 with BR5 OFF + 144kV 25MVA Cap at Vermilion
Worst Category B At Bus: 144kV Irish Creek 706S**



2.2.1 Category C Contingencies: Q-V Margin

For Alternative 1 and as identified under the steady state analysis in section 1.2 as well as in the P-V analysis under section 2.1 of this Appendix, two Category C contingencies cause voltage concerns. These include:

- Loss of 7L50 and 7L749 (SPS to curtail a minimum of 15 MW load in area)
- Loss of 7L50 and 7L53

Of these, only the first event causes regional voltage concerns without an SPS scheme in place. The second event has localized voltage issues which need to be managed. It is left to Operational group to determine the under voltage load shedding (UVLS) requirements for the second contingency.

The following figure is shown for the worst Category C N-1-1 event which is the combined loss of 7L50 from Battle River to Buffalo Creek with the loss of 7L749 from Edgerton to Lloydminster. In order to maintain adequate margin over 20 MW of load should be curtailed by 2017. See Table QV-C for stability margin details.

Figure QV-2012-C Category C event : 7L50 and 7L749 outage at Vermilion 710S 144kV bus




Table QV-C Worst N-1-1 Contingencies: Load Curtailment to maintain MVar Margin

		Performance Level A		Performance Level C		Level C within 50% Level A
Base Case	Most VAr Deficient Bus	Worst Case Scenario	Maximum Reactive Margin (100 % of base load) (MVar)	Combination of two elements	Maximum Reactive Margin (100 % of base load) (MVar)	Met WECC voltage stability criteria
2012wp	Vermilion Tapped Substation	Base Case with 7L50 out	-24.88	7L50 + 7L749 out	8.8	No
				7L50 + 7L749 + 15 MW SPS	-14.23	Yes
	Irish Creek	Base Case with 7L50 out	-35.13	7L50 + 7L53	3.9	No
				7L50 + 7L53 + 15 MW SPS	-6.28	No
			7L50 + 7L53 + 20 MW SPS	-18.55	Yes	
2017wp	Vermilion Tapped Substation	Base Case with 7L50 out	-21.74	7L50 + 7L749 + 15 MW SPS	-0.79	No
				7L50 + 7L749 + 22 MW SPS	-13.25	Yes
	Irish Creek	Base Case with 7L50 out	-35.75	7L50 + 7L53 + 20 MW SPS	-15.98	No
				7L50 + 7L53 + 34 MW SPS	-19.43	Yes

Contingencies

Category A, B, C & D

Contingency Matrix Cont List

Count= 406 x 2 = 812

Contingency Number	Category	Description	2012 Alt 1 WP	2012 Alt 1 SP	2012 Alt 1 SL	2017 Alt 1 WP	2017 Alt 1 SP	2017 Alt 1 SL	2012 Alt 2 WP	2012 Alt 2 SP	2012 Alt 2 SL	2017 Alt 2 WP	2017 Alt 2 SP	2017 Alt 2 SL	2012 Alt 3 WP	2012 Alt 3 SP	2012 Alt 3 SL	2017 Alt 3 WP	2017 Alt 3 SP	2017 Alt 3 SL	2012 Alt 1 WP BR #5 ON	2012 Alt 1 SP BR #5 ON	2017 Alt 1 WP BR #5 ON	2017 Alt 1 SP BR #5 ON	2012 Alt 2 WP BR #5 ON	2012 Alt 2 SP BR #5 ON	2017 Alt 2 WP BR #5 ON	2017 Alt 2 SP BR #5 ON	2012 Alt 3 WP BR #5 ON	2012 Alt 3 SP BR #5 ON	2017 Alt 3 WP BR #5 ON	2017 Alt 3 SP BR #5 ON			
D1-00	A	Base Case	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-01	B	Bonnyville 700S to Bourque 970S (7L146)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-02	B	Marguerite Lake 826S to Wolf Lake 822S (7L87)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-03	B	Leming Lake 715S to Ethel Lake 717S (7L66)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-04	B	Bonnyville 700S to Irish Creek 706S (7L53)	X	X		X	X								X	X		X	X																
D1-05	B	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap	X	X		X	X		X	X		X	X		X	X		X	X																
D1-06	B	Marguerite Lake 826S to LaCorey 721S (7L89)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-07	B	Hill 751S to Loyminster 716S (7L42)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-08	B	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X														
D1-09	B	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap	X	X		X	X		X	X		X	X		X	X		X	X																
D1-10	B	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap	X	X		X	X		X	X		X	X		X	X		X	X																
D1-11	B	Metiskow 648S to Killarney 267S (7L749)	X	X	X	X	X	X	X	X	X	X	X	X																					
D1-11b	B	Metiskow 648S to Edgerton 899S Killarney TP (7L749)													X	X	X	X	X	X															
D1-12	B	Hansman Lake 650S to Provost 545S (715L)	X	X	X	X	X	X	X	X	X	X	X	X																					
D1-13	B	Killarney Lake 267S to Hayter 277S (748L)			X			X			X			X			X																		
D1-14	B	Cordel 755S to Nevis 766S (9L20)	X	X		X	X		X	X		X	X		X	X		X	X																
D1-15	B	Battle River 144/72 kV Transformer 701T	X	X		X	X		X	X		X	X		X	X		X	X																
D1-16	B	Edgerton 899S to Killarney Lake 267S (749L)	X	X	X	X	X	X	X	X	X	X	X	X																					
D1-17	B	Vermilion 240/144 kV Transformer										X	X																						
D1-18	B	Loyminster to Wind Farm													X	X		X	X																
D1-19	B	Hansman Lake 650S to Wind Farm													X	X		X	X																

Contingency Matrix Cont List

Count= 406 x 2 = 812

Contingency Number	Category	Description	2012 Alt 1 WP	2012 Alt 1 SP	2012 Alt 1 SL	2017 Alt 1 WP	2017 Alt 1 SP	2017 Alt 1 SL	2012 Alt 2 WP	2012 Alt 2 SP	2012 Alt 2 SL	2017 Alt 2 WP	2017 Alt 2 SP	2017 Alt 2 SL	2012 Alt 3 WP	2012 Alt 3 SP	2012 Alt 3 SL	2017 Alt 3 WP	2017 Alt 3 SP	2017 Alt 3 SL	2012 Alt 1 WP BR #5	2012 Alt 1 SP BR #5	2012 Alt 1 WP BR #5	2012 Alt 1 SP BR #5	2012 Alt 2 WP BR #5	2012 Alt 2 SP BR #5	2012 Alt 2 WP BR #5	2012 Alt 2 SP BR #5	2017 Alt 2 WP BR #5	2017 Alt 2 SP BR #5	2012 Alt 3 WP BR #5	2012 Alt 3 SP BR #5	2017 Alt 3 WP BR #5	2017 Alt 3 SP BR #5				
D1-20	C	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)																																	X	X	X	X
D1-21	C	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarow 252S Tap																				X	X	X	X										X	X	X	X
D1-22	C	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap																																	X	X	X	X
D1-23	C	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-24	C	Battle River 757S to Buffalo Creek 526S (7L50) Jarow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-24b	C	Battle River 757S to Buffalo Creek 526S (7L50) Jarow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap																					X	X	X	X										X	X	
D1-25	C	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)																					X	X	X	X	X	X	X	X								
D1-26	D	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-27	D	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-28	D	Battle River 757S																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-29	C	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)																																	X	X	X	X
D1-30	D	Hansman Lake (650S) 138 kV																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-31	D	Hansman Lake (650S) 240 kV																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-32	D	Tucuman (478S) 138 kV																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-33	D	Nilrem 240 kV																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-34	D	Cordel 240 kV																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-35	D	Marguerite Lake (826S)																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
D1-36	D	Battle River Generating Station 3-4-5																					X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	

2012 Power Flow Plots

**Alternatives 1, 2 & 3
Battle River Unit # 5 OFF**

Case Summary Page 2012 Alt 1 WP		
Contingency Number	Fig #	Description
D1-00	2012WP-Alt 1-1.a	Base Case
D1-00	2012WP-Alt 1-1.b	Base Case
D1-01	2012WP-Alt 1-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012WP-Alt 1-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012WP-Alt 1-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012WP-Alt 1-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012WP-Alt 1-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012WP-Alt 1-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2012WP-Alt 1-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2012WP-Alt 1-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2012WP-Alt 1-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012WP-Alt 1-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012WP-Alt 1-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012WP-Alt 1-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012WP-Alt 1-8.a	Hill 751S to Loyminster 716S (7L42)
D1-07	2012WP-Alt 1-8.b	Hill 751S to Loyminster 716S (7L42)
D1-08	2012WP-Alt 1-9.a	Edgerton 899S to Loyminster 716S (7L749) Briker 880S Tap
D1-08	2012WP-Alt 1-9.b	Edgerton 899S to Loyminster 716S (7L749) Briker 880S Tap
D1-09	2012WP-Alt 1-10.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012WP-Alt 1-10.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012WP-Alt 1-11.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012WP-Alt 1-11.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2012WP-Alt 1-12.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2012WP-Alt 1-12.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2012WP-Alt 1-13.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2012WP-Alt 1-13.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2012WP-Alt 1-14.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012WP-Alt 1-14.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012WP-Alt 1-15.a	Battle River 144/72 kV Transformer 701T
D1-15	2012WP-Alt 1-15.b	Battle River 144/72 kV Transformer 701T
D1-16	2012WP-Alt 1-16.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2012WP-Alt 1-16.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2012 Alt 1 SP

Contingency Number	Fig #	Description
D1-00	2012SP-Alt 1-1.a	Base Case
D1-00	2012SP-Alt 1-1.b	Base Case
D1-01	2012SP-Alt 1-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012SP-Alt 1-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012SP-Alt 1-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012SP-Alt 1-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012SP-Alt 1-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012SP-Alt 1-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2012SP-Alt 1-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2012SP-Alt 1-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2012SP-Alt 1-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012SP-Alt 1-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012SP-Alt 1-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012SP-Alt 1-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012SP-Alt 1-8.a	Hill 751S to Loyminster 716S (7L42)
D1-07	2012SP-Alt 1-8.b	Hill 751S to Loyminster 716S (7L42)
D1-08	2012SP-Alt 1-9.a	Edgerton 899S to Loyminster 716S (7L749) Briker 880S Tap
D1-08	2012SP-Alt 1-9.b	Edgerton 899S to Loyminster 716S (7L749) Briker 880S Tap
D1-09	2012SP-Alt 1-10.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012SP-Alt 1-10.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012SP-Alt 1-11.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012SP-Alt 1-11.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2012SP-Alt 1-12.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2012SP-Alt 1-12.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2012SP-Alt 1-13.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2012SP-Alt 1-13.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2012SP-Alt 1-14.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012SP-Alt 1-14.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012SP-Alt 1-15.a	Battle River 144/72 kV Transformer 701T
D1-15	2012SP-Alt 1-15.b	Battle River 144/72 kV Transformer 701T
D1-16	2012SP-Alt 1-16.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2012SP-Alt 1-16.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2012 Alt 1 SL

Contingency Number	Fig #	Description
D1-00	2012SL-Alt 1-1.a	Base Case
D1-00	2012SL-Alt 1-1.b	Base Case
D1-08	2012SL-Alt 1-2.a	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-08	2012SL-Alt 1-2.b	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-11	2012SL-Alt 1-3.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2012SL-Alt 1-3.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2012SL-Alt 1-4.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2012SL-Alt 1-4.b	Hansman Lake 650S to Provost 545S (715L)
D1-13	2012SL-Alt 1-5.a	Killarney Lake 267S to Hayter 277S (748L)
D1-13	2012SL-Alt 1-5.b	Killarney Lake 267S to Hayter 277S (748L)
D1-16	2012SL-Alt 1-6.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2012SL-Alt 1-6.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2012 Alt 2 WP

Contingency Number	Fig #	Description
D1-00	2012WP-Alt 2-1.a	Base Case
D1-00	2012WP-Alt 2-1.b	Base Case
D1-01	2012WP-Alt 2-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012WP-Alt 2-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012WP-Alt 2-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012WP-Alt 2-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012WP-Alt 2-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012WP-Alt 2-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-05	2012WP-Alt 2-5.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012WP-Alt 2-5.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012WP-Alt 2-6.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012WP-Alt 2-6.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012WP-Alt 2-7.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2012WP-Alt 2-7.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2012WP-Alt 2-8.a	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-08	2012WP-Alt 2-8.b	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-09	2012WP-Alt 2-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012WP-Alt 2-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012WP-Alt 2-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012WP-Alt 2-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2012WP-Alt 2-11.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2012WP-Alt 2-11.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2012WP-Alt 2-12.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2012WP-Alt 2-12.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2012WP-Alt 2-13.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012WP-Alt 2-13.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012WP-Alt 2-14.a	Battle River 144/72 kV Transformer 701T
D1-15	2012WP-Alt 2-14.b	Battle River 144/72 kV Transformer 701T
D1-16	2012WP-Alt 2-15.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2012WP-Alt 2-15.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2012 Alt 2 SP


Contingency Number	Fig #	Description
D1-00	2012SP-Alt 2-1.a	Base Case
D1-00	2012SP-Alt 2-1.b	Base Case
D1-01	2012SP-Alt 2-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012SP-Alt 2-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012SP-Alt 2-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012SP-Alt 2-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012SP-Alt 2-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012SP-Alt 2-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-05	2012SP-Alt 2-5.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012SP-Alt 2-5.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012SP-Alt 2-6.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012SP-Alt 2-6.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012SP-Alt 2-7.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2012SP-Alt 2-7.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2012SP-Alt 2-8.a	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-08	2012SP-Alt 2-8.b	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-09	2012SP-Alt 2-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012SP-Alt 2-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012SP-Alt 2-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012SP-Alt 2-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2012SP-Alt 2-11.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2012SP-Alt 2-11.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2012SP-Alt 2-12.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2012SP-Alt 2-12.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2012SP-Alt 2-13.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012SP-Alt 2-13.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012SP-Alt 2-14.a	Battle River 144/72 kV Transformer 701T
D1-15	2012SP-Alt 2-14.b	Battle River 144/72 kV Transformer 701T
D1-16	2012SP-Alt 2-15.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2012SP-Alt 2-15.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2012 Alt 3 WP

Contingency Number	Fig #	Description
D1-00	2012WP-Alt 3-1.a	Base Case
D1-00	2012WP-Alt 3-1.b	Base Case
D1-01	2012WP-Alt 3-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012WP-Alt 3-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012WP-Alt 3-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012WP-Alt 3-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012WP-Alt 3-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012WP-Alt 3-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2012WP-Alt 3-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2012WP-Alt 3-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2012WP-Alt 3-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012WP-Alt 3-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012WP-Alt 3-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012WP-Alt 3-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012WP-Alt 3-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2012WP-Alt 3-8.b	Hill 751S to Loydminster 716S (7L42)
D1-09	2012WP-Alt 3-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012WP-Alt 3-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012WP-Alt 3-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012WP-Alt 3-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11b	2012WP-Alt 3-11.a	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-11b	2012WP-Alt 3-11.b	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-14	2012WP-Alt 3-12.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012WP-Alt 3-12.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012WP-Alt 3-13.a	Battle River 144/72 kV Transformer 701T
D1-15	2012WP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
D1-18	2012WP-Alt 3-14.a	Loydminster to Wind Farm
D1-18	2012WP-Alt 3-14.b	Loydminster to Wind Farm
D1-19	2012WP-Alt 3-15.a	Hansman Lake 650S to Wind Farm
D1-19	2012WP-Alt 3-15.b	Hansman Lake 650S to Wind Farm

Case Summary Page 2012 Alt 3 SP

Contingency Number	Fig #	Description
D1-00	2012SP-Alt 3-1.a	Base Case
D1-00	2012SP-Alt 3-1.b	Base Case
D1-01	2012SP-Alt 3-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2012SP-Alt 3-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2012SP-Alt 3-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2012SP-Alt 3-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2012SP-Alt 3-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2012SP-Alt 3-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2012SP-Alt 3-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2012SP-Alt 3-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2012SP-Alt 3-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2012SP-Alt 3-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2012SP-Alt 3-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2012SP-Alt 3-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2012SP-Alt 3-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2012SP-Alt 3-8.b	Hill 751S to Loydminster 716S (7L42)
D1-09	2012SP-Alt 3-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2012SP-Alt 3-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2012SP-Alt 3-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2012SP-Alt 3-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11b	2012SP-Alt 3-11.a	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-11b	2012SP-Alt 3-11.b	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-14	2012SP-Alt 3-12.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2012SP-Alt 3-12.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2012SP-Alt 3-13.a	Battle River 144/72 kV Transformer 701T
D1-15	2012SP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
D1-18	2012SP-Alt 3-14.a	Loydminster to Wind Farm
D1-18	2012SP-Alt 3-14.b	Loydminster to Wind Farm
D1-19	2012SP-Alt 3-15.a	Hansman Lake 650S to Wind Farm
D1-19	2012SP-Alt 3-15.b	Hansman Lake 650S to Wind Farm



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-00

2012WP-Alt 1-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-00

2012WP-Alt 1-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.0900V, 0.9200V
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 - LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-01

2012WP-Alt 1-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-01

2012WP-Alt 1-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-02


2012WP-Alt 1-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-03

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-03

2012WP-Alt 1-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:50
 D1-04

2012WP-Alt 1-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-05

2012WP-Alt 1-6.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-05

2012WP-Alt 1-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-06


2012WP-Alt 1-7.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-07

2012WP-Alt 1-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-08

2012WP-Alt 1-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-08

2012WP-Alt 1-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V, 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-09


2012WP-Alt 1-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0%RATEB
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-10

2012WP-Alt 1-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-10


2012WP-Alt 1-11.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V, 0.920UV
 kV: >0.000<=35.000<=69.000<=138.000<=240.000



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-12

2012WP-AIt 1-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:51
 D1-12

2012WP-Alt 1-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:52
 D1-14

2012WP-Alt 1-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 12:52
 D1-15

2012WP-AIt 1-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:52
 D1-15

2012WP-AIt 1-15.b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V, 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 12:52
 D1-16

2012WP-Alt 1-16.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 12:52
 D1-16

2012WP-AIt 1-16.b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA


LOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:42
 D1-00

2012SP-Alt 1-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA


VEGREVILLE AREA


LOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:42
 D1-01

2012SP-Alt 1-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:42
 D1-02

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


2012SP-Alt 1-3.a



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-02

2012SP-Alt 1-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-03

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 1-4.a







CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-04

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-05


2012SP-Alt 1-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-06

2012SP-Alt 1-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:120kV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
2012 SUMMER PEAK BASE CASE REVISION 7.2.1
FRI, APR 30 2010 16:43
D1-06

2012SP-Alt 1-7.b

Bus - VOLTAGE (kV/PU)
Branch - MVA% OF RATE A
Equipment - MW/Mvar
100.0% RATE A
1.090OV 0.920UV
kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-07

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-08

2012SP-Alt 1-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-08

2012SP-Alt 1-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-09


2012SP-Alt 1-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:43
 D1-10

2012SP-Alt 1-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-10

2012SP-AIt 1-11.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-11

2012SP-Alt 1-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0-000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-12

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 1-13.a

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-12

2012SP-Alt 1-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-14


2012SP-Alt 1-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 1-15.a

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA


LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:44
 D1-16

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
FRI, APR 30 2010 12:56
D1-00


2012SL-Alt 1-1.a

Bus - VOLTAGE (kV/PU)
Branch - MVA/% OF RATE A
Equipment - MW/Mvar
100.0% RATE A
1.1200V 0.940UV
kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 12:56
 D1-11


2012SL-Alt 1-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 12:57
 D1-13


2012SL-Alt 1-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 12:57
 D1-16

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=135.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 12:57
 D1-16

2012SL-Alt 1-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-00

2012WP-Alt 2-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-00

2012WP-Alt 2-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-01

2012WP-Alt 2-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-01

2012WP-Alt 2-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-02

2012WP-Alt 2-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-02

2012WP-Alt 2-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-03

2012WP-Alt 2-4.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-03

2012WP-Alt 2-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-05


2012WP-Alt 2-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-06


2012WP-Alt 2-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA





VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-07

2012WP-Alt 2-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 THU, APR 08 2010 15:03
 D1-08


2012WP-Alt 2-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-09

2012WP-Alt 2-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-09

2012WP-AIt 2-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-10

2012WP-Alt 2-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-10

2012WP-Alt 2-10.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-11

2012WP-Alt 2-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-11

2012WP-Alt 2-11.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000=<35.000 <69.000 <138.000 <240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-12


2012WP-Alt 2-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-14

2012WP-Alt 2-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-14

2012WP-Alt 2-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-15

2012WP-Alt 2-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA

BATTLE RIVER AREA

PROVOST AREA

BATTLE RIVER AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 15:04
 D1-16


2012WP-Alt 2-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-00


2012SP-Alt 2-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2011 15:16
 D1-01


2012SP-Alt 2-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-02

2012SP-Alt 2-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-02


2012SP-Alt 2-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 198.888 152.0UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-03

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-05


2012SP-Alt 2-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:120kV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-06

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-07


2012SP-Alt 2-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:16
 D1-08

2012SP-Alt 2-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:17
 D1-10


2012SP-Alt 2-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:17
 D1-11


2012SP-Alt 2-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/MW OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:17
 D1-12


2012SP-Alt 2-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







2012SP-Alt 2-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 1:1200V 0.940UV
 1:1200V <=35.000 <=69.000 <=138.000 <=240.000
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:17
 D1-15


2012SP-Alt 2-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 THU, APR 08 2010 16:14
 D1-16


2012SP-Alt 2-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:24
 D1-00


2012SL-Alt 2-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:24
 D1-08

2012SL-Alt 2-2.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 THU, APR 08 2010 15:24
 D1-13

2012SL-Alt 2-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:03
 D1-00

2012WP-Alt 3-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-00

2012WP-Alt 3-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920V
 kv: >0.000<=35.000<=69.000<=138.000<=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-01

2012WP-Alt 3-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-02

2012WP-Alt 3-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-03

2012WP-Alt 3-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-04

2012WP-Alt 3-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-04

2012WP-Alt 3-5.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-05

2012WP-Alt 3-6.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-06

2012WP-Alt 3-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-06

2012WP-Alt 3-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-07

2012WP-Alt 3-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-07

2012WP-Alt 3-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-09

2012WP-Alt 3-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:04
 D1-09

2012WP-Ait 3-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.00k=<35.00k=<69.00k=<138.00k=<240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-10


2012WP-Alt 3-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-11b

2012WP-Alt 3-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-11b

2012WP-AIt 3-11.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-14

2012WP-Alt 3-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-14

2012WP-Alt 3-12.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-15

2012WP-Alt 3-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-15

2012WP-Alt 3-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-18

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012WP-Alt 3-14.a

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-18

2012WP-Alt 3-14.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.00k=<35.00k=<69.00k=<138.00k=<240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 THU, APR 08 2010 17:05
 D1-19

2012WP-Alt 3-15.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.00k=<35.00k=<69.00k=<138.00k=<240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:25
 D1-00

2012SP-Alt 3-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:25
 D1-00

2012SP-Alt 3-1.b

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-01

2012SP-Alt 3-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/MW OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-01

2012SP-Alt 3-2.b

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-02

2012SP-Alt 3-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-02

2012SP-Alt 3-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090kV 0.920kV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-03

2012SP-Alt 3-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA


BATTLE RIVER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-04

2012SP-Alt 3-5.b

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-06

2012SP-Alt 3-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-09

2012SP-A1t 3-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-09

2012SP-Alt 3-9.b

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:26
 D1-10


2012SP-Alt 3-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:27
 D1-11b


2012SP-Alt 3-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA


LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:27
 D1-14

2012SP-Alt 3-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:27
 D1-18


2012SP-Alt 3-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:27
 D1-19


2012SP-Alt 3-15.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.120kV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:31
 D1-11b


2012SL-Alt 3-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/MW OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 0.940V
 kv: 30.000 <= 35.000 <= 69.000 <= 138.000 <= 240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER LIGHT BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 9:32
 D1-13

2012SL-Alt 3-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 0.940V
 kv: 30.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA



2012 Power Flow Plots

**Alternatives 1, 2 & 3
Battle River Unit # 5 ON**

Case Summary Page 2012 Alt 1 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2012WP-Alt 1 BR #5 ON-1.a	Base Case
D1-00	2012WP-Alt 1 BR #5 ON-1.b	Base Case
D1-21	2012WP-Alt 1 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2012WP-Alt 1 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-23	2012WP-Alt 1 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2012WP-Alt 1 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2012WP-Alt 1 BR #5 ON-4.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2012WP-Alt 1 BR #5 ON-4.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2012WP-Alt 1 BR #5 ON-5.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2012WP-Alt 1 BR #5 ON-5.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2012WP-Alt 1 BR #5 ON-6.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2012WP-Alt 1 BR #5 ON-6.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2012WP-Alt 1 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2012WP-Alt 1 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2012WP-Alt 1 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2012WP-Alt 1 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2012WP-Alt 1 BR #5 ON-9.a	Battle River 757S
D1-28	2012WP-Alt 1 BR #5 ON-9.b	Battle River 757S
D1-30	2012WP-Alt 1 BR #5 ON-10.a	Hansman Lake (650S) 138 kV
D1-30	2012WP-Alt 1 BR #5 ON-10.b	Hansman Lake (650S) 138 kV
D1-31	2012WP-Alt 1 BR #5 ON-11.a	Hansman Lake (650S) 240 kV
D1-31	2012WP-Alt 1 BR #5 ON-11.b	Hansman Lake (650S) 240 kV
D1-32	2012WP-Alt 1 BR #5 ON-12.a	Tucuman (478S) 138 kV
D1-32	2012WP-Alt 1 BR #5 ON-12.b	Tucuman (478S) 138 kV
D1-33	2012WP-Alt 1 BR #5 ON-13.a	Nilrem 240 kV
D1-33	2012WP-Alt 1 BR #5 ON-13.b	Nilrem 240 kV
D1-34	2012WP-Alt 1 BR #5 ON-14.a	Cordel 240 kV
D1-34	2012WP-Alt 1 BR #5 ON-14.b	Cordel 240 kV
D1-35	2012WP-Alt 1 BR #5 ON-15.a	Marguerite Lake (826S)
D1-35	2012WP-Alt 1 BR #5 ON-15.b	Marguerite Lake (826S)
D1-36	2012WP-Alt 1 BR #5 ON-16.a	Battle River Generating Station 3-4-6
D1-36	2012WP-Alt 1 BR #5 ON-16.b	Battle River Generating Station 3-4-6

Case Summary Page 2012 Alt 1 SP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2012SP-Alt 1 BR #5 ON-1.a	Base Case
D1-00	2012SP-Alt 1 BR #5 ON-1.b	Base Case
D1-21	2012SP-Alt 1 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2012SP-Alt 1 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-23	2012SP-Alt 1 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2012SP-Alt 1 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2012SP-Alt 1 BR #5 ON-4.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2012SP-Alt 1 BR #5 ON-4.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2012SP-Alt 1 BR #5 ON-5.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2012SP-Alt 1 BR #5 ON-5.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2012SP-Alt 1 BR #5 ON-6.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2012SP-Alt 1 BR #5 ON-6.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2012SP-Alt 1 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2012SP-Alt 1 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2012SP-Alt 1 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2012SP-Alt 1 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2012SP-Alt 1 BR #5 ON-9.a	Battle River 757S
D1-28	2012SP-Alt 1 BR #5 ON-9.b	Battle River 757S
D1-30	2012SP-Alt 1 BR #5 ON-10.a	Hansman Lake (650S) 138 kV
D1-30	2012SP-Alt 1 BR #5 ON-10.b	Hansman Lake (650S) 138 kV
D1-31	2012SP-Alt 1 BR #5 ON-11.a	Hansman Lake (650S) 240 kV
D1-31	2012SP-Alt 1 BR #5 ON-11.b	Hansman Lake (650S) 240 kV
D1-32	2012SP-Alt 1 BR #5 ON-12.a	Tucuman (478S) 138 kV
D1-32	2012SP-Alt 1 BR #5 ON-12.b	Tucuman (478S) 138 kV
D1-33	2012SP-Alt 1 BR #5 ON-13.a	Nilrem 240 kV
D1-33	2012SP-Alt 1 BR #5 ON-13.b	Nilrem 240 kV
D1-34	2012SP-Alt 1 BR #5 ON-14.a	Cordel 240 kV
D1-34	2012SP-Alt 1 BR #5 ON-14.b	Cordel 240 kV
D1-35	2012SP-Alt 1 BR #5 ON-15.a	Marguerite Lake (826S)
D1-35	2012SP-Alt 1 BR #5 ON-15.b	Marguerite Lake (826S)
D1-36	2012SP-Alt 1 BR #5 ON-16.a	Battle River Generating Station 3-4-6
D1-36	2012SP-Alt 1 BR #5 ON-16.b	Battle River Generating Station 3-4-6

Case Summary Page 2012 Alt 2 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2012WP-Alt 2 BR #5 ON-1.a	Base Case
D1-00	2012WP-Alt 2 BR #5 ON-1.b	Base Case
D1-23	2012WP-Alt 2 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2012WP-Alt 2 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2012WP-Alt 2 BR #5 ON-3.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2012WP-Alt 2 BR #5 ON-3.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2012WP-Alt 2 BR #5 ON-4.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2012WP-Alt 2 BR #5 ON-4.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2012WP-Alt 2 BR #5 ON-5.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2012WP-Alt 2 BR #5 ON-5.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2012WP-Alt 2 BR #5 ON-6.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2012WP-Alt 2 BR #5 ON-6.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2012WP-Alt 2 BR #5 ON-7.a	Battle River 757S
D1-28	2012WP-Alt 2 BR #5 ON-7.b	Battle River 757S
D1-30	2012WP-Alt 2 BR #5 ON-8.a	Hansman Lake (650S) 138 kV
D1-30	2012WP-Alt 2 BR #5 ON-8.b	Hansman Lake (650S) 138 kV
D1-31	2012WP-Alt 2 BR #5 ON-9.a	Hansman Lake (650S) 240 kV
D1-31	2012WP-Alt 2 BR #5 ON-9.b	Hansman Lake (650S) 240 kV
D1-32	2012WP-Alt 2 BR #5 ON-10.a	Tucuman (478S) 138 kV
D1-32	2012WP-Alt 2 BR #5 ON-10.b	Tucuman (478S) 138 kV
D1-33	2012WP-Alt 2 BR #5 ON-11.a	Nilrem 240 kV
D1-33	2012WP-Alt 2 BR #5 ON-11.b	Nilrem 240 kV
D1-34	2012WP-Alt 2 BR #5 ON-12.a	Cordel 240 kV
D1-34	2012WP-Alt 2 BR #5 ON-12.b	Cordel 240 kV
D1-35	2012WP-Alt 2 BR #5 ON-13.a	Marguerite Lake (826S)
D1-35	2012WP-Alt 2 BR #5 ON-13.b	Marguerite Lake (826S)
D1-36	2012WP-Alt 2 BR #5 ON-14.a	Battle River Generating Station 3-4-6
D1-36	2012WP-Alt 2 BR #5 ON-14.b	Battle River Generating Station 3-4-6

Case Summary Page 2012 Alt 2 SP BR #5 ON


Contingency Number	Fig #	Description
D1-00	2017SP-Alt 2 BR #5 ON-1.a	Base Case
D1-00	2017SP-Alt 2 BR #5 ON-1.b	Base Case
D1-23	2017SP-Alt 2 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017SP-Alt 2 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017SP-Alt 2 BR #5 ON-3.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2017SP-Alt 2 BR #5 ON-3.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2017SP-Alt 2 BR #5 ON-4.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2017SP-Alt 2 BR #5 ON-4.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2017SP-Alt 2 BR #5 ON-5.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017SP-Alt 2 BR #5 ON-5.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017SP-Alt 2 BR #5 ON-6.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017SP-Alt 2 BR #5 ON-6.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017SP-Alt 2 BR #5 ON-7.a	Battle River 757S
D1-28	2017SP-Alt 2 BR #5 ON-7.b	Battle River 757S
D1-30	2017SP-Alt 2 BR #5 ON-8.a	Hansman Lake (650S) 138 kV
D1-30	2017SP-Alt 2 BR #5 ON-8.b	Hansman Lake (650S) 138 kV
D1-31	2017SP-Alt 2 BR #5 ON-9.a	Hansman Lake (650S) 240 kV
D1-31	2017SP-Alt 2 BR #5 ON-9.b	Hansman Lake (650S) 240 kV
D1-32	2017SP-Alt 2 BR #5 ON-10.a	Tucuman (478S) 138 kV
D1-32	2017SP-Alt 2 BR #5 ON-10.b	Tucuman (478S) 138 kV
D1-33	2017SP-Alt 2 BR #5 ON-11.a	Nilrem 240 kV
D1-33	2017SP-Alt 2 BR #5 ON-11.b	Nilrem 240 kV
D1-34	2017SP-Alt 2 BR #5 ON-12.a	Cordel 240 kV
D1-34	2017SP-Alt 2 BR #5 ON-12.b	Cordel 240 kV
D1-35	2017SP-Alt 2 BR #5 ON-13.a	Marguerite Lake (826S)
D1-35	2017SP-Alt 2 BR #5 ON-13.b	Marguerite Lake (826S)
D1-36	2017SP-Alt 2 BR #5 ON-14.a	Battle River Generating Station 3-4-6
D1-36	2017SP-Alt 2 BR #5 ON-14.b	Battle River Generating Station 3-4-6

Case Summary Page 2012 Alt 3 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2012WP-Alt 3 BR #5 ON-1.a	Base Case
D1-00	2012WP-Alt 3 BR #5 ON-1.b	Base Case
D1-20	2012WP-Alt 3 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-20	2012WP-Alt 3 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-21	2012WP-Alt 3 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2012WP-Alt 3 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-22	2012WP-Alt 3 BR #5 ON-4.a	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-22	2012WP-Alt 3 BR #5 ON-4.b	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-23	2012WP-Alt 3 BR #5 ON-5.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2012WP-Alt 3 BR #5 ON-5.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2012WP-Alt 3 BR #5 ON-6.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24	2012WP-Alt 3 BR #5 ON-6.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24b	2012WP-Alt 3 BR #5 ON-7.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24b	2012WP-Alt 3 BR #5 ON-7.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-26	2012WP-Alt 3 BR #5 ON-8.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2012WP-Alt 3 BR #5 ON-8.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2012WP-Alt 3 BR #5 ON-9.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2012WP-Alt 3 BR #5 ON-9.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2012WP-Alt 3 BR #5 ON-10.a	Battle River 757S
D1-28	2012WP-Alt 3 BR #5 ON-10.b	Battle River 757S
D1-29	2012WP-Alt 3 BR #5 ON-11.a	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-29	2012WP-Alt 3 BR #5 ON-11.b	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-30b	2012WP-Alt 3 BR #5 ON-12.a	Hansman Lake (650S) 138 kV
D1-30b	2012WP-Alt 3 BR #5 ON-12.b	Hansman Lake (650S) 138 kV
D1-31	2012WP-Alt 3 BR #5 ON-13.a	Hansman Lake (650S) 240 kV
D1-31	2012WP-Alt 3 BR #5 ON-13.b	Hansman Lake (650S) 240 kV
D1-32	2012WP-Alt 3 BR #5 ON-14.a	Tucuman (478S) 138 kV
D1-32	2012WP-Alt 3 BR #5 ON-14.b	Tucuman (478S) 138 kV
D1-33	2012WP-Alt 3 BR #5 ON-15.a	Nilrem 240 kV
D1-33	2012WP-Alt 3 BR #5 ON-15.b	Nilrem 240 kV
D1-34	2012WP-Alt 3 BR #5 ON-16.a	Cordel 240 kV
D1-34	2012WP-Alt 3 BR #5 ON-16.b	Cordel 240 kV
D1-35	2012WP-Alt 3 BR #5 ON-17.a	Marguerite Lake (826S)
D1-35	2012WP-Alt 3 BR #5 ON-17.b	Marguerite Lake (826S)
D1-36	2012WP-Alt 3 BR #5 ON-18.a	Battle River Generating Station 3-4-6
D1-36	2012WP-Alt 3 BR #5 ON-18.b	Battle River Generating Station 3-4-6

Case Summary Page 2012 Alt 3 SP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2012SP-Alt 3 BR #5 ON-1.a	Base Case
D1-00	2012SP-Alt 3 BR #5 ON-1.b	Base Case
D1-20	2012SP-Alt 3 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-20	2012SP-Alt 3 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-21	2012SP-Alt 3 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2012SP-Alt 3 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-22	2012SP-Alt 3 BR #5 ON-4.a	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-22	2012SP-Alt 3 BR #5 ON-4.b	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-23	2012SP-Alt 3 BR #5 ON-5.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2012SP-Alt 3 BR #5 ON-5.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2012SP-Alt 3 BR #5 ON-6.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24	2012SP-Alt 3 BR #5 ON-6.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24b	2012SP-Alt 3 BR #5 ON-7.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24b	2012SP-Alt 3 BR #5 ON-7.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-26	2012SP-Alt 3 BR #5 ON-8.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2012SP-Alt 3 BR #5 ON-8.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2012SP-Alt 3 BR #5 ON-9.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2012SP-Alt 3 BR #5 ON-9.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2012SP-Alt 3 BR #5 ON-10.a	Battle River 757S
D1-28	2012SP-Alt 3 BR #5 ON-10.b	Battle River 757S
D1-29	2012SP-Alt 3 BR #5 ON-11.a	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-29	2012SP-Alt 3 BR #5 ON-11.b	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-30b	2012SP-Alt 3 BR #5 ON-12.a	Hansman Lake (650S) 138 kV
D1-30b	2012SP-Alt 3 BR #5 ON-12.b	Hansman Lake (650S) 138 kV
D1-31	2012SP-Alt 3 BR #5 ON-13.a	Hansman Lake (650S) 240 kV
D1-31	2012SP-Alt 3 BR #5 ON-13.b	Hansman Lake (650S) 240 kV
D1-32	2012SP-Alt 3 BR #5 ON-14.a	Tucuman (478S) 138 kV
D1-32	2012SP-Alt 3 BR #5 ON-14.b	Tucuman (478S) 138 kV
D1-33	2012SP-Alt 3 BR #5 ON-15.a	Nilrem 240 kV
D1-33	2012SP-Alt 3 BR #5 ON-15.b	Nilrem 240 kV
D1-34	2012SP-Alt 3 BR #5 ON-16.a	Cordel 240 kV
D1-34	2012SP-Alt 3 BR #5 ON-16.b	Cordel 240 kV
D1-35	2012SP-Alt 3 BR #5 ON-17.a	Marguerite Lake (826S)
D1-35	2012SP-Alt 3 BR #5 ON-17.b	Marguerite Lake (826S)
D1-36	2012SP-Alt 3 BR #5 ON-18.a	Battle River Generating Station 3-4-6
D1-36	2012SP-Alt 3 BR #5 ON-18.b	Battle River Generating Station 3-4-6



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:11
 D1-21

2012WP-Alt 1 BR#5 ON-2.a

Bus - VOLTAGE (kV/Pu)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:11
 D1-21

2012WP-Ait 1 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:11
 D1-23

2012WP-Alt 1 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:11
 D1-23

2012WP-AIt 1 BR#5 ON-3.B

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.0900V 0.9200V
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-24


2012WP-Alt 1 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-24b

2012WP-A1t 1 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-25

2012WP-Alt 1 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-25

2012WP-Alt 1 BR#5 ON-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-26


2012WP-Alt 1 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-27

2012WP-Ait 1 BR#5 ON-8.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-28

2012WP-AIt 1 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0%RATEB
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-28

2012WP-Alt 1 BR#5 ON-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-30


2012WP-AIt 1 BR#5 ON-10.a

Bus - VOLTAGE (kV/Pu)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 30 2010 13:12
 D1-31


2012WP-Alt 1 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:13
 D1-32

2012WP-Alt 1 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:13
 D1-32

2012WP-Alt 1 BR#5 ON-12.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA





CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 30 2010 13:13
 D1-33

2012WP-AIt 1 BR#5 ON-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000







COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 30 2010 13:13
 D1-36

2012WP-Ait 1 BR#5 ON-16.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-00

2012SP-Alt 1 BR#5 ON-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-00

2012SP-Alt 1 BR#5 ON-1.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA

BATTLE RIVER AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-23

2012SP-A1t 1 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-24


2012SP-Alt 1 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-24b

2012SP-AIt 1 BR#5 ON-5.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:47
 D1-25

2012SP-Alt 1 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-26


2012SP-Alt 1 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-27

2012SP-AIt 1 BR#5 ON-8.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-27

2012SP-Alt 1 BR#5 ON-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.0900V 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-28


2012SP-Alt 1 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-30


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-AIt 1 BR#5 ON-10.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-31


2012SP-Alt 1 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-32


2012SP-AIt 1 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-33

2012SP-Alt 1 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:48
 D1-34


2012SP-AIt 1 BR#5 ON-14.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0-000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA








CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 30 2010 16:49
 D1-36

2012SP-Alt 1 BR#5 ON-16.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 - LOAD CHANGE IN P
 FRI, APR 09 2010 10:51
 D1-00

2012WP-Alt 2 BR#5 ON-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:51
 D1-00

2012WP-Alt 2 BR#5 ON-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 09 2010 10:51
 D1-23

2012WP-Alt 2 BR#5 ON-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:51
 D1-23

2012WP-Ait 2 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000

COLD LAKE AREA



VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
FRI, APR 09 2010 12:24


2012WP-Alt 2 BR#5 ON-4.a

Bus - VOLTAGE (KV/PU)
Branch - MVA/% OF RATE B
Equipment - MW/MVAR
100.0% RATE B
KV: 50.000<=35.000<=69.000<=138.000<=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-26

2012WP-Alt 2 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-26

2012WP-Alt 2 BR#5 ON-5.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-27

2012WP-Alt 2 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 - LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-28

2012WP-Alt 2 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-28

2012WP-Ait 2 BR#5 ON-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <69.000 <138.000 <240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-30

2012WP-Ait 2 BR#5 ON-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-30

2012WP-AIt 2 BR#5 ON-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <69.000 <138.000 <240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-31

2012WP-Alt 2 BR#5 ON-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-32

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


2012WP-Alt 2 BR#5 ON-10.a

VEGREVILLE AREA

WAINWRIGHT AREA



COLD LAKE AREA



VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
FRI, APR 09 2010 11:39


2012WP-Ait 2 BR#5 ON-11.a

Bus - VOLTAGE (KV/PU)
Branch - MVA/% OF RATE B
Equipment - MW/MVAR
100.0% RATE B
KV: 50.000<=55.000<=69.000<=138.000<=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-34

2012WP-Alt 2 BR#5 ON-12.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-34

2012WP-Alt 2 BR#5 ON-12.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kV: >0.000=<35.000 <69.000 <138.000 <240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 FRI, APR 09 2010 10:52
 D1-35

2012WP-Alt 2 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:53
 D1-35

2012WP-Alt 2 BR#5 ON-13.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 FRI, APR 09 2010 10:53
 D1-36

2012WP-Ait 2 BR#5 ON-14.a


Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 FRI, APR 09 2010 10:53
 D1-36

2012WP-Ait 2 BR#5 ON-14.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:56
 D1-00


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 2 BR#5 ON-1.a

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-23

2012SP-Alt 2 BR#5 ON-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-23

2012SP-Alt 2 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 1988287520UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-24

2012SP-Alt 2 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-24

2012SP-Alt 2 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 198828.6520UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 12:30
 D1-25


2012SP-Alt 2 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-26

2012SP-Alt 2 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UW
 2:35.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-26


2012SP-Alt 2 BR#5 ON-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 198.888 152.0UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-28


2012SP-Alt 2 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 10:57
 D1-30

2012SP-Alt 2 BR#5 ON-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 MON, APR 12 2010 10:41
 D1-00

2012WP-Alt 3 BR#5 ON-1.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:41
 D1-00

2012WP-Alt 3 BR#5 ON-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kv: >0.00<=35.00<=69.00<=138.00<=240.00






CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:41
 D1-21

2012WP-A1t 3 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kv: >0.00<=35.00<=69.00<=138.00<=240.00




CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 MON, APR 12 2010 10:41
 D1-22


2012WP-Alt 3 BR#5 ON-4.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 LOAD CHANGE IN P
 MON, APR 12 2010 10:41
 D1-23

2012WP-Alt 3 BR#5 ON-5.a

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-23

2012WP-Alt 3 BR#5 ON-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 - LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-24


2012WP-Alt 3 BR#5 ON-6.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 - LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-24b

2012WP-Alt 3 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA


BATTLE RIVER AREA

CENTRAL AREA STUDY
2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
MON, APR 12 2010 10:42
D1-24b

2012WP-Ait 3 BR#5 ON-7.b

Bus - VOLTAGE (kV/PU)
Branch - MVA/% OF RATE B
Equipment - MW/Mvar
100.0% RATE B
1.0900V0.920UV
kV: >0.000<=35.000<=69.000<=138.000<=240.000





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-26

2012WP-Ait 3 BR#5 ON-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-27

2012WP-Alt 3 BR#5 ON-9.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-27

2012WP-Alt 3 BR#5 ON-9.b

Bus - VOLTAGE (kV/P)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0 920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 - LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-28

2012WP-Alt 3 BR#5 ON-10.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-28

2012WP-Alt 3 BR#5 ON-10.b


Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kv: >0.00<=35.00<=69.00<=138.00<=240.00



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-29

2012WP-Ait 3 BR#5 ON-11.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900 V0.920 VV
 kV: >0.000<=35.000<=69.000<=138.000<=240.000



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 - LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-30b

2012WP-Alt 3 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 LOAD CHANGE IN P
 MON, APR 12 2010 10:42
 D1-31

2012WP-Ait 3 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-31

2012WP-Alt 3 BR#5 ON-13.b

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kv: >0.000<=35.000<=69.000<=138.000<=240.000


VEGREVILLE AREA

WAINWRIGHT AREA



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-33

2012WP-Alt 3 BR#5 ON-15.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kV: >0.00<=35.00<=69.00<=138.00<=240.00



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-34

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-34

2012WP-Alt 3 BR#5 ON-16.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920V
 kv: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 WINTER PEAK CASE REVISION 7.2.1 'LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-35

2012WP-Ait 3 BR#5 ON-17.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2012 WINTER PEAK BASE CASE REVISION 7.2.1 *LOAD CHANGE IN P
 MON, APR 12 2010 10:43
 D1-35

2012WP-Alt 3 BR#5 ON-17.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kv: >0.000<=35.000<=69.000<=138.000<=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:14
 D1-00


2012SP-Alt 3 BR#5 ON-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 MON, APR 12 2010 10:39
 D1-20

2012SP-Alt 3 BR#5 ON-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA


BATTLE RIVER AREA



VEGREVILLE AREA

WAINWRIGHT AREA







CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:14
 D1-23

2012SP-Alt 3 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:14
 D1-24


2012SP-Alt 3 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:14
 D1-24b


2012SP-Alt 3 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-26


2012SP-Ait 3 BR#5 ON-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-27

2012SP-Alt 3 BR#5 ON-9.b


Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 MON, APR 12 2010 9:43

2012SP-Alt 3 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-29


2012SP-Ait 3 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 MON, APR 12 2010 9:40

2012SP-Alt 3 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-31

2012SP-Alt 3 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/MW OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-32

2012SP-Ait 3 BR#5 ON-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:58
 D1-33


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 3 BR#5 ON-15.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:15
 D1-34


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Ait 3 BR#5 ON-16.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:16
 D1-35


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Alt 3 BR#5 ON-17.a

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2012 SUMMER PEAK BASE CASE REVISION 7.2.1
 FRI, APR 09 2010 11:16
 D1-36

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2012SP-Ait 3 BR#5 ON-18.a

VEGREVILLE AREA

WAINWRIGHT AREA



2017 Power Flow Plots

**Alternatives 1, 2 & 3
Battle River Unit # 5 OFF**

Case Summary Page 2017 Alt 1 WP

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 1-1.a	Base Case
D1-00	2017WP-Alt 1-1.b	Base Case
D1-01	2017WP-Alt 1-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017WP-Alt 1-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017WP-Alt 1-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017WP-Alt 1-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017WP-Alt 1-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017WP-Alt 1-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2017WP-Alt 1-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2017WP-Alt 1-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2017WP-Alt 1-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017WP-Alt 1-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017WP-Alt 1-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017WP-Alt 1-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017WP-Alt 1-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017WP-Alt 1-8.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2017WP-Alt 1-9.a	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-08	2017WP-Alt 1-9.b	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-09	2017WP-Alt 1-10.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017WP-Alt 1-10.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017WP-Alt 1-11.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017WP-Alt 1-11.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2017WP-Alt 1-12.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2017WP-Alt 1-12.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2017WP-Alt 1-13.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2017WP-Alt 1-13.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2017WP-Alt 1-14.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017WP-Alt 1-14.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017WP-Alt 1-15.a	Battle River 144/72 kV Transformer 701T
D1-15	2017WP-Alt 1-15.b	Battle River 144/72 kV Transformer 701T
D1-16	2017WP-Alt 1-16.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2017WP-Alt 1-16.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2017 Alt 1 SP

Contingency Number	Fig #	Description
D1-00	2017SP-Alt 1-1.a	Base Case
D1-00	2017SP-Alt 1-1.b	Base Case
D1-01	2017SP-Alt 1-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017SP-Alt 1-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017SP-Alt 1-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017SP-Alt 1-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017SP-Alt 1-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017SP-Alt 1-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2017SP-Alt 1-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2017SP-Alt 1-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2017SP-Alt 1-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017SP-Alt 1-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017SP-Alt 1-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017SP-Alt 1-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017SP-Alt 1-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017SP-Alt 1-8.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2017SP-Alt 1-9.a	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-08	2017SP-Alt 1-9.b	Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-09	2017SP-Alt 1-10.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017SP-Alt 1-10.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017SP-Alt 1-11.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017SP-Alt 1-11.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2017SP-Alt 1-12.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2017SP-Alt 1-12.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2017SP-Alt 1-13.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2017SP-Alt 1-13.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2017SP-Alt 1-14.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017SP-Alt 1-14.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017SP-Alt 1-15.a	Battle River 144/72 kV Transformer 701T
D1-15	2017SP-Alt 1-15.b	Battle River 144/72 kV Transformer 701T
D1-16	2017SP-Alt 1-16.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2017SP-Alt 1-16.b	Edgerton 899S to Killarney Lake 267S (749L)

Case Summary Page 2017 Alt 2 WP

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 2-1.a	Base Case
D1-00	2017WP-Alt 2-1.b	Base Case
D1-01	2017WP-Alt 2-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017WP-Alt 2-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017WP-Alt 2-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017WP-Alt 2-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017WP-Alt 2-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017WP-Alt 2-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-05	2017WP-Alt 2-5.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017WP-Alt 2-5.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017WP-Alt 2-6.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017WP-Alt 2-6.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017WP-Alt 2-7.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017WP-Alt 2-7.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2017WP-Alt 2-8.a	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-08	2017WP-Alt 2-8.b	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-09	2017WP-Alt 2-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017WP-Alt 2-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017WP-Alt 2-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017WP-Alt 2-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2017WP-Alt 2-11.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2017WP-Alt 2-11.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2017WP-Alt 2-12.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2017WP-Alt 2-12.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2017WP-Alt 2-13.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017WP-Alt 2-13.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017WP-Alt 2-14.a	Battle River 144/72 kV Transformer 701T
D1-15	2017WP-Alt 2-14.b	Battle River 144/72 kV Transformer 701T
D1-16	2017WP-Alt 2-15.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2017WP-Alt 2-15.b	Edgerton 899S to Killarney Lake 267S (749L)
D1-17	2017WP-Alt 2-16.a	Vermilion 240/144 kV Transformer
D1-17	2017WP-Alt 2-16.b	Vermilion 240/144 kV Transformer

Case Summary Page 2017 Alt 2 SP


Contingency Number	Fig #	Description
D1-00	2017SP-Alt 2-1.a	Base Case
D1-00	2017SP-Alt 2-1.b	Base Case
D1-01	2017SP-Alt 2-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017SP-Alt 2-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017SP-Alt 2-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017SP-Alt 2-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017SP-Alt 2-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017SP-Alt 2-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-05	2017SP-Alt 2-5.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017SP-Alt 2-5.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017SP-Alt 2-6.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017SP-Alt 2-6.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017SP-Alt 2-7.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017SP-Alt 2-7.b	Hill 751S to Loydminster 716S (7L42)
D1-08	2017SP-Alt 2-8.a	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-08	2017SP-Alt 2-8.b	Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-09	2017SP-Alt 2-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017SP-Alt 2-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017SP-Alt 2-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017SP-Alt 2-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11	2017SP-Alt 2-11.a	Metiskow 648S to Killarney 267S (7L749)
D1-11	2017SP-Alt 2-11.b	Metiskow 648S to Killarney 267S (7L749)
D1-12	2017SP-Alt 2-12.a	Hansman Lake 650S to Provost 545S (715L)
D1-12	2017SP-Alt 2-12.b	Hansman Lake 650S to Provost 545S (715L)
D1-14	2017SP-Alt 2-13.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017SP-Alt 2-13.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017SP-Alt 2-14.a	Battle River 144/72 kV Transformer 701T
D1-15	2017SP-Alt 2-14.b	Battle River 144/72 kV Transformer 701T
D1-16	2017SP-Alt 2-15.a	Edgerton 899S to Killarney Lake 267S (749L)
D1-16	2017SP-Alt 2-15.b	Edgerton 899S to Killarney Lake 267S (749L)
D1-17	2017SP-Alt 2-16.a	Vermilion 240/144 kV Transformer
D1-17	2017SP-Alt 2-16.b	Vermilion 240/144 kV Transformer

Case Summary Page 2017 Alt 3 WP

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 3-1.a	Base Case
D1-00	2017WP-Alt 3-1.b	Base Case
D1-01	2017WP-Alt 3-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017WP-Alt 3-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017WP-Alt 3-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017WP-Alt 3-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017WP-Alt 3-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017WP-Alt 3-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2017WP-Alt 3-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2017WP-Alt 3-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2017WP-Alt 3-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017WP-Alt 3-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017WP-Alt 3-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017WP-Alt 3-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017WP-Alt 3-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017WP-Alt 3-8.b	Hill 751S to Loydminster 716S (7L42)
D1-09	2017WP-Alt 3-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017WP-Alt 3-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017WP-Alt 3-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017WP-Alt 3-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11b	2017WP-Alt 3-11.a	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-11b	2017WP-Alt 3-11.b	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-14	2017WP-Alt 3-12.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017WP-Alt 3-12.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017WP-Alt 3-13.a	Battle River 144/72 kV Transformer 701T
D1-15	2017WP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
D1-18	2017WP-Alt 3-14.a	Loydminster to Wind Farm
D1-18	2017WP-Alt 3-14.b	Loydminster to Wind Farm
D1-19	2017WP-Alt 3-15.a	Hansman Lake 650S to Wind Farm
D1-19	2017WP-Alt 3-15.b	Hansman Lake 650S to Wind Farm

Case Summary Page 2017 Alt 3 SP

Contingency Number	Fig #	Description
D1-00	2017SP-Alt 3-1.a	Base Case
D1-00	2017SP-Alt 3-1.b	Base Case
D1-01	2017SP-Alt 3-2.a	Bonnyville 700S to Bourque 970S (7L146)
D1-01	2017SP-Alt 3-2.b	Bonnyville 700S to Bourque 970S (7L146)
D1-02	2017SP-Alt 3-3.a	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-02	2017SP-Alt 3-3.b	Marguerite Lake 826S to Wolf Lake 822S (7L87)
D1-03	2017SP-Alt 3-4.a	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-03	2017SP-Alt 3-4.b	Leming Lake 715S to Ethel Lake 717S (7L66)
D1-04	2017SP-Alt 3-5.a	Bonnyville 700S to Irish Creek 706S (7L53)
D1-04	2017SP-Alt 3-5.b	Bonnyville 700S to Irish Creek 706S (7L53)
D1-05	2017SP-Alt 3-6.a	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-05	2017SP-Alt 3-6.b	Vermilion 710S to Hill 751S (7L14) Kitscoty 705S Tap
D1-06	2017SP-Alt 3-7.a	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-06	2017SP-Alt 3-7.b	Marguerite Lake 826S to LaCorey 721S (7L89)
D1-07	2017SP-Alt 3-8.a	Hill 751S to Loydminster 716S (7L42)
D1-07	2017SP-Alt 3-8.b	Hill 751S to Loydminster 716S (7L42)
D1-09	2017SP-Alt 3-9.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-09	2017SP-Alt 3-9.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-10	2017SP-Alt 3-10.a	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-10	2017SP-Alt 3-10.b	Battle River 757S to Strome 223S (7L701) Heisler 764S Tap
D1-11b	2017SP-Alt 3-11.a	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-11b	2017SP-Alt 3-11.b	Metiskow 648S to Edgerton 899S Killarney TP (7L749)
D1-14	2017SP-Alt 3-12.a	Cordel 755S to Nevis 766S (9L20)
D1-14	2017SP-Alt 3-12.b	Cordel 755S to Nevis 766S (9L20)
D1-15	2017SP-Alt 3-13.a	Battle River 144/72 kV Transformer 701T
D1-15	2017SP-Alt 3-13.b	Battle River 144/72 kV Transformer 701T
D1-18	2017SP-Alt 3-14.a	Loydminster to Wind Farm
D1-18	2017SP-Alt 3-14.b	Loydminster to Wind Farm
D1-19	2017SP-Alt 3-15.a	Hansman Lake 650S to Wind Farm
D1-19	2017SP-Alt 3-15.b	Hansman Lake 650S to Wind Farm



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-00


2017WP-Alt 1-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-01

2017WP-Alt 1-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATEB
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-02

2017WP-Alt 1-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

BATTLE RIVER AREA


PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
2017 WINTER PEAK BASE CASE REVISION 7.2
FRI, APR 30 2010 13:00
D1-02


2017WP-Alt 1-3.b

Bus - VOLTAGE (kV/PU)
Branch - MVA% OF RATE B
Equipment - MW/Mvar
100.0% RATED
1.0900V0.920UV
kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-03

2017WP-Alt 1-4.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-04

2017WP-Alt 1-5.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:00
 D1-05


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 1-6.a




VEGREVILLE AREA

WAINWRIGHT AREA



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-07


2017WP-Alt 1-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000<=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-08

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA


BATTLE RIVER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-08

2017WP-Alt 1-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000<=240.000






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-10


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 1-11.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-11

2017WP-Alt 1-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0%RATEB
 1.200KV 0.940KV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:01
 D1-12

2017WP-Alt 1-13.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:02
 D1-15

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 1-15.a






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:02
 D1-16


2017WP-Alt 1-16.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:46
 D1-01

2017SP-Alt 1-2.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:46
 D1-02

2017SP-Alt 1-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:46
 D1-03

2017SP-Alt 1-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:46
 D1-04

2017SP-Alt 1-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 13:30


2017SP-Alt 1-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-06

2017SP-Alt 1-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-08


2017SP-Alt 1-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-09


2017SP-Alt 1-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-10


2017SP-Alt 1-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA






VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-12


2017SP-Alt 1-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:47
 D1-14


2017SP-Alt 1-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 14:48
 D1-15


2017SP-Alt 1-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:04
 D1-16

2017SP-Alt 1-16.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:05
 D1-00


2017SL-Alt 1-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:05
 D1-08

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017SL-Alt 1-2.a



VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:05
 D1-08

2017SL-Alt 1-2.b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V0.920UV
 kV: >0.000<=35.000<=69.000<=138.000<=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:05
 D1-11


2017SL-Alt 1-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/Mvar OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.200V 0.940Uv
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 30 2010 13:05
 D1-12


2017SL-Alt 1-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







2017SL-Alt 1-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA






VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:22
 D1-00

2017WP-Alt 2-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:22
 D1-01

2017WP-Alt 2-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:22
 D1-01

2017WP-Alt 2-2.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:22
 D1-02

2017WP-Alt 2-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:23
 D1-03

2017WP-Alt 2-4.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:120kV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:23
 D1-03

2017WP-Alt 2-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 13:41


2017WP-Alt 2-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:23
 D1-06

2017WP-Alt 2-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:23
 D1-07


2017WP-Alt 2-7.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 13:43


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 2-8.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:23
 D1-09

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 2-9.a




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-10


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 2-10.a

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-11


2017WP-Alt 2-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-12


2017WP-Alt 2-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-14


2017WP-Alt 2-13.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-15

2017WP-Alt 2-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-15

2017WP-Alt 2-14.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D1-16


2017WP-Alt 2-15.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/MVar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:24
 D0-17

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:29
 D1-00

2017SP-Alt 2-1.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 =<=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 10:16:29
 D1-01

2017SP-Alt 2-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/MVar OF RATE A
 Equipment - MW/MVar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:29
 D1-02


2017SP-Alt 2-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 =<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:29
 D1-03

2017SP-Alt 2-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:29
 D1-03

2017SP-Alt 2-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 13:46

2017SP-Alt 2-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 13:46

2017SP-Alt 2-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA%/ OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV 0.920UV
 kV: >0.00<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-06

2017SP-Alt 2-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 =>35.000 <=<69.000 <=<138.000 <=<240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-06

2017SP-Alt 2-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920UV
 kV: >0.00<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-07

2017SP-Alt 2-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090QV 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-08

2017SP-Alt 2-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-08

2017SP-Alt 2-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090kV 0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-09

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-09

2017SP-Alt 2-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920UV
 kV: >0.00=<=35.00 <=69.00 <=138.00 <=240.00





CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-10

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-11


2017SP-Alt 2-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-12

2017SP-Alt 2-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 20 2010 16:30
 D1-14


2017SP-Alt 2-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 =<=35.000 <=<69.000 <=<138.000 <=<240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:30
 D1-15


2017SP-Alt 2-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/MVar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:31
 D1-16

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA







CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 THU, APR 08 2010 16:31
 D1-17

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.200V 0.940UV
 kv: >0.000 =<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:34
 D1-00

2017SL-Alt 2-1.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 06 2010 16:34
 D1-00

2017SL-Alt 2-1.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV.0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:34
 D1-08

2017SL-Alt 2-2.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-11

2017SL-Alt 2-3.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-11

2017SL-Alt 2-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-12

2017SL-Alt 2-4.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-12

2017SL-Alt 2-4.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920LUV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-13

2017SL-Alt 2-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-16

2017SL-Alt 2-6.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 THU, APR 08 2010 16:35
 D1-16

2017SL-Alt 2-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090kV/0.920LUV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-00

2017WP-Alt 3-1.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-00

2017WP-Alt 3-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090QV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-01

Bus - VOLTAGE (KV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-02


Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 3-3.a

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-03

2017WP-Alt 3-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:120kV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-03

2017WP-Alt 3-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-04

2017WP-Alt 3-5.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-04

2017WP-Alt 3-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-05


2017WP-Alt 3-6.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-06

2017WP-Alt 3-7.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:36
 D1-06

2017WP-Alt 3-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-07

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017WP-Alt 3-8.a

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-07

2017WP-Alt 3-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-09

2017WP-Alt 3-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-10

2017WP-Alt 3-10.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-11b


2017WP-Alt 3-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-14


2017WP-Alt 3-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-18


2017WP-Alt 3-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:37
 D1-19

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:53
 D1-00

2017SP-Alt 3-1.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-01

2017SP-Alt 3-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-02

2017SP-Alt 3-3.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-02

2017SP-Alt 3-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-03

2017SP-Alt 3-4.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-03

2017SP-Alt 3-4.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900OV 0.9200UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-04

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-04

2017SP-Alt 3-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-05

2017SP-Alt 3-6.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-05

2017SP-Alt 3-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-06

2017SP-Alt 3-7.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-06

2017SP-Alt 3-7.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
FRI, APR 09 2010 9:54
D1-07

Bus - VOLTAGE (KV/PU)
Branch - MVA/% OF RATE A
Equipment - MW/Mvar
100.0% RATE A
1:1200V 0.940UV
KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-07

2017SP-Alt 3-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090QV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:54
 D1-09

2017SP-Alt 3-9.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.2kV 0.94kV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-09

2017SP-Alt 3-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-10

2017SP-Alt 3-10.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-11b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.200V 0.940V
 0.480V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-14

2017SP-Alt 3-12.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-15


Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.120KV 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017SP-Alt 3-13.a

VEGREVILLE AREA

WAINWRIGHT AREA






COLD LAKE AREA

VEGREVILLE AREA

LOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 9:55
 D1-19

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 KV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:01
 D1-00

2017SL-Alt 3-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090QV0.920UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:01
 D1-11b

Bus - VOLTAGE (KV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017SL-Alt 3-2.a

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:01
 D1-11b

2017SL-Alt 3-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090 QVO.920 UV
 KV: >0.000 <=35.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER LIGHT BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:01
 D1-13

2017SL-Alt 3-3.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA



2017 Power Flow Plots

**Alternatives 1, 2 & 3
Battle River Unit # 5 ON**

Case Summary Page 2017 Alt 1 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 1 BR #5 ON-1.a	Base Case
D1-00	2017WP-Alt 1 BR #5 ON-1.b	Base Case
D1-21	2017WP-Alt 1 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2017WP-Alt 1 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-23	2017WP-Alt 1 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017WP-Alt 1 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017WP-Alt 1 BR #5 ON-4.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2017WP-Alt 1 BR #5 ON-4.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2017WP-Alt 1 BR #5 ON-5.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2017WP-Alt 1 BR #5 ON-5.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2017WP-Alt 1 BR #5 ON-6.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2017WP-Alt 1 BR #5 ON-6.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2017WP-Alt 1 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017WP-Alt 1 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017WP-Alt 1 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017WP-Alt 1 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017WP-Alt 1 BR #5 ON-9.a	Battle River 757S
D1-28	2017WP-Alt 1 BR #5 ON-9.b	Battle River 757S
D1-30	2017WP-Alt 1 BR #5 ON-10.a	Hansman Lake (650S) 138 kV
D1-30	2017WP-Alt 1 BR #5 ON-10.b	Hansman Lake (650S) 138 kV
D1-31	2017WP-Alt 1 BR #5 ON-11.a	Hansman Lake (650S) 240 kV
D1-31	2017WP-Alt 1 BR #5 ON-11.b	Hansman Lake (650S) 240 kV
D1-32	2017WP-Alt 1 BR #5 ON-12.a	Tucuman (478S) 138 kV
D1-32	2017WP-Alt 1 BR #5 ON-12.b	Tucuman (478S) 138 kV
D1-33	2017WP-Alt 1 BR #5 ON-13.a	Nilrem 240 kV
D1-33	2017WP-Alt 1 BR #5 ON-13.b	Nilrem 240 kV
D1-34	2017WP-Alt 1 BR #5 ON-14.a	Cordel 240 kV
D1-34	2017WP-Alt 1 BR #5 ON-14.b	Cordel 240 kV
D1-35	2017WP-Alt 1 BR #5 ON-15.a	Marguerite Lake (826S)
D1-35	2017WP-Alt 1 BR #5 ON-15.b	Marguerite Lake (826S)
D1-36	2017WP-Alt 1 BR #5 ON-16.a	Battle River Generating Station 3-4-6
D1-36	2017WP-Alt 1 BR #5 ON-16.b	Battle River Generating Station 3-4-6

Case Summary Page 2017 Alt 1 SP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2017SP-Alt 1 BR #5 ON-1.a	Base Case
D1-00	2017SP-Alt 1 BR #5 ON-1.b	Base Case
D1-21	2017SP-Alt 1 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2017SP-Alt 1 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-23	2017SP-Alt 1 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017SP-Alt 1 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017SP-Alt 1 BR #5 ON-4.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2017SP-Alt 1 BR #5 ON-4.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2017SP-Alt 1 BR #5 ON-5.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24b	2017SP-Alt 1 BR #5 ON-5.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2017SP-Alt 1 BR #5 ON-6.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2017SP-Alt 1 BR #5 ON-6.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2017SP-Alt 1 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017SP-Alt 1 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017SP-Alt 1 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017SP-Alt 1 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017SP-Alt 1 BR #5 ON-9.a	Battle River 757S
D1-28	2017SP-Alt 1 BR #5 ON-9.b	Battle River 757S
D1-30	2017SP-Alt 1 BR #5 ON-10.a	Hansman Lake (650S) 138 kV
D1-30	2017SP-Alt 1 BR #5 ON-10.b	Hansman Lake (650S) 138 kV
D1-31	2017SP-Alt 1 BR #5 ON-11.a	Hansman Lake (650S) 240 kV
D1-31	2017SP-Alt 1 BR #5 ON-11.b	Hansman Lake (650S) 240 kV
D1-32	2017SP-Alt 1 BR #5 ON-12.a	Tucuman (478S) 138 kV
D1-32	2017SP-Alt 1 BR #5 ON-12.b	Tucuman (478S) 138 kV
D1-33	2017SP-Alt 1 BR #5 ON-13.a	Nilrem 240 kV
D1-33	2017SP-Alt 1 BR #5 ON-13.b	Nilrem 240 kV
D1-34	2017SP-Alt 1 BR #5 ON-14.a	Cordel 240 kV
D1-34	2017SP-Alt 1 BR #5 ON-14.b	Cordel 240 kV
D1-35	2017SP-Alt 1 BR #5 ON-15.a	Marguerite Lake (826S)
D1-35	2017SP-Alt 1 BR #5 ON-15.b	Marguerite Lake (826S)
D1-36	2017SP-Alt 1 BR #5 ON-16.a	Battle River Generating Station 3-4-6
D1-36	2017SP-Alt 1 BR #5 ON-16.b	Battle River Generating Station 3-4-6

Case Summary Page 2017 Alt 2 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 2 BR #5 ON-1.a	Base Case
D1-00	2017WP-Alt 2 BR #5 ON-1.b	Base Case
D1-23	2017WP-Alt 2 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017WP-Alt 2 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017WP-Alt 2 BR #5 ON-3.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2017WP-Alt 2 BR #5 ON-3.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2017WP-Alt 2 BR #5 ON-4.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2017WP-Alt 2 BR #5 ON-4.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2017WP-Alt 2 BR #5 ON-5.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017WP-Alt 2 BR #5 ON-5.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017WP-Alt 2 BR #5 ON-6.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017WP-Alt 2 BR #5 ON-6.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017WP-Alt 2 BR #5 ON-7.a	Battle River 757S
D1-28	2017WP-Alt 2 BR #5 ON-7.b	Battle River 757S
D1-30	2017WP-Alt 2 BR #5 ON-8.a	Hansman Lake (650S) 138 kV
D1-30	2017WP-Alt 2 BR #5 ON-8.b	Hansman Lake (650S) 138 kV
D1-31	2017WP-Alt 2 BR #5 ON-9.a	Hansman Lake (650S) 240 kV
D1-31	2017WP-Alt 2 BR #5 ON-9.b	Hansman Lake (650S) 240 kV
D1-32	2017WP-Alt 2 BR #5 ON-10.a	Tucuman (478S) 138 kV
D1-32	2017WP-Alt 2 BR #5 ON-10.b	Tucuman (478S) 138 kV
D1-33	2017WP-Alt 2 BR #5 ON-11.a	Nilrem 240 kV
D1-33	2017WP-Alt 2 BR #5 ON-11.b	Nilrem 240 kV
D1-34	2017WP-Alt 2 BR #5 ON-12.a	Cordel 240 kV
D1-34	2017WP-Alt 2 BR #5 ON-12.b	Cordel 240 kV
D1-35	2017WP-Alt 2 BR #5 ON-13.a	Marguerite Lake (826S)
D1-35	2017WP-Alt 2 BR #5 ON-13.b	Marguerite Lake (826S)
D1-36	2017WP-Alt 2 BR #5 ON-14.a	Battle River Generating Station 3-4-6
D1-36	2017WP-Alt 2 BR #5 ON-14.b	Battle River Generating Station 3-4-6

Case Summary Page 2017 Alt 2 SP BR #5 ON


Contingency Number	Fig #	Description
D1-00	2017SP-Alt 2 BR #5 ON-1.a	Base Case
D1-00	2017SP-Alt 2 BR #5 ON-1.b	Base Case
D1-23	2017SP-Alt 2 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017SP-Alt 2 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017SP-Alt 2 BR #5 ON-3.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-24	2017SP-Alt 2 BR #5 ON-3.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Lloydminster 716S (7L749) Briker 880S Tap
D1-25	2017SP-Alt 2 BR #5 ON-4.a	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-25	2017SP-Alt 2 BR #5 ON-4.b	Hansman Lake 650S to Provost 545S (715L) and Metiskow 648S to Killarney 267S (7L749)
D1-26	2017SP-Alt 2 BR #5 ON-5.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017SP-Alt 2 BR #5 ON-5.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017SP-Alt 2 BR #5 ON-6.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017SP-Alt 2 BR #5 ON-6.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017SP-Alt 2 BR #5 ON-7.a	Battle River 757S
D1-28	2017SP-Alt 2 BR #5 ON-7.b	Battle River 757S
D1-30	2017SP-Alt 2 BR #5 ON-8.a	Hansman Lake (650S) 138 kV
D1-30	2017SP-Alt 2 BR #5 ON-8.b	Hansman Lake (650S) 138 kV
D1-31	2017SP-Alt 2 BR #5 ON-9.a	Hansman Lake (650S) 240 kV
D1-31	2017SP-Alt 2 BR #5 ON-9.b	Hansman Lake (650S) 240 kV
D1-32	2017SP-Alt 2 BR #5 ON-10.a	Tucuman (478S) 138 kV
D1-32	2017SP-Alt 2 BR #5 ON-10.b	Tucuman (478S) 138 kV
D1-33	2017SP-Alt 2 BR #5 ON-11.a	Nilrem 240 kV
D1-33	2017SP-Alt 2 BR #5 ON-11.b	Nilrem 240 kV
D1-34	2017SP-Alt 2 BR #5 ON-12.a	Cordel 240 kV
D1-34	2017SP-Alt 2 BR #5 ON-12.b	Cordel 240 kV
D1-35	2017SP-Alt 2 BR #5 ON-13.a	Marguerite Lake (826S)
D1-35	2017SP-Alt 2 BR #5 ON-13.b	Marguerite Lake (826S)
D1-36	2017SP-Alt 2 BR #5 ON-14.a	Battle River Generating Station 3-4-6
D1-36	2017SP-Alt 2 BR #5 ON-14.b	Battle River Generating Station 3-4-6

Case Summary Page 2017 Alt 3 WP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2017WP-Alt 3 BR #5 ON-1.a	Base Case
D1-00	2017WP-Alt 3 BR #5 ON-1.b	Base Case
D1-20	2017WP-Alt 3 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-20	2017WP-Alt 3 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-21	2017WP-Alt 3 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2017WP-Alt 3 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-22	2017WP-Alt 3 BR #5 ON-4.a	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-22	2017WP-Alt 3 BR #5 ON-4.b	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-23	2017WP-Alt 3 BR #5 ON-5.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017WP-Alt 3 BR #5 ON-5.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017WP-Alt 3 BR #5 ON-6.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24	2017WP-Alt 3 BR #5 ON-6.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-26	2017WP-Alt 3 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017WP-Alt 3 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017WP-Alt 3 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017WP-Alt 3 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017WP-Alt 3 BR #5 ON-9.a	Battle River 757S
D1-28	2017WP-Alt 3 BR #5 ON-9.b	Battle River 757S
D1-29	2017WP-Alt 3 BR #5 ON-10.a	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-29	2017WP-Alt 3 BR #5 ON-10.b	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-30	2017WP-Alt 3 BR #5 ON-11.a	Hansman Lake (650S) 138 kV
D1-30	2017WP-Alt 3 BR #5 ON-11.b	Hansman Lake (650S) 138 kV
D1-31	2017WP-Alt 3 BR #5 ON-12.a	Hansman Lake (650S) 240 kV
D1-31	2017WP-Alt 3 BR #5 ON-12.b	Hansman Lake (650S) 240 kV
D1-32	2017WP-Alt 3 BR #5 ON-13.a	Tucuman (478S) 138 kV
D1-32	2017WP-Alt 3 BR #5 ON-13.b	Tucuman (478S) 138 kV
D1-33	2017WP-Alt 3 BR #5 ON-14.a	Nilrem 240 kV
D1-33	2017WP-Alt 3 BR #5 ON-14.b	Nilrem 240 kV
D1-34	2017WP-Alt 3 BR #5 ON-15.a	Cordel 240 kV
D1-34	2017WP-Alt 3 BR #5 ON-15.b	Cordel 240 kV
D1-35	2017WP-Alt 3 BR #5 ON-16.a	Marguerite Lake (826S)
D1-35	2017WP-Alt 3 BR #5 ON-16.b	Marguerite Lake (826S)
D1-36	2017WP-Alt 3 BR #5 ON-17.a	Battle River Generating Station 3-4-6
D1-36	2017WP-Alt 3 BR #5 ON-17.b	Battle River Generating Station 3-4-6

Case Summary Page 2017 Alt 3 SP BR #5 ON

Contingency Number	Fig #	Description
D1-00	2017SP-Alt 3 BR #5 ON-1.a	Base Case
D1-00	2017SP-Alt 3 BR #5 ON-1.b	Base Case
D1-20	2017SP-Alt 3 BR #5 ON-2.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-20	2017SP-Alt 3 BR #5 ON-2.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S to Loydminster 716S (7L42)
D1-21	2017SP-Alt 3 BR #5 ON-3.a	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-21	2017SP-Alt 3 BR #5 ON-3.b	Bonnyville 700S to Irish Creek 706S (7L53) and Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap
D1-22	2017SP-Alt 3 BR #5 ON-4.a	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-22	2017SP-Alt 3 BR #5 ON-4.b	Bonnyville 700S to Irish Creek 706S (7L53) and Vermilion 710S to Kitscoty 705S Tap
D1-23	2017SP-Alt 3 BR #5 ON-5.a	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-23	2017SP-Alt 3 BR #5 ON-5.b	Bonnyville 700S to Irish Creek 706S (7L53) and Hill 751S (7L14) to Kitscoty 705S Tap
D1-24	2017SP-Alt 3 BR #5 ON-6.a	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-24	2017SP-Alt 3 BR #5 ON-6.b	Battle River 757S to Buffalo Creek 526S (7L50) Jarrow 252S Tap and Edgerton 899S to Loydminster 716S (7L749) Briker 880S Tap
D1-26	2017SP-Alt 3 BR #5 ON-7.a	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-26	2017SP-Alt 3 BR #5 ON-7.b	Cordel 755S to Paintearth Creek 863S (9L27) and Cordel 755S to Nilrem (9LNew)
D1-27	2017SP-Alt 3 BR #5 ON-8.a	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-27	2017SP-Alt 3 BR #5 ON-8.b	Bonnyville 700S (7L24) (7L53) (7L89) (7L139)
D1-28	2017SP-Alt 3 BR #5 ON-9.a	Battle River 757S
D1-28	2017SP-Alt 3 BR #5 ON-9.b	Battle River 757S
D1-29	2017SP-Alt 3 BR #5 ON-10.a	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-29	2017SP-Alt 3 BR #5 ON-10.b	Metiskow (648S) 138 kV (70L3) (749L) (885L) (Killarney Tap)
D1-30	2017SP-Alt 3 BR #5 ON-11.a	Hansman Lake (650S) 138 kV
D1-30	2017SP-Alt 3 BR #5 ON-11.b	Hansman Lake (650S) 138 kV
D1-31	2017SP-Alt 3 BR #5 ON-12.a	Hansman Lake (650S) 240 kV
D1-31	2017SP-Alt 3 BR #5 ON-12.b	Hansman Lake (650S) 240 kV
D1-32	2017SP-Alt 3 BR #5 ON-13.a	Tucuman (478S) 138 kV
D1-32	2017SP-Alt 3 BR #5 ON-13.b	Tucuman (478S) 138 kV
D1-33	2017SP-Alt 3 BR #5 ON-14.a	Nilrem 240 kV
D1-33	2017SP-Alt 3 BR #5 ON-14.b	Nilrem 240 kV
D1-34	2017SP-Alt 3 BR #5 ON-15.a	Cordel 240 kV
D1-34	2017SP-Alt 3 BR #5 ON-15.b	Cordel 240 kV
D1-35	2017SP-Alt 3 BR #5 ON-16.a	Marguerite Lake (826S)
D1-35	2017SP-Alt 3 BR #5 ON-16.b	Marguerite Lake (826S)
D1-36	2017SP-Alt 3 BR #5 ON-17.a	Battle River Generating Station 3-4-6
D1-36	2017SP-Alt 3 BR #5 ON-17.b	Battle River Generating Station 3-4-6



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-00

2017WP-Alt 1 BR#5 ON-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-00

2017WP-Alt 1 BR#5 ON-1.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV.0.920UV
 kV: >0.000=<35.000 <69.000 <138.000=<240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-21

2017WP-Alt 1 BR#5 ON-2.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0%RATEB
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-21

2017WP-Ait 1 BR#5 ON-2.b


Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.0900V0.920UV
 kV: >0.000=<35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-23

2017WP-Alt 1 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:13
 D1-24

2017WP-Alt 1 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-24b

2017WP-Alt 1 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-25

2017WP-Alt 1 BR#5 ON-6.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-26

2017WP-Alt 1 BR#5 ON-7.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-27

2017WP-Ait 1 BR#5 ON-8.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.2kV/0.94kV/0.48kV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-27

2017WP-AIt 1 BR#5 ON-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV.0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-28

2017WP-Alt 1 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-30

2017WP-A1t 1 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-31

2017WP-Ait 1 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA


VEGREVILLE AREA


LOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:14
 D1-32

2017WP-Alt 1 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA


VEGREVILLE AREA


LYOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:15
 D1-33

2017WP-Alt 1 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:15
 D1-34


2017WP-AIt 1 BR#5 ON-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA


LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 30 2010 16:15
 D1-35

2017WP-Alt 1 BR#5 ON-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0%RATEB
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000










CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:53
 D1-00

2017SP-Alt 1 BR#5 ON-1.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000







COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:54
 D1-23

2017SP-A1t 1 BR#5 ON-3.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:54
 D1-23

2017SP-AIt 1 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:54
 D1-24b

2017SP-Alt 1 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA




VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA


BATTLE RIVER AREA



VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-28

2017SP-Alt 1 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-28

2017SP-Alt 1 BR#5 ON-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-30

2017SP-AIt 1 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-32


2017SP-Alt 1 BR#5 ON-12.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:50
 D1-33


2017SP-Alt 1 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-34


2017SP-Ait 1 BR#5 ON-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:55
 D1-35


2017SP-Ait 1 BR#5 ON-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

Cold Lake Area Vegreville Area

Cold Lake Area Lloydminster Area

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
FRI, APR 09 2010 10:55
D1-36


2017SP-Alt 1 BR#5 ON-16.a

Bus - VOLTAGE (kV/PU)
Branch - MVA/% OF RATE A
Equipment - MW/Mvar
100.0% RATE A
1:1200V 0.940UV
kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:59
 D1-00


2017WP-Alt 2 BR#5 ON-1.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:59
 D1-23

2017WP-Alt 2 BR#5 ON-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:59
 D1-23

2017WP-Alt 2 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:59
 D1-24

2017WP-Alt 2 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 10:59
 D1-24

2017WP-AIt 2 BR#5 ON-3.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1.090OV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 12:31
 D1-25

2017WP-Alt 2 BR#5 ON-4.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-26

2017WP-Alt 2 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-27

2017WP-Alt 2 BR#5 ON-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-28


2017WP-Alt 2 BR#5 ON-7.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-30

2017WP-Ait 2 BR#5 ON-8.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-31


2017WP-Alt 2 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-32


2017WP-AIt 2 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:55
 D1-33


2017WP-Ait 2 BR#5 ON-11.a

Bus - VOLTAGE (kV/PV)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:00
 D1-34


2017WP-Alt 2 BR#5 ON-12.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATE B
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA








CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:01
 D1-36


2017WP-AIt 2 BR#5 ON-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-00

2017SP-Alt 2 BR#5 ON-1.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/M OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-00

2017SP-Alt 2 BR#5 ON-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090QV 0.920UV
 kV: >0.00<=35.00 <=69.00 <=138.00 <=240.00




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-23


2017SP-Alt 2 BR#5 ON-2.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-24

2017SP-Ait 2 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.1200V 0.9400V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-24

2017SP-AIt 2 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090QV 0.920UV
 kV: >0.00<=35.000 <=69.000 <=138.000 <=240.000





2017SP-Alt 2 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-26

2017SP-Alt 2 BR#5 ON-5.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-26

2017SP-Alt 2 BR#5 ON-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920UV
 kV: >0.00<=35.000 <=69.000 <=138.000 <=240.000



2017SP-Alt 2 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1.1200V, 0.9400V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA

Vegreville Area
Wainwright Area

Wainwright Area
Provost Area


Wainwright Area
Battle River Area


Battle River Area
Provost Area



VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-30


2017SP-Alt 2 BR#5 ON-8.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:07
 D1-31


2017SP-Alt 2 BR#5 ON-9.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:08
 D1-32


2017SP-AIt 2 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:56
 D1-33


2017SP-A1t 2 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:08
 D1-34

2017SP-Alt 2 BR#5 ON-12.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:08
 D1-34

2017SP-Alt 2 BR#5 ON-12.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.920UV
 kV: >0.00<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:08
 D1-35


2017SP-Alt 2 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:08
 D1-36


2017SP-Ait 2 BR#5 ON-14.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-00

2017WP-Alt 3 BR#5 ON-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090QV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:53
 D1-20

2017WP-Alt 3 BR#5 ON-2.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:53
 D1-20

2017WP-Ait 3 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-21

2017WP-Alt 3 BR#5 ON-3.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-21

2017WP-AIt 3 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090QV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:52
 D1-22


2017WP-Alt 3 BR#5 ON-4.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-23


2017WP-Alt 3 BR#5 ON-5.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-24

2017WP-Alt 3 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-24

2017WP-Alt 3 BR#5 ON-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090QV0.920UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:14
 D1-26

2017WP-Alt 3 BR#5 ON-7.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-27

2017WP-Alt 3 BR#5 ON-8.b


Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-28

2017WP-Alt 3 BR#5 ON-9.a


Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-28

2017WP-Alt 3 BR#5 ON-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.090OV0.920UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:51
 D1-29

2017WP-Alt 3 BR#5 ON-10.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:51
 D1-29

2017WP-Alt 3 BR#5 ON-10.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.0900OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-30

2017WP-Ait 3 BR#5 ON-11.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V, 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA


WAINWRIGHT AREA



VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-32


2017WP-Alt 3 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:59
 D1-33

2017WP-Ait 3 BR#5 ON-14.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000


VEGREVILLE AREA

WAINWRIGHT AREA



VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-34

2017WP-Alt 3 BR#5 ON-15.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATED
 1.090OV0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA


LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:15
 D1-35

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:16
 D1-35

2017WP-Alt 3 BR#5 ON-16.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.0900V0.920UV
 KV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:16
 D1-36

2017WP-Alt 3 BR#5 ON-17.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 WINTER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:16
 D1-36

2017WP-AIt 3 BR#5 ON-17.6

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE B
 Equipment - MW/Mvar
 100.0% RATES
 1.0900V0.920UV
 kV: >0.000<=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:19
 D1-00

2017SP-Alt 3 BR#5 ON-1.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:19
 D1-00

2017SP-Alt 3 BR#5 ON-1.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:55
 D1-20

2017SP-AIt 3 BR#5 ON-2.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0-000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:55
 D1-20

2017SP-Alt 3 BR#5 ON-2.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATEA
 1.090QV 0.920UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




2017SP-Alt 3 BR#5 ON-3.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 1.1200V, 0.940UV, 1.000V
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:19
 D1-21

2017SP-AIt 3 BR#5 ON-3.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090kV 0.920kV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:55
 D1-22


2017SP-Alt 3 BR#5 ON-4.a

Bus - VOLTAGE (KV/PH)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-23

2017SP-AIt 3 BR#5 ON-5.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-23

2017SP-Alt 3 BR#5 ON-5.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200UV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-24

2017SP-Alt 3 BR#5 ON-6.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-24

2017SP-Alt 3 BR#5 ON-6.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.090kV 0.920kV
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA


CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-26


2017SP-Alt 3 BR#5 ON-7.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-27

2017SP-Alt 3 BR#5 ON-8.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-27

2017SP-Alt 3 BR#5 ON-8.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-28

2017SP-AIt 3 BR#5 ON-9.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA


WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-28

2017SP-Alt 3 BR#5 ON-9.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA

VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 MON, APR 12 2010 10:54
 D1-29

2017SP-Alt 3 BR#5 ON-10.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

PROVOST AREA


BATTLE RIVER AREA


Vegreville Area
Wainwright Area

Wainwright Area
Provost Area

Battle River Area
Wainwright Area

Battle River Area
Provost Area






CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-30


Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017SP-Alt 3 BR#5 ON-11.a

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-31

2017SP-Alt 3 BR#5 ON-12.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



VEGREVILLE AREA

WAINWRIGHT AREA


PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-31

2017SP-Alt 3 BR#5 ON-12.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000



COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:20
 D1-32

2017SP-Alt 3 BR#5 ON-13.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 12:00
 D1-33


2017SP-AIt 3 BR#5 ON-14.a

Bus - VOLTAGE (KV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0%RATE
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA





COLD LAKE AREA


VEGREVILLE AREA

LLOYDMINSTER AREA

CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:21
 D1-34

2017SP-AIt 3 BR#5 ON-15.a

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000




CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:21
 D1-35

Bus - VOLTAGE (KV/PU)
 Branch - MVA% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1:1200V 0.940UV
 kv: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

2017SP-Ait 3 BR#5 ON-16.a

VEGREVILLE AREA

WAINWRIGHT AREA



CENTRAL AREA STUDY
 2017 SUMMER PEAK BASE CASE REVISION 7.2
 FRI, APR 09 2010 11:21
 D1-35

2017SP-Alt 3 BR#5 ON-16.b

Bus - VOLTAGE (kV/PU)
 Branch - MVA/% OF RATE A
 Equipment - MW/Mvar
 100.0% RATE A
 1.0900V 0.9200V
 kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

VEGREVILLE AREA

WAINWRIGHT AREA

BATTLE RIVER AREA

PROVOST AREA

BATTLE RIVER AREA

CENTRAL AREA STUDY
2017 SUMMER PEAK BASE CASE REVISION 7.2
FRI, APR 09 2010 11:21
D1-36

2017SP-Alt 3 BR#5 ON-17.b

Bus - VOLTAGE (kV/PU)
Branch - MVA/% OF RATE A
Equipment - MW/Mvar
100.0% RATE A
1.0900V 0.9200V
kV: >0.000 <=35.000 <=69.000 <=138.000 <=240.000

