

## Number of transaction requests by type:

Type	# of Sites	# of transaction requests
DOS 7 minute	31 (2 sites currently)	2501
DOS 1 hour	11 (last used in 2004)	207
DOS term	22 (1 site currently)	66

DOS recalls occur for three primary reasons:

- 1) supply adequacy (Energy Emergency Alert (EEA) events)
- 2) real-time transmission constraint
- 3) voltage support

## Number of recalls by reason:

Year	Reason	# of DOS recalls
2006 - 2012	Supply Adequacy	32 EEA events
	Constraint and Voltage	70
2013 - 2021	Supply Adequacy	41 EEA events
	Constraint and Voltage	1*

\*Information on transmission constraint frequency resolved by in merit generation is available in the *Estimated Cost of Constraint* report on [ets.aeso.ca](https://www.aeso.ca/ets)