

October 14, 2020

To: Market Surveillance Administrator, Market Participants and Other Interested Parties

Re: **Letter of Notice for the Proposed Removal of Section 305.2 of the ISO Rules, *Calgary Under Voltage Load Shed***

Pursuant to Section 4 of Alberta Utilities Commission Rule 017: *Procedures and Process for Development of ISO Rules and Filing of ISO Rules with the Alberta Utilities Commission*, the Alberta Electric System Operator (“AESO”) is providing notice and seeking feedback from the Market Surveillance Administrator, market participants, and other interested parties (“Stakeholders”) on the proposed removal of Section 305.2 of the ISO rules, *Calgary Under Voltage Load Shed* (“Section 305.2”).

### Issue

Section 305.2 was originally implemented in 2012 and outlines the obligations of the operator of a transmission facility in relation to the operation of components of the Calgary under voltage load shed scheme. The Calgary under voltage load shed scheme was disabled on February 28, 2017. As a result, Section 305.2 is no longer required.

### Objectives/Purpose

The intent of this consultation is to notify Stakeholders that Section 305.2 is no longer required.

### Proposed Consultation and Timeline

The AESO is proposing that no further consultation on the removal of Section 305.2 take place. Further, the AESO proposes to move directly to filing an application with the Alberta Utilities Commission (“Commission”) for approval of the proposed removal of Section 305.2.

### Stakeholder Comments

Stakeholders may submit:

- (i) written comments;
- (ii) a notice of intent to participate in consultation; and
- (iii) comments on the form of consultation;

Please use the *Stakeholder Comment Matrix – Proposed Removal of Section 305.2* when submitting comments to the AESO. Stakeholders should ensure that comments provided represent all interests within their organization.

The deadline for Stakeholders to provide comments is November 2, 2020, to [rules\\_comments@aeso.ca](mailto:rules_comments@aeso.ca). Adherence to deadlines is essential to the integrity of the comment process, and as such, the AESO may choose not to consider any Stakeholder comments received after the deadline.

The AESO will publish all Stakeholder comments, received by the deadline, on the AESO website on November 6, 2020.

If no comments are received by the AESO regarding the proposed removal of Section 305.2, the AESO will proceed directly to filing an application with the Commission for approval.

**Related Materials**

1. [Stakeholder Comment Matrix – Proposed Removal of Section 305.2](#)
2. [Copy of existing Section 305.2, Calgary Under Voltage Load Shed](#)

Sincerely,

*Alison Desmarais*

Regulatory Administrator  
Legal & Regulatory Affairs  
[rules\\_comments@aeso.ca](mailto:rules_comments@aeso.ca)