

Proposed Proposed New Alberta Reliability Standard PRC-002-AB-2, *Disturbance Monitoring and Reporting Requirements* (“new PRC-002-AB-2”)

Date of Request for Comment: <u>September 18, 2018</u> Period of Comment: <u>September 18, 2018</u> through <u>October 3, 2018</u> Comments From: <u>TransAlta</u> Date [yyyy/mm/dd]: <u>2018/10/03</u>	Contact: <u>Morgan Tam</u> Phone: <u>403.267.4642</u> Email: <u>Morgan_Tam@TransAlta.com</u>
--	--

Listed below is the summary description of changes for the proposed new PRC-002-AB-2. Please refer back to the Consultation Letter under the “Attachments” section to view materials related to the proposed new PRC-002-AB-2”. Please place your comments/reasons for position underneath (if any).

Alberta Reliability Standard	Market Participant Comments and/or Alternative Proposal
<p>New</p> <p>The AESO is seeking comments from market participants with regard to the following matters:</p> <ol style="list-style-type: none"> Are there any requirements contained in proposed new PRC-002-AB-2 that are not clearly articulated? If yes, please indicate the specific section of proposed new PRC-002-AB-2 , describe the concern and suggest alternative language. Please provide any additional comments regarding proposed new PRC-002-AB-2. 	<p><i>Comment # 1:</i></p> <p>R1, R5: TransAlta requests the AESO includes a list of all identified system elements in R1 and R5. The list can be similar to that available in PRC-018-AB-1 and should include either disturbance monitoring equipment (DME) list or system elements where sequence of events recording data, fault recording data, and dynamic disturbance recording data are required.</p> <p>.</p>