

Alberta Reliability Standard UFLS Performance Following an Underfrequency Event PRC-009-AB-0

PRC-009-AB-0 UFLS Performance Following an Underfrequency Event

1. Purpose

The purpose of this *reliability standard* is to ensure effectiveness of the *UFLS* program performance.

2. Applicability

This *reliability standard* applies to:

ISO

3. Definitions

Italicized terms used in this *reliability standard* have the meanings as set out in the <u>Alberta Reliability Standards Glossary of Terms</u> and Part 1 of the <u>ISO Rules</u>.

4. Requirements

- R1 The ISO must analyze and document its UFLS program performance in accordance with WECC's UFLS program. The analysis must address the performance of UFLS equipment and program effectiveness following system events resulting in system frequency excursions below the initializing set points of the UFLS program. The analysis must include, without limitation the following:
 - A description of the *system* event including initiating conditions.
 - A review of the UFLS set points and tripping times.
 - A simulation of the system event.
 - · A summary of the findings.
- R2 The *ISO* must provide documentation of the analysis of the *UFLS* program performance to *WECC* on request and within the timeframe agreed to by the *ISO* and *WECC*.

5. Processes and Procedures

No procedures have been defined for this *reliability standard*.

6. Measures

The following measures correspond to the requirements identified in Section 4 of this *reliability standard*. For example, MR1 is the measure for R1.

MR1 Disturbance document(s) exist for each *UFLS* event. The disturbance document(s) contain analysis of the event.

MR2 Written confirmation from WECC that documentation was received.

Effective: 2009-10-03 Page 1 of 2

7. Appendices

No appendices have been defined for this reliability standard.

8. Guidelines

No guidelines have been defined for this reliability standard.

Revision History

Effective	Description
2009-10-03	New Issue

Effective: 2009-10-03 Page 2 of 2