

**Settlement: 2009 Inter-Ties Loss Factors**

**BC Tie**

Transaction Type	Loss Factor (%)	Average Loss Charge (%)	Settlement LF (%)
Import	-0.62%	0.99%	0.36%
Export	0	1.05%	1.05%

**SK Tie**

Transaction Type	Loss Factor (%)	Average Loss Charge (%)	Settlement LF (%)
Import	1.35%	2.50%	3.85%
Export	-	2.30%	2.30%

**Notes:**

1. As per the 2007 Transmission Regulation, the inter-tie losses will be included in the overall loss factor calculation
2. The losses are calculated based on the historic flows on the BC 138 kV and 500 kV inter-tie
3. The losses on the Saskatchewan inter-tie are based on the converter station at McNeill
4. For inter-tie loss details, please refer to the work provided on the AESO web site:  
[http://www.aeso.ca/downloads/Tie\\_Loss\\_New\\_T-Reg\\_20070927.pdf](http://www.aeso.ca/downloads/Tie_Loss_New_T-Reg_20070927.pdf)
5. Values may not add due to rounding.

October 22, 2008