

**A. Introduction**

- 1. Title:** Maintenance and Distribution of Steady-State Data Requirements and Reporting Procedures.
- 2. Number:** MOD-011-0
- 3. Purpose:** To establish consistent data requirements, reporting procedures, and system models to be used in the analysis of the reliability of the interconnected transmission systems.
- 4. Applicability:**
  - 4.1.** Regional Reliability Organization
- 5. Effective Date:** April 1, 2005

**B. Requirements**

- R1.** The Regional Reliability Organizations within an Interconnection, in conjunction with the Transmission Owners, Transmission Planners, Generator Owners, and Resource Planners, shall develop comprehensive steady-state data requirements and reporting procedures needed to model and analyze the steady-state conditions for each of the NERC Interconnections: Eastern, Western, and ERCOT. Within an Interconnection, the Regional Reliability Organizations shall jointly coordinate the development of the data requirements and reporting procedures for that Interconnection. The Interconnection-wide requirements shall include the following steady-state data requirements:
  - R1.1.** Bus (substation): name, nominal voltage, electrical demand supplied (consistent with the aggregated and dispersed substation demand data supplied per Reliability Standards MOD-016-0, MOD-017-0, and MOD-020-0 ), and location.
  - R1.2.** Generating Units (including synchronous condensers, pumped storage, etc.): location, minimum and maximum Ratings (net Real and Reactive Power), regulated bus and voltage set point, and equipment status.
  - R1.3.** AC Transmission Line or Circuit (overhead and underground): nominal voltage, impedance, line charging, Normal and Emergency Ratings (consistent with methodologies defined and Ratings supplied per Reliability Standard FAC-004-0 and FAC-005-0 ) equipment status, and metering locations.
  - R1.4.** DC Transmission Line (overhead and underground): line parameters, Normal and Emergency Ratings, control parameters, rectifier data, and inverter data.
  - R1.5.** Transformer (voltage and phase-shifting): nominal voltages of windings, impedance, tap ratios (voltage and/or phase angle or tap step size), regulated bus and voltage set point, Normal and Emergency Ratings (consistent with methodologies defined and Ratings supplied per Reliability Standard FAC-004-0 and FAC-005-0.), and equipment status.
  - R1.6.** Reactive Compensation (shunt and series capacitors and reactors): nominal Ratings, impedance, percent compensation, connection point, and controller device.
  - R1.7.** Interchange Schedules: Existing and future Interchange Schedules and/or assumptions.
- R2.** The Regional Reliability Organizations within an Interconnection shall document their Interconnection's steady-state data requirements and reporting procedures, shall review those data requirements and reporting procedures (at least every five years), and shall make the data

requirements and reporting procedures available on request (within five business days) to Regional Reliability Organizations, NERC, and all users of the interconnected transmission systems.

**C. Measures**

- M1.** The Regional Reliability Organization shall have documentation of its Interconnection’s steady-state data requirements and reporting procedures and shall provide the documentation as specified in Reliability Standard MOD-011-0\_R2.

**D. Compliance**

**1. Compliance Monitoring Process**

**1.1. Compliance Monitoring Responsibility**

Compliance Monitor: NERC.

**1.2. Compliance Monitoring Period and Reset Timeframe**

Periodic review of data requirements and reporting procedures: at least every five years.

**1.3. Data Retention**

None specified.

**1.4. Additional Compliance Information**

None.

**2. Levels of Non-Compliance**

**2.1. Level 1:** Data requirements and reporting procedures for steady-state data were provided, but were incomplete in one of the seven areas defined in Reliability Standard MOD-011-0\_R1.

**2.2. Level 2:** Data requirements and reporting procedures for steady-state data were provided, but were incomplete in two of the seven areas defined in Reliability Standard MOD-011-0\_R1.

**2.3. Level 3:** Not applicable.

**2.4. Level 4:** Data requirements and reporting procedures for steady-state data were not provided, or the data requirements and reporting procedures provided were incomplete in three or more of the seven areas defined in Reliability Standard MOD-011-0\_R1.

**E. Regional Differences**

- 1.** None identified.

**Version History**

<b>Version</b>	<b>Date</b>	<b>Action</b>	<b>Change Tracking</b>
0	April 1, 2005	Effective Date	New

