

## **APPENDIX A CONNECTION ASSESSMENT**

# Engineering Connection Assessment

## P2122 Cypress Wind Power Project




### Connection


Cypress Renewable Energy Centre LP.

**Date:** March 09, 2020

**Version:** Final

**Classification:** Public

Role	Name	Date	Signature
Prepared	Payam Zamani, PhD, P. Eng.	March 9, 2020	
Reviewed	Siavash Zoroofi, PhD, P. Eng.	March 09, 2020	
Approved	Maz Mazadi, PhD, P. Eng.	March 9, 2020	



**APEGA**  
Permit-to-Practice

P-8200   
2020-03-16

## Engineering Connection Assessment

P2122 Cypress Wind Power Project Connection

Final



### NOTE:

The conclusions and recommendations in this report are based on the results presented in *Attachment A: Engineering Connection Assessment: Study Results*, which was prepared by a third party consultant in accordance with the AESO Connection Process.

The AESO has reviewed the *Engineering Connection Assessment: Study Results*, and finds it acceptable for the purpose of assessing the potential impacts of the proposed connection on the performance of the Alberta interconnected electric system.

# Contents

<b>1</b>	<b>Introduction .....</b>	<b>1</b>
1.1	Project Overview .....	1
<b>2</b>	<b>Assessment Scope .....</b>	<b>2</b>
2.1	Objectives .....	2
2.2	Existing System .....	2
2.3	Study Area .....	2
<b>3</b>	<b>Connection Alternatives .....</b>	<b>3</b>
3.1	Overview .....	3
3.2	Connection Alternatives Examined .....	3
3.3	Connection Alternatives Selected for Further Study .....	7
3.4	Connection Alternatives Not Selected for Further Study .....	7
<b>4</b>	<b>Assessment Approach .....</b>	<b>8</b>
4.1	Standards, Criteria and Assumptions .....	8
4.2	Studies Performed .....	8
4.2.1	<i>Power Flow Studies</i> .....	9
4.2.2	<i>Transient Stability Studies</i> .....	9
4.2.3	<i>Short-Circuit Current Level Studies</i> .....	9
4.3	Mitigation Measure Development and Evaluation .....	9
4.3.1	<i>Post-Mitigation Studies</i> .....	9
4.3.2	<i>Constraint Effective Factor Studies</i> .....	9
<b>5</b>	<b>Interpretation of Results .....</b>	<b>10</b>
5.1	Results Overview .....	10
5.2	Pre-Project Study Results .....	12
5.2.1	<i>Category A Conditions</i> .....	12
5.2.2	<i>Category B Conditions</i> .....	12
5.3	Post-Project Study Results .....	12
5.3.1	<i>Category A Conditions</i> .....	12
5.3.2	<i>Category B Conditions</i> .....	12
5.4	Mitigation Measures .....	12
5.4.1	<i>Pre-Project</i> .....	12
5.4.2	<i>Post-Project</i> .....	13
5.4.3	<i>Post-Project Mitigation Study Results</i> .....	13
<b>6</b>	<b>Project Dependencies .....</b>	<b>14</b>
<b>7</b>	<b>Conclusions and Recommendations .....</b>	<b>15</b>



## Tables

Table 4-1: Connection Study Scenarios.....	8
Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures .....	11

## Figures

Figure 3-1: Connection Alternative 1.....	4
Figure 3-2: Connection Alternative 2.....	6

## Attachments

Attachment A: Engineering Connection Assessment Results

# 1 Introduction

This AESO Engineering Connection Assessment describes the engineering studies that were completed to assess the impact of the Project (as defined below) on the performance of the Alberta interconnected electric system (AIES). This report also provides the AESO's conclusions and recommendations based on the results of the engineering studies.

Attached to this Engineering Connection Assessment are the results of the engineering studies (see Attachment A) and the scope and methodology used to perform the studies (see Attachment A1 to Attachment A). These attachments provide details regarding the technical criteria, assumptions, and methods for performing these engineering studies, and the results of the engineering studies.

## 1.1 Project Overview

Cypress Renewable Energy Centre LP. (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its approved Cypress Wind Power Project (Facility) to the AIES. The Facility includes an approved collector station, designated as the Woolchester 1019S substation. The Facility is planned to be located in the Dunmore area, in the AESO planning area of Medicine Hat (Area 4).

The Market Participant's request includes: a request for a new system access service in the area, with a Rate STS, *Supply Transmission Service*, contract capacity of 201.6 MW, and a Rate DTS, *Demand Transmission Service*, contract capacity of 2.7 MW, and a request for transmission development (collectively, the Project).

The scheduled in-service date (ISD) for the Project is November 1, 2021.

## 2 Assessment Scope

### 2.1 Objectives

The objectives of the AESO Engineering Connection Assessment are as follows:

- Assess the impact of the Project on the performance of the AIES.
- Evaluate Project connection alternatives and identify the AESO's preferred alternative.
- Recommend mitigation measures, if required, to reliably connect the Project to the AIES.
- Identify Project dependencies, including any legal owner of a transmission facility (TFO) projects or AESO plans to expand or enhance the transmission system that must be completed prior to connection.

### 2.2 Existing System

Geographically, the Project is located in the AESO planning area of Medicine Hat (Area 4) which is part of the AESO South Planning Region. Medicine Hat (Area 4) is surrounded by the planning areas of Brooks (Area 47), Empress (Area 48), and Vauxhall (Area 52).

From a transmission system perspective, Medicine Hat (Area 4) consists primarily of 240 kV and 138 kV transmission systems. Medicine Hat (Area 4) is connected to the AESO planning area of Brooks (Area 47) through the 240 kV transmission lines 1034L and 1035L and 138 kV transmission line 100L, connected to the AESO planning area of Empress (Area 48) through the 138 kV transmission line 658L, and connected to the AESO planning area of Vauxhall (Area 52) through the 138 kV transmission line 879L.

Existing constraints in the South planning region are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, Real Time Transmission Constraint Management (TCM Rule).

### 2.3 Study Area

The Study Area for the Project consists of the AESO Planning areas of Medicine Hat (Area 4), Brooks (Area 47), Empress (Area 48), and Vauxhall (Area 52), including the tie lines connecting these planning areas to the rest of the AIES. All transmission facilities within the Study Area will be studied and monitored for violations of the Reliability Criteria (defined in Section 3.1 of Attachment A1).

## 3 Connection Alternatives

### 3.1 Overview

The AESO, in consultation with the TFO in the Study Area and the Market Participant, examined two (2) transmission alternatives to meet the Market Participant's request for system access service, as detailed in Section 3.2.

### 3.2 Connection Alternatives Examined

Below is a description of the developments associated with the transmission alternatives that were examined for the Project.

#### **Alternative 1 – T-tap connection to the 240 kV transmission line 983L**

This alternative includes the following developments:


- Add one 240 kV circuit, approximately 70 metres in length,<sup>1</sup> to connect the Facility to the existing 240 kV transmission line 983L (between the Bowmanton 244S substation and the Whittle 251S substation) using a T-tap configuration; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-1.

---

<sup>1</sup> Exact line length is to be determined by the TFO

Figure 3-1: Connection Alternative 1



**Alternative 2 – T-tap connection to the 240 kV transmission line 964L**

This alternative includes the following developments:

- Add one 240kV circuit, approximately 90 metres in length,<sup>2</sup> to connect the Facility to the existing 240 kV transmission line 964L (between the Bowmanton 244S substation and the

<sup>2</sup> Exact line length is to be determined by the TFO

## Engineering Connection Assessment

P2122 Cypress Wind Power Project Connection

Final




Whitla 251S substation) using a T-tap configuration. This alternative also requires a crossing of the existing 240 kV transmission line 983L; and

- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-2.

**Figure 3-2: Connection Alternative 2**



### **3.3 Connection Alternatives Selected for Further Study**

Alternative 1 is considered technically feasible and was selected for further study.

### **3.4 Connection Alternatives Not Selected for Further Study**

Alternative 2 includes similar scope of work as Alternative 1, but also requires crossing the 240 kV transmission line 983L. Thus, Alternative 2 would involve increased transmission development and hence, increased cost, compared to Alternative 1. Therefore, Alternative 2 was not selected for further study.



## 4 Assessment Approach

### 4.1 Standards, Criteria and Assumptions

A detailed description of the standards, criteria, and assumptions that were used for the connection assessment is provided in Attachment A (see Attachment A1).

### 4.2 Studies Performed

At the time of study, the scheduled ISD for the Project was June 1, 2021. As a result, studies were performed using scenarios for 2021 Summer Peak (SP) and 2021 Summer Light (SL). The scheduled ISD has since been revised from June 1, 2021 to November 1, 2021. The shift in the scheduled ISD would not impact the results of this connection assessment, and would not change the conclusions and recommendations contained in this report.

Short-circuit studies were performed using the 2021 SP and the 2029 SP scenarios.

Table 4-1 lists the study scenarios. Post-Project scenarios reflect the requested Rate STS contract capacity of 201.6 MW at the Woolchester 1019S substation.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
<b>Pre-Project</b>					
1	2021 Summer Peak (SP)	High Wind, High Import	2021 SP Pre-Project	0	0
2	2021 Summer Light (SL)	High Wind, Zero Import	2021 SL Pre-Project	0	0
<b>Post-Project</b>					
3	2021 SP	High Wind, High Import	2021 SP Post-Project	2.7	201.6
4	2021 SL	High Wind, Zero Import	2021 SL Post-Project	2.7	201.6
5	2029 SP	All generators in service	2029 SP Post-Project	2.7	201.6

The AESO Planning Region load forecasts used for the connection studies were based on the AESO *2019 Long Term Outlook* (2019 LTO).

### **4.2.1 Power Flow Studies**

The purpose of the power flow studies is to identify and quantify any thermal and voltage criteria violations in the Study Area.

In addition, power flow studies are also used to identify point of delivery (POD) low voltage bus voltage deviations beyond the limits listed in Table 3-1 of Attachment A1.<sup>3</sup>

Power flow studies were performed for 2021 SP and 2021 SL pre-Project scenarios, and for 2021 SP and 2021 SL post-Project scenarios.

### **4.2.2 Transient Stability Studies**

The purpose of the transient stability studies is to assess the post-Project stability of the transmission system after three-phase to ground faults are applied on select transmission lines in the Study Area.

Transient stability studies were performed for 2021 SP and 2021 SL post-Project scenarios.

### **4.2.3 Short-Circuit Current Level Studies**

The purpose of short-circuit current level studies is to determine the expected system short-circuit current levels in the vicinity of the Project.

Short circuit studies were performed for the 2021 SP pre-Project scenario and for 2021 SP and 2029 SP post-Project scenarios.

## **4.3 Mitigation Measure Development and Evaluation**

As explained in Section 6 of Attachment A1, mitigation measures were developed to address system performance issues that were identified in the post-Project scenarios. Studies performed to assess the effectiveness of mitigation measures are briefly outlined below.

### **4.3.1 Post-Mitigation Studies**

Power flow studies were performed to assess the impact of the Project on the performance of the AES following implementation of the AESO's proposed mitigation measures.

### **4.3.2 Constraint Effective Factor Studies**

Constraint effective factor studies were used to determine the generator and load constraint effective factors and to identify the most effective generators or loads to manage thermal criteria violations that were observed under Category B conditions.

---

<sup>3</sup> The AESO's desired post-contingency voltage deviations for low voltage busses represent guidelines rather than criteria. A POD bus voltage deviation that exceeds the desired limits shown in Table 3-1 of Attachment A1 does not represent a Reliability Criteria violation. Mitigation measures would not be developed to specifically address POD bus voltage deviations that exceed the desired values in Table 3-1 of Attachment A1.

## **5 Interpretation of Results**

### **5.1 Results Overview**

This section provides an assessment of the impact of the Project on the performance of the AIES. The Reliability Criteria violations observed during the connection assessment studies, and the proposed mitigation measures are summarized in Table 5-1.

- Section 5.2 includes an overview of the pre-Project studies results.
- Section 5.3 includes an overview of the post-Project studies results.
- Section 5.4 includes a description of the proposed mitigation measures to address observed Reliability Criteria violations.
- Section 5.5 includes an overview of the post-mitigation studies results.

Detailed study results are provided in Attachment A.

**Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures**

Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2021 SP	Thermal - above emergency rating	Thermal - above emergency rating	1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	Materially decreased	Existing RAS 149	Existing RAS 149

**Notes:**

- Materially decreased refers to a percent loading difference (post-Project percent loading minus pre-Project percent loading) below or equal to -3%.
- RAS 149 is an existing RAS (see Section 1.2.2 of Attachment A1).

## 5.2 Pre-Project Study Results

### 5.2.1 Category A Conditions

No Reliability Criteria violations were observed under the Category A conditions (i.e., all elements in service) for any of the pre-Project scenarios. The short-circuit fault levels were found to be within the typical capabilities of the nearby facilities.

### 5.2.2 Category B Conditions

The pre-Project power flow studies identified a thermal criteria violation on the 240 kV transmission line 1087L (Cassils 324S to Newell 2075S) following the loss of the 240 kV transmission line 1088L (Cassils 324S to Newell 2075S).

No voltage criteria violations were observed under Category B conditions.

No voltage deviations were observed that were beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) under Category B conditions.

## 5.3 Post-Project Study Results

### 5.3.1 Category A Conditions

No Reliability Criteria violations were observed under Category A conditions for any post-Project scenarios. Post-Project short-circuit fault levels were not significantly higher than pre-Project levels.

The long term short circuit levels were found to be within the designed capabilities of the nearby facilities.

### 5.3.2 Category B Conditions

The post-Project power flow studies identified a thermal criteria violation on the 240 kV transmission line 1087L (Cassils 324S to Newell 2075S) following the loss of the 240 kV transmission line 1088L (Cassils 324S to Newell 2075S).

No voltage criteria violations were observed under Category B conditions.

No POD bus voltage deviations were observed under Category B conditions.

Results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied.

## 5.4 Mitigation Measures

This section discusses the AESO's proposed mitigation measures to address the system performance issues that were identified in the pre-Project and post-Project scenarios.

### 5.4.1 Pre-Project

Prior to connection of the Project, all of the observed thermal criteria violations can be mitigated by the existing RAS 149.

### ***5.4.2 Post-Project***

After connection of the Project, all of the observed thermal criteria violations can be mitigated by the existing RAS 149.

### ***5.4.3 Post-Project Mitigation Study Results***

Under Category B conditions, all of the observed Reliability Criteria violations requiring RAS were mitigated.

## **6 Project Dependencies**

The Project does not require the completion of any other AESO plans to expand or enhance the transmission system prior to connection.

## 7 Conclusions and Recommendations

Based on the study results, Alternative 1 is technically viable. The connection assessment identified a pre-Project and post-Project system performance issue.

This issue can be mitigated through the use of existing RAS 149. With implementation of this mitigation measure, connecting the project with the preferred alternative does not adversely affect the performance of the AIES.

Alternative 1 involves adding one 240 kV transmission circuit to connect the Facility to the existing 240 kV transmission line 983L using a T-tap configuration. The conductor to be used for the 240 kV circuit should have a minimum capacity of 225 MVA to meet the Market Participant's requested STS contract capacity.



# Attachment A: Engineering Connection Assessment Results

# Engineering Connection Assessment: Study Results


## P2122 Cypress Wind Power Project Connection



Cypress Renewable Energy Centre LP.

Date: January 23, 2020

Version: Final

Classification: Public

<b>PERMIT TO PRACTICE ALTALINK MANAGEMENT LTD</b>	
RM SIGNATURE	
RM APEGA ID #:	95919
DATE:	2020-03-10
<b>PERMIT NUMBER: P007862</b> The Association of Professional Engineers and Geoscientists of Alberta (APEGA)	

Role	Name	Date	Signature
Prepared	Carl Wang, P. Eng.	2020-03-09	
Reviewed & Approved	Ryan Cui, P. Eng.	2020-03-09	



# Contents

<b>1</b>	<b>Introduction .....</b>	<b>3</b>
<b>2</b>	<b>Pre-Project Study Results .....</b>	<b>4</b>
2.1	Power Flow Studies .....	4
2.1.1	Scenario 1: 2021 Summer Peak High Generation Pre-Project .....	4
2.1.2	Scenario 2: 2021 Summer Light High Generation Pre-Project .....	5
<b>3</b>	<b>Post-Project Study Results .....</b>	<b>6</b>
3.1	Power Flow Studies .....	6
3.1.1	Scenario 3: 2021 Summer Peak High Generation Post-Project .....	6
3.1.2	Scenario 4: 2021 Summer Light High Generation Post-Project .....	6
3.2	Transient Stability Studies .....	7
<b>4</b>	<b>Short Circuit Studies .....</b>	<b>8</b>
4.1	Pre-Project Results .....	8
4.2	Post-Project Results .....	8
4.2.1	Scenario 3: 2021 Summer Peak High Generation Post-Project .....	8
4.2.2	Scenario 5: 2029 Summer Peak Post-Project .....	9
<b>5</b>	<b>Mitigation Measure Development and Evaluation .....</b>	<b>10</b>
5.1	Pre-Project .....	10
5.2	Post-Project .....	10
5.3	Evaluation of Mitigation Measures .....	10
5.3.1	Scenario 1: 2021 Summer Peak Pre-Project .....	11
5.3.2	Scenario 3: 2021 Summer Peak Post-Project .....	11
5.4	Constraint Effective Factor Studies .....	11

## Tables

Table 2-1: Thermal Criteria Violations under Category B Conditions for Scenario 1 .....	4
Table 3-1: Thermal Criteria Violations under Category B Conditions for Scenario 3 .....	6
Table 3-3: Transient Stability Study Results under Category B Conditions for Scenarios 3 and 4 .....	7
Table 4-1: Pre-Project Short-Circuit Current Levels for Scenario 1 .....	8
Table 4-2: Post-Project Short-Circuit Current Levels for Scenario 3 .....	8
Table 4-3: Post-Project Short-Circuit Current Levels for Scenario 5 .....	9
Table 5-1: Pre-Project Mitigation Measures .....	10
Table 5-2: Post-Project Mitigation Measures .....	10
Table 5-3: Post-RAS Power Flow Study Results for Scenario 1.....	11
Table 5-5: Post-RAS Power Flow Study Results for Scenario 3.....	11

## Attachments

**Attachment A1 Engineering Connection Assessment: Study Scope**

**Attachment A2 Pre-Project Power Flow Diagrams**

**Attachment A3 Post-Project Power Flow Diagrams**

**Attachment A4 Post-Project Transient Stability Diagrams**

**Attachment A5 Project Dynamic Data and Assumptions**

**Attachment A6 Post-Mitigation Power Flow Diagrams**

**Attachment A7 Constraint Effective Factors Table**

# 1 Introduction

This report presents the results of the engineering studies that were completed by AltaLink Management Ltd. (the Studies Consultant) to assess the impact of the Project (as defined in Attachment A1: AESO Engineering Connection Assessment Scope) on the performance of the Alberta interconnected electric system (AIES). The studies were performed in accordance with Attachment A1: AESO Engineering Connection Assessment: Study Scope, which was prepared by the AESO.

The power system network analysis tool that was used for the studies in this connection assessment was PSS/E version 33.

## 2 Pre-Project Study Results

This section describes the results of the pre-Project power flow studies.

### 2.1 Power Flow Studies

Power flow diagrams illustrating the pre-Project power flow studies results for Category A and Category B conditions are provided in Attachment A2.

#### 2.1.1 Scenario 1: 2021 Summer Peak High Generation Pre-Project

##### Category A Conditions

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

##### Category B Conditions

###### *Thermal Criteria Violations*

Thermal criteria violations were observed under certain Category B conditions as shown in Table 2-1.

**Table 2-1: Thermal Criteria Violations under Category B Conditions for Scenario 1**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>a</sup> (MVA)	% Loading <sup>b</sup>
1088L	1087L (Cassils 324S to Newell 2075S)	547	656	741.2	135.5

Notes:

<sup>a</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ )

<sup>b</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in Attachment A1.

###### *Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

###### *POD Bus Voltage Deviations*

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.

**Engineering Connection Assessment: Study Results**

P2122 Cypress Wind Power Project Connection

Final

***2.1.2 Scenario 2: 2021 Summer Light High Generation Pre-Project***

**Category A Conditions**

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

**Category B Conditions**

No Reliability Criteria violations were observed under Category B conditions.

### 3 Post-Project Study Results

This section describes the results of the post-Project power flow studies and transient stability studies.

As described in Section 2 of Attachment A1, the post-Project studies were performed using Alternative 1.

#### 3.1 Power Flow Studies

Power flow diagrams illustrating the post-Project power flow studies results for Category A and Category B conditions are included in Attachment A3.

##### 3.1.1 Scenario 3: 2021 Summer Peak High Generation Post-Project

###### Category A Conditions

No Reliability Criteria violations were observed under Category A conditions.

###### Category B Conditions

Thermal criteria violations were observed under certain Category B conditions as shown in Table 3-1.

**Table 3-1: Thermal Criteria Violations under Category B Conditions for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
1088L (Cassils 324S to Newell 2075S)	1087L (Cassils 324S to Newell 2075S)	547	656	741.2	135.5	719.3	131.5	-4.0

###### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

###### POD Bus Voltage Deviations

No POD bus voltage deviations were observed.

##### 3.1.2 Scenario 4: 2021 Summer Light High Generation Post-Project

###### Category A Conditions

No Reliability Criteria violations were observed under Category A conditions.

###### Category B Conditions

No Reliability Criteria violations were observed under Category B conditions.



## 3.2 Transient Stability Studies

Transient stability studies were completed for the post-project scenarios: Scenario 3 2021 Summer Peak and Scenario 4 2021 Summer Light.

The results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied, as shown in Table 3-2. The post-Project transient stability plots are provided in Attachment A4. The dynamic data and assumptions of all equipment proposed for the Facility are provided in Attachment A5.

**Table 3-2: Transient Stability Study Results under Category B Conditions for Scenarios 3 and 4**

Studied Contingency	Fault Description and Location	Results
1074L (Elkwater 264S – Bowmanton 244S)	3-phase fault at Elkwater 264S	Stable
	3-phase fault at Bowmanton 244S	Stable
983L (Elkwater 264S – Whitla 251S)	3-phase fault at Elkwater 264S	Stable
	3-phase fault at Whitla 251S	Stable
964L (Whitla 251S – Bowmanton 244S)	3-phase fault at Whitla 251S	Stable
	3-phase fault at Bowmanton 244S	Stable
1034L (Cassils 324S – Bowmanton 244S)	3-phase fault at Cassils 324S	Stable
	3-phase fault at Bowmanton 244S	Stable
1035L (Newell 2075S – Bowmanton 244S)	3-phase fault at Newell 2075S	Stable
	3-phase fault at Bowmanton 244S	Stable
892L (Suffield 895S – Bowmanton 244S)	3-phase fault at Suffield 895S	Stable
	3-phase fault at Bowmanton 244S	Stable
676L (Bullshead 523S – Bowmanton 244S)	3-phase fault at Bullshead 523S	Stable
	3-phase fault at Bowmanton 244S	Stable
600L (Peace Butte 404S – Bullshead 523S)	3-phase fault at Peace Butte 404S	Stable
	3-phase fault at Bullshead 523S	Stable
880L (Al Rothbauer 321S – Bullshead 523S)	3-phase fault at Al Rothbauer 321S	Stable
	3-phase fault at Bullshead 523S	Stable
675L (Al Rothbauer 321S – Bowmanton 244S)	3-phase fault at Al Rothbauer 321S	Stable
	3-phase fault at Bowmanton 244S	Stable
879L (Burdett 368S – Bowmanton 244S)	3-phase fault at Burdett 368S	Stable
	3-phase fault at Bowmanton 244S	Stable
658L/674L (Cypress 562S – Bowmanton 244S)	3-phase fault at Cypress 562S	Stable
	3-phase fault at Bowmanton 244S	Stable

## 4 Short Circuit Studies

### 4.1 Pre-Project Results

Pre-Project short-circuit current levels are provided in Table 4-1<sup>1</sup>.

**Table 4-1: Pre-Project Short-Circuit Current Levels for Scenario 1**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Bowmanton 244S	240	249.8	6.97	0.004675+ j0.040710	7.36	0.008785+ j0.039973
	138	142.3	9.32	0.005067+ j0.051274	9.15	0.009598+ j0.057798
Whitla 251S	240	251.7	4.61	0.005380+ j0.061508	4.87	0.010574+ j0.060063
Shamrock 1018S	240	252.0	4.13	0.005981+ j0.068686	4.43	0.009018+ j0.062503
Elkwater 264S	240	249.0	4.76	0.005857+ j0.059452	6.96	0.002452+ j0.017596

### 4.2 Post-Project Results

#### 4.2.1 Scenario 3: 2021 Summer Peak High Generation Post-Project

Post-Project short-circuit current levels for Scenario 3 are provided in Table 4-2.

**Table 4-2: Post-Project Short-Circuit Current Levels for Scenario 3**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Bowmanton 244S	240	247.7	6.96	0.004673+ j0.040694	7.35	0.008785+ j0.039972
	138	141.2	9.31	0.005068+ j0.051260	9.14	0.009598+ j0.057797
Whitla 251S	240	251.7	4.64	0.005377+ j0.061491	4.90	0.010573+ j0.060062
Shamrock 1018S	240	252.0	4.15	0.005978+ j0.068670	4.46	0.009018+ j0.062503
Elkwater 264S	240	248.0	4.78	0.005853+ j0.059426	6.99	0.002451+ j0.017595
Woolschester 1019S	240	248.4	4.88	0.005791+ j0.058251	6.74	0.004088+ j0.023695

<sup>1</sup> Short-circuit current studies were based on modeling information provided to the AESO by third parties. The authenticity of the modeling information has not been validated. Fault levels could change as a result of system developments, new customer connections, or additional generation in the area. It is recommended that these changes be monitored and fault levels reviewed to ensure that the fault levels are within equipment operating limits. The information provided in this study should not be used as the sole source of information for electrical equipment specifications or for the design of safety-grounding systems.

## Engineering Connection Assessment: Study Results

P2122 Cypress Wind Power Project Connection

Final

### 4.2.2 Scenario 5: 2029 Summer Peak Post-Project

Post-Project short-circuit current levels for Scenario 5 are provided in Table 4-3.

**Table 4-3: Post-Project Short-Circuit Current Levels for Scenario 5**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Bowmanton 244S	240	246.5	6.96	0.004686+ j0.040630	7.35	0.008740+ j0.039836
	138	142.1	9.28	0.005176+ j0.051873	9.11	0.009739+ j0.058485
Whitla 251S	240	253.1	4.65	0.005459+ j0.061902	4.91	0.010677+ j0.060452
Shamrock 1018S	240	254.4	4.17	0.006097+ j0.069283	4.47	0.009209+ j0.063138
Elkwater 264S	240	247.9	4.47	0.005588+ j0.055618	6.48	0.002380+ j0.016948
Woolschester 1019S	240	248.3	4.89	0.005828+ j0.058337	6.75	0.004087+ j0.023693

## 5 Mitigation Measure Development and Evaluation

The Studies Consultant, in consultation with the AESO, developed mitigation measures to address the system performance issues that were identified in the post-Project scenarios. Existing remedial action schemes (RASs) are described in Section 1.2.2 of Attachment A1.

### 5.1 Pre-Project

Pre-Project mitigation measures are summarized in Table 5-1.

**Table 5-1: Pre-Project Mitigation Measures**

Mitigation Measure	Location of Observed Violation	Contingency
Existing RAS 149	1087L (Cassils 324S - Newell 2075S)	1088L (Cassils 324S - Newell 2075S)

### 5.2 Post-Project

Post-Project mitigation measures are summarized in Table 5-2.

**Table 5-2: Post-Project Mitigation Measures**

Mitigation Measure	Location of Observed Violation	Contingency
Existing RAS 149	1087L (Cassils 324S - Newell 2075S)	1088L (Cassils 324S - Newell 2075S)

### 5.3 Evaluation of Mitigation Measures

This section describes the results of the power flow studies that were performed to assess the impact of the Project on the performance of the AIES following the implementation of proposed mitigation measures.

The post-mitigation measures studies were performed under Category B conditions for Scenarios 1 and 3 using Alternative 1 and the RASs described in the previous section.

The post-mitigation power flow diagrams for selected Category B conditions are provided in Attachment A6. Post-mitigation power flow diagrams present only those post-Project contingencies that result in thermal criteria violations that require RAS mitigation. Post-Project contingencies that result in thermal criteria violations that can be mitigated by real-time operational practices or TFO capital maintenance projects were not studied.

### 5.3.1 Scenario 1: 2021 Summer Peak Pre-Project

#### Category B Conditions

Thermal criteria violations observed under certain Category B conditions in the pre-Project studies were mitigated by RASs as shown in Table 5-3.

**Table 5-3: Post-RAS Power Flow Study Results for Scenario 1**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Pre-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
1088L	1087L	547	656	741.2	135.5	528.4	96.6

### 5.3.2 Scenario 3: 2021 Summer Peak Post-Project

#### Category B Conditions

Thermal criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 5-3.

**Table 5-4: Post-RAS Power Flow Study Results for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
1088L	1087L	547	656	719.3	131.5	506.5	92.6

## 5.4 Constraint Effective Factor Studies

Constraint effective factor studies were conducted for all post-Project scenarios. The constraint effective factors were calculated for all Category B conditions when the loadings of the monitored transmission elements in the Study Area exceeded 100% (i.e., for all of the contingencies that resulted in thermal criteria violations). The results of the constraint effective factor studies are provided in Attachment A7.

# Attachment A1

## Engineering Connection Assessment: Study Scope



# Engineering Connection Assessment: Study Scope

## Cypress Wind Project Connection

Cypress Renewable Energy LP.

AESO Project Number: P2122

**Date:** November 20, 2019

**Version:** Final

**Classification:** Public

Company Name	Name and Credentials	Date	Signature
Altalink Management Ltd. (Studies Consultant)	Carl Wang, P. Eng.	2019-11-26	
AESO	Payam Zamani, PhD, EIT Jorge Villena, PhD, P. Eng.	2019-11-28 2019-11-28	
AltaLink (Transmission Facility Owner)	Andrew Smith, P. Eng.	2019-11-14	
Cypress Renewable Energy LP. (Market Participant)	Zakaria Chayed	25-11-2019	

Alberta Electric System Operator

📍 Calgary Place, 2500, 330-5th Avenue SW Calgary, AB T2P 0L4

☎ Phone: 403-539-2450 | Fax: 403-539-2949

[www.aeso.ca](http://www.aeso.ca)

🐦 @theaeso

# Contents

<b>1</b>	<b>Introduction .....</b>	<b>1</b>
1.1	Project Overview .....	1
1.2	Existing System Overview .....	2
1.2.1	<i>Study Area .....</i>	<i>2</i>
1.2.2	<i>Existing Constraints .....</i>	<i>3</i>
<b>2</b>	<b>Connection Alternative to be Studied .....</b>	<b>5</b>
	Alternative 1 – T-tap connection to the existing 240 kV transmission line 983L .....	5
<b>3</b>	<b>Criteria, Standards and Requirements .....</b>	<b>7</b>
3.1	AESO Reliability Criteria .....	7
3.2	ISO Rules and Information Documents .....	8
3.3	Aggregated Generating Facility Requirements .....	8
<b>4</b>	<b>Scenarios and Assumptions .....</b>	<b>9</b>
4.1	Scenarios .....	9
4.2	Assumptions .....	9
4.2.1	<i>System Project Assumptions .....</i>	<i>9</i>
4.2.2	<i>Connection Project Assumptions .....</i>	<i>9</i>
4.2.3	<i>Load Assumptions .....</i>	<i>10</i>
4.2.4	<i>Generation Assumptions .....</i>	<i>10</i>
4.2.5	<i>Intertie Flow Assumptions .....</i>	<i>13</i>
4.2.6	<i>HVDC Power Order Assumptions .....</i>	<i>14</i>
4.2.7	<i>Transmission Facility Ratings .....</i>	<i>14</i>
4.2.8	<i>Protection Fault Clearing Times .....</i>	<i>16</i>
4.2.9	<i>Project Dynamic Data .....</i>	<i>17</i>
4.2.10	<i>Voltage Profile Assumption .....</i>	<i>17</i>
<b>5</b>	<b>Study Methodology .....</b>	<b>18</b>
5.1	Power Flow Studies .....	18
5.1.1	<i>Contingencies to be Studied .....</i>	<i>19</i>
5.2	Transient Stability Studies .....	19
5.2.1	<i>Contingencies to be Studied .....</i>	<i>19</i>
5.3	Short-Circuit Current Level Studies .....	19
<b>6</b>	<b>Mitigation Measures .....</b>	<b>21</b>
6.1	Development .....	21
6.2	Evaluation .....	21
6.2.1	<i>Post-Mitigation Studies .....</i>	<i>21</i>
6.2.2	<i>Constraint Effective Factor Studies .....</i>	<i>21</i>
<b>7</b>	<b>Changes to Study Assumptions .....</b>	<b>22</b>



## Tables

Table 1-1: Project Load and Generation Details.....	1
Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses .....	8
Table 4-1: Connection Study Scenarios.....	9
Table 4-2: Forecast Area Peak Load (2019 LTO at AESO South Planning Region Peak) .....	10
Table 4-3: Existing Non-Renewable and Hydro Generation Dispatch Conditions.....	10
Table 4-4: Dispatch Conditions for Existing Renewable Generation Facilities .....	11
Table 4-5: Dispatch Conditions for Planned Renewable Generation Projects .....	12
Table 4-6: Intertie Flows by Scenario.....	13
Table 4-7: HVDC Power Order by Scenario .....	14
Table 4-8: HVDC to Adjacent AC System MVar Exchange Limits .....	14
Table 4-9: Thermal Rating Assumptions for Key Transmission Lines in the Study Area .....	14
Table 4-10: Summary of Key Transformers in the Study Area .....	15
Table 4-11: Summary of Key Shunt Elements in the Study Area .....	16
Table 4-12: Protection Fault Clearing Times.....	16
Table 5-1: Summary of the Studies to be Performed.....	18

## Figures

Figure 1-1: Transmission System in the Study Area.....	3
Figure 2-1: Connection Alternative 1.....	6

## Attachments

Attachment A: Transmission Planning Criteria – Basis and Assumptions

# 1 Introduction

This Study Scope provides an overview of the engineering studies to be completed by AltaLink Management Ltd. (the Studies Consultant) to assess the impact of the Project (as defined in Section 1.1) on the performance of the Alberta interconnected electric system (AIES). Technical criteria, assumptions and methods for performing these engineering studies are provided in this document.

## 1.1 Project Overview

Cypress Renewable Energy Centre LP. (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its approved Cypress Wind Power Project (Facility) to the AIES. The Facility includes an approved collector station, designated as the Woolchester 1019S substation. The Facility is planned to be located in the Dunmore area, in the AESO planning area of Medicine Hat (Area 4).

The Market Participant’s request includes: a request for a new system access service in the area, with a Rate STS, *Supply Transmission Service*, contract capacity of 201.6 MW, and a Rate DTS, *Demand Transmission Service*, contract capacity of 2.7 MW, and a request for transmission development (collectively, the Project).

The scheduled in-service date (ISD) for the Project is November 1, 2021.

Load and generation components of the Project are listed in Table 1-1.

**Table 1-1: Project Load and Generation Details**

Project Component		Description
Load	Existing Rate DTS, <i>Demand Transmission Service</i> , contract capacity	No existing contract
	Requested Rate DTS	2.7 MW
	Type	Station Service
	Motors (number and size)	Not Applicable
	Power factor	Not Applicable
	Future load expansion plans	None
Generation	Generation type	Wind
	Existing Rate STS, <i>Supply Transmission Service</i> , contract capacity	No existing contract
	Requested Rate STS	201.6 MW
	Number and size of generating units	48 wind turbines at 4.2 MW each
	Maximum authorized real power (MARP)	201.6 MW
	Maximum capability (MC)	201.6 MW

Project Component		Description
	Reactive power capability	69.22 MVar (0.95 pf absorbing)
		97.64 MVar (0.9 pf producing)
	Future generation expansion plans	None

**Note:**

MARP and MC are defined in the AESO's *Consolidated Authoritative Document Glossary*, which can be found on the AESO's website.

## 1.2 Existing System Overview


### 1.2.1 Study Area

Geographically, the Project is located in the AESO planning area of Medicine Hat (Area 4) which is part of the AESO South Planning Region.

The Study Area consists of the AESO planning areas of Vauxhall (Area 52), Medicine Hat (Area 4), Empress (Area 48), and Brooks (Area 47).

The existing transmission system in the Study Area is shown in Figure 1-1.

Figure 1-1: Transmission System in the Study Area



### 1.2.2 Existing Constraints

Existing constraints in the Study Area are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management (TCM Rule)*.

There are a number of constraints in the Study Area that are mitigated by existing remedial action schemes (RASs) and/or other protection schemes.

The following existing RASs and/or other protection schemes are used to manage constraints in the area:

- RAS 27: 562S Cypress McNeil Power and Undervoltage Scheme
- RAS 28: 163S Amoco Empress Reverse Power and Undervoltage Scheme
- RAS 29: McNeil (840s) Under Voltage Runback Scheme
- RAS 33: Cypress (T562s) Reverse Power and Undervoltage Scheme
- RAS 141: 498S Voltage Instability Mitigation
- RAS 149: EATL HVDC

**Engineering Connection Assessment: Study Scope**

Cypress Wind Power Project Connection

Final



- RAS 150: WATL HVDC
- RAS 164: 1034L and 1035L Contingency Mitigation

## 2 Connection Alternative to be Studied

The following alternative will be studied:

### **Alternative 1 – T-tap connection to the existing 240 kV transmission line 983L**

This alternative includes the following developments:

- Add one 240kV circuit, approximately 70 metres in length,<sup>1</sup> to connect the Facility to the 240kV transmission line 983L (between the Bownmanton 244S substation and the Whitla 251S substation) using a T-tap configuration; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 2-1.

---

<sup>1</sup> Exact line length is to be determined by the TFO


**Engineering Connection Assessment: Study Scope**

Cypress Wind Power Project Connection

Final



**Figure 2-1: Connection Alternative 1**



## 3 Criteria, Standards and Requirements

### 3.1 AESO Reliability Criteria

The Transmission Planning (TPL) Standards, which are included in the Alberta Reliability Standards, and *Transmission Planning Criteria – Basis and Assumptions* (see Attachment A), (collectively, the Reliability Criteria) will be applied to evaluate system performance under Category A system conditions (i.e., all elements in-service) and following Category B contingencies (i.e., single element outage), prior to and following the studied alternatives. Below is a summary of Category A and Category B system conditions.

**Category A**, often referred to as the N-0 condition, represents a normal system with no contingencies and all facilities in service. Under this condition, the system must be able to supply all firm load and firm transfers to other areas. All equipment must operate within its applicable rating, voltages must be within their applicable range, and the system must be stable with no cascading outages.

**Category B** events, often referred to as an N-1 or N-G-1 with the most critical generator out of service, result in the loss of any single specified system element under specified fault conditions with normal clearing. These elements are a generator, a transmission circuit, a transformer, or a single pole of a DC transmission line. The acceptable impact on the system is the same as Category A. Planned or controlled interruptions of electric supply to radial customers or some local network customers, connected to or supplied by the faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted firm (non-recallable reserved) transmission service electric power transfers.

The TPL standards, TPL-001-AB-0 and TPL-002-AB1-0, have referenced Applicable Ratings when specifying the required system performance under Category A and Category B events. For the purpose of applying the TPL standards to the studies documented in this report, Applicable Ratings are defined as follows:

- Normal thermal rating of the line's loading limits for each season;
- The highest specified loading limits for transformers;
- For Category A conditions: Voltage range under normal operating condition per AESO Information Document #2010-007RS, *General Operating Practices – Voltage Control* (ID #2010-007RS). For the busses not listed in ID #2010-007RS, Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions* applies;
- For Category B conditions: The extreme voltage range values per Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions*; and
- Desired post-contingency voltage deviation limits for three defined post-event timeframes as provided in Table 3-1.



**Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses**

Parameter and reference point	Time Period		
	Post Transient (up to 30 sec)	Post Auto Control (30 sec to 5 min)	Post Manual Control (Steady State)
Voltage deviation from steady state at point-of-delivery (POD) low voltage bus.	±10%	±7%	±5%

### 3.2 ISO Rules and Information Documents

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for the Study Area.

The TCM Rule will be followed to set up the study scenarios and assess the impact of the Project. In addition, due regard will be given to the AESO’s *Connection Study Requirements*, the AESO’s *Generation and Load Interconnection Standard*, Section 502.5 of the ISO rules, *Generating Unit Technical Requirements*, and Section 502.6 of the ISO rules, *Generating Unit Operating Requirements*.

### 3.3 Aggregated Generating Facility Requirements

The Facility should meet the technical requirements presented in Section 502.1 of the ISO rules, *Aggregated Generating Facilities Technical Requirements*.

## 4 Scenarios and Assumptions

### 4.1 Scenarios

The studies will be performed using 2021 study scenarios. The Study Area has low load variation between winter and summer seasons, however the transmission facilities in the Study Area have summer ratings that are lower than their winter ratings. Therefore, only summer loading scenarios are selected for engineering studies as they provide the most stressed operating conditions.

Connection scenarios must be studied as outlined in Table 4-1.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Project Load (MW)	Project Generation (MW)
<b>pre-Project</b>					
1	2021 Summer Peak (SP)	High Wind, High Import	2021 SP Pre-Project	0	0
2	2021 Summer Light (SL)	High Wind, Zero Import	2021 SL Pre-Project	0	0
<b>post-Project</b>					
3	2021 SP	High Wind, High Import	2021 SP Post-Project	2.7	201.6
4	2021 SL	High Wind, Zero Import	2021 SL Post-Project	2.7	201.6
5	2029 SP	All generators in service	2029 SP Post-Project	2.7	201.6

Note: The 138 kV bus-tie breaker and switch at the Bowmanton 244S substation are assumed to be open for all of the above scenarios.

### 4.2 Assumptions

#### 4.2.1 System Project Assumptions

The pre-Project and post-Project connection assessment will not include any system transmission projects because there are no planned system transmission developments in the Study Area that are expected to be in service before the scheduled Project ISD.

#### 4.2.2 Connection Project Assumptions

The pre-Project and post-Project connection assessment will not include any connection projects other than those listed in

Table 4-5.

### 4.2.3 Load Assumptions

The load forecast to be used for the studies is shown in Table 4-2 and is a forecast for the AESO South Planning Region peak based on the AESO's 2019 Long-term Outlook (2019 LTO)<sup>2</sup>. For the studies, when loads for the Alberta Internal Load (AIL) are modified to align with the load forecast in the 2019 LTO, the active power to reactive power ratio in the base case scenarios will be maintained.

**Table 4-2: Forecast Area Peak Load (2019 LTO at AESO South Planning Region Peak)**

AESO Planning Area or Region Name	Forecast Peak Load by Year/Season (MW)	
	2021 SP	2021 SL
South Planning Region <sup>a</sup>	1513	919

**Note:**

<sup>a</sup> The South Region comprises the following AESO planning areas: 4, 43, 44, 45, 46, 47, 48, 49, 52, 53, 54, and 55

IDEV files contain non-motor loads in zones 34, 36, and 351. These loads are not accounted for in the forecasted peak loads shown above and should not be considered when scaling load. The AESO engineer will provide guidance to load scaling procedures as required.

### 4.2.4 Generation Assumptions

The generation forecast to be used for the studies is based on the 2019 LTO. The generation assumptions for the studies will assume high wind dispatch conditions. Additional studies may be required in the event of changes to the AESO's corporate forecast.

The existing non-renewable and hydro generation dispatch conditions for the study scenarios are described in Table 4-3.

**Table 4-3: Existing Non-Renewable and Hydro Generation Dispatch Conditions**

Facility Name	Unit No.	Bus No.	Pmax (MW)	AESO Planning Area No.	Unit Net Generation <sup>a</sup> (MW) per Scenario	
					2021 SP	2021 SL
Irrican Hydro	1	450	7	55	6.4	6.0
Lethbridge Taber	2	3272	8	52	7.4	0
Lethbridge Burdett	3	4269	7	52	6.6	0
Altagas Bantry	1	4275	7	47	5.1	0

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

Per the 2019 LTO, the total forecast renewable electricity generation in 2021 is 2,686.7 MW. This includes existing, under construction and planned renewable electricity generation facilities.

<sup>2</sup> The 2019 LTO is available on the AESO website.

Using the 2019 LTO’s 2021 renewable generation forecast of 2,686.7 MW, the generation assumptions will dispatch the renewable electricity generation facilities in order to yield the credible worst-case power flow conditions for the Study Area. Post-Project dispatch levels for the existing and under-construction renewable electricity generation facilities are shown in Table 4-4.

Table 4-5 lists the pre-Project dispatch levels for the planned wind and solar generation projects in the AESO South and Central planning regions that are included in the study scenarios.

**Table 4-4: Dispatch Conditions for Existing Renewable Generation Facilities**

Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generation <sup>s</sup> (MW)
				2021 SP/2021 SL
Ardenville Wind (ARD1)	53	4735, 4740	68	68
Blue Trail Wind (BTR1)	53	66328, 67328	66	66
Castle River #1 (CR1)	53	2234, 3234	39	39
Castle Rock Wind Farm (CRR1)	53	67221	77	77
Cowley Ridge (CRWD)	53	255, 265, 4264	20	20
Enmax Taber (TAB1)	52	15343, 16343	81	81
Kettles Hill (KHW1)	53	2402, 3402	63	63
McBride Lake Windfarm (AKE1)	53	2901, 3901, 4901	73	73
Soderglen Wind (GWW1)	53	12358, 13358	71	71
Summerview 1 (IEW1)	53	2338, 3338	66	66
Summerview 2 (IEW2)	53	4339, 5337	66	66
Suncor Chin Chute (SCR3)	54	2389	30	30
Suncor Magrath (SCR2)	53	11002	30	30
Suncor Wintering Hills (SCR4)	43	60789, 60791, 60793, 60846, 60848, 60850	88	88
Old Man River(OWF1)	53	61543	46	46
Blackspring Ridge(BSR1)	49	61736, 61737	300	300
Brooks Solar (BSC1)	47	553257	15	15
Whitla (WHT1)	4	60990	201.6	201.6
Castle Rock Ridge 2 (CRR2)	53	567221	30.6	7.9
Riverview (RIV1)	53	69221	105	0
<b>AESO South Planning Region Subtotal</b>			<b>1,546.2</b>	<b>1,408.5</b>

## Engineering Connection Assessment: Study Scope

Cypress Wind Power Project Connection

Final



Facility Name and Code	AESO Planning Area No.	Bus No.	MC (MW)	Unit Net Generation <sup>s</sup> (MW)
				2021 SP/2021 SL
Ghost Pine (NEP1)	42	2621 to 2625	82	82
Halkirk (HAL1)	42	66435, 67435	150	150
Fortis Bull Creek Phases 1 and 2(Bul1 & BUL2)	37	4222	29.5	29.5
<b>AESO Central Planning Region Subtotal</b>			<b>261.5</b>	<b>261.5</b>
<b>Total</b>			<b>1,807.7</b>	<b>1,670.0</b>

**Note:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

**Table 4-5: Dispatch Conditions for Planned Renewable Generation Projects<sup>3</sup>**

AESO Project No. and Name	Project Type	Planned ISD	Planning Area No.	AESO Stage	Pmax (MW)	Unit Net Generation <sup>s</sup> (MW)
						2021 SL/ 2021 SP Pre-Project
<b>AESO South Planning Region</b>						
P1892 Fortis Buffalo Atlee Cluster 3 WAGF (REP #2)	BTF	18-Mar-19	47	5	17.3	17.3
P1853 Fortis Buffalo Atlee Cluster 1 WAGF (REP #2)	BTF	01-Mar-19	47	5	18.3	18.3
P2199 Buffalo Atlee Wind Farm 2 (REP #2)	BTF	30-Jun-21	47	2	13.8	13.8
P1719 Stirling WAGF Project (REP #2)	Connection	20-Dec-19	54	4	113	28
P2122 EDF Cypress Wind (REP #2)	Connection	01-Jun-21	4	2	201.6	0
P1533 Joss MPC WAGF (REP #3)	Connection	28-Jun-19	47	5	122	122
P1698 Joss Jenner WAGF - Phase 2 (REP #3)	BTF	01-May-19	47	5	71.4	71.4
P2041 TransAlta Windrise MPC Wind (REP #3)	Connection	02-Nov-20	53	2	207	207
P1838 Fortis 895S Suffield DG PV	BTF	01-Feb-2020	4	5	22	22
P1878 Fortis 257S Hull DER Solar	BTF	15-Oct-2019	52	5	24.5	24.5

<sup>3</sup> As of October 2019, <https://www.aeso.ca/grid/projects/project-reports>

## Engineering Connection Assessment: Study Scope

Cypress Wind Power Project Connection

Final



P1922 FortisAlberta Vauxhall Solar DER	BTF	01-Nov-2019	52	5	22	22
P1812 Suncor Forty Mile Granlea WAGF	Connection	01-Jun-2020	4	5	200	200
<b>AESO South Planning Region Subtotal</b>					<b>1,032.9</b>	<b>746.3</b>
<b>AESO Central Planning Region</b>						
P1567 EDPR Sharp Hills Wind Farm (REP #1)	Connection	01-May-19	42	4	248.4	248.4
P2097 FortisAlberta Innisfail 214S DER Solar	BTF	Dec 15, 2019	39	5	22	22
<b>Total Planned</b>					<b>1,303.3</b>	<b>1,016.7</b>
<b>Total Planned, Existing and Under Construction</b>					<b>3,111</b>	<b>2686.7</b>

**Note: 85**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

The pre-project scenarios will represent the situations where the Project is not in service. Thus, the Project will be switched off in pre-project scenarios.

The post-Project scenario renewable generation dispatch levels were identical to the pre-Project scenario dispatch levels shown in Table 4-4 and Table 4-5, with the following adjustments:

- Dispatch the Project (P2122 Cypress Wind Power Project Connection) to 201.6 MW
- Dispatch the planned P2041 Windrise Wind Power Project Connection to 5.4 MW

This will result in a total renewable dispatch consistent with the 2019 LTO's renewable generation forecast of 2,686.7 MW for 2021.

### 4.2.5 Intertie Flow Assumptions

The intertie flow assumptions for the Alberta-British Columbia (AB-BC), Alberta-Saskatchewan (AB-SK), and Alberta-Montana (MATL) interties are shown in

Table 4-6.

For the 2029 SP post-Project scenario, the intertie flows should be as per the published AESO base cases.

**Table 4-6: Intertie Flows by Scenario**

Scenario Name	Import (-) / Export (+) by Intertie		
	AB-BC	AB-SK	MATL
2021 SP	-794	-150	0
2021 SL	0	0	0

#### 4.2.6 HVDC Power Order Assumptions

The Western Alberta Transmission Line (WATL) and the Eastern Alberta Transmission Line (EATL) are high-voltage direct current (HVDC) transmission lines. The HVDC power order assumptions for the studies will be set to minimize losses for the pre-Project and post-Project study scenarios.

For the 2029 SP Post-Project scenario, the HVDC flows should be as per the published AESO base cases.

**Table 4-7: HVDC Power Order by Scenario**

Scenario Name	WATL (MW)	EATL (MW)
2021 SP	250 S → N	800 S → N
2021 SL	575 S → N	1000 S → N

**Notes:**

N → S: HVDC flow direction is North to South

S → N: HVDC flow direction is South to North

The reactive power limits of the MVAR exchanges between the HVDC terminals (WATL and EATL) and the connected alternating current (AC) transmission systems are shown in Table 4-8. These limits must be maintained when performing the studies.

**Table 4-8: HVDC to Adjacent AC System MVAR Exchange Limits**

HVDC Facility	North Terminal Reactive Power Limit (MVAR)	South Terminal Reactive Power Limit (MVAR)
EATL	-85 to 75	-35 to 35
WATL	-75 to 75	-35 to 35

#### 4.2.7 Transmission Facility Ratings

The legal owner of transmission facilities (TFO) provided the thermal ratings assumptions for the existing transmission lines in the Study Area. Table 4-9 shows the normal ratings and emergency ratings for the key transmission lines in the Study Area, which will be used to perform the engineering studies.

**Table 4-9: Thermal Rating Assumptions for Key Transmission Lines in the Study Area**

Line ID	Line Description	Voltage Class (kV)	Normal Rating (MVA)	Emergency Rating (MVA)
			Summer	Summer
964L	Bowmanton 244S - Whittla 251S	240	952	1047
983L	Whittla 251S - Elkwater 264S	240	952	1047
1074L	Bowmanton 244S - Elkwater 264S	240	952	1047

## Engineering Connection Assessment: Study Scope

Cypress Wind Power Project Connection

Final



Line ID	Line Description	Voltage Class (kV)	Normal Rating (MVA)	Emergency Rating (MVA)
			Summer	Summer
1034L	Bowmanton 244S - Cassils 324S	240	931	1024
1035L	Bowmanton 244S - Newell 2075S	240	952	1047
1087L	Cassils 324S - Newell 2075S	240	547	656
676L	Bowmanton 244S - Bullshead 523S	138	369	406
675L	Al Rothbauer 321S - Bowmanton 244S	138	96	133
880L	Bullshead 523S - Al Rothbauer 321S	138	123	135
892L	Bowmanton 244S - Suffield 895S	138	67	74
666L	West Brooks 28S - Tilley 498S	138	120	133
100L	Tilley 498S - Suffield 895S	138	69	76
612L	Fincastle 336S - Burdett 368S	138	85	94
610L	Taber 83S - Fincastle 336S	138	85	94
879L	Bowmanton 244S - Burdett 368S	138	85	94
658L	Chappice Lake 649S - Cypress 562S	138	81	89
668L	Cypress 562S - Empress 394S	138	121	133
669L	Cypress 562S - Amoco Empress 163S	138	177	195
674L	Bowmanton 244S - Chappice Lake 649S	138	121	133
1087L	Cassils 324S - Newell 2075S	240	547	656
1088L	Cassils 324S - Newell 2075S	240	931	1117

The TFO provided the details of the substation transformers in the Study Area. The key transformers in the Study Area are shown in Table 4-10.

**Table 4-10: Summary of Key Transformers in the Study Area**

Substation Name and Number	Transformer ID	Transformer Voltages (kV)	Transformer Rating (MVA)
North Lethbridge 370S	T3	240/138 kV	193.6
	T5	240/138 kV	200
	T6	240/138 kV	200
Westbrooks 28S	T1	240/138 kV	400
	T2	240/138 kV	400
Bowmanton 244S	T1	240/138 kV	200
	T2	240/138 kV	200



The TFO provided the details of the shunt elements in the Study Area. The key shunt elements in the Study Area are shown in Table 4-11.

**Table 4-11: Summary of Key Shunt Elements in the Study Area**

Substation Name and Number	Voltage Class (kV)	Capacitors		Reactors	
		Number of Switched Shunt Blocks	Total at Nominal Voltage (MVar)	Number of Switched Shunt Blocks	Total at Nominal Voltage (MVar)
Taber 83S	138	1	24.46	-	-
		1	24.5		
Hays 421S	138	1	22.96	-	-
Picture Butte 120S	240	2	50	-	-
Burdett 368S	138	1	24.46	-	-
		1	24.5		
Tilley 498S	138	1	27.17	-	-
West Brooks 28S	240	-	-	1	50
Whitla 251S	240	-	-	2	75
McNeil 840S	138	2	24.8	-	-
Bullshead 523S	138	1	18.3	-	-

#### 4.2.8 Protection Fault Clearing Times

The transient stability studies will be performed using the actual fault clearing times for the selected contingencies, as provided by the TFO and as shown in Table 4-12. Only those contingencies shown in Table 4-12 will be studied for transient stability studies.

**Table 4-12: Protection Fault Clearing Times**

Contingency (System Element Lost)	Fault Location	Clearing Times (Cycles)	
		Near End	Far End
1074L (Elkwater 264S – Bowmanton 244S)	Elkwater 264S	5	6
1074L (Elkwater 264S – Bowmanton 244S)	Bowmanton 244S	5	6
983L (Elkwater 264S – Whitla 251S)	Elkwater 264S	5	6
983L (Elkwater 264S – Whitla 251S)	Whitla 251S	5	6

## Engineering Connection Assessment: Study Scope

Cypress Wind Power Project Connection

Final



964L (Whitla 251S – Bowmanton 244S)	Whitla 251S	4	5
964L (Whitla 251S – Bowmanton 244S)	Bowmanton 244S	4	5
1034L (Cassils 324S – Bowmanton 244S)	Cassils 324S	4	5
1034L (Cassils 324S – Bowmanton 244S)	Bowmanton 244S	4	5
1035L (Newell 2075S – Bowmanton 244S)	Newell 2075S	4	5
1035L (Newell 2075S – Bowmanton 244S)	Bowmanton 244S	4	5
892L (Suffield 895S – Bowmanton 244S)	Suffield 895S	6	27
892L (Suffield 895S – Bowmanton 244S)	Bowmanton 244S	6	27
676L (Bullshead 523S – Bowmanton 244S)	Bullshead 523S	6	27
676L (Bullshead 523S – Bowmanton 244S)	Bowmanton 244S	6	27
600L (Peace Butte 404S – Bullshead 523S)	Peace Butte 404S	9	30
600L (Peace Butte 404S – Bullshead 523S)	Bullshead 523S	9	30
880L (AI Rothbauer 321S – Bullshead 523S)	AI Rothbauer 321S	9	30
880L (AI Rothbauer 321S – Bullshead 523S)	Bullshead 523S	9	30
675L (AI Rothbauer 321S – Bowmanton 244S)	AI Rothbauer 321S	6	8
675L (AI Rothbauer 321S – Bowmanton 244S)	Bowmanton 244S	6	8
879L (Burdett 368S – Bowmanton 244S)	Burdett 368S	6	27
879L (Burdett 368S – Bowmanton 244S)	Bowmanton 244S	6	27
658L/674L (Cypress 562S – Bowmanton 244S)	Cypress 562S	6	27
658L/674L (Cypress 562S – Bowmanton 244S)	Bowmanton 244S	6	27

### 4.2.9 Project Dynamic Data

Dynamic data for the Project can be found in Attachment A7.

### 4.2.10 Voltage Profile Assumption

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for key area busses prior to commencing any studies. Table 2-1 of the *Transmission Planning Criteria – Basis and Assumptions* applies for the busses not included in ID #2010-007RS. These voltages will be used to set the voltage profile for the study base cases prior to the power flow studies.

## 5 Study Methodology

The studies to be performed for this connection assessment are identified in Table 5-1.

**Table 5-1: Summary of the Studies to be Performed**

Scenario No. and Name		Power Flow		Transient Stability		Short Circuit
		Category		Category		Category A
		A	B	A	B	
<b>pre-Project</b>						
1	2021 SP	X	X			X
2	2021 SL	X	X			
<b>post-Project</b>						
3	2021 SP	X	X		X	X
4	2021 SL	X	X		X	
5	2029 SP					X

For the engineering studies, all transmission facilities 69kV and above within the Study Area and the transmission lines connecting these planning areas to neighboring planning areas will be studied and monitored to assess the impact of the Project on the performance of the AIES, including any violations of the Reliability Criteria (as defined in Section 3.1).

### 5.1 Power Flow Studies

Power flow studies will be performed to identify thermal and voltage criteria violations as per the Reliability Criteria, and any deviations from the limits listed in Table 3-1.

For the Category B power flow studies, the transformer taps and switched shunt reactive compensating devices such as shunt capacitors and reactors will be locked and continuous shunt devices will be enabled.

Voltage deviations at point-of-delivery (POD) low voltage busses will also be assessed for both the pre-Project and post-Project networks by first locking all tap changers and area shunt reactive compensating devices to identify any post-transient voltage deviations above 10%. Second, tap changers will be allowed to move while shunt reactive compensating devices remained locked to determine if any voltage deviations above 7% would occur in the area. Third, all the taps and shunt reactive compensating devices will be allowed to adjust, and voltage deviations above 5% will be reported.

The scenarios to be studied are shown in Table 5-1.

### **5.1.1 Contingencies to be Studied**

Power flow studies will be performed for the Category A and all Category B conditions in the Study Area. The transmission elements in the study area and the ties to the adjacent areas are to be monitored.

## **5.2 Transient Stability Studies**

The Genesee generating unit 3 in Wabamun (Area 40) will be used as the reference for the studies.

The report presenting the results of the transient stability studies must provide response plots for several variables, including rotor angle, and active and reactive power output for the proposed generation facility and generators listed below:

- City of Medicine Hat system
- Shepard Power Plant
- Capital Power Whitla Wind Power Facility
- EDF Cypress Wind Power Facility

The results report must also provide the response plots for following key 240 kV and 138 kV buses:

- Bowmanton 244S substation 240 kV bus
- Bowmanton 244S substation 138kV bus
- Whitla 251S substation 240kV bus
- Shamrock 1018S substation 240kV bus
- Planned Woolchester 1019S substation 240 kV bus (including in post-Project studies only)

Other busses will be monitored and will be reported as determined by the results. The results report must also provide the key branch active and reactive power flow surrounding the Facility.

Transient stability studies will be performed for the post-Project scenarios as shown in Table 5-1. If any transient stability issues are observed, transient stability analysis will be performed for the corresponding pre-Project scenarios.

### **5.2.1 Contingencies to be Studied**

Transient stability studies will be performed for the contingencies shown in Table 4-12.

## **5.3 Short-Circuit Current Level Studies**

A maximum fault level must be provided for the substations in the vicinity of the Project assuming normal system operation with all transmission elements in service and generation dispatched. Three-phase faults and single line-to-ground faults will be simulated. Polar coordinates and per-unit values will be used for reporting the results.

Estimated maximum three-phase faults and single line-to-ground short-circuit current levels will be reported for the following substations:

## Engineering Connection Assessment: Study Scope

Cypress Wind Power Project Connection

Final



- Bowmanton 244S substation 240 kV and 138 kV busses
- Whitla 251S substation 240 kV bus
- Shamrock 1018S substation 240k bus
- Planned Woolchester 1019S substation 240 kV bus (including in post-Project studies only)

Further sensitivity studies, in consultation with the TFO, may be required if the primary short-circuit analysis indicates a potential to exceed or approach the existing fault rating of the transmission facilities.

The scenarios to be studied are as shown in Table 5-1.

## 6 Mitigation Measures

### 6.1 Development

Mitigation measures may be required if the post-Project study results identify system performance issues. Mitigation measures for the Project may involve modifying or adding real-time operational practices and/or remedial action schemes (RASs).

The Studies Consultant must notify the AESO of any system performance issues in a timely manner, following which the AESO Studies Engineer may instruct the Studies Consultant as follows:

- Develop tables showing the constraint effective factors<sup>4</sup> for generation or load based on thermal criteria violations that are observed.
- Collaborate with the AESO to propose changes, if any, to the connection alternatives that could remove the requirement for a RAS.
- Collaborate with the AESO to study modifications to existing and/or planned RASs, proposed by the AESO, to ensure the coordination of existing protection schemes with the addition of any proposed protection schemes.
- Collaborate with the AESO to identify and study new RASs, if any, that may be required to ensure system reliability is maintained after connecting the Project to the AES.

The AESO Studies Engineer will work closely with the Studies Consultant and guide the development and/or modifications of the proposed mitigation measures to ensure system reliability, security and compliance with AESO ID #2018-018T, *Provision of System Access Service and the Connection Process*.

### 6.2 Evaluation

#### 6.2.1 Post-Mitigation Studies

Studies to evaluate the effectiveness of mitigation measures, if required, will be performed in accordance with the technical criteria, assumptions, and methods provided in this Study Scope and in accordance with further instructions from the AESO.

#### 6.2.2 Constraint Effective Factor Studies

Constraint effective factor analysis are used to determine the generator- and load- constraint effective factors and to identify the most effective generators or loads to manage the thermal criteria violations, if any, that are observed under Category B conditions.

---

<sup>4</sup> Constraint effective factor studies are performed to determine the generator- and load- constraint effective factors. Constraint effective factors are used to estimate the ability of generators and loads to manage transmission constraints. A generator's or load's constraint effective factor is defined as the change in power flow over a specific transmission line following a change in the generator's energy production or in the load's energy consumption. The greater the constraint effective factor, the more effective a generator or load can be in managing a thermal criteria violation on the specific transmission line.

## **7 Changes to Study Assumptions**

This study will utilize the AESO's planning base cases, which include the AESO's current corporate forecast (2019 LTO). Sensitivity studies or restudy may be required in the event of revisions to the AESO's corporate forecast or other study assumptions. Additional engineering studies may also be required to assess new connection alternatives, changes to project ISD, or delays in proposed system developments. Any additional or revised study requirements shall be captured in a signed Study Scope Amendment document.

# Attachment A: Transmission Planning Criteria – Basis and Assumptions



# Transmission Planning Criteria – Basis and Assumptions

**Date:** July 9, 2019

**Version:** V1.2

## 1. Introduction

This document presents the reliability standards, criteria, and assumptions to be used as the basis for planning the Alberta Transmission System. The criteria, standards and assumptions identified in this document supersede those previously established.

## 2. Transmission Reliability Standards and Criteria<sup>1</sup>

The AESO applies the following Alberta Reliability Standards to ensure that the transmission system is planned to meet applicable performance requirements under a defined set of system conditions and contingencies. A brief description of each of these standards is given below:

### 1. TPL-001-AB-0: System Performance Under Normal Conditions

Category A represents a normal system condition with all elements in service (N-0). All equipment must be within its applicable rating, voltages must be within their applicable ratings and the system must be stable with no cascading outages. Under Category A, electric supply to load cannot be interrupted and generating units cannot be removed from service.

### 2. TPL-002-AB1-0: System Performance Following Loss of a Single BES Element

Category B events result in the loss of any single element (N-1) under specified fault conditions with normal clearing. The specified elements are a generating unit, a transmission circuit, a transformer or a single pole of a direct current transmission line. The acceptable impact on the system is the same as Category A with the exception that radial customers or some local network customers, including loads or generating units, are allowed to be disconnected from the system if they are connected through the faulted element. The loss of opportunity load or opportunity interchanges is allowed. No cascading can occur.

### 3. TPL-003-AB-0: System Performance Following Loss of Two or More BES Elements

Category C events result in the loss of two or more bulk electric system elements (sequential, N-1-1 or concurrent, N-2) under specified fault conditions and include both normal and delayed fault clearing. All of the system limits for Category A and B events apply with the exception that planned and controlled loss of firm load, firm transfers and/or generation is acceptable provided there is no cascading.

### 4. TPL-004-AB-0: System Performance Following Extreme BES Events

Category D represents a wide variety of extreme, rare and unpredictable events, which may result in the loss of load and generation in widespread areas. The system may not be able to reach a new stable steady state, which means a blackout is a possible outcome. The AESO needs to evaluate these events, at its discretion, for risks and consequences prior to creating mitigation plans.

### 5. FAC-014-AB1-2: Establishing and Communicating System Operating Limits

The AESO is required to establish system operating limits where a contingency is not mitigated through construction of transmission facilities

---

<sup>1</sup> A complete description of the *Alberta Reliability Standards* can be found on the AESO's website: <https://www.aeso.ca/rules-standards-and-tariff/alberta-reliability-standards/>

## 2.1 Thermal Loading Criteria

The AESO Thermal Loading Criteria require that the continuous thermal rating of any transmission element is not exceeded under normal and post-contingency operating conditions. Thermal limits are assumed to be 100% of the respective normal summer and winter ratings. Emergency limits are not considered in the planning evaluations.

## 2.2 Voltage Range and Voltage Stability Criteria

The normal minimum and maximum voltage limits as specified in the following table are used to identify Category A system voltage violations, while the extreme minimum and maximum limits are used to identify Category B and C system violations. Table 2-1 presents the acceptable steady state and contingency state voltage ranges for the AIES. Table 2-2 provides voltage stability criteria used to test the system performance.

**Table 2-1: Acceptable Range of Steady State Voltage (kV)**

Nominal Voltage	Extreme Minimum	Normal Minimum	Normal Maximum	Extreme Maximum
500	475	500	525	550
240	216	234	252	264
260 (Northeast & Northwest)*	234	247	266	275
144	130	137	151	155
138	124	135	145	152
72	65	68.5	75.5	79
69	62	65.5	72.5	76

**Table 2-2: Voltage Stability Criteria**

Performance Level	Disturbance (1)(2)(3)(4) Initiated by: Fault or No Fault DC Disturbance	MW Margin (P-V method) (5)(6)(7)	MVAr Margin (V-Q method) (6)(7)
A	Any element such as: One Generator One Circuit One Transformer One Reactive Power Source One DC Monopole	$\geq 5\%$	Worst Case Scenario(8)
B	Bus Section	$\geq 5\%$	50% of Margin Requirement in Level A
C	Any combination of two elements such as: A Line and a Generator A Line and a Reactive Power Source Two Generators Two Circuits Two Transformers Two Reactive Power Sources DC Bipole	$\geq 2.5\%$	50% of Margin Requirement in Level A
D	Any combination of three or more elements such as: Three or More Circuits on ROW Entire Substation Entire Plant Including Switchyard	$> 0$	$> 0$

## 2.3 Transient Stability Analysis Assumptions

Standard fault clearing times as shown in Table 2-3 are used for the new facilities or when the actual clearing times are not available for the existing facilities. Double line-to-ground faults are applied for the Category C5 events with normal clearing times. Single line-to-ground faults are applied for Category C6 to C9 events with delayed clearing times as depicted in Table 2-4 and Table 2-5.

**Table 2-3: Fault Clearing Times**

Nominal (kV)	Near End (Cycles)	Far End (Cycles)
500	4	5
240	5	6
144/138 with telecommunications	6	8
144/138 without telecommunications	6	30

**Table 2-4: Stuck Breaker Clearing Times for Lines**

Voltage (kV)	Fault Clearing Times (Cycles)		
	Near End	Far End	2 <sup>nd</sup> Ckt (C5 and C7 only)
138/144	15	24	24
240	12	6	14
500	9	5	11


**Table 2-5: Stuck Breaker Clearing Times for Transformers**

Voltage (kV)	Fault Location	Fault Clearing Times (Cycles)		
		High Side	Low Side	2 <sup>nd</sup> Ckt (breaker fail)
240/138	240 kV side	12	6	14
	138 kV side	5	15	24
500/240	500 kV side	9	5	11
	240 kV side	4	12	14

# Attachment A2

## Pre-Project Power Flow Diagrams





**P2122 Cypress Wind Farm (REP)**

BC Import:796.86 MW Sask Import:150.00 MW MATL Import:-0.00 MW  
 MH Export: -62.17 MW


**FIGURE A2.1-2 N-1: 1088L (CASSILS 324S TO NEWELL A2075S)  
 2021 SUMMER PEAK (PRE-PROJECT)  
 PRINTED ON FRIDAY 31. JANUARY 2020**

Bus - Voltage (KV) / MW  
 Branch - MW / MW  
 Equipment - MW / MW  
 1.000 / 0.000 / 0.000  
 417 -> 25.000 -> 189.000 -> 128.000 -> 94.000 -> 50.000 -> 50.000

# Attachment A3

## Post-Project Power Flow Diagrams






**P2122 Cypress Wind Farm (REP)**

BC Import:793.18 MW Sask Import:150.00 MW MATL Import:0.00 MW  
 MH Export: -62.17 MW

**FIGURE A3.1-1-N-0: NORMAL OPERATION  
 2021 SUMMER PEAK (POST-PROJECT)  
 PRINTED ON FRIDAY 31, JANUARY 2020**

Bus - Voltage (KV) / MW  
 Branch - MW / MW  
 Equipment - MW / MW  
 1.000 / 0.000 / 0.000  
 47 -> 25.00 -> 189.00 -> 128.00 -> 94.00 -> 50.00 -> 50.00



**P2122 Cypress Wind Farm (REP)**

BC Import:796.16 MW Sask Import:150.00 MW MATL Import:0.00 MW  
MH Export: -62.17 MW

**FIGURE A3.1-2 N-1: 1088L (CASSILS 324S TO NEWELL A2075S)  
2021 SUMMER PEAK (POST-PROJECT)  
PRINTED ON FRIDAY 31, JANUARY 2020**

Sw - Voltage (KV) Bus - MW/MVA Export - MW/MVA  
1.000/0.000/0.000  
1.000/0.000/0.000  
1.000/0.000/0.000  
1.000/0.000/0.000  
1.000/0.000/0.000


# Attachment A4

## Post-Project Transient Stability Diagrams



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_00\_NOFAULT

FILE: Scn3\_SP\_00\_NoFault.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_01\_1074L\_ELKWATER

FILE: Scn3\_SP\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out

1.2303	CHNL# 27: [VOLT 976 [ROTRAUR 138.00]]	0.18630
1.1939	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.60900
1.3782	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	-0.0607
1.6943	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	-0.0133
1.3136	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.04920
1.1259	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.70780




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out

2.1169	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1008
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.1380	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.17600
3.2816	CHNL# 6: [POWR 773[SECST 20.000]I]	2.8124
0.56760	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.08820




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out

1.0921	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	-0.0520
0.95550	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	-0.0500
2.1169	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1008




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out

2.1606	CHNL# 2: [ANGL 773[SECST 20.000]I]	-4.712
-4.343	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-34.68




FRI, JAN 31 2020 11:13  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_02\_1074L\_BOWMANTON

FILE: Scn3\_SP\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]

1.2061	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.43710
3.1688	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.73980
1.3387	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.24720
1.6569	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	-0.0276
1.2814	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.33110
1.1055		0.79800




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out

2.2125	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1054
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.05000
2.3961	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	0.22590
3.2243	CHNL# 6: [POWR 773[SECST 20.000[1]]	2.7774
0.45490	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.15570




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out

1.2453	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.05350
3.3106	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	-0.1060
2.2125	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1054




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out

2.7838	CHNL# 2: [ANGL 773[SECST 20.000[1]]	-3.292
-6.117	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-23.67




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_03\_983L\_ELKWATER

FILE: Scn3\_SP\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_04\_983L\_WHITLA

FILE: Scn3\_SP\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_05\_964L\_WHITLA

FILE: Scn3\_SP\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out

1.1455	CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]	0.20040
3.1473	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.61450
1.2589	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	-0.0473
1.4240	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	-0.0029
1.2092	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.06440
1.0926	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.71170




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out

2.1959	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1046
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.0500
2.2365	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	0.17990
3.2951	CHNL# 6: [POWR 773[SECST 20.000[1]]	2.7285
0.58590	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.04940




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out

1.2284	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.02320
2.6272	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	-0.1678
2.1959	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1046




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out

2.4448	CHNL# 2: [ANGL 773[SECST 20.000[1]]	-5.019
-6.480	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-33.59




FRI, JAN 31 2020 11:13  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_06\_964L\_BOWMANTON

FILE: Scn3\_SP\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_07\_1034L\_CASSILS

FILE: Scn3\_SP\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:13  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out

1.1901	CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]	0.19240
1.1543	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.60930
1.3095	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	-0.0534
1.4236	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	-0.0038
1.2582	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.05470
1.1016	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.70790




FRI, JAN 31 2020 11:13  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out

2.3287	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1109
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.1676	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.22780
3.2011	CHNL# 6: [POWR 773[SECST 20.000]I]	2.7694
0.45280	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.14960




FRI, JAN 31 2020 11:13  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out

1.2454	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.01980
1.5408	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	-1.269
2.3287	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1109




FRI, JAN 31 2020 11:13  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out

2.2931	CHNL# 2: [ANGL 773[SECST 20.000]I]	-3.094
10.325	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-11.79




FRI, JAN 31 2020 11:13  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_08\_1034L\_BOWMANTON

FILE: Scn3\_SP\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:13  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_09\_1035L\_NEWELL

FILE: Scn3\_SP\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_10\_1035L\_BOWMANTON

FILE: Scn3\_SP\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_11\_892L\_SUFFIELD

FILE: Scn3\_SP\_11\_892L\_Suffield.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_12\_892L\_BOWMANTON

FILE: Scn3\_SP\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_13\_676L\_BULLSHEAD

FILE: Scn3\_SP\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out

1.0814	CHNL# 27: [VOLT 976 [ROTRAUR 138.00]]	0.10760
1.1361	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.73830
1.1492	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.24490
1.2886	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.13510
1.1024	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	-0.0400
1.0929	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.79640




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out

2.6025	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1239
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.5542	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.05240
3.1121	CHNL# 6: [POWR 773[SECST 20.000]I]	2.8529
0.46990	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.13430




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out

1.2387	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.27240
1.6932	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	0.19500
2.6025	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1239




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out

1.7732	CHNL# 2: [ANGL 773[SECST 20.000]I]	-0.7501
3.7335	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-25.23




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_14\_676L\_BOWMANTON

FILE: Scn3\_SP\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_15\_600L\_PEACEBUTTE

FILE: Scn3\_SP\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_16\_600L\_BULLSHEAD

FILE: Scn3\_SP\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out

CHNL#	UNIT	NAME	VALUE
27	[VOLT]	976 [ROTBUR 138.001]	-0.0484
26	[VOLT]	918 [CASS01 240.001]	0.82760
25	[VOLT]	669 [BOWMAN1 240.001]	0.44850
24	[VOLT]	662 [WHITLA1 240.001]	0.38250
23	[VOLT]	659 [BOWMAN2 138.001]	0.22760
22	[VOLT]	645 [BOWMAN3 138.001]	0.85910




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out

CHNL#	UNIT	NAME	VALUE
9	[POWR560003[P2122_GEN 0.69001G1]]		0.11660
8	[POWR 61990[SHAMROC6 0.65001G2]]		-0.05000
7	[POWR 60990[SHAMROC5 0.65001G1]]		0.54960
6	[POWR 773[SECST 20.00011]]		2.8524
5	[POWR 713[CMH 14 13.800114]]		-0.0023




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out

CHNL#	UNIT	NAME	VALUE
21	[ETRM560003[P2122_GEN 0.69001G1]]		0.46870
14	[VAR560003[P2122_GEN 0.69001G1]]		0.31820
9	[POWR560003[P2122_GEN 0.69001G1]]		0.11660




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out

CHNL#	UNIT	NAME	VALUE
2	[ANGL 773[SECST 20.00011]]		-1.655
1	[ANGL 713[CMH 14 13.800114]]		-35.47




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_17\_880L\_ALR

FILE: Scn3\_SP\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out

1.0943	CHNL# 27: [VOLT 976 [ROTBUR 138.00]]	0.18120
3.0895	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.86000
1.0927	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.52850
1.1062	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.48090
1.0990	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.32920
1.0500	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.88120




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out

2.7411	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	0.37570
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.3088	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.80650
3.1227	CHNL# 6: [POWR 773[SECST 20.000]I]	2.7897
0.46660	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.14690




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out

1.1896	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.54480
2.0659	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	0.38530
2.7411	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	0.37570




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out

2.2811	CHNL# 2: [ANGL 773[SECST 20.000]I]	-1.366
8.3801	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-30.87




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_18\_880L\_BULLSHEAD

FILE: Scn3\_SP\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_19\_675L\_ALR

FILE: Scn3\_SP\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out

1.0599	CHNL# 27: [VOLT 976 [ROTBUR 138.00]]	0.10050
3.1402	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.73770
1.1617	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.24550
1.3010	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.14550
1.1103	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	-0.0470
1.0955	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.79580




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out

2.2237	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1059
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.5549	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.17980
3.1191	CHNL# 6: [POWR 773[SECST 20.000]I]	2.8714
0.62510	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.05540




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out

1.2362	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.27590
1.4489	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	0.20440
2.2237	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1059




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out

1.5793	CHNL# 2: [ANGL 773[SECST 20.000]I]	-0.7184
6.2705	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-29.02




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_20\_675L\_BOWMANTON

FILE: Scn3\_SP\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT


FILE: Scn3\_SP\_21\_879L\_Burdett.out





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_21\_879L\_BURDETT

FILE: Scn3\_SP\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_22\_879L\_BOWMANTON

FILE: Scn3\_SP\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out

1.0404	CHNL# 27: [VOLT 976 [ROTBUR 138.00]]	0.78710
1.0854	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.73660
1.0862	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.73360
1.1120	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.71230
1.0676	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.75850
1.0982	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.27670




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out

2.6451	CHNL# 9: [POWR 61990[P2122_GEN 0.6900[G1]]	1.2288
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.05000
2.8081	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	1.2914
3.1131	CHNL# 6: [POWR 773[SECS7 20.000[1]]	2.7838
0.46630	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.17110




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out

1.1588	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.73490
1.7431	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	0.55250
2.6451	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	1.2288




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out

2.3472	CHNL# 2: [ANGL 773[SECS7 20.000[1]]	-2.299
-2.802	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-16.77




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_23\_658L\_CYPRESS

FILE: Scn3\_SP\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN3\_SP\_24\_658L\_BOWMANTON

FILE: Scn3\_SP\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_00\_NOFAULT

FILE: Scn4\_SL\_00\_NoFault.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_01\_1074L\_ELKWATER

FILE: Scn4\_SL\_01\_1074L\_Elkwater.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_02\_1074L\_BOWMANTON

FILE: Scn4\_SL\_02\_1074L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
P122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_03\_983L\_ELKWATER

FILE: Scn4\_SL\_03\_983L\_Elkwater.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out

300.63	CHNL# 41: [POWR 669 TO 918 CKT '34']	-17.22
53.066	CHNL# 39: [POWR 669 TO 547004 CKT '74']	-367.6
238.63	CHNL# 37: [POWR 662 TO 720 CKT '64']	-11.49
42.369	CHNL# 35: [POWR 669 TO 720 CKT '64']	-433.4
7.7831	CHNL# 33: [POWR 477 TO 662 CKT '83']	-163.4
162.40	CHNL# 31: [POWR 477 TO 547004 CKT '74']	-49.08




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out

57.016	CHNL# 44: [VARS 669 TO 1012 CKT '35']	-249.4
321.18	CHNL# 43: [POWR 669 TO 1012 CKT '35']	-8.851




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out

1.7650	CHNL# 14: [VARS60003[P2122_GEN 0.6900]G1]	0.16760
0.05000	CHNL# 13: [VARS 61990[SHAMROC6 0.6500]G2]	-0.0500
0.15190	CHNL# 12: [VARS 60990[SHAMROC5 0.6500]G1]	-0.0334
0.35070	CHNL# 11: [VARS 773[SECT 20.000]I]	-0.4472
0.56160	CHNL# 10: [VARS 713[CMH 14 13.800]I4]	-0.0901




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_04\_983L\_WHITLA

FILE: Scn4\_SL\_04\_983L\_Whitla.out

49.206	CHNL# 42: [VARS 669 TO 918 CKT '34']	-250.1
651.66	CHNL# 40: [VARS 669 TO 547004 CKT '74']	-157.1
1.7090	CHNL# 38: [VARS 662 TO 720 CKT '64']	-50.67
326.07	CHNL# 36: [VARS 669 TO 720 CKT '64']	-94.59
26.236	CHNL# 34: [VARS 477 TO 662 CKT '83']	-1.249
25.160	CHNL# 32: [VARS 477 TO 547004 CKT '74']	-528.4




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_05\_964L\_WHITLA

FILE: Scn4\_SL\_05\_964L\_Whitla.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]

1.1531	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.22230
1.1642	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.63360
1.2715	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	-0.0477
1.4215	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	-0.0021
1.2019	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.07420
1.1143		0.73320




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out

2.2040	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1050
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.4677	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.27180
0.99820	CHNL# 6: [POWR 773[SECST 20.000]I1]	0.42300
0.48500	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	-0.0798




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out

1.2315	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.01470
2.7588	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	-0.2045
2.2040	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1050




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out

-35.69	CHNL# 2: [ANGL 773[SECST 20.000]I1]	-43.07
-3.455	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-32.70




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_06\_964L\_BOWMANTON

FILE: Scn4\_SL\_06\_964L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
P122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_07\_1034L\_CASSILS

FILE: Scn4\_SL\_07\_1034L\_Cassils.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out

1.1679	CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]	0.21840
1.1554	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.62920
1.2794	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	-0.0521
1.3300	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	-0.0486
1.2143	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.06940
1.1124	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.73000




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out

2.1696	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1033
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.05000
2.5391	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	0.24390
1.0000	CHNL# 6: [POWR 773[SECS7 20.000[1]]	0.44820
0.31390	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.06350




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out

1.2521	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.01180
1.6015	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	-0.1747
2.1696	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	-0.1033




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out

-36.51	CHNL# 2: [ANGL 773[SECS7 20.000[1]]	-41.77
11.752	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-7.598




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_08\_1034L\_BOWMANTON

FILE: Scn4\_SL\_08\_1034L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_09\_1035L\_NEWELL

FILE: Scn4\_SL\_09\_1035L\_Newell.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out

584.54	CHNL# 41: [POWR 669 TO 918 CKT '34']	-31.34
39.694	CHNL# 39: [POWR 669 TO 547004 CKT '74']	-366.1
45.308	CHNL# 37: [POWR 662 TO 720 CKT '64']	-4.524
13.787	CHNL# 35: [POWR 669 TO 720 CKT '64']	-247.3
17.036	CHNL# 33: [POWR 477 TO 662 CKT '83']	-191.8
191.76	CHNL# 31: [POWR 477 TO 547004 CKT '74']	-17.02




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out

1159.9	CHNL# 44: [VARS 669 TO 1012 CKT '35']	-55.23
30415.	CHNL# 43: [POWR 669 TO 1012 CKT '35']	-1448.




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out

4.5171	CHNL# 14: [VARS60003[P2122_GEN 0.6900]G1]	-1.998
0.05000	CHNL# 13: [VARS 61990[SHAMROC6 0.6500]G2]	-0.0500
3.2405	CHNL# 12: [VARS 60990[SHAMROC5 0.6500]G1]	-0.4873
0.75570	CHNL# 11: [VARS 773[SECT 20.000]I]	-0.5718
0.77270	CHNL# 10: [VARS 713[CMH 14 13.800]I4]	-0.1522




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_10\_1035L\_BOWMANTON

FILE: Scn4\_SL\_10\_1035L\_Bowmanton.out

330.18	CHNL# 42: [VARS 669 TO 918 CKT '34']	-139.0
85.564	CHNL# 40: [VARS 669 TO 547004 CKT '74']	-222.8
21.261	CHNL# 38: [VARS 662 TO 720 CKT '64']	-26.94
139.23	CHNL# 36: [VARS 669 TO 720 CKT '64']	-291.9
159.10	CHNL# 34: [VARS 477 TO 662 CKT '83']	-315.9
315.54	CHNL# 32: [VARS 477 TO 547004 CKT '74']	-159.1




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]

1.0401	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.93480
1.0831	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.93260
1.0835	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.93240
1.0883	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.92630
1.0515	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.92240
1.0709		0.47650




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

2.2099	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	1.7520
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.05000
2.2394	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	1.7214
0.79360	CHNL# 6: [POWR 773[SECST 20.000[1]]	0.44960
0.27140	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.12000




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

1.0915	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.92190
1.2832	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	0.64830
2.2099	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	1.7520




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

-37.20	CHNL# 2: [ANGL 773[SECST 20.000[1]]	-41.12
-3.802	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-10.35




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

293.59	CHNL# 41: [POWR 669 TO 918 CKT '34']	235.64
-304.7	CHNL# 39: [POWR 669 TO 547004 CKT '74']	-378.8
46.052	CHNL# 37: [POWR 662 TO 720 CKT '64']	37.242
-204.5	CHNL# 35: [POWR 669 TO 720 CKT '64']	-255.7
-132.1	CHNL# 33: [POWR 477 TO 662 CKT '83']	-168.1
168.08	CHNL# 31: [POWR 477 TO 547004 CKT '74']	132.11




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

-3.158	CHNL# 44: [VARS 669 TO 1012 CKT '35']	-10.19
314.34	CHNL# 43: [POWR 669 TO 1012 CKT '35']	252.46




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

1.2832	CHNL# 14: [VARS560003[P2122_GEN 0.6900]G1]	0.64830
0.05000	CHNL# 13: [VARS 61990[SHAMROC6 0.6500]G2]	-0.0500
0.14600	CHNL# 12: [VARS 60990[SHAMROC5 0.6500]G1]	0.02770
0.15450	CHNL# 11: [VARS 773[SECT 20.000]I]	-0.2772
0.21470	CHNL# 10: [VARS 713[CMH 14 13.800]I4]	0.01140




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_11\_892L\_SUFFIELD

FILE: Scn4\_SL\_11\_892L\_Suffield.out

-4.252	CHNL# 42: [VARS 669 TO 918 CKT '34']	-17.10
16.596	CHNL# 40: [VARS 669 TO 547004 CKT '74']	-20.07
4.0885	CHNL# 38: [VARS 662 TO 720 CKT '64']	-2.738
32.533	CHNL# 36: [VARS 669 TO 720 CKT '64']	13.520
44.564	CHNL# 34: [VARS 477 TO 662 CKT '83']	20.799
-20.80	CHNL# 32: [VARS 477 TO 547004 CKT '74']	-44.56




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P, Q & ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_12\_892L\_BOWMANTON

FILE: Scn4\_SL\_12\_892L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_13\_676L\_BULLSHEAD

FILE: Scn4\_SL\_13\_676L\_Bullshead.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]

1.1056	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.12060
1.1294	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.75670
1.1474	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.25660
1.2827	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.13980
1.1027	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	-0.0397
1.0956		0.81640




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out

2.6069	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1241
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500]G2]	-0.05000
2.5591	CHNL# 7: [POWR 60990[SHAMROC5 0.6500]G1]	0.03010
0.94790	CHNL# 6: [POWR 773[SECST 20.000]I]	0.41590
0.34770	CHNL# 5: [POWR 713[CMH 14 13.800]I4]	0.06670




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out

1.2397	CHNL# 21: [ETRM560003[P2122_GEN 0.6900]G1]	0.27460
1.6938	CHNL# 14: [VAR560003[P2122_GEN 0.6900]G1]	0.17960
2.6069	CHNL# 9: [POWR560003[P2122_GEN 0.6900]G1]	-0.1241




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out

-37.67	CHNL# 2: [ANGL 773[SECST 20.000]I]	-41.23
1.1353	CHNL# 1: [ANGL 713[CMH 14 13.800]I4]	-16.10




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_14\_676L\_BOWMANTON

FILE: Scn4\_SL\_14\_676L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_15\_600L\_PEACEBUTTE

FILE: Scn4\_SL\_15\_600L\_Peacebutte.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
 BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
 ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
 P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshhead.out




FRI, JAN 31 2020 11:14  
 ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_16\_600L\_BULLSHEAD

FILE: Scn4\_SL\_16\_600L\_Bullshead.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_17\_880L\_ALR

FILE: Scn4\_SL\_17\_880L\_Alr.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshead.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshead.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshhead.out

307.05	CHNL# 41: [POWR 669 TO 918 CKT '34']	76.603
-115.3	CHNL# 39: [POWR 669 TO 547004 CKT '74']	-436.1
45.420	CHNL# 37: [POWR 662 TO 720 CKT '64']	7.1134
-91.74	CHNL# 35: [POWR 669 TO 720 CKT '64']	-276.0
-72.43	CHNL# 33: [POWR 477 TO 662 CKT '83']	-193.4
193.40	CHNL# 31: [POWR 477 TO 547004 CKT '74']	72.429




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshhead.out

21.788	CHNL# 44: [VARS 669 TO 1012 CKT '35']	-234.5
327.97	CHNL# 43: [POWR 669 TO 1012 CKT '35']	86.510




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshhead.out

2.0885	CHNL# 14: [VARS560003[P2122_GEN 0.6900]G]	0.36660
0.05000	CHNL# 13: [VARS 61990[SHAMROC6 0.6500]G2]	-0.0500
1.1478	CHNL# 12: [VARS 60990[SHAMROC5 0.6500]G1]	-0.0478
0.24360	CHNL# 11: [VARS 773[SECT 20.000]I]	-0.2920
0.80190	CHNL# 10: [VARS 713[CMH 14 13.800]I4]	0.02400




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_18\_880L\_BULLSHEAD

FILE: Scn4\_SL\_18\_880L\_Bullshhead.out

14.571	CHNL# 42: [VARS 669 TO 918 CKT '34']	-236.2
35.960	CHNL# 40: [VARS 669 TO 547004 CKT '74']	-63.36
25.652	CHNL# 38: [VARS 662 TO 720 CKT '64']	-7.323
87.881	CHNL# 36: [VARS 669 TO 720 CKT '64']	-6.968
86.575	CHNL# 34: [VARS 477 TO 662 CKT '83']	4.7701
-4.770	CHNL# 32: [VARS 477 TO 547004 CKT '74']	-86.57




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR

FILE: Scn4\_SL\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR

FILE: Scn4\_SL\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR

FILE: Scn4\_SL\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR


FILE: Scn4\_SL\_19\_675L\_Alr.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR




SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_19\_675L\_ALR





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
 CONTINGENCY -SCN4\_SL\_20\_675L\_BOWMANTON

FILE: Scn4\_SL\_20\_675L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
 REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE





SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out  
CHNL# 41: [POWR 669 TO 918 CKT '34']




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_21\_879L\_BURDETT

FILE: Scn4\_SL\_21\_879L\_Burdett.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out  
CHNL# 27: [VOLT 976 [ROTBRAU 138.00]]

1.0379	CHNL# 26: [VOLT 918 [CASS01 240.00]]	0.93250
1.0790	CHNL# 25: [VOLT 669 [BOWMAN1 240.00]]	0.92970
1.0792	CHNL# 24: [VOLT 662 [WHITLA1 240.00]]	0.92920
1.0836	CHNL# 23: [VOLT 659 [BOWMAN2 138.00]]	0.92280
1.0482	CHNL# 22: [VOLT 645 [BOWMAN3 138.00]]	0.91960
1.0825		-0.0311




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out

2.2301	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	1.7459
0.05000	CHNL# 8: [POWR 61990[SHAMROC6 0.6500[G2]]	-0.05000
2.2664	CHNL# 7: [POWR 60990[SHAMROC5 0.6500[G1]]	1.7144
0.82220	CHNL# 6: [POWR 773[SECST 20.000[1]]	0.43520
0.26960	CHNL# 5: [POWR 713[CMH 14 13.800[14]]	0.11670




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out

1.1039	CHNL# 21: [ETRM560003[P2122_GEN 0.6900[G1]]	0.91800
1.2921	CHNL# 14: [VAR560003[P2122_GEN 0.6900[G1]]	0.65470
2.2301	CHNL# 9: [POWR560003[P2122_GEN 0.6900[G1]]	1.7459




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out

-37.54	CHNL# 2: [ANGL 773[SECST 20.000[1]]	-41.00
-4.520	CHNL# 1: [ANGL 713[CMH 14 13.800[14]]	-9.491




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_22\_879L\_BOWMANTON

FILE: Scn4\_SL\_22\_879L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out  
CHNL# 27: [VOLT 976 [ROTBUR 138.00]]




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
P2122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_23\_658L\_CYPRESS

FILE: Scn4\_SL\_23\_658L\_Cypress.out




FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
BUS VOLTAGE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
ACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out




FRI, JAN 31 2020 11:14  
P122 P, Q&ETERM



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
ROTOR ANGLE



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
BRANCH FLOW



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out





FRI, JAN 31 2020 11:14  
REACTIVE POWER



SCENARIO: P2122 SYSTEM IMPACT STUDY  
CONTINGENCY -SCN4\_SL\_24\_658L\_BOWMANTON

FILE: Scn4\_SL\_24\_658L\_Bowmanton.out



FRI, JAN 31 2020 11:14  
BRANCH FLOW

## Attachment A5

# Project Dynamic Data and Assumptions

The dynamic data of the equipment proposed for connection of the Cypress Wind Power Project to the grid is listed in the below tables.

**Table A5-1: Renewable Energy Generator/Converter Model WT4G1**

TIQCmd	TIPCcmd	VLVPL1	VLVPL2	GLVPL	VHVR CR	CURHVR CR	RIP_LVPL	T_LVPL
0.02	0.02	0.4	0.9	1.11	1.2	2.0	2.0	0.02


**Table A5-2: Renewable Energy Electric Control Model WT4E1**

Remote Bus	PF FALG	VAR FLAG	PQ FLAG	Tfv	Kpv	Kiv	Kpp	Kip	Kf	Tf	Qmx	Qmn
560003	0	1	0	0.15	18.0	5.0	0.05	0.1	0.0	0.08	0.47	-0.47
IPmax	Trv	dPmx	dPmn	T_power	Kqi	Vmincl	Vmaxcl	Kvi	Tv	Tp	ImaxTD	lphi
1.1	0.0	0.5	-0.5	0.05	0.1	0.9	1.1	120.	0.05	0.05	1.7	1.11
Iqhl												
1.11												



# Attachment A6

## Post-Mitigation Power Flow Diagrams




**P2122 Cypress Wind Farm (REP)**

BC Import:793.73 MW Sask Import:150.00 MW MATL Import:-0.00 MW  
 MH Export: -62.17 MW

**FIGURE A6.1-1-N-0: NORMAL OPERATION  
 2021 SUMMER PEAK (PRE-PROJECT)  
 PRINTED ON FRIDAY 31. JANUARY 2020**

Bus - Voltage (KV) / MW  
 Branch - MW / MW  
 Equipment - MW / MW  
 1.000 / 0.000 / 0.000  
 47 -> 25.00 -> 189.00 -> 128.00 -> 94.00 -> 50.00 -> 50.00




**P2122 Cypress Wind Farm (REP)**

BC Import:801.17 MW Sask Import:150.00 MW MATL Import:-0.00 MW  
 MH Export: -62.15 MW

**FIGURE A6.1-2 N-1: 1088L (CASSILS 324S TO NEWELL A2075S) WITH EATL RAS  
 2021 SUMMER PEAK (PRE-PROJECT)  
 PRINTED ON FRIDAY 31. JANUARY 2020**

Bus - Voltage (KV) / MW  
 Branch - MW / MW  
 Equipment - MW / MW  
 1.000 / 0.000 / 0.000  
 47 -> 25.000 -> 189.000 -> 128.000 -> 94.000 -> 500.000 -> 500.000




**P2122 Cypress Wind Farm (REP)**

BC Import:793.18 MW Sask Import:150.00 MW MATL Import:0.00 MW  
MH Export: -62.17 MW

**FIGURE A6.2-1-N-0: NORMAL OPERATION  
2021 SUMMER PEAK (POST-PROJECT)  
PRINTED ON FRIDAY 31, JANUARY 2020**

Bus - Voltage (KV) / MW  
Branch - MW/MW  
Equipment - MW/MW  
100% / 100%  
1.000 / 0.000 / 0  
WT - 25.00 / 189.00 / 128.00 / 24.00 / 250.00 / 50.00



**P2122 Cypress Wind Farm (REP)**

BC Import:805.55 MW Sask Import:150.00 MW MATL Import:-0.00 MW  
 MH Export: -62.15 MW

**FIGURE A6.2-2 N-1: 1088L (CASSILS 324S TO NEWELL A2075S) WITH EATL RAS  
 2021 SUMMER PEAK (POST-PROJECT)  
 PRINTED ON FRIDAY 31. JANUARY 2020**

Bus - Voltage (KV) Busbar - MW/MVA Equipment - MW/MVA  
 1.000 (0.000) 1.000 (0.000) 1.000 (0.000)  
 47 -<25.00 ->189.00 -<128.00 ->40.00 -<500.00 ->500.00

## Attachment A7 Constraint Effective Factors Table

Contingency (System Element Lost)	Constraint Effective Factors on Thermal Loading on 1087L		
	Medicine Hat Generators	P1812	P2122
<b>2021 SP Scenario 1 (pre-Project)</b>			
<b>1088L</b>	-0.1720	-0.1621	0.0000
<b>2021 SP Scenario 1 (post-Project)</b>			
<b>1088L</b>	-0.1696	-0.1589	-0.1625