

## **APPENDIX A CONNECTION ASSESSMENT**



# Engineering Connection Assessment

## P2032 Cascade Power Plant Project Connection

Cascade Power Project Limited Partnership

**Date:** June 26, 2020

**Version:** V3

**Classification:** Public

Role	Name	Date	Signature
Prepared	Myron Jin-Li, P. Eng	June 26, 2020	<i>Myron Jin-Li</i>
Reviewed	Maz Mazadi, P. Eng	June 26, 2020	<i>Mazadi</i>
Approved	Robert Davidson, P. Eng	June 26, 2020	<i>Robert Davidson</i>

**APEGA**  
Permit-to-Practice *Robert Davidson*  
P-8200 June 26, 2020



Alberta Electric System Operator

Calgary Place, 2500, 330-5th Avenue SW Calgary, AB T2P 0L4  
Phone: 403-539-2450 | Fax: 403-539-2949

www.aeso.ca  
@theaeso

**NOTE:**

The conclusions and recommendations in this report are based on the results presented in *Attachment A: Engineering Connection Assessment: Study Results*, which was prepared by the AESO.

# Contents

<b>1</b>	<b>Introduction .....</b>	<b>1</b>
1.1	Project Overview.....	1
<b>2</b>	<b>Assessment Scope .....</b>	<b>2</b>
2.1	Objectives .....	2
2.2	Existing System .....	2
2.3	Study Area .....	2
<b>3</b>	<b>Connection Alternatives .....</b>	<b>4</b>
3.1	Overview .....	4
3.2	Connection Alternatives Examined.....	4
3.3	Connection Alternatives Selected for Further Study.....	6
3.4	Connection Alternatives Not Selected for Further Study.....	6
<b>4</b>	<b>Assessment Approach .....</b>	<b>8</b>
4.1	Standards, Criteria and Assumptions .....	8
4.2	Studies Performed .....	8
4.2.1	<i>Power Flow Studies</i> .....	9
4.2.2	<i>Transient Stability Studies</i> .....	9
4.2.3	<i>Short-Circuit Current Level Studies</i> .....	9
4.3	Mitigation Measure Development and Evaluation .....	9
4.3.1	<i>Post-Mitigation Studies</i> .....	9
4.3.2	<i>Constraint Effective Factor Studies</i> .....	9
<b>5</b>	<b>Interpretation of Results .....</b>	<b>10</b>
5.1	Results Overview .....	10
5.2	Pre-Project Study Results.....	17
5.2.1	<i>Category A Conditions</i> .....	17
5.2.2	<i>Category B Conditions</i> .....	17
5.3	Post-Project Study Results .....	17
5.3.1	<i>Category A Conditions</i> .....	17
5.3.2	<i>Category B Conditions</i> .....	17
5.4	Mitigation Measures.....	17
5.4.1	<i>Pre-Project</i> .....	17
5.4.2	<i>Post-Project</i> .....	18
5.4.2.1	<i>Category A Conditions</i> .....	18
5.4.2.2	<i>Category B Conditions</i> .....	18
5.4.3	<i>Post-Project Mitigation Study Results</i> .....	18
<b>6</b>	<b>Project Dependencies .....</b>	<b>19</b>
<b>7</b>	<b>Conclusions and Recommendations .....</b>	<b>20</b>

## Tables

Table 4-1: Connection Study Scenarios..... 8  
Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures ..... 11

## Figures

Figure 2-1: Transmission System in the Study Area..... 3  
Figure 3-1: Connection Alternative 1..... 5  
Figure 3-2: Connection Alternative 2..... 6

## Attachments

Attachment A: Engineering Connection Assessment Results

# 1 Introduction

This AESO Engineering Connection Assessment describes the engineering studies that were completed to assess the impact of the Project (as defined below) on the performance of the Alberta interconnected electric system (AIES). This report also provides the AESO's conclusions and recommendations based on the results of the engineering studies.

Attached to this Engineering Connection Assessment are the results of the engineering studies (see Attachment A) and the scope and methodology used to perform the studies (see Attachment A1 to Attachment A). These attachments provide details regarding the technical criteria, assumptions, and methods for performing these engineering studies, and the results of the engineering studies.

## 1.1 Project Overview

Cascade Power Project Limited Partnership (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its approved Cascade Power Plant (Facility) to the AIES. The Facility includes a substation, to be designated Whisky Jack 1047S.

The market participant's request includes a request for new Rate STS, *Supply Transmission Service*, contract capacity of 900 MW and a new Rate DTS, *Demand Transmission Service*, contract capacity of 11.5 MW. There are two development phases for the Facility. Phase 1 includes the addition of one combined cycle gas generation unit with a maximum authorized real power (MARP) of 462.5 MW and a maximum capability (MC) of 450 MW. Phase 2 includes the addition of a second combined cycle generation unit with an MARP of 462.5 MW. After Phase 2, the MC of the Facility will be 900 MW.

The Project in-service date (ISD) for both Phase 1 and Phase 2 is March 25, 2022.

## 2 Assessment Scope

### 2.1 Objectives

The objectives of the AESO Engineering Connection Assessment are as follows:

- Assess the impact of the Project on the performance of the AIES.
- Evaluate Project connection alternatives and identify the AESO's preferred alternative.
- Recommend mitigation measures, if required, to reliably connect the Project to the AIES.
- Identify Project dependencies, including any TFO projects or AESO plans to expand or enhance the transmission system that must be completed prior to connection.

### 2.2 Existing System

Geographically, the Project is located in the AESO planning area of Hinton/Edson (Area 29), which is part of the AESO Central Planning Region.

From a transmission system perspective, Hinton/Edson (Area 29) consists primarily of a 240 kV and 138 kV transmission system. Hinton/Edson is connected to Wabamun (Area 40) via both 240 kV and 138 kV transmission lines, as well as Fox Creek (Area 24) and Drayton Valley (Area 30) via 138 kV transmission lines.

### 2.3 Study Area


The Study Area consists of the AESO planning areas of Hinton/Edson (Area 29), Grande Cache (Area 22), Fox Creek (Area 24), Drayton Valley (Area 30) and Wabamun (Area 40), including the tie lines connecting these planning areas to the rest of the AIES.

Existing constraints in the Study Area are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management* (TCM Rule).

Additionally, there are a number of constraints in the Study Area that are mitigated by existing protection schemes. The following existing automatic protection schemes (APS) are used to manage constraints in the area:

- APS 25: Brazeau 62S Generation Tripping Scheme
- APS 46: Bickerdike 39S – 740L Load Trip Scheme
- APS 47: Obed Mountain Coal 411S - Load Trip Scheme
- APS 150: WATL HVDC

Figure 2-1: Transmission System in the Study Area





## 3 Connection Alternatives

### 3.1 Overview

The AESO, in consultation with the TFO in the Study Area and the MP, examined several transmission alternatives to meet the MP's request for system access service, as detailed in Section 3.3.<sup>1</sup>

Due to the location and the size of the project, the only viable connection was determined to be the 240 kV transmission system via the existing Bickerdike 39S substation. Other potential connections were not advanced beyond preliminary consideration due to either the distance involved or the insufficient capacity of a 138 kV connection.

### 3.2 Connection Alternatives Examined

Below is a description of the developments associated with the transmission alternatives that were examined for the Project.

#### **Alternative 1 –Connection to the existing Bickerdike 39S substation via three 240 kV circuits**

- Add three 240 kV transmission lines to connect the Facility to the existing Bickerdike 39S substation;
- Modify the existing Bickerdike 39S substation, including adding four 240 kV circuit breakers; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-1.

#### **Alternative 2 - Connection to the existing Bickerdike 39S substation via two 240 kV circuits**

This alternative includes the following developments:

- Add two 240 kV transmission lines to connect the Facility to the existing Bickerdike 39S substation;
- Modify the existing Bickerdike 39S substation, including adding three 240 kV circuit breakers; and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 3-2.

Figure 3-1: Connection Alternative 1





Figure 3-2: Connection Alternative 2



### 3.3 Connection Alternatives Selected for Further Study

Alternative 1 is considered technically feasible and was selected for further study.

### 3.4 Connection Alternatives Not Selected for Further Study

Alternative 2 can carry the full STS of the Project to the Bickerdike 39S substation following the loss of one of the two new 240 kV lines, similar to Alternative 1. However, under certain Category C conditions resulting in the loss of one of the new 240 kV lines and certain substation equipment, equipment ratings

V3

within the Bickerdike 39S substation could be exceeded. Therefore, Alternative 2 is not viable and is not selected for further study.

## 4 Assessment Approach

### 4.1 Standards, Criteria and Assumptions

A detailed description of the standards, criteria, and assumptions that were used for the connection assessment is provided in Attachment A (see Attachment A1).

### 4.2 Studies Performed

The scheduled ISD for the Project is March 25, 2022. Therefore, studies were performed using scenarios for 2022 Summer Peak (SP), 2022 Summer Light (SL) and 2022 Winter Peak (WP). Short-circuit studies were performed using the 2022 WP and 2029 WP scenarios.

Table 4-1 lists the study scenarios. Post-Project scenarios reflect the requested Rate STS contract capacity 900 MW at the Bickerdike 39S substation. The relatively small DTS contract requested, which is for station service load, was assessed to have no adverse impact on the Study Area. A high Northwest import scenario was identified as being critical to study due to the potential impacts on the 138 kV transmission path serving the AESO Northwest Planning Region from Bickerdike 39S substation post-Project.

For post-Project transient stability studies, a high AESO Central Planning Region generation sensitivity scenario is added during 2022 Summer Light (SL) conditions, as low load and high local generation may impact system transient stability following the connection of the Project.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Net-to-Grid Generation (MW)
<b>Pre-Project</b>				
1	2022 SP	High Northwest (NW) Import	2021 SP Pre-Project	0
2	2022 WP		2021 WP Pre-Project	0
<b>Post-Project</b>				
3	2022 SP	High NW Import	2022 SP Post-Project	900
4	2022 WP		2022 WP Post-Project	900
5	2029 WP	All study area generation online	2028 WP Post-Project	900
<b>Post-Project Sensitivity (Transient Stability)</b>				
6	2022 SL	High Central Generation	2022 SL Post-Project	900

The AESO Planning Region load forecasts used for the connection studies were based on the 2019 Long-Term Outlook (2019 LTO).

### **4.2.1 Power Flow Studies**

The purpose of the power flow studies is to identify and quantify any thermal and voltage criteria violations in the Study Area.

In addition, power flow studies are also used to identify point of delivery (POD) low voltage bus voltage deviations beyond the limits listed in Table 3-1 of Attachment A1.<sup>2</sup>

Power flow studies were performed for the 2022 SP and 2022 WP pre-Project and post-Project scenarios.

### **4.2.2 Transient Stability Studies**

The purpose of the transient stability studies is to assess the post-Project stability of the transmission system after three-phase to ground faults are applied on select transmission lines in the Study Area.

Transient stability studies were performed for the 2022 SP and 2022 WP post-Project scenarios, as well as the 2022 SL post-Project sensitivity scenario.

### **4.2.3 Short-Circuit Current Level Studies**

The purpose of short-circuit current level studies is to determine the expected system short-circuit current levels in the vicinity of the Project.

Short circuit studies were performed for the 2022 WP pre-Project scenario and for the 2022 WP and 2029 WP post-Project scenarios.

## **4.3 Mitigation Measure Development and Evaluation**

As explained in Section 6 of Attachment A1, mitigation measures were developed to address system performance issues that were identified in the post-Project scenarios. Studies performed to assess the effectiveness of mitigation measures are briefly outlined below.

### **4.3.1 Post-Mitigation Studies**

Power flow studies were performed to assess the impact of the Project on the performance of the AIES following implementation of the AESO's proposed mitigation measures.

### **4.3.2 Constraint Effective Factor Studies**

Constraint effective factor studies were used to determine the generator and load constraint effective factors and to identify the most effective generators or loads to manage thermal criteria violations that were observed under Category B conditions.

---

<sup>2</sup> The AESO's desired post-contingency voltage deviations for low voltage busses represent guidelines rather than criteria. A POD bus voltage deviation that exceeds the desired limits shown in Table 3-1 of Attachment A1 does not represent a Reliability Criteria violation. Mitigation measures would not be developed to specifically address POD bus voltage deviations that exceed the desired values in Table 3-1 of Attachment A1.

## 5 Interpretation of Results

### 5.1 Results Overview

This section provides an assessment of the impact of the Project on the performance of the AIES. The Reliability Criteria violations observed during the connection assessment studies, and the proposed mitigation measures are summarized in Table 5-1.

- Section 5.2 includes an overview of the pre-Project studies results.
- Section 5.3 includes an overview of the post-Project studies results.
- Section 5.4 includes a description of the proposed mitigation measures to address observed Reliability Criteria violations.
- Section 5.5 includes an overview of the post-mitigation studies results.

Detailed study results are provided in Attachment A.

**Table 5-1: Summary of Reliability Criteria Violations, Project Impact and Mitigation Measures**

Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 SP	None	Thermal - above normal rating	None	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	TCM Rule
2022 SP	None	Thermal - above normal rating	None	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	TCM Rule
2022 SP	Thermal - above normal rating	None	995L (62S Brazeau – 68S Willesden Green – 17S Benalto)	202L (61S Lodgepole – 62S Brazeau)	Resolved violation	Real time operational practices (RTOP)	None
2022 SP	None	Thermal - above normal rating	202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	202L (58S Edson - 178S Cynthia)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above emergency rating	202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above emergency rating	58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 720L RAS
2022 SP	None	Thermal - above normal rating	61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above emergency rating	207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	207S Pinedale T1/T2	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	320P Keephills GT1	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	320P Keephills GT2	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	320P Keephills GT3	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	320P Keephills T1	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	62S Brazeau T5	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above emergency rating	671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 740L RAS
2022 SP	None	Thermal - above normal rating	672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above emergency rating	685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	685L (397S Benbow - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	720L (347S Fox Creek - 397S Benbow)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS





Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 SP	None	Thermal - above emergency rating	720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above emergency rating	744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	178S Cynthia T1	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above emergency rating	178S Cynthia T1	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	834L (384S Keystone - 320P Keephills)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	836L (61S Lodgepole - 283S Violet Grove)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above emergency rating	1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	1012S Deer Hill T1	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above normal rating	890L (58S Edson - 207S Pinedale)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 202L RAS
2022 SP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	902L (19S Wabamun Generation Station - 310P Sundance)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	902L (19S Wabamun Generation Station - 310P Sundance)	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	902L (19S Wabamun Generation Station - 310P Sundance)	744L (235S Entwistle - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance)	909L (310P Sundance - Dome)	Materially increased violation	None	New 890L RAS and New 202L RAS



Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 SP	None	Thermal - above normal rating	905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	905L (19S Wabamun Generation Station - 37S North Calder)	909L (310P Sundance - Dome)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	909L (310P Sundance - Dome)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	909L (310P Sundance - Dome)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	909L (310P Sundance - Dome)	902L (19S Wabamun Generation Station - 310P Sundance )	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	913L (69S North Barrhead - 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 SP	None	Thermal - above normal rating	919L (310P Sundance - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above normal rating	919L (310P Sundance - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above normal rating	922L (310P Sundance - 17S Benalto)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	922L (310P Sundance - 17S Benalto)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	926L (310P Sundance - 17S Benalto)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	926L (310P Sundance - 17S Benalto)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	744L (235S Entwistle - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	974L (39S Bickerdike - 310P Sundance )	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	744L (235S Entwistle - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	973L (39S Bickerdike - 310P Sundance )	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 SP	None	Thermal - above normal rating	989L (310P Sundance - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and RTOP



Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 SP	None	Thermal - above normal rating	989L (310P Sundance - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above normal rating	1046L (310P Sundance to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above normal rating	1046L (310P Sundance to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above emergency rating	19S Wabamun T10	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and RTOP
2022 SP	None	Thermal - above emergency rating	39S Bickerdike T1	39S Bickerdike T2	Materially increased violation	None	New Bickerdike T1/T2 RAS
2022 SP	None	Thermal - above emergency rating	39S Bickerdike T1	39S Bickerdike T2	Materially increased violation	None	New Bickerdike T1/T2 RAS
2022 SP	None	Thermal - above emergency rating	39S Bickerdike T2	39S Bickerdike T1	Materially increased violation	None	New Bickerdike T1/T2 RAS
2022 SP	None	Thermal - above emergency rating	39S Bickerdike T2	39S Bickerdike T1	Materially increased violation	None	New Bickerdike T1/T2 RAS
2022 WP	None	Thermal - above normal rating	202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above normal rating	202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above normal rating	58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 720L RAS
2022 WP	None	Thermal - above normal rating	61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	320P Keephills T1	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 740L RAS
2022 WP	None	Thermal - above normal rating	672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above emergency rating	685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above emergency rating	744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS



Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 WP	None	Thermal - above normal rating	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	62S Brazeau T1	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	62S Brazeau T2	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above normal rating	178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	178S Cynthia T1	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above normal rating	834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above emergency rating	1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 202L RAS
2022 WP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance )	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	902L (19S Wabamun Generation Station - 310P Sundance )	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	902L (19S Wabamun Generation Station - 310P Sundance )	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	909L (310P Sundance - Dome)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	909L (310P Sundance - Dome)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	909L (310P Sundance - Dome)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	909L (310P Sundance - Dome)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	913L (69S North Barrhead - 338S Cherhill)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	919L (310P Sundance - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above normal rating	919L (310P Sundance - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	922L (310P Sundance - 17S Benalto)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	922L (310P Sundance - 17S Benalto)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	926L (310P Sundance - 17S Benalto)	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	926L (310P Sundance - 17S Benalto)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS



Scenario	Type of Reliability Criteria Violation		Contingency (System Element Lost)	Details of Violation	Project Impact	Pre-Project Mitigation Measures	Post-Project Mitigation Measures
	Pre-Project	Post-Project					
2022 WP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	744L (235S Entwistle - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	973L (39S Bickerdike - 310P Sundance )	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	973L (39S Bickerdike - 310P Sundance )	974L (39S Bickerdike - 310P Sundance )	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	202L (58S Edson - 178S Cynthia)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	740L (58S Edson - 39S Bickerdike)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	744L (228S T.M.P.L. Niton - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	744L (235S Entwistle - 744AL Tap)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	974L (39S Bickerdike - 310P Sundance )	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	974L (39S Bickerdike - 310P Sundance )	973L (39S Bickerdike - 310P Sundance )	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above normal rating	989L (310P Sundance - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above normal rating	989L (310P Sundance - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	1046L (310P Sundance to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	1046L (310P Sundance to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS and New 202L RAS
2022 WP	None	Thermal - above emergency rating	19S Wabamun T10	890L (58S Edson - 207S Pinedale)	Materially increased violation	None	New 890L RAS
2022 WP	None	Thermal - above emergency rating	39S Bickerdike T1	39S Bickerdike T2	Materially increased violation	None	New Bickerdike T1/T2 RAS
2022 WP	None	Thermal - above emergency rating	39S Bickerdike T2	39S Bickerdike T1	Materially increased violation	None	New Bickerdike T1/T2 RAS

**Notes:**

- Materially increased (or materially decreased) refers to a percent loading difference (post-Project percent loading minus pre-Project percent loading) above or equal to 3% (or below or equal to -3%).
- Due to the high Category A loading on 890L and 202L (>99%), only Category B conditions which result in more than a 1% loading increase over the Category A loading are reported.

## 5.2 Pre-Project Study Results

### 5.2.1 Category A Conditions

No Reliability Criteria violations were observed under the Category A conditions (i.e., all elements in service) for any of the pre-Project scenarios. The short-circuit fault levels were found to be within the typical capabilities of the nearby facilities.

### 5.2.2 Category B Conditions

The pre-Project power flow studies identified one thermal violation under Category B conditions (i.e., loss of a single system element).

No voltage criteria violations or voltage deviations were observed that were beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) under Category B conditions.

## 5.3 Post-Project Study Results

### 5.3.1 Category A Conditions

Marginal thermal criteria violations were observed under the Category A condition for the 2022 SP post-Project scenario.

Near-term Post-Project short-circuit fault levels are higher than pre-Project levels but do not approach or exceed existing equipment ratings at the respective substations. The long term short circuit levels were found to be within the designed capabilities of the nearby facilities.

### 5.3.2 Category B Conditions

Due to the Category A thermal violations observed for the 2022 SP post-Project scenario, the TCM Rule was first applied to mitigate the violations by re-dispatching effective generation prior to simulating any contingency. Post-Project power flow studies identified numerous thermal criteria violations under Category B conditions, as shown in Table 5-1.

No voltage criteria violations or POD bus voltage deviations were observed under Category B conditions.

The post-Project study results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied.

## 5.4 Mitigation Measures

This section discusses the AESO's proposed mitigation measures to address the system performance issues that were identified in the pre-Project and post-Project scenarios.

### 5.4.1 Pre-Project

Prior to connection of the Project, the observed thermal criteria violation would be managed by using real-time operational practices.

## **5.4.2 Post-Project**

### **5.4.2.1 Category A Conditions**

The Category A violations observed in the study are mitigated by applying the TCM Rule to dispatch down effective generation. The forecast study conditions represent the credible worst case scenario, which assumes that the Facility is exporting its full STS to the system. The possibility of this scenario occurring is dependent on the generation profile of the Facility.

Should these Category A violations materialize, mitigations would be required to address the potential marginal thermal criteria violations under the Category A condition. The AESO would develop operational procedures or other mitigation measures, such as the following:

- Redispatching the 500 kV HVDC transmission lines EATL and WATL
- Operational system reconfiguration
- Increasing the thermal rating of 138 kV transmission lines 890L and 202L

### **5.4.2.2 Category B Conditions**

After connection of the Project, all of the observed Category B thermal criteria violations observed would be mitigated by using new RASs and/or real-time operational practices. Five new RASs are proposed to mitigate thermal criteria violations observed under Category B conditions: 890L RAS, 202L RAS, 740L RAS, 720L RAS, and Bickerdike 39S substation transformer T1/T2 RAS.

The new 890L, 202L, 740L and 720L RASs will trip or send a runback signal to one of the two Facility generation units if one of the 138 kV transmission lines 890L, 202L, 740L or 720L exceeds its emergency or continuous thermal rating. Based on the post-mitigation studies, these RAS actions (in combination with real-time operational practices where appropriate) will successfully mitigate all other related (i.e. resulting from the same contingency) thermal criteria violations.

The new Bickerdike 39S substation T1/T2 RAS will trip or send a runback signal to one of the two Facility generators to mitigate thermal criteria violations on Bickerdike transformer T1 or T2, following the loss or either Bickerdike 39S transformer T1 or T2. In the Winter Peak scenario, real-time operational practices may also be required post RAS action, to fully mitigation thermal criteria violations.

### **5.4.3 Post-Project Mitigation Study Results**

Under Category A and Category B conditions, all the observed Reliability Criteria violations were mitigated following simulated RAS action.

## 6 Project Dependencies

The Project is dependent upon the restoration of thermal ratings for two existing transmission lines; the 138 kV transmission line 720L, and the 144 kV transmission line 7L199.

The 138 kV transmission line 720L is currently limited to a normal rating of 86 MVA in the summer, and 91 MVA in the winter. The TFO, in discussion with the Market Participant, has committed to restoring 720L to seasonal normal ratings of 120/148 MVA prior to the ISD of the Project.

The 144 kV transmission line 7L199 is currently limited to a normal rating of 114 MVA in the summer and 146 MVA in the winter. ATCO Electric Ltd. has a planned capital maintenance project that will restore 7L199 to seasonal normal ratings of 129/157 MVA. The work is planned to be completed prior to the ISD of the Project as part of ATCO's capital maintenance program.

The studies were performed assuming the restored ratings for 720L and 7L199 as both transmission lines are being restored outside the scope of the Project and are planned to be in-service prior to the ISD of the Project. Additional mitigation measures may be required if these transmission line thermal rating restorations are not completed prior to the ISD of the Project.



## 7 Conclusions and Recommendations

Based on the study results, Alternative 1 is technically viable. The connection assessment identified pre-Project and post-Project system performance issues.

The connection assessment identified the potential for marginal system performance issues (thermal criteria violations) under the Category A condition when the Facility is exporting its full STS to the system.

The probability of Category A issues materializing is highly dependent upon the merit order generation profile of the Facility. Should the AESO determine that mitigation is required to address Category A issues based on the generation profile for the Facility, the AESO will develop operational procedures or other mitigation measures closer to the ISD of the Project.

It is recommended that Category B issues be mitigated through the use of five new RASs (890L RAS, 202L RAS, 740L RAS, 720L RAS, and Bickerdike 39S substation transformer T1/T2 RAS), and real-time operational practices, alone or in combination, as appropriate.

The AESO recommends proceeding with the Project using Alternative 1 as the preferred alternative to respond to the Market Participant's request for system access service. Alternative 1 involves adding three 240 kV transmission lines to connect the Facility to the existing Bickerdike 39S substation and modifying the existing Bickerdike 39S substation including adding four 240 kV circuit breakers. The conductor used for the new 240 kV circuits should have a minimum thermal rating of 514 MVA.

# Attachment A: Engineering Connection Assessment Results

# Engineering Connection Assessment: Study Results




## P2032 Cascade Power Plant Project Connection

Cascade Power Project Limited Partnership

**Date:** June 26, 2020

**Version:** V3


**Classification:** Public

Role	Name	Date	Signature
Prepared	Myron Jin-Li, P. Eng	June 26, 2020	
Reviewed	Maz Mazadi, P. Eng	June 26 2020	
Approved	Robert Davidson, P. Eng	June 26 2020	

**APEGA**

Permit-to-Practice

P-8200

  
June 26, 2020



June 26, 2020

# Contents

<b>1</b>	<b>Introduction</b> .....	<b>1</b>
<b>2</b>	<b>Pre-Project Study Results</b> .....	<b>2</b>
2.1	Power Flow Studies .....	2
2.1.1	Scenario 1: 2020 Summer Peak Pre-Project .....	2
2.1.2	Scenario 2: 2022 Winter Peak Pre-Project .....	3
<b>3</b>	<b>Post-Project Study Results</b> .....	<b>4</b>
3.1	Power Flow Studies .....	4
3.1.1	Scenario 3: 2022 Summer Peak Post-Project .....	4
3.1.2	Scenario 4: 2022 Winter Peak Post-Project .....	10
3.2	Transient Stability Studies .....	15
<b>4</b>	<b>Short Circuit Studies</b> .....	<b>16</b>
4.1	Pre-Project Results .....	16
4.1.1	Scenario 2: 2022 WP Pre-Project .....	16
4.2	Post-Project Results .....	16
4.2.1	Scenario 4: 2022 WP Post-Project .....	16
4.2.2	Scenario 5: 2029 WP Post-Project .....	17
<b>5</b>	<b>Mitigation Measure Development and Evaluation</b> .....	<b>19</b>
5.1	Pre-Project .....	19
5.2	Post-Project .....	19
5.3	Evaluation of Mitigation Measures .....	23
5.3.1	Scenario 3: 2022 SP Post-Project .....	24
5.3.2	Scenario 4: 2022 WP Post-Project .....	32
5.4	Constraint Effective Factor Studies .....	38

## Tables

Table 2-1: Thermal Criteria Violations under Category B Conditions for [Scenario 1] .....	2
Table 3-1: Thermal Criteria Violations under Category A Conditions for Scenario 3 .....	4
Table 3-2: Thermal Criteria Violations under Category B Conditions for Scenario 3 .....	5
Table 3-1: Thermal Criteria Violations under Category B Conditions for Scenario 4 .....	10
Table 3-4: Transient Stability Study Results under Category B Conditions for All Scenarios .....	15
Table 4-1: Pre-Project Short-Circuit Current Levels for Scenario 2 .....	16
Table 4-2: Post-Project Short-Circuit Current Levels for Scenario 4 .....	17
Table 4-3: Post-Project Short-Circuit Current Levels for Scenario 5 .....	17
Table 5-1: Pre-Project Mitigation Measures .....	19
Table 5-2: Post-Project Mitigation Measures .....	19
Table 5-3: Post-RAS Power Flow Study Results for Scenario 3.....	24
Table 5-3: Post-RAS Power Flow Study Results for Scenario 3.....	24
Table 5-5: Post-RAS Power Flow Study Results for Scenario 4.....	32

## Attachments

**Attachment A1 Engineering Connection Assessment: Study Scope**

**Attachment A2 Pre-Project Power Flow Diagrams**

**Attachment A3 Post-Project Power Flow Diagrams**

**Attachment A4 Post-Project Transient Stability Diagrams**

**Attachment A5 Dynamic Data and Assumptions**

**Attachment A6 Post-Mitigation Power Flow Diagrams**

**Attachment A7 Constraint Effective Factors Table**

# 1 Introduction

This report presents the results of the engineering studies that were completed by the Alberta Electric System Operator (AESO) to assess the impact of the Project (as defined in Attachment A1: AESO Engineering Connection Assessment Scope) on the performance of the Alberta Interconnected Electric System (AIES). The studies were performed in accordance with Attachment A1: AESO Engineering Connection Assessment: Study Scope, which was prepared by the AESO.

The power system network analysis tools that were used for the studies in this connection assessment were PSS/E version 33 and PSS/E version 34.

## 2 Pre-Project Study Results

This section describes the results of the pre-Project power flow studies.

### 2.1 Power Flow Studies

Power flow diagrams illustrating the pre-Project power flow studies results for Category A and Category B conditions are provided in Attachment A2.

#### 2.1.1 Scenario 1: 2020 Summer Peak Pre-Project

##### Category A Conditions

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

##### Category B Conditions

Thermal criteria violations were observed under certain Category B conditions as shown in Table 2-1.

**Table 2-1: Thermal Criteria Violations under Category B Conditions for Scenario 1**

Contingency (System Element Lost)	Violation Location Details	Thermal Ratings <sup>a</sup> (MVA)		Pre-Project Results	
		Normal Rating	Emergency Rating	Power Flow <sup>b</sup> (MVA)	% Loading <sup>c</sup>
995L (62S Brazeau – 68S Willesden Green – 17S Benalto)	202L (61S Lodgepole – 62S Brazeau)	119	131	120.37	101.15

Notes:

<sup>b</sup> Power flow (MVA) is current expressed as MVA (i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ )

<sup>c</sup> Reported as a percentage of the power flow (in MVA, i.e.,  $S = \sqrt{3} \times V_{base} \times I_{actual}$ ) relative to the transmission line's Normal Rating (also in MVA), as shown in Attachment A1.

##### Voltage Criteria Violations

No voltage criteria violations were observed under Category B conditions.

##### POD Bus Voltage Deviations

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.

## **Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

### ***2.1.2 Scenario 2: 2022 Winter Peak Pre-Project***

#### **Category A Conditions**

No Reliability Criteria (as defined in Section 3.1 of Attachment A1) violations were observed under Category A conditions.

#### **Category B Conditions**

No Reliability Criteria violations were observed under Category B conditions.

#### *Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

#### *POD Bus Voltage Deviations*

No voltage deviations beyond the limits listed in Table 3-1 of Attachment A1 (hereafter referred to as point of delivery (POD) bus voltage deviations) were observed.



### 3 Post-Project Study Results

This section describes the results of the post-Project power flow studies and transient stability studies.

#### 3.1 Power Flow Studies

Power flow diagrams illustrating the post-Project power flow studies results for selected Category A and Category B conditions are included in Attachment A3.

##### 3.1.1 Scenario 3: 2022 Summer Peak Post-Project

###### Category A Conditions

Thermal criteria violations were observed under Category A conditions as shown in Table 3-1.

**Table 3-1: Thermal Criteria Violations under Category A Conditions for Scenario 3**

Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
			Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
890L (58S Edson to 207S Pinedale)	75	83	15.55	20.73	78.59	104.78	84.05
202L (58S Edson to 178S Cynthia)	85	94	-7.81*	9.19	88.51	104.13	113.32*

Notes:

\*Flow direction is from 178S Cynthia to 58S Edson in Pre-Project and from 58S Edson to 178S Cynthia in Post-Project

###### Category B Conditions

Due to the observed Category A thermal criteria violations, ISO TCM Rule 302.1 is applied to adjust effective generation until these violations are eliminated. This case with adjusted generation dispatch per ISO TCM Rule 302.1 is used for Category B power flow analysis for Scenario 3.

Thermal criteria violations were observed under certain Category B conditions as shown in Table 3-2.

Due to the high Category A loading on 890L (>99%), only Category B conditions which result in more than a 1% loading increase over the Category A loading are reported.

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

**Table 3-2: Thermal Criteria Violations under Category B Conditions for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
1046L (310P Sundance (Plant) to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	120	132	68.09	56.74	124.43	103.69	46.95
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	75	83	16.86	22.48	76.32	101.76	79.28
202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	75	83	15.20	20.27	79.85	106.46	86.19
202L (58S Edson - 178S Cynthia)	720L (347S Fox Creek - 397S Benbow)	120	132	56.15	46.79	121.76	101.47	54.68
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	1.89	2.52	79.44	105.92	103.4
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	4.76	6.35	75.08	100.11	93.76
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	75	83	16.50	22.00	91.97	122.63	100.63
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	120	132	60.55	50.46	139.76	116.47	66.01
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	75	83	17.27	23.03	81.02	108.03	85
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	85	94	12.50	14.71	99.16	116.66	101.95
207S Pinedale T1/T2	720L (347S Fox Creek - 397S Benbow)	120	132	58.38	48.65	121.28	101.07	52.42
320P Keephills GT1	890L (58S Edson - 207S Pinedale)	75	83	16.82	22.42	75.92	101.22	78.8
320P Keephills GT2	890L (58S Edson - 207S Pinedale)	75	83	16.73	22.30	75.80	101.07	78.77
320P Keephills GT3	890L (58S Edson - 207S Pinedale)	75	83	16.33	21.77	75.40	100.53	78.76
Genesee GT3	890L (58S Edson - 207S Pinedale)	75	83	16.30	21.73	75.39	100.52	78.79
320P Keephills T1	202L (58S Edson - 178S Cynthia)	85	94	12.02	14.14	86.08	101.27	87.13
345S Hornbeck T1	890L (58S Edson - 207S Pinedale)	75	83	16.62	22.16	75.44	100.59	78.43
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	85	94	11.48	13.50	85.51	100.6	87.1
602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	75	83	17.66	23.54	76.64	102.19	78.65
62S Brazeau T5	202L (58S Edson - 178S Cynthia)	85	94	28.92	34.02	88.30	103.88	69.86
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	112	124	36.09	32.22	167.16	149.25	117.03
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	85	94	16.48	19.39	86.41	101.66	82.27

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	85	94	17.17	20.20	85.36	100.42	80.22
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	85	94	9.96	11.72	97.12	114.26	102.54
685L (397S Benbow - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	112	124	26.78	23.91	116.98	104.45	80.54
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	9.41	12.54	76.97	102.63	90.09
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	75	83	22.31	29.75	89.48	119.31	89.56
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	85	94	8.98	10.56	95.57	112.43	101.87
720L (347S Fox Creek - 397S Benbow)	740L (58S Edson - 39S Bickerdike)	112	124	24.90	22.23	115.25	102.9	80.67
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	8.05	10.73	75.33	100.44	89.71
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	75	83	20.54	27.39	87.79	117.05	89.66
744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	85	94	12.18	14.33	96.42	113.43	99.1
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	85	94	12.78	15.04	95.33	112.15	97.11
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	85	94	9.43	11.09	88.25	103.82	92.73
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	75	83	18.89	25.18	79.31	105.75	80.57
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	85	94	11.06	13.01	87.11	102.48	89.47
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	75	83	17.53	23.37	77.84	103.78	80.41
178S Cynthia T1	720L (347S Fox Creek - 397S Benbow)	120	132	56.16	46.80	121.78	101.48	54.68
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	1.86	2.48	78.78	105.04	102.56
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	75	83	16.06	21.41	91.29	121.72	100.31
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	85	94	12.15	14.29	85.71	100.83	86.54
834L (384S Keystone - 320P)	890L (58S Edson - 207S Pinedale)	75	83	19.20	25.60	75.63	100.84	75.24

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
Keephills)								
836L (61S Lodgepole - 283S Violet Grove)	890L (58S Edson - 207S Pinedale)	75	83	18.62	24.83	79.34	105.78	80.95
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	85	94	10.48	12.33	98.12	115.44	103.11
1012S Deer Hill T1	740L (58S Edson - 39S Bickerdike)	112	124	27.73	24.76	117.95	105.31	80.55
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	10.09	13.45	77.72	103.63	90.18
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	75	83	23.09	30.79	90.25	120.33	89.54
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	85	94	10.12	11.91	97.96	115.25	103.34
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	112	124	27.59	24.63	117.94	105.3	80.67
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	10.28	13.71	77.85	103.8	90.09
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	75	83	23.17	30.89	90.37	120.49	89.6
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	85	94	12.81	15.07	99.60	117.18	102.11
890L (58S Edson - 207S Pinedale)	720L (347S Fox Creek - 397S Benbow)	120	132	58.57	48.81	121.52	101.27	52.46
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	12.12	14.26	95.94	112.87	98.61
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	30.76	27.46	119.59	106.78	79.32
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	13.67	18.23	82.97	110.63	92.4
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	9.26	12.34	78.56	104.75	92.41
902L (19S Wabamun)	744L (235S Entwistle - 744AL)	75	83	7.19	9.59	76.29	101.72	92.13

**Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
Generation Station - 310P Sundance (Plant))	Tap)							
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	28.10	37.46	96.12	128.16	90.7
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	909L (310P Sundance (Plant) - Dome)	481	481	240.88	50.08	519.43	107.99	57.91
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	85	94	11.54	13.58	89.45	105.23	91.65
905L (19S Wabamun Generation Station - 37S North Calder)	909L (310P Sundance (Plant) - Dome)	481	481	215.15	44.73	483.69	100.56	55.83
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	85	94	11.43	13.45	95.60	112.47	99.02
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	75	83	18.25	24.33	80.83	107.77	83.44
909L (310P Sundance (Plant) - Dome)	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	499	652	273.00	54.71	525.30	105.27	50.56
913L (69S North Barrhead - 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	120	132	67.36	56.13	123.66	103.05	46.92
913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	75	83	17.45	23.26	76.20	101.6	78.34
919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	120	132	73.86	61.55	125.72	104.77	43.22
919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	75	83	17.29	23.05	76.97	102.63	79.58
922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	85	94	11.38	13.39	88.51	104.13	90.74
922L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	75	83	16.07	21.43	75.85	101.13	79.7
926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	85	94	11.37	13.38	88.52	104.14	90.76
926L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	75	83	16.07	21.43	75.86	101.14	79.71

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	17.31	20.36	108.91	128.13	107.77
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	120	132	47.88	39.90	142.45	118.71	78.81
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	14.43	12.88	128.21	114.47	101.59
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	7.94	10.59	85.47	113.96	103.37
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	12.43	16.57	81.12	108.16	91.59
973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	75	83	14.72	19.62	78.83	105.11	85.49
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	8.96	11.94	97.98	130.64	118.7
973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))	333	499	133.27	40.02	353.48	106.15	66.13
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	17.36	20.42	108.88	128.09	107.67
974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	120	132	47.84	39.87	142.34	118.62	78.75
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	14.63	13.06	128.16	114.43	101.37
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	7.85	10.47	85.41	113.88	103.41
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	12.35	16.47	81.07	108.09	91.62
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	75	83	14.66	19.54	78.77	105.03	85.49
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	9.13	12.17	97.91	130.55	118.38
974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	333	499	133.27	40.02	353.85	106.26	66.24
989L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	120	132	72.53	60.44	124.67	103.89	43.45
989L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	75	83	21.11	28.15	76.78	102.37	74.22
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	75	83	24.26	32.34	84.38	112.5	80.16

**Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loadin g	Observed Power Flow (MVA)	% Loadin g	
39S Bickerdike T1	39S Bickerdike T2	269	269	150.64	56.00	344.29	127.99	71.99
39S Bickerdike T2	39S Bickerdike T1	269	269	150.67	56.01	344.32	128	71.99

*Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

*POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

**3.1.2 Scenario 4: 2022 Winter Peak Post-Project**

**Category A Conditions**

No Reliability Criteria violations were observed under Category A conditions.

**Category B Conditions**

Thermal criteria violations were observed under certain Category B conditions as shown in Table 3-2. Due to the high Category A loading on 890L and 202L (>99%), only Category B conditions which result in more than a 1% loading increase over the Category A loading are reported.

**Table 3-3: Thermal Criteria Violations under Category B Conditions for Scenario 4**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	79	87	16.13	20.42	85.64	108.41	87.99
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	9.70	12.28	84.00	106.33	94.05
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	79	87	17.37	21.99	98.92	125.21	103.22
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	148	163	81.67	55.18	160.79	108.64	53.46
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	79	87	19.84	25.12	85.15	107.78	82.66
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	90	99	8.70	9.67	108.52	120.58	110.91

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
320P Keepphills T1	202L (58S Edson - 178S Cynthia)	90	99	15.18	16.87	98.44	109.38	92.51
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	90	99	5.15	5.72	92.30	102.55	98.82
602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	79	87	17.66	22.36	80.56	101.97	79.61
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	135	146	43.09	31.92	185.34	137.29	105.37
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	90	99	2.53	2.81	97.04	107.82	105.01
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	90	99	3.49	3.88	95.54	106.15	102.27
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	90	99	12.48	13.87	107.33	119.25	105.38
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	14.31	18.11	81.73	103.46	85.35
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	79	87	26.39	33.41	96.47	122.12	88.71
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	90	99	11.75	13.05	106.16	117.96	104.91
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	13.54	17.14	80.51	101.91	84.77
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	79	87	25.07	31.73	95.21	120.52	88.79
744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	90	99	8.72	9.69	105.26	116.96	107.27
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	90	99	8.64	9.60	103.66	115.18	105.58
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	90	99	9.39	10.43	97.90	108.78	98.35
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	79	87	22.19	28.09	85.45	108.17	80.08
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	90	99	9.58	10.64	96.50	107.22	96.58
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	79	87	20.07	25.41	83.61	105.83	80.42
62S Brazeau T1	202L (58S Edson - 178S Cynthia)	90	99	6.73	7.48	91.22	101.35	93.87
62S Brazeau T2	202L (58S Edson - 178S Cynthia)	90	99	6.79	7.54	91.18	101.31	93.77
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	8.58	10.86	83.32	105.47	94.61



## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	79	87	17.15	21.71	98.14	124.23	102.52
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	90	99	14.84	16.49	98.05	108.94	92.45
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	90	99	13.25	14.72	108.36	120.4	105.68
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	14.84	18.79	82.51	104.44	85.65
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	79	87	27.24	34.48	97.27	123.13	88.65
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	90	99	13.27	14.74	108.20	120.22	105.48
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	15.09	19.10	82.65	104.62	85.52
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	79	87	27.38	34.66	97.41	123.31	88.65
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	90	99	8.67	9.63	109.06	121.18	111.55
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	10.81	12.01	102.41	113.79	101.78
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	15.59	19.74	82.62	104.58	84.84
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	30.78	38.96	98.08	124.15	85.19
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	90	99	8.02	8.91	96.53	107.25	98.34
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	90	99	9.00	10.00	101.31	112.57	102.57
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	79	87	20.19	25.56	84.90	107.47	81.91
913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	79	87	16.80	21.27	80.58	102.00	80.73
913L (69S North Barrhead - 338S Cherhill)	202L (58S Edson - 178S Cynthia)	90	99	6.74	7.49	90.50	100.55	93.06

**Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	148	163	99.52	67.24	151.52	102.38	35.14
919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	79	87	21.60	27.34	83.23	105.36	78.02
922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	90	99	7.88	8.75	99.21	110.23	101.48
922L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	79	87	16.08	20.36	80.45	101.84	81.48
926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	90	99	7.88	8.76	99.23	110.25	101.49
926L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	79	87	16.08	20.36	80.45	101.84	81.48
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	14.25	15.83	118.80	132	116.17
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	148	163	61.78	41.74	163.16	110.24	68.5
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	135	146	11.14	8.25	138.48	102.58	94.33
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	13.56	17.17	89.70	113.55	96.38
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	79	87	19.25	24.37	83.32	105.47	81.1
973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	79	87	19.77	25.03	81.85	103.61	78.58
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	7.89	9.99	104.72	132.56	122.57
973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))	333	499	144.06	43.26	381.15	114.46	71.2
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	14.05	15.61	118.72	131.91	116.3
974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	148	163	61.73	41.71	163.01	110.14	68.43
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	135	146	11.26	8.34	138.39	102.51	94.17
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	13.37	16.93	89.62	113.44	96.51
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton -	79	87	19.09	24.16	83.24	105.37	81.21

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Normal Rating (MVA)	Emergency Rating (MVA)	Pre-Project Results		Post-Project Results		% Loading Difference (Post-Pre)
				Observed Power Flow (MVA)	% Loading	Observed Power Flow (MVA)	% Loading	
Sundance (Plant))	744AL Tap)							
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	79	87	19.62	24.83	81.77	103.51	78.68
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	7.92	10.03	104.62	132.43	122.4
974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	333	499	144.09	43.27	381.42	114.54	71.27
989L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	79	87	21.31	26.98	82.97	105.02	78.04
1046L (310P Sundance (Plant) to 338S Cherhill)	202L (58S Edson - 178S Cynthia)	90	99	7.58	8.42	90.56	100.62	92.2
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	79	87	18.91	23.94	80.74	102.20	78.26
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	79	87	29.18	36.94	90.46	114.51	77.57
39S Bickerdike T1	39S Bickerdike T2	269	269	160.51	59.67	382.54	142.21	82.54
39S Bickerdike T2	39S Bickerdike T1	269	269	160.49	59.66	382.54	142.21	82.55

### *Voltage Criteria Violations*

No voltage criteria violations were observed under Category B conditions.

### *POD Bus Voltage Deviations*

No POD bus voltage deviations were observed.

## 3.2 Transient Stability Studies

Transient stability studies were completed for Scenario 3, 4, and 6.

The results did not indicate any transient stability concerns, and the system showed acceptable dynamic response to all Category B conditions studied, as shown in Table 3-4. The post-Project transient stability plots are provided in Attachment A4. The dynamic data and assumptions of all equipment proposed for the Facility are provided in Attachment A5.

**Table 3-4: Transient Stability Study Results under Category B Conditions for All Scenarios**

Studied Contingency	Fault Description and Location	Results
685L (Deer Hill 1012S to Benbow 397S)	3-phase fault at Deer Hill 1012S	Stable
	3-phase fault at Benbow 397S	Stable
854L (Deer Hill 1012S to Bickerdike 39S)	3-phase fault at Deer Hill 1012S	Stable
	3-phase fault at Bickerdike 39S	Stable
744L (Entwistle 235S to Pinedale 207S)	3-phase fault at Entwistle 235S	Stable
	3-phase fault at Pinedale 207S	Stable
890L (Edson 58S to Pinedale 207S)	3-phase fault at Edson 58S	Stable
	3-phase fault at Pinedale 207S	Stable
671L (Bickerdike 39S to Edson 58S)	3-phase fault at Bickerdike 39S	Stable
	3-phase fault at Edson 58S	Stable
740L (Bickerdike 39S to Edson 58S)	3-phase fault at Bickerdike 39S	Stable
	3-phase fault at Edson 58S	Stable
973L (Bickerdike 39S to Sundance 310P)	3-phase fault at Bickerdike 39S	Stable
	3-phase fault at Sundance 310P	Stable
202L (Edson 58S to Cynthia 178S)	3-phase fault at Edson 58S	Stable
	3-phase fault at Cynthia 178S	Stable
745L (Bickerdike 39S to Cold Creek 602S)	3-phase fault at Bickerdike 39S	Stable
	3-phase fault at Cold Creek 602S	Stable

## 4 Short Circuit Studies

### 4.1 Pre-Project Results

#### 4.1.1 Scenario 2: 2022 WP Pre-Project

Pre-Project short-circuit current levels are provided in Table 4-1<sup>1</sup>.

**Table 4-1: Pre-Project Short-Circuit Current Levels for Scenario 2**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Mountain Obed 411S	138	134.71	2.8	0.041+0.140j	2	0.087+0.306j
Cold Creek 602S	138	133.19	3.6	0.033+0.108j	2.9	0.051+0.185j
Gulf Robb 414S	138	138.22	2.1	0.079+0.185j	1.4	0.162+0.489j
Edson 58S	138	139.09	8.2	0.015+0.049j	7.4	0.017+0.066j
Bickerdike 39S 138kV	138	139.39	10.1	0.011+0.041j	12.2	0.001+0.021j
Bickerdike 39S 240kV	240	257.52	6.2	0.010+0.040j	6.4	0.002+0.038j
Sundance 310P	240	259.54	23.7	0.002+0.011j	25.1	0.001+0.009j
Dalehurst 975S	138	134.81	3.5	0.032+0.114j	2.6	0.064+0.219j
Marlboro 348S	138	139.73	4.4	0.028+0.092j	3.1	0.059+0.206j
Hornbeck 345S	138	138.6	6.9	0.016+0.059j	6.2	0.020+0.078j
Deer Hill 1012S	138	140	5.3	0.020+0.077j	4	0.041+0.156j
Fickle Lake 406S	138	137.96	5.6	0.024+0.070j	4.7	0.035+0.113j

### 4.2 Post-Project Results

#### 4.2.1 Scenario 4: 2022 WP Post-Project

Post-Project short-circuit current levels for Scenario 4 are provided in Table 4-2.

<sup>1</sup> Short-circuit current studies were based on modeling information provided to the AESO by third parties. The authenticity of the modeling information has not been validated. Fault levels could change as a result of system developments, new customer connections, or additional generation in the area. It is recommended that these changes be monitored and fault levels reviewed to ensure that the fault levels are within equipment operating limits. The information provided in this study should not be used as the sole source of information for electrical equipment specifications or for the design of safety-grounding systems.

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

**Table 4-2: Post-Project Short-Circuit Current Levels for Scenario 4**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Mountain Obed 411S	138	141.79	3.1	0.036+0.132j	2.2	0.091+0.307j
Cold Creek 602S	138	141.38	4	0.030+0.102j	3.1	0.057+0.193j
Gulf Robb 414S	138	142.45	2.3	0.071+0.171j	1.5	0.161+0.480j
Edson 58S	138	142.95	11.2	0.009+0.038j	9.4	0.017+0.059j
Bickerdike 39S 138kV	138	143.52	16.2	0.004+0.027j	20.4	0.000+0.011j
Bickerdike 39S 240kV	240	263.12	14	0.002+0.019j	16.7	0.000+0.011j
Sundance 310P	240	258.48	26.1	0.002+0.010j	26.9	0.001+0.009j
Dalehurst 975S	138	141.88	3.9	0.028+0.105j	2.9	0.067+0.220j
Marlboro 348S	138	143	5.2	0.022+0.080j	3.5	0.059+0.200j
Hornbeck 345S	138	143.17	9.3	0.009+0.046j	7.9	0.020+0.070j
Deer Hill 1012S	138	142.68	6.3	0.015+0.067j	4.4	0.041+0.152j
Fickle Lake 406S	138	142.87	7.2	0.018+0.058j	5.6	0.035+0.107j
Whisky Jack 1047S	240	263.16	14	0.002+0.019j	16.8	0.000+0.011j

### 4.2.2 Scenario 5: 2029 WP Post-Project

Post-Project short-circuit current levels for Scenario 5 are provided in Table 4-3.

**Table 4-3: Post-Project Short-Circuit Current Levels for Scenario 5**

Substation Name and Number	Base Voltage (kV)	Pre-Fault Voltage (kV)	3- $\Phi$ Fault (kA)	Positive Sequence Thevenin Source Impedance (R1+jX1) (pu)	1- $\Phi$ Fault (kA)	Zero Sequence Thevenin Source Impedance (R0+jX0) (pu)
Mountain Obed 411S	138	139.04	3.1	0.037+0.131j	2.1	0.091+0.307j
Cold Creek 602S	138	138.32	4	0.031+0.100j	3.1	0.057+0.193j
Gulf Robb 414S	138	140.6	2.3	0.072+0.170j	1.5	0.161+0.480j
Edson 58S	138	141.25	11.4	0.009+0.037j	9.5	0.016+0.058j
Bickerdike 39S 138kV	138	141.91	16.7	0.004+0.026j	20.9	0.000+0.011j
Bickerdike 39S 240kV	240	259.05	14.9	0.002+0.017j	17.7	0.000+0.010j
Sundance 310P	240	257.28	30.9	0.001+0.008j	32.9	0.000+0.007j
Dalehurst 975S	138	139.15	3.9	0.029+0.104j	2.8	0.067+0.220j

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Marlboro 348S	138	142.46	5.3	0.022+0.079j	3.5	0.059+0.199j
Hornbeck 345S	138	141.38	9.4	0.009+0.045j	7.9	0.020+0.070j
Deer Hill 1012S	138	142.9	6.4	0.014+0.067j	4.4	0.041+0.152j
Fickle Lake 406S	138	140.87	7.2	0.018+0.057j	5.6	0.035+0.106j
Whisky Jack 1047S	240	259.53	14.9	0.002+0.017j	17.8	0.000+0.010j

## 5 Mitigation Measure Development and Evaluation

The AESO developed mitigation measures to address the system performance issues that were identified in the post-Project scenarios. Existing remedial action schemes (RASs) are described in Section 1.2.2 of Attachment A1.

### 5.1 Pre-Project

Pre-Project mitigation measures are summarized in Table 5-1.

**Table 5-1: Pre-Project Mitigation Measures**

Mitigation Measure	Location of Observed Violation	Contingency
Real time operational practices	995L/995AL (62S Brazeau – 68S Willesden Green – 17S Benalto)	202L (61S Lodgepole – 62S Brazeau)

### 5.2 Post-Project

Post-Project mitigation measures are summarized in Table 5-2.

**Table 5-2: Post-Project Mitigation Measures**

Mitigation Measure	Contingency	Location of Observed Violation
ISO TCM Rule 302.1	None	890L (58S Edson to 207S Pinedale)
ISO TCM Rule 302.1	None	202L (58S Edson to 178S Cynthia)
New T1 and T2 - 39S Bickerdike Overload Mitigation*	39S Bickerdike T1	39S Bickerdike T2
	39S Bickerdike T2	39S Bickerdike T1
New 890L overload mitigation scheme and New 202L overload mitigation scheme	685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	685L (397S Benbow - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	720L (347S Fox Creek - 397S Benbow)	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)



## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

New 890L overload mitigation scheme and New 202L overload mitigation scheme	720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	320P Keephills T1	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	320P Keephills T1	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	1012S Deer Hill T1	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	834L (384S Keystone - 320P Keephills)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and	902L (19S Wabamun Generation	744L (228S T.M.P.L. Niton

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

New 202L overload mitigation scheme	Station - 310P Sundance (Plant))	- 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	909L (310P Sundance (Plant) - Dome)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	905L (19S Wabamun Generation Station - 37S North Calder)	909L (310P Sundance (Plant) - Dome)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)
	909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	909L (310P Sundance (Plant) - Dome)	902L (19S Wabamun Generation Station - 310P Sundance (Plant))
New 890L overload mitigation scheme and New 202L overload mitigation scheme	913L (69S North Barrhead – 338S Cherhill)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	913L (69S North Barrhead – 338S Cherhill)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	922L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	926L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and New 202L overload mitigation scheme	974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))
New 890L overload mitigation scheme	202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	202L (58S Edson - 178S Cynthia)	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme	202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme	202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 744AL Tap)
New 890L overload mitigation scheme	202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	178S Cynthia T1	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme	178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)
New 890L overload mitigation scheme	178S Cynthia T1	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	836L (61S Lodgepole - 283S Violet Grove)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	19S Wabamun T10	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and real-time operational practices	919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme	919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme and real-time operational practices	989L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme	989L (310P Sundance (Plant) - 77S	890L (58S Edson - 207S

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

	Sagitawah)	Pinedale)
New 890L overload mitigation scheme and real-time operational practices	1046L (310P Sundance (Plant) to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)
New 890L overload mitigation scheme	1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)
New 890L overload mitigation scheme	19S Wabamun T10	890L (58S Edson - 207S Pinedale)
New 202L overload mitigation scheme	207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	207S Pinedale T1/T2	720L (347S Fox Creek - 397S Benbow)
New 202L overload mitigation scheme	62S Brazeau T5	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)
New 202L overload mitigation scheme	890L (58S Edson - 207S Pinedale)	720L (347S Fox Creek - 397S Benbow)
New 740L overload mitigation scheme	671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)
New 720L overload mitigation scheme	58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)

Notes:

\*In the Winter Peak scenario, post-RAS loading observed on the remaining Bickerdike transformer is below the seasonal rating when calculated based on current, but above the seasonal rating when calculated based on MVA. Real-time operational practices may be required to completely mitigate the overload depending on system conditions.

### 5.3 Evaluation of Mitigation Measures

This section describes the results of the power flow studies that were performed to assess the impact of the Project on the performance of the AIES following the implementation of proposed mitigation measures.

The post-mitigation measures studies were performed under Category B conditions for Scenario 3 (after applying ISO TCM Rule 302.1 for Category A conditions) and Scenario 4 using Alternative 1 and the RASs described in the previous section.

The post-mitigation power flow diagrams for selected Category B conditions are provided in Attachment A6. Post-mitigation power flow diagrams present only selected post-Project contingencies that result in thermal criteria violations that require RAS mitigation. Post-Project contingencies that result in thermal

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

criteria violations that can be mitigated by real-time operational practices or TFO capital maintenance projects were not studied.

### 5.3.1 Scenario 3: 2022 SP Post-Project

#### Category A Conditions

Thermal criteria violations observed under Category A conditions in the post-Project studies were mitigated by applying ISO TCM Rule 302.1 as shown in Table 5-3.

**Table 5-3: Post-TCM Rule 302.1 Power Flow Study Results for Scenario 3**

Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-TCM Rule 302.1 Results	
			Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
890L (58S Edson to 207S Pinedale)	75	83	78.59	104.78	74.35	99.13
202L (58S Edson to 178S Cynthia)	85	94	88.51	104.13	82.40	96.94

#### Category B Conditions

Thermal criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 5-4.

**Table 5-4: Post-RAS Power Flow Study Results for Scenario 3**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	75	83	79.85	106.46	72.42	96.56
202L (58S Edson - 178S Cynthia)	720L (347S Fox Creek - 397S Benbow)	120	132	121.76	101.47	85.81	71.51
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	79.44	105.92	43.65	58.20

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	75.08	100.11	39.38	52.50
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	75	83	91.97	122.63	56.04	74.72
320P Keephills GT1	890L (58S Edson - 207S Pinedale)	75	83	75.92	101.22	72.60	96.80
320P Keephills GT2	890L (58S Edson - 207S Pinedale)	75	83	75.80	101.07	72.51	96.68
320P Keephills GT3	890L (58S Edson - 207S Pinedale)	75	83	75.40	100.53	72.10	96.13
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	120	132	139.76	116.47	98.05	81.71
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	75	83	81.02	108.03	51.62	68.83
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	85	94	99.16	116.66	53.09	62.46
207S Pinedale T1/T2	720L (347S Fox Creek - 397S Benbow)	120	132	121.28	101.07	86.60	72.17
320P Keephills T1	202L (58S Edson - 178S Cynthia)	85	94	86.08	101.27	48.37	56.91
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	85	94	85.51	100.60	79.81	93.89
602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	75	83	76.64	102.19	72.67	96.89
62S Brazeau T5	202L (58S Edson - 178S Cynthia)	85	94	88.30	103.88	62.08	73.03
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	112	124	167.16	149.25	104.82	93.59
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	85	94	86.41	101.66	43.82	51.55
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	85	94	85.36	100.42	43.41	51.07
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	85	94	97.12	114.26	53.58	63.04
685L (397S Benbow -	740L (58S Edson - 39S Bickerdike)	112	124	116.98	104.45	75.61	67.51

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

1012S Deer Hill)							
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	76.97	102.63	45.87	61.16
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	75	83	89.48	119.31	58.25	77.66
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	85	94	95.57	112.43	52.04	61.22
720L (347S Fox Creek - 397S Benbow)	740L (58S Edson - 39S Bickerdike)	112	124	115.25	102.90	73.88	65.96
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	75.33	100.44	44.24	58.99
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	75	83	87.79	117.05	56.57	75.43
744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	85	94	96.42	113.43	50.35	59.23
744L (235S Entwistle - 744AL Tap)	202L (58S Edson - 178S Cynthia)	85	94	94.94	111.69	48.86	57.48
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	85	94	95.33	112.15	49.26	57.95
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	85	94	88.25	103.82	47.46	55.84
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	75	83	79.31	105.75	51.11	68.14
7L90 (347S Fox Creek - 2018S Muir -	202L (58S Edson - 178S Cynthia)	85	94	87.11	102.48	79.54	93.58

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

813S Little Smoky)							
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	75	83	77.84	103.78	72.55	96.73
178S Cynthia T1	720L (347S Fox Creek - 397S Benbow)	120	132	121.78	101.48	85.82	71.52
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	78.78	105.04	43.06	57.41
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	75	83	91.29	121.72	55.43	73.91
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	85	94	85.71	100.83	81.62	96.02
834L (384S Keystone - 320P Keephills)	890L (58S Edson - 207S Pinedale)	75	83	75.63	100.84	72.73	96.97
836L (61S Lodgepole - 283S Violet Grove)	890L (58S Edson - 207S Pinedale)	75	83	79.34	105.78	72.32	96.43
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	85	94	98.12	115.44	54.58	64.21
1012S Deer Hill T1	740L (58S Edson - 39S Bickerdike)	112	124	117.95	105.31	76.57	68.37
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	77.72	103.63	46.61	62.15
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	75	83	90.25	120.33	59.00	78.67
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	85	94	97.96	115.25	54.43	64.03
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	112	124	117.94	105.30	76.57	68.37
854L (39S Bickerdike -	744L (228S T.M.P.L. Niton -	75	83	77.85	103.80	46.76	62.34



## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

348S Marlboro - 1012S Deer Hill)	207S Pinedale)						
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	75	83	90.37	120.49	59.13	78.84
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	85	94	99.60	117.18	53.53	62.98
890L (58S Edson - 207S Pinedale)	720L (347S Fox Creek - 397S Benbow)	120	132	121.52	101.27	86.86	72.38
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	95.94	112.87	54.36	63.95
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	119.59	106.78	79.99	71.42
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	82.97	110.63	53.14	70.85
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	78.56	104.75	48.77	65.02
902L (19S Wabamun Generation Station - 310P Sundance	744L (235S Entwistle - 744AL Tap)	75	83	76.29	101.72	46.52	62.03

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

(Plant))							
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	96.12	128.16	66.35	88.47
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	909L (310P Sundance (Plant) - Dome)	481	481	519.43	107.99	431.22	89.65
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	85	94	89.45	105.23	48.36	56.89
905L (19S Wabamun Generation Station - 37S North Calder)	909L (310P Sundance (Plant) - Dome)	481	481	483.69	100.56	398.56	82.86
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	85	94	95.60	112.47	53.23	62.62
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	75	83	80.83	107.77	52.22	69.63
909L (310P Sundance (Plant) - Dome)	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	499	652	525.30	105.27	447.30	89.64
913L (69S North Barrhead - 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	120	132	123.66	103.05	119.66	99.72
913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	75	83	76.20	101.60	72.50	96.67
919L (310P)	720L (347S)	120	132	125.72	104.77	122.62	102.18

**Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

SUNDANCE (PLANT) to 77S SAGITAWAH)	FOXCREEK to 397S BENBOW)						
919L (310P SUNDANCE (PLANT) to 77S SAGITAWAH)	890L (58S EDSON to 207S Pinedale)	75	83	76.97	102.63	72.41	96.55
922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	85	94	88.51	104.13	82.16	96.66
922L (310P Sundance (Plant) - 17S Benalto)	890L (58S EDSON to 207S Pinedale)	75	83	75.85	101.13	71.69	95.58
926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	85	94	88.52	104.14	82.17	96.67
926L (310P Sundance (Plant) - 17S Benalto)	890L (58S EDSON to 207S Pinedale)	75	83	75.86	101.14	71.69	95.58
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	108.91	128.13	52.57	61.85
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	120	132	142.45	118.71	92.16	76.80
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	128.21	114.47	73.71	65.81
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	85.47	113.96	43.37	57.83
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	81.12	108.16	39.10	52.13

**Engineering Connection Assessment: Study Results**

P2032 Cascade Power Plant Project Connection

V3

973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	75	83	78.83	105.11	36.80	49.07
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	97.98	130.64	55.76	74.34
973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))	333	499	353.48	106.15	132.13	39.68
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	85	94	108.88	128.09	52.56	61.83
974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	120	132	142.34	118.62	92.12	76.77
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	112	124	128.16	114.43	73.68	65.79
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	75	83	85.41	113.88	43.36	57.81
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	75	83	81.07	108.09	39.08	52.11
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	75	83	78.77	105.03	36.79	49.05
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	75	83	97.91	130.55	55.73	74.31

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	333	499	353.85	106.26	132.17	39.69
989L (310P SUNDANCE (PLANT) to 77S SAGITAWAH)	720L (347S FOXCREEK to 397S BENBOW)	120	132	124.67	103.89	121.79	101.49
989L (310P SUNDANCE (PLANT) to 77S SAGITAWAH)	890L (58S EDSON to 207S Pinedale)	75.05	83	76.83	102.37	72.60	96.73
1046L (310P Sundance (Plant) to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	120	132	124.43	103.69	120.41	100.34
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	75	83	76.32	101.76	72.62	96.83
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	75	83	84.38	112.50	57.13	76.17
39S Bickerdike T1	39S Bickerdike T2	269	269	344.29	127.99	252.81	93.98
39S Bickerdike T2	39S Bickerdike T1	269	269	344.32	128.00	252.81	93.98

### 5.3.2 Scenario 4: 2022 WP Post-Project

#### Category B Conditions

The thermal criteria violations observed under certain Category B conditions in the post-Project studies were mitigated by RASs as shown in Table 5-5.

**Table 5-5: Post-RAS Power Flow Study Results for Scenario 4**

Contingency (System Element Lost)	Details of Violation (Violation Observed On)	Seasonal Continuous Rating (MVA)	Short-term (Emergency ) Rating (MVA)	Post-Project Results		Post-RAS Action Results	
				Power Flow (MVA)	% Loading	Power Flow (MVA)	% Loading
202L (178S Cynthia - 359S)	890L (58S Edson - 207S Pinedale)	79	87	93.21	108.41	51.72	65.47

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

Esso West Pembina - 61S Lodgepole)							
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	88.33	106.33	43.06	54.50
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	79	87	124.27	125.21	57.16	72.36
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	148	163	175.25	108.64	114.64	77.46
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	79	87	92.00	107.78	56.25	71.20
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	90	99	131.40	120.58	46.32	51.47
320P Keephills T1	202L (58S Edson - 178S Cynthia)	90	99	108.07	109.38	43.13	47.92
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	90	99	98.15	102.55	86.12	95.69
602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	79	87	85.08	101.97	76.24	96.50
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	135	146	255.88	137.29	99.06	73.38
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	90	99	105.22	107.82	35.87	39.85
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	90	99	101.99	106.15	34.23	38.03
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	90	99	128.19	119.25	48.02	53.35
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	83.40	103.46	48.68	61.62
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	79	87	117.86	122.12	62.83	79.53
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	90	99	125.43	117.96	46.88	52.09
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	80.95	101.91	47.49	60.11
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	79	87	114.80	120.52	61.58	77.95
744L (228S T.M.P.L. Niton -	202L (58S Edson - 178S Cynthia)	90	99	123.26	116.96	43.11	47.90

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

207S Pinedale)							
744L (235S Entwistle - 744AL Tap)	202L (58S Edson - 178S Cynthia)	90	99	119.08	114.94	41.30	45.89
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	90	99	119.52	115.18	41.53	46.14
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	90	99	106.99	108.78	41.52	46.13
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	79	87	92.74	108.17	54.94	69.55
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	90	99	103.71	107.22	40.10	44.56
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	79	87	88.58	105.83	53.04	67.14
62S Brazeau T1	202L (58S Edson - 178S Cynthia)	90	99	95.84	101.35	87.03	96.70
62S Brazeau T2	202L (58S Edson - 178S Cynthia)	90	99	95.78	101.31	87.04	96.71
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	86.96	105.47	42.77	54.14
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	79	87	122.37	124.23	56.76	71.85
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	90	99	107.19	108.94	42.71	47.45
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	90	99	130.68	120.40	49.05	54.50
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	84.97	104.44	49.44	62.58
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	79	87	119.83	123.13	63.61	80.52
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	90	99	130.22	120.22	48.88	54.31
854L (39S Bickerdike -	744L (228S T.M.P.L. Niton -	79	87	85.22	104.62	49.60	62.78

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

348S Marlboro - 1012S Deer Hill)	207S Pinedale)						
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	79	87	120.12	123.31	63.76	80.71
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	90	99	132.64	121.18	46.88	52.09
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	116.73	113.79	47.41	52.68
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	84.84	104.58	54.30	68.73
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	121.82	124.15	69.63	88.14
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	90	99	104.13	107.25	41.00	45.56
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	90	99	114.55	112.57	46.08	51.20
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	79	87	91.52	107.47	55.28	69.97
913L (69S North Barrhead – 338S Cherhill)	202L (58S Edson - 178S Cynthia)	90	99	94.18	100.55	84.29	93.66
913L (69S North Barrhead – 338S Cherhill)	890L (58S Edson - 207S Pinedale)	79	87	84.96	102.00	76.24	96.51
919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	148	163	156.42	102.38	120.07	81.13
919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	79	87	87.87	105.36	53.51	67.74



## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	90	99	109.82	110.23	86.59	96.21
922L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	79	87	84.76	101.84	73.16	92.61
926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	90	99	109.86	110.25	86.60	96.22
926L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	79	87	84.77	101.84	73.16	92.61
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	156.06	132.00	44.25	49.17
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	148	163	180.60	110.24	108.56	73.35
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	135	146	141.82	102.58	67.04	49.66
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	99.70	113.55	43.48	55.04
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	79	87	85.87	105.47	37.38	47.32
973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	79	87	83.19	103.61	35.68	45.17
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	137.98	132.56	57.61	72.92
973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))	333	499	462.62	114.46	115.58	34.71
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	90	99	155.80	131.91	44.25	49.17
974L (39S Bickerdike -	720L (347S Fox Creek - 397S	148	163	180.23	110.14	108.54	73.34

## Engineering Connection Assessment: Study Results

P2032 Cascade Power Plant Project Connection

V3

310P Sundance (Plant))	Benbow)						
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	135	146	141.56	102.51	67.03	49.65
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	79	87	99.49	113.44	43.48	55.04
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	79	87	85.70	105.37	37.39	47.33
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	79	87	83.03	103.51	35.69	45.18
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	79	87	137.66	132.43	57.60	72.91
974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	333	499	463.07	114.54	115.62	34.72
989L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	79	87	87.32	105.02	76.05	96.26
1046L (310P Sundance (Plant) to 338S Cherhill)	202L (58S Edson - 178S Cynthia)	90	99	94.28	100.62	84.35	93.72
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	79	87	85.27	102.20	76.39	96.70
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	79	87	103.76	114.51	61.57	77.94
39S Bickerdike T1*	39S Bickerdike T2	269	269	548.69	142.21	268.70	99.89
39S Bickerdike T2*	39S Bickerdike T1	269	269	548.70	142.21	268.73	99.90

### Notes:

\*Post-RAS loading observed on the remaining Bickerdike 39S transformer is below the seasonal rating when calculated based on current, but above the seasonal rating when calculated based on MVA. Real-time operational practices may be required to completely mitigate the overload depending on system conditions.

## **5.4 Constraint Effective Factor Studies**

Constraint effective factor studies were conducted for all post-Project scenarios. The constraint effective factors were calculated for all Category B conditions when the loadings of the monitored transmission elements in the Study Area exceeded 100% and were greater than the Category A loading by more than 1%. The results of the constraint effective factor studies are provided in Attachment A7.

# Attachment A1

## Engineering Connection Assessment: Study Scope



# Engineering Connection Assessment: Study Scope

## Cascade Power Plant Project Connection

Cascade Power Project Limited Partnership

AESO Project Number: P2032

**Date:** May 15<sup>th</sup>, 2020

**Version:** V4

**Classification:** Public

Company Name	Name and Credentials	Date	Signature
AESO	Myron Jin-Li, P. Eng	June 24, 2020	
Cascade Power Project LP (Market Participant)	Guido Bachmann	June 23, 2020	

# Contents

<b>1</b>	<b>Introduction .....</b>	<b>1</b>
1.1	Project Overview .....	1
1.2	Existing System Overview .....	2
1.2.1	<i>Study Area</i> .....	2
1.2.2	<i>Existing Constraints</i> .....	2
<b>2</b>	<b>Connection Alternative to be Studied .....</b>	<b>4</b>
2.1	Alternative 1 –240 kV connection to the existing Bickerdike 39S substation with three 240 kV transmission lines .....	4
<b>3</b>	<b>Criteria, Standards and Requirements .....</b>	<b>6</b>
3.1	AESO Reliability Criteria .....	6
3.2	ISO Rules and Information Documents .....	7
<b>4</b>	<b>Scenarios and Assumptions .....</b>	<b>8</b>
4.1	Scenarios .....	8
4.2	Assumptions .....	8
4.2.1	<i>System Project Assumptions</i> .....	8
4.2.2	<i>Connection Project Assumptions</i> .....	8
4.2.3	<i>Load Assumptions</i> .....	9
4.2.4	<i>Generation Assumptions</i> .....	9
4.2.5	<i>Intertie Flow Assumptions</i> .....	12
4.2.6	<i>HVDC Power Order Assumptions</i> .....	12
4.2.7	<i>Transmission Facility Ratings</i> .....	13
4.2.8	<i>Protection Fault Clearing Times</i> .....	14
4.2.9	<i>Project Dynamic Data</i> .....	15
4.2.10	<i>Voltage Profile Assumption</i> .....	15
4.2.11	<i>Sub-synchronous Interaction (SSI) Screening</i> .....	15
<b>5</b>	<b>Study Methodology .....</b>	<b>16</b>
5.1	Power Flow Studies .....	16
5.1.1	<i>Contingencies to be Studied</i> .....	17
5.2	Transient Stability Studies .....	17
5.2.1	<i>Contingencies to be Studied</i> .....	17
5.3	Short-Circuit Current Level Studies .....	17
<b>6</b>	<b>Mitigation Measures .....</b>	<b>19</b>
6.1	Development .....	19
6.2	Evaluation .....	19
6.2.1	<i>Post-Mitigation Studies</i> .....	19
6.2.2	<i>Constraint Effective Factor Studies</i> .....	19
<b>7</b>	<b>Changes to Study Assumptions .....</b>	<b>20</b>

## Tables

Table 1-1: Project Load and Generation Details.....	1
Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses.....	7
Table 4-1: Connection Study Scenarios.....	8
Table 4-2: Planned Connection Projects Included in the Studies.....	9
Table 4-3: Forecast Load (at AESO Northwest Planning Region Peak) .....	9
Table 4-4: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SP and 2022WP Pre-Project Scenarios .....	10
Table 4-5: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SP and 2022WP Post-Project Scenarios.....	11
Table 4-6: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SL Scenario	12
Table 4-7: HVDC to Adjacent AC System MVar Exchange Limits .....	12
Table 4-8: Thermal Rating Assumptions for Key Transmission Lines in the Study Area .....	13
Table 4-9: Summary of Key Transformer Ratings in the Study Area.....	14
Table 4-10: Summary of Key Shunt Elements in the Study Area .....	14
Table 4-11: Protection Fault Clearing Times.....	14
Table 5-1: Summary of the Studies to be Performed.....	16

## Figures

Figure 1-1: Transmission System in the Study Area.....	3
Figure 2-1: Connection Alternative 1.....	5

## Attachments

Attachment A: Transmission Planning Criteria – Basis and Assumptions

# 1 Introduction

This Study Scope provides an overview of the engineering studies to assess the impact of the Project (as defined in section 1.1) on the performance of the Alberta interconnected electric system (AIES). Technical criteria, assumptions and methods for performing these engineering studies are provided in this document.

## 1.1 Project Overview

Cascade Power Project Limited Partnership (Market Participant) has submitted a request for system access service to the Alberta Electric System Operator (AESO) to connect its approved Cascade Power Plant (Facility) to the AIES.

The Facility includes a proposed substation, to be designated Whisky Jack 1047S.

The market participant's request includes a request for new Rate STS, Supply Transmission Service, contract capacity of 900 MW and a new Rate DTS, Demand Transmission Service, contract capacity of 11.5 MW. There are two development phases for the Facility. Phase 1 includes the addition of one combined cycle gas generation unit with a maximum authorized real power (MARF) of 462.5 MW and a maximum capability (MC) of 450 MW. Phase 2 includes the addition of a second combined cycle generation unit with a MARF of 462.5 MW. After Phase 2, the MC of the Facility will be 900 MW.

The Project in-service date (ISD) used for the purpose of the studies is March 25, 2022.

Load and generation components of the Project are listed in Table 1-1.

**Table 1-1: Project Load and Generation Details**

Project Component		Description
Load	Existing Rate DTS, <i>Demand Transmission Service</i> , contract capacity	No existing contract
	Requested Rate DTS	11.5 MW
	Type	Station service
	Motors (number and size)	N/A
	Power factor	0.9 pf
	Future load expansion plans	No
Generation	Generation type	Combined Cycle
	Existing Rate STS, <i>Supply Transmission Service</i> , contract capacity	No existing contract
	Requested Rate STS	900 MW
	Number and size of generating units	2 units at 549 MVA each
	Maximum authorized real power (MARF)	462.5 MW (individually)
	Maximum capability (MC)	450 MW (individually)



Project Component		Description
	Reactive power capability	220.7 MVar (individually) (0.9 pf over-excited)
		149.8 MVar (individually) (0.95 pf under-excited)
	Future generation expansion plans	No

**Note:**

MARP and MC are defined in the AESO's *Consolidated Authoritative Document Glossary*, which can be found on the AESO's website.

## 1.2 Existing System Overview

### 1.2.1 Study Area

Geographically, the Project is located in the AESO planning area of Hinton/Edson (Area 29), which is part of the AESO Central Planning Region. The Hinton/Edson planning area borders the AESO Northwest Planning Region.

The Study Area consists of the AESO planning areas of Hinton/Edson (Area 29), Grande Cache (Area 22), Fox Creek (Area 24), Drayton Valley (Area 30) and Wabamun (Area 40), including the tie lines connecting these planning areas to the rest of the AIES.

The existing transmission system in the Study Area is shown in Figure 1-1.

### 1.2.2 Existing Constraints


There are existing Category B thermal and voltage constraints in the Study Area. Notably, Hinton/Edson (Area 29) borders the AESO Northwest Planning Region.

Existing constraints in the Study Area are managed in accordance with the procedures set out in Section 302.1 of the ISO rules, *Real Time Transmission Constraint Management* (TCM Rule).

Additionally, there are a number of constraints in the Study Area that are mitigated by existing protection schemes. The following existing automatic protection schemes (APS) are used to manage constraints in the area:

- APS 25: Brazeau 62S Generation Tripping Scheme
- APS 46: Bickerdike 39S – 740L Load Trip Scheme
- APS 47: Obed Mountain Coal 411S - Load Trip Scheme
- APS 150: WATL HVDC

Figure 1-1: Transmission System in the Study Area



## 2 Connection Alternative to be Studied

The following alternative will be studied:


### 2.1 Alternative 1 –240 kV connection to the existing Bickerdike 39S substation with three 240 kV transmission lines

This alternative included the following developments:

- Add three 240 kilovolt (kV) transmission lines to connect the Facility to the existing Bickerdike 39S substation;
- Modify the existing Bickerdike 39S substation, including adding four 240 kV circuit breakers ;  
and
- Add or modify associated equipment as required for the above transmission developments.

The proposed connection configuration is shown in Figure 2-1.

Figure 2-1: Connection Alternative 1



## 3 Criteria, Standards and Requirements

### 3.1 AESO Reliability Criteria

The Transmission Planning (TPL) Standards, which are included in the Alberta Reliability Standards, and *Transmission Planning Criteria – Basis and Assumptions* (see Attachment A), (collectively, the Reliability Criteria) will be applied to evaluate system performance under Category A system conditions (i.e., all elements in-service) and following Category B contingencies (i.e., single element outage), prior to and following the studied alternatives. Below is a summary of Category A and Category B system conditions.

**Category A**, often referred to as the N-0 condition, represents a normal system with no contingencies and all facilities in service. Under this condition, the system must be able to supply all firm load and firm transfers to other areas. All equipment must operate within its applicable rating, voltages must be within their applicable range, and the system must be stable with no cascading outages.

**Category B** events, often referred to as an N-1 or N-G-1 with the most critical generator out of service, result in the loss of any single specified system element under specified fault conditions with normal clearing. These elements are a generator, a transmission circuit, a transformer, or a single pole of a DC transmission line. The acceptable impact on the system is the same as Category A. Planned or controlled interruptions of electric supply to radial customers or some local network customers, connected to or supplied by the faulted element or by the affected area, may occur in certain areas without impacting the overall reliability of the interconnected transmission systems. To prepare for the next contingency, system adjustments are permitted, including curtailments of contracted firm (non-recallable reserved) transmission service electric power transfers.

The TPL standards, TPL-001-AB-0 and TPL-002-AB1-0 have referenced Applicable Ratings when specifying the required system performance under Category A and Category B events. For the purpose of applying the TPL standards to the studies documented in this report, Applicable Ratings are defined as follows:

- Normal thermal rating of the line's loading limits for each season;
- The highest specified loading limits for transformers;
- For Category A conditions: Voltage range under normal operating condition per AESO Information Document #2010-007RS, *General Operating Practices – Voltage Control* (ID #2010-007RS). For the busses not listed in ID #2010-007RS, Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions* applies;
- For Category B conditions: The extreme voltage range values per Table 2-1 in the *Transmission Planning Criteria – Basis and Assumptions*; and
- Desired post-contingency voltage deviation limits for three defined post-event timeframes as provided in Table 3-1.

**Table 3-1: Post-Contingency Voltage Deviation Guidelines for Low Voltage Busses**

Parameter and reference point	Time Period		
	Post Transient (up to 30 sec)	Post Auto Control (30 sec to 5 min)	Post Manual Control (Steady State)
Voltage deviation from steady state at point of delivery (POD) low voltage bus.	±10%	±7%	±5%

### 3.2 ISO Rules and Information Documents

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for the Study Area.

The TCM Rule will be followed to set up the study scenarios and assess the impact of the Project. In addition, due regard will be given to the AESO's, Section 502.5 of the ISO rules *Generating Unit Technical Requirements*, and Section 502.6 of the ISO rules *Generating Unit Operating Requirements*.

## 4 Scenarios and Assumptions

### 4.1 Scenarios

The following section describes the scenarios to be studied and the assumptions to be used in the studies.

Connection scenarios must be studied as outlined in Table 4-1.

For the main study scenarios, a light load scenario is not studied as high Northwest import is the most limiting study condition for power flow.

For transient stability studies, a high Central generation 2022 Summer Light sensitivity scenario is added, as low load is a critical study condition to assess the impact of the Project on system transient stability.

**Table 4-1: Connection Study Scenarios**

Scenario No.	Year/Season	System Generation Dispatch Conditions	Scenario Name	Net-to-Grid Generation (MW)
<b>Pre-Project</b>				
1	2022 SP	High Northwest (NW) Import	2021 SP Pre-Project	0
2	2022 WP		2021 WP Pre-Project	0
<b>Post-Project</b>				
3	2022 SP	High NW Import	2022 SP Post-Project	900
4	2022 WP		2022 WP Post-Project	900
5	2029 WP	All study area generation online	2029 WP Post-Project	900
<b>Post-Project Sensitivity (Transient Stability)</b>				
6	2022 SL	High Central Generation	2022 SL Post-Project	900

### 4.2 Assumptions

#### 4.2.1 System Project Assumptions

The pre-Project and post-Project connection assessment will not include any system transmission projects because there are no planned system transmission developments in the Study Area that are expected to be in service before the scheduled Project ISD.

#### 4.2.2 Connection Project Assumptions

Table 4-2 summarizes the connection projects in the Study Area that should be included in the studies.

**Table 4-2: Planned Connection Projects Included in the Studies**

AESO Project No.	AESO Project Name	AESO Planning Area No.	Generation (MW)	Load (MW)	Scheduled ISD	AUC NID Decision No.
2012	Keyera West Pembina 359S Gas Turbine	30-Drayton Valley	0.0	0.0	Jun 3, 2020	25506-D01-2020
2224	Capital Power Genesee Unit 2 Change	40-Wabamun	0.0	0.0	Apr 6, 2021	24715-D01-2019

### 4.2.3 Load Assumptions

The load forecast to be used for the studies is shown in Table 4-3 and is a forecast for the AESO Northwest Planning Region peak based on the *AESO 2019 Long-Term Outlook (2019 LTO)*<sup>1</sup>. For the post-Project studies, when the Study Area loads are modified to align with the regional load forecast in the 2019 LTO, the active power to reactive power ratio in the base case scenarios shall be maintained.

**Table 4-3: Forecast Load (at AESO Northwest Planning Region Peak)**

AESO Planning Region Name	Forecast Peak Load by Year/Season (MW)	
	2022 SP	2022 WP
Northwest Planning Region <sup>1</sup>	1070	1254

**Note:**

<sup>1</sup> The Northwest Region comprises the following AESO planning areas: Rainbow Lake (Area 17), High Level (Area 18), Peace River (Area 19), Grande Prairie (Area 20), High Prairie (Area 21), Grande Cache (Area 22), Valleyview (Area 23), Fox Creek (Area 24), and Swan Hills (Area 26).

IDEV files contain non-motor loads in zones 34, 36, and 351. These loads are not accounted for in the forecasted peak loads shown above and should not be considered when scaling load. The AESO engineer will provide guidance to load scaling procedures as required.

### 4.2.4 Generation Assumptions

The generation forecast to be used for the studies is based on the 2019 LTO with modifications to incorporate the latest forecasting intelligence. The generation assumptions for the studies will assume low Northwest generation in order to maximize Northwest import through the 138/144 kV transmission paths in Fox Creek (Area 24), which has been identified as a limiting factor for generation integration at Bickerdike 39S substation. In addition, Brazeau Hydro has been identified as a critical generator in the Study Area that can result in more severe thermal criteria violations when at lower dispatch and as such a high Central generation scenario is not selected. Additional studies may be required in the event of changes to the AESO’s corporate forecast.

<sup>1</sup> The 2019 LTO is available on the AESO website.



The existing generation (excluding wind and solar) dispatch conditions for the study scenarios are described in Table 4-5, Table 4-5 and Table 4-6.

**Table 4-4: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SP and 2022WP Pre-Project Scenarios**

Facility Name	Unit No.	Bus No.	MC (MW)	AESO Planning Area No.	Unit Net Generation <sup>a</sup> (MW) by Scenario	
					2022 SP	2022 WP
Bear Creek 1 (BCRK)	1	19142	64	20	42	58
Bear Creek 2 (BCR2)	2	18142	36	20	19	16
Brazeau Hydro (BRA)	1, 2	151, 154	350	30	181.2	143.1
Gold Creek Facility (GOC1)	1	19145	5	20	Not in merit <sup>b</sup>	
Grande Prairie EcoPower (GPEC)	2	17101	27	20	5.2	5.1
H.R. Milner (HRM)	1	1148c	144	22	53.9	65.8
Northstone Power (NPC1 & NPC2)	5	17134	20	20	Not in merit	
	6	17134				
	7	18134				
	8	18134				
Northern Prairie Power Project (NPP1)	1	17120	105	20	69.9	63.8
Poplar Hill #1 (PH1)	1	16118	48	20	Not in merit	
Edson Gas Plant (TLM2)	G1	13020	13	29	8.5	10.6
Weldwood (VWD1)	1, 2	4017	50	29	37.1	36.5
Weyerhaeuser (WEY1)	1A	1146	48	20	17	34.6
Valley View 1 (VWV1)	1	1171	50	23	Not in merit	
Valley View 2 (VWV2)	2	1173	50	23	Not in merit	
DAI1 Daishowa (DAI1)	1	108	52	19	42	41

**Table 4-5: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SP and 2022WP Post-Project Scenarios**

Facility Name	Unit No.	Bus No.	MC (MW)	AESO Planning Area No.	Unit Net Generation <sup>a</sup> (MW) by Scenario	
					2022 SP	2022 WP
Bear Creek 1 (BCRK)	1	19142	64	20	42	58
Bear Creek 2 (BCR2)	2	18142	36	20	19	16
Brazeau Hydro (BRA)	1, 2	151, 154	350	30	61.9	47.3
Gold Creek Facility (GOC1)	1	19145	5	20	Not in merit <sup>b</sup>	
Grande Prairie EcoPower (GPEC)	2	17101	27	20	5.2	5.1
H.R. Milner (HRM)	1	1148c	144	22	53.9	65.8
Northstone Power (NPC1 & NPC2)	5	17134	20	20	Not in merit	
	6	17134				
	7	18134				
	8	18134				
Northern Prairie Power Project (NPP1)	1	17120	105	20	69.9	63.8
Poplar Hill #1 (PH1)	1	16118	48	20	Not in merit	
Edson Gas Plant (TLM2)	G1	13020	13	29	8.5	10.6
Weldwood (WWD1)	1, 2	4017	50	29	37.1	36.5
Weyerhaeuser (WEY1)	1A	1146	48	20	17	34.6
Valley View 1 (VWV1)	1	1171	50	23	Not in merit	
Valley View 2 (VWV2)	2	1173	50	23	Not in merit	
DAI1 Daishowa (DAI1)	1	108	52	19	42	41

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

<sup>b</sup> "Not in merit" means that the generating unit has operating blocks whose prices are above the system marginal price.

<sup>c</sup> After the cases were prepared, the MC of H.R. Milner was changed to 167 MW (effective May 2, 2020)

**Table 4-6: Existing Generation (excluding Wind and Solar) Dispatch Conditions for 2022SL Scenario**

Facility Name	Unit No.	Bus No.	MC (MW)	AESO Planning Area No.	Unit Net Generation <sup>a</sup> (MW) by Scenario
					2022 SL
Brazeau Hydro (BRA)	1, 2	151, 154	350	30	58.5
H.R. Milner (HRM)	1	1148c	144	22	0
Edson Gas Plant (TLM2)	G1	13020	13	29	9.9
Weldwood (WWD1)	1, 2	4017	50	29	41.2

**Notes:**

<sup>a</sup> "Unit Net Generation" refers to gross generating unit output (MW) less unit service load.

<sup>b</sup> "Not in merit" means that the generating unit has operating blocks whose prices are above the system marginal price.

#### 4.2.5 Intertie Flow Assumptions

The Alberta-British Columbia (AB-BC), Alberta-Saskatchewan (AB-SK), and Alberta-Montana (MATL) intertie points are deemed to be too far away from the Study Area to have any material impact on the connection assessment. Therefore, intertie flow values shall be set to the AESO planning base case values and will not be adjusted for the studies.

#### 4.2.6 HVDC Power Order Assumptions

The Western Alberta Transmission Line (WATL) and the Eastern Alberta Transmission Line (EATL) are high-voltage direct current (HVDC) transmission lines. The HVDC assumptions shall initially be set to be the same as in the AESO planning base cases which is set to minimize system losses.

The reactive power limits of the MVAR exchanges between the HVDC terminals (WATL and EATL) and the connected alternating current (AC) transmission systems are shown in Table 4-7. These limits must be maintained when performing the studies.

**Table 4-7: HVDC to Adjacent AC System MVAR Exchange Limits**

HVDC Facility	North Terminal Reactive Power Limit (MVAR)	South Terminal Reactive Power Limit (MVAR)
EATL	-85 to 75	-35 to 35
WATL	-75 to 75	-35 to 35

## 4.2.7 Transmission Facility Ratings

The legal owners of transmission facilities (TFOs) provided the thermal ratings assumptions for the existing transmission lines in the Study Area. Table 4-8 shows the normal ratings and emergency ratings for the key transmission lines in the Study Area, which will be used to perform the engineering studies.

**Table 4-8: Thermal Rating Assumptions for Key Transmission Lines in the Study Area**

Line ID	Line Description	Voltage Class (kV)	Normal Rating (MVA)		Emergency Rating (MVA)	
			Summer	Winter	Summer	Winter
199L	Fox Creek 347S – 7L199 Tap	138	119	146	131	161
995L	Brazeau 62S – Benalto 17S	240	333	333	499	499
202L	Cynthia 178S – Lodgepole 61S	138	98	132	108	145
836L	Lodgepole 61S – Violet Grove 283S	138	119	146	131	161
740L	740AL Tap – 743L & 762L Tap	138	99	133	109	146
740L	743L & 762 Tap – Coalspur 462S	138	119	147	131	162
740L	740L Tap – Gulf Robb 414S	138	119	147	131	162
744L	TMPL Niton 228S - Entwistle 235S	138	75	79	83	87
890L	Edson 58S - Pinedale 207S	138	75	79	83	87
671L	Bickerdike 39S - Edson 58S	138	172	212	189	233
973L	Bickerdike 39S - Sundance 310P	240	333	333	499	499
974L	Bickerdike 39S - Sundance 310P	240	333	333	499	499
202L	Edson 58S - Cynthia 178S	138	85	90	94	99
745L	Bickerdike 39S - Cold Creek 602S	138	172	212	189	233
847L	Bickerdike 39S – Fickle Lake 406S	138	121	148	133	163
685L	Deer Hill 1012S - Benbow 397S	138	167	201	184	218
740L	Bickerdike 39S - Edson 58S	138	112	135	124	146
740L	Bickerdike 39S – 740AL Tap	138	99	133	109	146
744L	TMPL Niton 228S - Pinedale 207S	138	75	79	83	87
854L	Bickerdike 39S - Jct. 854AL	138	263	263	311	373
854L	Jct. 854AL -Deer Hill 1012S	138	283	287	311	373
720L	Benbow 397S – Fox Creek 347S	138	120	148	132	163
7L199	Fox Creek 741S – 7L199 Tap	144	129	157	129	157

**Notes:**

AltaLink submitted a facility ratings update dated May 12<sup>th</sup> 2020 which lists several temporary derates for lines in the Study Area. As AltaLink has confirmed that these temporary derates will be mitigated within 18 months (by January 2022), the original ratings for these lines is listed and assumed for the studies

7L199 line rating increase has been identified as part of ATCO TFO's Transmission Capital Maintenance program and is expected to be completed prior to the ISD of the Project. The ratings assumed in the study are the anticipated values after clearance mitigation work is complete.

720L line rating increase has been identified by AltaLink in communication with the Market Participant and is expected to be completed prior to the ISD of the Project. The ratings assumed in the study are the anticipated values after the work is completed.

The TFOs provided the details of the substation transformers in the Study Area. The key transformers in the Study Area are shown in Table 4-9.

**Table 4-9: Summary of Key Transformer Ratings in the Study Area**

Substation Name and Number	Transformer ID	Transformer Voltages (kV)	Transformer Rating (MVA)
Bickerdike 39S	T1	240/138	269
	T2	240/138	269

The TFOs provided the details of the shunt elements in the Study Area. The key shunt elements in the Study Area are shown in Table 4-10.

**Table 4-10: Summary of Key Shunt Elements in the Study Area**

Substation Name and Number	Voltage Class (kV)	Capacitors		Reactors	
		Number of Switched Shunt Blocks	Total at Nominal Voltage (MVA <sub>r</sub> )	Number of Switched Shunt Blocks	Total at Nominal Voltage (MVA <sub>r</sub> )
Cold Creek 602S	138	1	32.5	-	-
Edson 58S	138	1	27.0	-	-
Brazeau 62S	138	1	33.	-	-
Cynthia 178S	138	1	27.0	-	-
Amoco Brazeau 358S	138	1	21.0	-	-
Violet Grove 283S	138	1	25.0	-	-

#### 4.2.8 Protection Fault Clearing Times

The transient stability studies will be performed using the actual fault clearing times for the selected contingencies, as provided by the TFOs and as shown in Table 4-11. Only those contingencies shown in Table 4-11 will be studied for transient stability studies. If the TFOs did not specify the fault clearing times (e.g. for new transmission lines) for a selected contingency, then the studies for that contingency will be performed using the standard fault clearing times that are specified in Table 2-3 of the AESO's *Transmission Planning Criteria – Basis and Assumptions*.

**Table 4-11: Protection Fault Clearing Times**

Contingency (System Element Lost)	Fault Location	Clearing Times (Cycles)
-----------------------------------	----------------	-------------------------

		Near End	Far End
685L (Deer Hill 1012S to Benbow 397S)	Deer Hill 1012S	6	27
	Benbow 397S	6	27
854L (Deer Hill 1012S to Benbow 397S)	Deer Hill 1012S	6	7
	Benbow 397S	6	7
744L (Entwistle 235S to Pinedale 207S)	Entwistle 235S	6	27
	Pinedale 207S	6	27
890L (Edson 58S to Pinedale 207S)	Edson 58S	6	7
	Pinedale 207S	6	7
671L (Bickerdike 39S to Edson 58S)	Bickerdike 39S	6	6
	Edson 58S	6	6
740L (Bickerdike 39S to Edson 58S)	Bickerdike 39S	6	6
	Edson 58S	6	6
973L (Bickerdike 39S to Sundance 310P)	Bickerdike 39S	5	6
	Sundance 310P	5	6
202L (Edson 58S to Cynthia 178S)	Edson 58S	7.25	28.25
	Cynthia 178S	7.25	28.25
745L (Bickerdike 39S to Cold Creek 602S)	Bickerdike 39S	6	32.75
	Cold Creek 602S	5.75	27

#### 4.2.9 Project Dynamic Data

Dynamic data for the Project can be found in Attachment A5.

#### 4.2.10 Voltage Profile Assumption

ID #2010-007RS will be used to establish system normal (i.e., pre-contingency) voltage profiles for key area busses prior to commencing any studies. Table 2-1 of the *Transmission Planning Criteria – Basis and Assumptions* applies for the busses not included in ID #2010-007RS. These voltages will be used to set the voltage profile for the study base cases prior to the power flow studies.

#### 4.2.11 Sub-synchronous Interaction (SSI) Screening

Screening for unit interaction factor (UIF) was deemed to be unnecessary for the Project, due to the large electrical distance and low likelihood of contingencies resulting in radial connections to series-compensated lines or HVDC converter stations.

## 5 Study Methodology

The studies to be performed for this connection assessment are identified in Table 5-1.

**Table 5-1: Summary of the Studies to be Performed**

Scenario No. and Name		Power Flow		Voltage Stability		Transient Stability		Motor Starting		Short Circuit
		Category		Category		Category		Category		Category
		A	B	A	B	A	B	A	B	A
<b>Pre-Project</b>										
1	2022 SP Pre-Project	X	X							
2	2022 WP Pre-Project	X	X							X
<b>Post-Project</b>										
3	2022 SP Post-Project	X	X			X*	X*			
4	2022 WP Post-Project	X	X			X*	X*			X
5	2029 WP Post-Project									X
<b>Post-Project Sensitivity (Transient Stability)</b>										
6	2022 SL Post-Project					X*	X*			

\*Pre-project transient stability studies will be conducted if stability issues are identified in the post-Project studies

For the engineering studies, all transmission facilities 69 kV and above within the Study Area and the transmission lines connecting these planning areas to neighbouring planning areas will be studied and monitored to assess the impact of the Project on the performance of the AIES, including any violations of the Reliability Criteria (as defined in Section 3.1).

### 5.1 Power Flow Studies

Power flow studies will be performed to identify thermal and voltage criteria violations as per the Reliability Criteria, and any deviations from the limits listed in Table 3-1.

For the Category B power flow studies, the transformer taps and switched shunt reactive compensating devices such as shunt capacitors and reactors will be locked and continuous shunt devices will be enabled.

Voltage deviations at point-of-delivery (POD) low voltage busses will also be assessed for both the pre-Project and post-Project networks by first locking all tap changers and area shunt reactive compensating devices to identify any post-transient voltage deviations above 10%. Second, tap changers will be allowed

to move while shunt reactive compensating devices remained locked to determine if any voltage deviations above 7% would occur in the area. Third, all the taps and shunt reactive compensating devices will be allowed to adjust, and voltage deviations above 5% will be reported.

The scenarios to be studied are shown in Table 5-1.

### **5.1.1 Contingencies to be Studied**

Power flow studies will be performed for the Category A and all Category B conditions in the Study Area.

## **5.2 Transient Stability Studies**

The Shepard ST in Calgary (Area 6) will be used as the reference for the studies.

The report presenting the results of the transient stability studies must provide response plots for several variables, including rotor angle, and active and reactive power output for one generating unit at each of the following facilities in the Study Area as well as the Project facility.

- Brazeau Hydro
- Weldwood
- Genesee
- Sundance
- Keephills

The results report must also provide bus voltage levels for substations 138 kV and above near the point of connection. Other busses will be monitored and will be reported as determined by the results. The results report must also provide the key branch active and reactive power flow surrounding the Facility.

Transient stability studies will be performed for the post-Project scenarios as shown in Table 5-1. If any transient stability issues are observed, transient stability analysis will be performed for the corresponding pre-Project scenarios.

### **5.2.1 Contingencies to be Studied**

Transient stability studies will be performed for Category B events shown in Table 4-11

## **5.3 Short-Circuit Current Level Studies**

A maximum fault level must be provided for the substations in the vicinity of the Project assuming normal system operation with all transmission elements in service and generation dispatched. Three-phase faults and single line-to-ground faults will be simulated. Polar coordinates and per-unit values will be used for reporting the results.

Winter peak scenarios will be used for the short-circuit studies because winter peak scenarios generally produce higher short-circuit current levels than summer peak scenarios.

Estimated maximum three-phase faults and single line-to-ground short-circuit current levels will be reported for the following substations:

- Edson 58S



## Engineering Connection Assessment: Study Scope

Cascade Power Plant Project Connection

V4



- Bickerdike 39S
- Sundance 310P
- Cold Creek 602S
- Dalehurst 975S
- Mountain Obed 411S
- Hornbeck 345S
- Marlboro 348S
- Deer Hill 1012S
- Gulf Robb 414S
- Fickle Lake 406S

Further sensitivity studies, in consultation with the TFO, may be required if the primary short-circuit analysis indicates a potential to exceed or approach the existing fault rating of the transmission facilities.

The scenarios to be studied are as shown in Table 5-1.

## 6 Mitigation Measures

### 6.1 Development

Mitigation measures may be required if the post-Project study results identify system performance issues. Mitigation measures for the Project may involve modifying or adding real-time operational practices and/or remedial action schemes (RASs).

The AESO will proceed as follows:

- Develop tables showing the constraint effective factors<sup>2</sup> for generation or load based on thermal criteria violations that are observed.
- Propose changes, if any, to the connection alternatives that could remove the requirement for a RAS.
- Study modifications to existing and/or planned RASs, proposed by the AESO, to ensure the coordination of existing protection schemes with the addition of any proposed protection schemes.
- Identify and study new RASs, if any, that may be required to ensure system reliability is maintained after connecting the Project to the AIES.

### 6.2 Evaluation

#### 6.2.1 Post-Mitigation Studies

Studies to evaluate the effectiveness of mitigation measures, if required, will be performed in accordance with the technical criteria, assumptions, and methods provided in this Study Scope and in accordance with further instructions from the AESO.

#### 6.2.2 Constraint Effective Factor Studies

Constraint effective factor analysis are used to determine the generator- and load- constraint effective factors and to identify the most effective generators or loads to manage the thermal criteria violations, if any, that are observed under Category B conditions.

---

<sup>2</sup> Constraint effective factor studies are performed to determine the generator- and load- constraint effective factors. Constraint effective factors are used to estimate the ability of generators and loads to manage transmission constraints. A generator's or load's constraint effective factor is defined as the change in power flow over a specific transmission line following a change in the generator's energy production or in the load's energy consumption. The greater the constraint effective factor, the more effective a generator or load can be in managing a thermal criteria violation on the specific transmission line.

## 7 Changes to Study Assumptions

This study will utilize the AESO's planning base cases, which include the AESO's current corporate forecast (2019 LTO). Sensitivity studies or restudy may be required in the event of revisions to the AESO's corporate forecast or other study assumptions. Additional engineering studies may also be required to assess new connection alternatives, changes to project ISD, or delays in proposed system developments. Any additional or revised study requirements shall be captured in a signed Study Scope Amendment document.

# Attachment A: Transmission Planning Criteria – Basis and Assumptions

# Transmission Planning Criteria – Basis and Assumptions

**Date:** July 9, 2019

**Version:** V1.2

## 1. Introduction

This document presents the reliability standards, criteria, and assumptions to be used as the basis for planning the Alberta Transmission System. The criteria, standards and assumptions identified in this document supersede those previously established.

## 2. Transmission Reliability Standards and Criteria<sup>1</sup>

The AESO applies the following Alberta Reliability Standards to ensure that the transmission system is planned to meet applicable performance requirements under a defined set of system conditions and contingencies. A brief description of each of these standards is given below:

### 1. TPL-001-AB-0: System Performance Under Normal Conditions

Category A represents a normal system condition with all elements in service (N-0). All equipment must be within its applicable rating, voltages must be within their applicable ratings and the system must be stable with no cascading outages. Under Category A, electric supply to load cannot be interrupted and generating units cannot be removed from service.

### 2. TPL-002-AB1-0: System Performance Following Loss of a Single BES Element

Category B events result in the loss of any single element (N-1) under specified fault conditions with normal clearing. The specified elements are a generating unit, a transmission circuit, a transformer or a single pole of a direct current transmission line. The acceptable impact on the system is the same as Category A with the exception that radial customers or some local network customers, including loads or generating units, are allowed to be disconnected from the system if they are connected through the faulted element. The loss of opportunity load or opportunity interchanges is allowed. No cascading can occur.

### 3. TPL-003-AB-0: System Performance Following Loss of Two or More BES Elements

Category C events result in the loss of two or more bulk electric system elements (sequential, N-1-1 or concurrent, N-2) under specified fault conditions and include both normal and delayed fault clearing. All of the system limits for Category A and B events apply with the exception that planned and controlled loss of firm load, firm transfers and/or generation is acceptable provided there is no cascading.

### 4. TPL-004-AB-0: System Performance Following Extreme BES Events

Category D represents a wide variety of extreme, rare and unpredictable events, which may result in the loss of load and generation in widespread areas. The system may not be able to reach a new stable steady state, which means a blackout is a possible outcome. The AESO needs to evaluate these events, at its discretion, for risks and consequences prior to creating mitigation plans.

### 5. FAC-014-AB1-2: Establishing and Communicating System Operating Limits

The AESO is required to establish system operating limits where a contingency is not mitigated through construction of transmission facilities

---

<sup>1</sup> A complete description of the *Alberta Reliability Standards* can be found on the AESO's website: <https://www.aeso.ca/rules-standards-and-tariff/alberta-reliability-standards/>

## 2.1 Thermal Loading Criteria

The AESO Thermal Loading Criteria require that the continuous thermal rating of any transmission element is not exceeded under normal and post-contingency operating conditions. Thermal limits are assumed to be 100% of the respective normal summer and winter ratings. Emergency limits are not considered in the planning evaluations.

## 2.2 Voltage Range and Voltage Stability Criteria

The normal minimum and maximum voltage limits as specified in the following table are used to identify Category A system voltage violations, while the extreme minimum and maximum limits are used to identify Category B and C system violations. Table 2-1 presents the acceptable steady state and contingency state voltage ranges for the AIES. Table 2-2 provides voltage stability criteria used to test the system performance.

**Table 2-1: Acceptable Range of Steady State Voltage (kV)**

Nominal Voltage	Extreme Minimum	Normal Minimum	Normal Maximum	Extreme Maximum
500	475	500	525	550
240	216	234	252	264
260 (Northeast & Northwest)*	234	247	266	275
144	130	137	151	155
138	124	135	145	152
72	65	68.5	75.5	79
69	62	65.5	72.5	76

**Table 2-2: Voltage Stability Criteria**

Performance Level	Disturbance (1)(2)(3)(4) Initiated by: Fault or No Fault DC Disturbance	MW Margin (P-V method) (5)(6)(7)	MVAr Margin (V-Q method) (6)(7)
A	Any element such as: One Generator One Circuit One Transformer One Reactive Power Source One DC Monopole	$\geq 5\%$	Worst Case Scenario(8)
B	Bus Section	$\geq 5\%$	50% of Margin Requirement in Level A
C	Any combination of two elements such as: A Line and a Generator A Line and a Reactive Power Source Two Generators Two Circuits Two Transformers Two Reactive Power Sources DC Bipole	$\geq 2.5\%$	50% of Margin Requirement in Level A
D	Any combination of three or more elements such as: Three or More Circuits on ROW Entire Substation Entire Plant Including Switchyard	$> 0$	$> 0$

### 2.3 Transient Stability Analysis Assumptions

Standard fault clearing times as shown in Table 2-3 are used for the new facilities or when the actual clearing times are not available for the existing facilities. Double line-to-ground faults are applied for the Category C5 events with normal clearing times. Single line-to-ground faults are applied for Category C6 to C9 events with delayed clearing times as depicted in Table 2-4 and Table 2-5.

**Table 2-3: Fault Clearing Times**

Nominal (kV)	Near End (Cycles)	Far End (Cycles)
500	4	5
240	5	6
144/138 with telecommunications	6	8
144/138 without telecommunications	6	30

**Table 2-4: Stuck Breaker Clearing Times for Lines**

Voltage (kV)	Fault Clearing Times (Cycles)		
	Near End	Far End	2 <sup>nd</sup> Ckt (C5 and C7 only)
138/144	15	24	24
240	12	6	14
500	9	5	11


**Table 2-5: Stuck Breaker Clearing Times for Transformers**

Voltage (kV)	Fault Location	Fault Clearing Times (Cycles)		
		High Side	Low Side	2 <sup>nd</sup> Ckt (breaker fail)
240/138	240 kV side	12	6	14
	138 kV side	5	15	24
500/240	500 kV side	9	5	11
	240 kV side	4	12	14



# Attachment A2

## Pre-Project Power Flow Diagrams




2022SP PRE-PROJECT  
 CATEGORY A  
 FIG A2-1  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000





2022SP PRE-PROJECT  
 973L  
 FIG A2-2  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00<=69.00 <=138.00 <=240.00 <=500.00-500.00






2022SP PRE-PROJECT  
 890L  
 FIG A2-4  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 202L  
 FIG A2-5  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 720L  
 FIG A2-6  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 671L  
 FIG A2-7  
 FRI, MAY 22 2020 16:51

**AESO**

- Bus - Voltage (kV/pu)
- Branch - MW/Mvar
- Equipment - MVA/Mvar
- 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022SP PRE-PROJECT  
 902L  
 FIG A2-8  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
905L  
FIG A2-9  
FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
TOU 0% Rate %

kV: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00-500.00




2022SP PRE-PROJECT  
 909L  
 FIG A2-10  
 FRI, MAY 22 2020 16:51

---

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MWMvar  
 Equipment - MWMvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 854L  
 FIG A2-11  
 FRI, MAY 22 2020 16:51

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 1046L  
 FIG A2-12  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 685L  
 FIG A2-13  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00-500.00



2022SP PRE-PROJECT  
 39ST1  
 FIG A2-14  
 FRI, MAY 22 2020 16:52

**AESO**


Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000










2022SP PRE-PROJECT  
 207ST1 OR 207ST2  
 FIG A2-17  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP PRE-PROJECT  
 1012ST1  
 FIG A2-18  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 BASE CASE  
 FIG A2-19  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 973L  
 FIG A2-20  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00-500.00




2022WP PRE-PROJECT  
 974L  
 FIG A2-21  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 890L  
 FIG A2-22  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00<=69.00 <=138.00 <=240.00 <=500.00-500.00




2022WP PRE-PROJECT  
 202L  
 FIG A2-23  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MWMvar  
 Equipment - MWMvar  
 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022WP PRE-PROJECT  
 720L  
 FIG A2-24  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 671L  
 FIG A2-25  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 902L  
 FIG A2-26  
 FRI, MAY 22 2020 16:52

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00 <=49.00 <=138.00 <=240.00 <=500.00-500.00



2022WP PRE-PROJECT  
 905L  
 FIG A2-27  
 FRI, MAY 22 2020 16:52


**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000








2022/WP PRE-PROJECT  
1046L  
FIG A2-30  
FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
100.0% Rate %

kV: <math>\le 25.000</math> <math>\le 69.000</math> <math>\le 138.000</math> <math>\le 240.000</math> <math>\le 500.000</math> <math>500.000</math>




2022WP PRE-PROJECT  
 685L  
 FIG A2-31  
 FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022/WP PRE-PROJECT  
 39ST1  
 FIG A2-32  
 FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 39ST2  
 FIG A2-33  
 FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP PRE-PROJECT  
 58ST1 OR 58ST2  
 FIG A2-34  
 FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 LOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022/WP PRE-PROJECT  
 207ST1 OR 207ST2  
 FIG A2-35  
 FRI, MAY 22 2020 16:53

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000



2022/WP PRE-PROJECT  
 1012ST1  
 FIG A2-36  
 FRI, MAY 22 2020 16:53


**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00<=69.00 <=138.00 <=240.00 <=500.000-500.000

# Attachment A3

## Post-Project Power Flow Diagrams




2022SP POST-PROJECT  
 CATEGORY A (PRE-TCM)  
 FIG A3-1  
 WED, JUN 24 2020 13:06

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY A (POST-TCM)  
 FIG A3-1B  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000</math> <math>500.000</math>






2022SP POST-PROJECT  
 CATEGORY B: 973L  
 FIG A3-2  
 WED, JUN 24 2020 13:07

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 974L  
 FIG A3-3  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 890L  
 FIG A3-4  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 202L  
 FIG A3-5  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 720L  
 FIG A3-6  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 671L  
 FIG A3-7  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 902L  
 FIG A3-8  
 WED, JUN 24 2020 13:07

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 905L  
 FIG A3-9  
 WED, JUN 24 2020 13:08

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\le 25.000</math> <math>\le 69.000</math> <math>\le 138.000</math> <math>\le 240.000</math> <math>\le 500.000</math> <math>500.000</math>






2022SP POST-PROJECT  
 CATEGORY B: 909L  
 FIG A3-10  
 WED, JUN 24 2020 13:08

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\le 25.000</math> <math>\le 69.000</math> <math>\le 138.000</math> <math>\le 240.000</math> <math>\le 500.000</math> <math>500.000</math>




2022SP POST-PROJECT  
 CATEGORY B: 854L  
 FIG A3-11  
 WED, JUN 24 2020 13:08

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 685L  
 FIG A3-12  
 WED, JUN 24 2020 13:08

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 39ST1  
 FIG A3-13  
 WED, JUN 24 2020 13:08

**AESO**


Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000



2022SP POST-PROJECT  
 CATEGORY B: 39ST2  
 FIG A3-14  
 WED, JUN 24 2020 13:09

**AESO**  
 Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %  
 kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 58ST1 OR 58ST2  
 FIG A3-15  
 WED, JUN 24 2020 13:09

---

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT  
 CATEGORY B: 207ST1 OR 207ST2  
 FIG A3-16  
 WED, JUN 24 2020 13:09

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00 <=69.00 <=138.00 <=240.00 <=500.00-500.00




2022SP POST-PROJECT  
 CATEGORY B: 1012ST1  
 FIG A3-17  
 WED, JUN 24 2020 13:09


**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <math>\leq 25.000</math> <math>25.000 < \leq 69.000</math> <math>69.000 < \leq 138.000</math> <math>138.000 < \leq 240.000</math> <math>240.000 < \leq 500.000</math> <math>500.000 < \leq 1000.000</math>









2022/WP POST-PROJECT  
 CATEGORY B: 973L  
 FIG A3-19  
 WED, JUN 24 2020 13:09

**AESO**



2022WP POST-PROJECT  
 CATEGORY B: 974L  
 FIG A3-20  
 WED, JUN 24 2020 13:09

**AESO**  
 Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %  
 kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022/WP POST-PROJECT  
 CATEGORY B: 890L  
 FIG A3-21  
 WED, JUN 24 2020 13:10

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022/WP POST-PROJECT  
 CATEGORY B: 202L  
 FIG A3-22  
 WED, JUN 24 2020 13:10

# AESO

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022/WP POST-PROJECT  
 CATEGORY B: 720L  
 FIG A3-23  
 WED, JUN 24 2020 13:10

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022\WP POST-PROJECT  
 CATEGORY B: 671L  
 FIG A3-24  
 WED, JUN 24 2020 13:10

---

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT  
 CATEGORY B: 902L  
 FIG A3-25  
 WED, JUN 24 2020 13:10

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\le 25.000</math> <math>\le 69.000</math> <math>\le 138.000</math> <math>\le 240.000</math> <math>\le 500.000</math> <math>500.000</math>






2022WP POST-PROJECT  
 CATEGORY B: 905L  
 FIG A3-26  
 WED, JUN 24 2020 13:10

**AESO**

Bus - Voltage (kV/μ)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT  
 CATEGORY B: 909L  
 FIG A3-27  
 WED, JUN 24 2020 13:10

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\leq 25.000</math> <math>\leq 69.000</math> <math>\leq 138.000</math> <math>\leq 240.000</math> <math>\leq 500.000</math> <math>500.000</math>




2022WP POST-PROJECT  
CATEGORY B: 854L  
FIG A3-28  
WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
Branch - MW/Mvar  
Equipment - MW/Mvar  
100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT  
 CATEGORY B: 685L  
 FIG A3-29  
 WED, JUN 24 2020 13:11

**AESO**


Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\le 25.000</math> <math>\le 69.000</math> <math>\le 138.000</math> <math>\le 500.000</math> <math>500.000</math>



2022WP POST-PROJECT  
 CATEGORY B: 39ST1  
 FIG A3-30  
 WED, JUN 24 2020 13:11


**AESO**



2022/WP POST-PROJECT  
 CATEGORY B: 39ST2  
 FIG A3-31  
 WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %  
 kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT  
 CATEGORY B: 58ST1 OR 58ST2  
 FIG A3-32  
 WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT  
 CATEGORY B: 207ST1 OR 207ST2  
 FIG A3-33  
 WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000





2022/WP POST-PROJECT  
 CATEGORY B: 1012ST1  
 FIG A3-34  
 WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <math>\le 25.000</math> <math>25.000 < \le 69.000</math> <math>69.000 < \le 138.000</math> <math>138.000 < \le 240.000</math> <math>240.000 < \le 500.000</math> <math>500.000 < \le 1000.000</math>

# Attachment A4

## Post-Project Transient Stability Diagrams



FIGURE D-1B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out






FIGURE D-1F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out




FIGURE D-1G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-1\_685L\_DeerHill\_1012S.out








FIGURE D-1J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-1\_685L\_DeerHill\_1012S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:33  
 BRANCH FLOW (Q)



FIGURE D-1I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-1\_685L\_DeerHill\_1012S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:33  
 BRANCH FLOW (P)



FIGURE D-2B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out






FIGURE D-2F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out




FIGURE D-2G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out








FIGURE D-2J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-2I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-2\_685L\_Benbow\_397S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)





FIGURE D-3B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out






FIGURE D-3F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out




FIGURE D-3G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-3\_854L\_DeerHill\_1012S.out








FIGURE D-3J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-3\_854L\_DeerHill\_1012S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-3I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-3\_854L\_DeerHill\_1012S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-4B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out






FIGURE D-4F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out




FIGURE D-4G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-4\_854L\_Bickerdike\_39S.out







FIGURE D-4J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-4\_854L\_Bickerdike\_39S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-4I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-4\_854L\_Bickerdike\_39S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-5B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out




FIGURE D-5D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out




FIGURE D-5A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out




FIGURE D-5C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out






FIGURE D-5F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-5H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)




FIGURE D-5E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-5G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-5\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)









FIGURE D-5J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-5\_744L\_Entwistle\_235S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-5I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-5\_744L\_Entwistle\_235S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-6B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out






FIGURE D-6F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALED 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALED 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALED 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out




FIGURE D-6G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALED 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-6\_744L\_Pinedale\_207S.out







FIGURE D-6J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-6\_744L\_Pinedale\_207S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-6I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-6\_744L\_Pinedale\_207S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-7B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out






FIGURE D-7F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out




FIGURE D-7G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-7\_890L\_Edson\_58S.out







FIGURE D-7J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-7\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)





FIGURE D-7I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-7\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)






FIGURE D-8B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out




FIGURE D-8D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out




FIGURE D-8A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out








FIGURE D-8C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out









**FIGURE D-8F**  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out





**FIGURE D-8H**  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out




**FIGURE D-8E**  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out




**FIGURE D-8G**  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-8\_890L\_Pinedale\_207S.out







FIGURE D-8J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-8\_890L\_Pinedale\_207S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-8I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-8\_890L\_Pinedale\_207S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-9B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out




FIGURE D-9D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out




FIGURE D-9A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out




FIGURE D-9C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out






FIGURE D-9F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-9H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)




FIGURE D-9E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-9G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)






FIGURE D-9J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)




FIGURE D-9I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-9\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)






FIGURE D-10B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out




FIGURE D-10D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out




FIGURE D-10A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out




FIGURE D-10C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out






FIGURE D-10F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-10H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)




FIGURE D-10E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-10G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)






FIGURE D-10J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)




FIGURE D-10I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-10\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)








FIGURE D-11B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out




FIGURE D-11D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out




FIGURE D-11A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out




FIGURE D-11C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out






FIGURE D-11F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-11H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)




FIGURE D-11E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-11G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-11\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)








FIGURE D-11J  
2022SP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
FILE: D-11\_740L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:34  
BRANCH FLOW (Q)



FIGURE D-11I  
2022SP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
FILE: D-11\_740L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:34  
BRANCH FLOW (P)



FIGURE D-12B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out






FIGURE D-12F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out




FIGURE D-12G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out






FIGURE D-12J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)




FIGURE D-12I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-12\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)






FIGURE D-13B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out




FIGURE D-13D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out




FIGURE D-13A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out




FIGURE D-13C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out






FIGURE D-13F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-13H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)




FIGURE D-13E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 MACHINE POWER (MW)




FIGURE D-13G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:34  
 BUS VOLTAGE (PU)










FIGURE D-13J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (Q)



FIGURE D-13I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-13\_973L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:34  
 BRANCH FLOW (P)



FIGURE D-14B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out




FIGURE D-14D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out




FIGURE D-14A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out




FIGURE D-14C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out






FIGURE D-14F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-14H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-14E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-14G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)






FIGURE D-14J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)




FIGURE D-14I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-14\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)






FIGURE D-15B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out




FIGURE D-15D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out




FIGURE D-15A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out




FIGURE D-15C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out






FIGURE D-15F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-15H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-15E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-15G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-15\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)







FIGURE D-15J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-15\_202L\_Edson\_58S.out

CHNL# 79: [VARS 88 TO 472 CKT '50']  
 CHNL# 81: [VARS 88 TO 913 CKT '40']  
 CHNL# 73: [VARS 20 TO 88 CKT '71']  
 CHNL# 71: [VARS 20 TO 88 CKT '40']  
 CHNL# 85: [VARS 90 TO 135 CKT '74']  
 CHNL# 83: [VARS 90 TO 135 CKT '73']




WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-15I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-15\_202L\_Edson\_58S.out

CHNL# 78: [POWR 88 TO 472 CKT '50']  
 CHNL# 80: [POWR 88 TO 913 CKT '40']  
 CHNL# 72: [POWR 20 TO 88 CKT '71']  
 CHNL# 70: [POWR 20 TO 88 CKT '40']  
 CHNL# 84: [POWR 90 TO 135 CKT '74']  
 CHNL# 82: [POWR 90 TO 135 CKT '73']



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)



FIGURE D-16B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out




FIGURE D-16D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out




FIGURE D-16A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out




FIGURE D-16C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out








FIGURE D-16F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-16H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-16E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-16G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-16\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)








FIGURE D-16J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-16\_202L\_Cynthia\_178S.out  
 CHNL# 79: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-16I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-16\_202L\_Cynthia\_178S.out  
 CHNL# 78: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)



FIGURE D-17B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out




FIGURE D-17D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out




FIGURE D-17A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out




FIGURE D-17C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out






FIGURE D-17F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-17H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-17E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-17G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)






FIGURE D-17J  
2022SP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
BRANCH FLOW (Q)




FIGURE D-17I  
2022SP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
FILE: D-17\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
BRANCH FLOW (P)






FIGURE D-18B  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out




FIGURE D-18D  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out




FIGURE D-18A  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out




FIGURE D-18C  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out






FIGURE D-18F  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-18H  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-18E  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-18G  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)








FIGURE D-18J  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out



WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-18I  
 2022SP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-18\_745L\_ColdCreek\_602S.out



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)





FIGURE D-19B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out




FIGURE D-19D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out




FIGURE D-19A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out




FIGURE D-19C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out






FIGURE D-19F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-19H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-19E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-19G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-19\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)






FIGURE D-19J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-19\_685L\_DeerHill\_1012S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





FIGURE D-19I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-19\_685L\_DeerHill\_1012S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']







FIGURE D-20B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out






FIGURE D-20F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out




FIGURE D-20G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-20\_685L\_Benbow\_397S.out








FIGURE D-20J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-20\_685L\_Benbow\_397S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-20I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-20\_685L\_Benbow\_397S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)



FIGURE D-21B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out




FIGURE D-21D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out




FIGURE D-21A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out




FIGURE D-21C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out






FIGURE D-21F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-21H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-21E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-21G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-21\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)










FIGURE D-21J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-21\_854L\_DeerHill\_1012S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:35



FIGURE D-21I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-21\_854L\_DeerHill\_1012S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:35



FIGURE D-22B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out




FIGURE D-22D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out




FIGURE D-22A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out




FIGURE D-22C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out






FIGURE D-22F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-22H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-22E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-22G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-22\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)








FIGURE D-22J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-22\_854L\_Bickerdike\_39S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-22I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-22\_854L\_Bickerdike\_39S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)



FIGURE D-23B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out




FIGURE D-23D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out




FIGURE D-23A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out




FIGURE D-23C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out






FIGURE D-23F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-23H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)




FIGURE D-23E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:35  
 MACHINE POWER (MW)




FIGURE D-23G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-23\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:35  
 BUS VOLTAGE (PU)








FIGURE D-23J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-23\_744L\_Entwistle\_235S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:35  
 BRANCH FLOW (Q)



FIGURE D-23I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-23\_744L\_Entwistle\_235S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:35  
 BRANCH FLOW (P)



FIGURE D-24B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out






FIGURE D-24F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out




FIGURE D-24G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-24\_744L\_Pinedale\_207S.out








FIGURE D-24J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-24\_744L\_Pinedale\_207S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)



FIGURE D-24I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-24\_744L\_Pinedale\_207S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)



FIGURE D-25B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out




FIGURE D-25D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out




FIGURE D-25A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out




FIGURE D-25C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out






FIGURE D-25F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-25H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-25E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-25G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-25\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)







FIGURE D-25J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-25\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)





FIGURE D-25I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-25\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-26B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out




FIGURE D-26D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out




FIGURE D-26A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out







FIGURE D-26C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out





**FIGURE D-26F**  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out

WED, MAY 13 2020 23:36  
**MACHINE POWER (MW)**





**FIGURE D-26H**  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out


WED, MAY 13 2020 23:36  
**BUS VOLTAGE (PU)**




**FIGURE D-26E**  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out

WED, MAY 13 2020 23:36  
**MACHINE POWER (MW)**




**FIGURE D-26G**  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-26\_890L\_Pinedale\_207S.out

WED, MAY 13 2020 23:36  
**BUS VOLTAGE (PU)**







FIGURE D-26J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-26\_890L\_Pinedale\_207S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)



FIGURE D-26I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-26\_890L\_Pinedale\_207S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)





FIGURE D-27B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out




FIGURE D-27G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out






FIGURE D-27J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-27I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-27\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-28B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out




FIGURE D-28D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out




FIGURE D-28A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out




FIGURE D-28C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out








FIGURE D-28F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-28H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-28E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)



FIGURE D-28G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)



FIGURE D-28J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-28I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-28\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-29B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out




FIGURE D-29D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out




FIGURE D-29A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out




FIGURE D-29C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out






FIGURE D-29F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-29H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-29E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-29G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)








FIGURE D-29J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-29I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-29\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-30B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out




FIGURE D-30D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out




FIGURE D-30A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out




FIGURE D-30C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out






FIGURE D-30F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-30H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-30E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-30G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)






FIGURE D-30J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-30I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-30\_740L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-31B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out




FIGURE D-31D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out




FIGURE D-31A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out




FIGURE D-31C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out






FIGURE D-31F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-31H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-31E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-31G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)






FIGURE D-31J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-31I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-31\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-32B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out




FIGURE D-32D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out




FIGURE D-32A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out




FIGURE D-32C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out








FIGURE D-32F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-32H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-32E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-32G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)






FIGURE D-32J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)




FIGURE D-32I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-32\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)






FIGURE D-33B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out




FIGURE D-33D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out




FIGURE D-33A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out




FIGURE D-33C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out






FIGURE D-33F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-33H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)




FIGURE D-33E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 MACHINE POWER (MW)




FIGURE D-33G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-33\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:36  
 BUS VOLTAGE (PU)








FIGURE D-33J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-33\_202L\_Edson\_58S.out





WED, MAY 13 2020 23:36  
 BRANCH FLOW (Q)



FIGURE D-33I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-33\_202L\_Edson\_58S.out



WED, MAY 13 2020 23:36  
 BRANCH FLOW (P)



FIGURE D-34B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out




FIGURE D-34D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out




FIGURE D-34A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out




FIGURE D-34C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out






FIGURE D-34F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-34H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-34E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-34G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-34\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)








FIGURE D-34J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-34\_202L\_Cynthia\_178S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-34I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-34\_202L\_Cynthia\_178S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)





FIGURE D-35B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out




FIGURE D-35D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out




FIGURE D-35A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out




FIGURE D-35C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out






FIGURE D-35F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-35H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-35E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-35G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-35\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)








FIGURE D-35J  
2022WP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
FILE: D-35\_745L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:37  
BRANCH FLOW (Q)



FIGURE D-35I  
2022WP, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
FILE: D-35\_745L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:37  
BRANCH FLOW (P)



FIGURE D-36B  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out




FIGURE D-36D  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out




FIGURE D-36A  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out




FIGURE D-36C  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out






FIGURE D-36F  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-36H  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-36E  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-36G  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-36\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)








FIGURE D-36J  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES

FILE: D-36\_745L\_ColdCreek\_602S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-36I  
 2022WP, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES

FILE: D-36\_745L\_ColdCreek\_602S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-37B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out




FIGURE D-37D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out




FIGURE D-37A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out




FIGURE D-37C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out






FIGURE D-37F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-37H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-37E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-37G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-37\_685L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)










FIGURE D-37J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-37\_685L\_DeerHill\_1012S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-37I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-37\_685L\_DeerHill\_1012S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-38B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out




FIGURE D-38D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out




FIGURE D-38A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out




FIGURE D-38C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out






FIGURE D-38F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-38H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-38E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-38G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)







FIGURE D-38J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']  
 CHNL# 86: [VARS 88 TO 913 CKT '40']  
 CHNL# 78: [VARS 20 TO 88 CKT '71']  
 CHNL# 76: [VARS 20 TO 88 CKT '40']  
 CHNL# 90: [VARS 90 TO 135 CKT '74']  
 CHNL# 88: [VARS 90 TO 135 CKT '73']




WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-38I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BENBOW 397S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-38\_685L\_Benbow\_397S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']  
 CHNL# 85: [POWR 88 TO 913 CKT '40']  
 CHNL# 77: [POWR 20 TO 88 CKT '71']  
 CHNL# 75: [POWR 20 TO 88 CKT '40']  
 CHNL# 89: [POWR 90 TO 135 CKT '74']  
 CHNL# 87: [POWR 90 TO 135 CKT '73']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-39B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out




FIGURE D-39D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out




FIGURE D-39A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out




FIGURE D-39C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out






FIGURE D-39F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-39H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-39E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-39G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-39\_854L\_DeerHill\_1012S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)








FIGURE D-39J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-39\_854L\_DeerHill\_1012S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-39I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT DEER HILL 1012S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-39\_854L\_DeerHill\_1012S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-40B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out




FIGURE D-40D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out




FIGURE D-40A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out




FIGURE D-40C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out








FIGURE D-40F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-40H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-40E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-40G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)










FIGURE D-40J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-40I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-40\_854L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-41B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out




FIGURE D-41D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out




FIGURE D-41A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out




FIGURE D-41C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out






FIGURE D-41F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-41H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)




FIGURE D-41E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:37  
 MACHINE POWER (MW)




FIGURE D-41G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-41\_744L\_Entwistle\_235S.out

WED, MAY 13 2020 23:37  
 BUS VOLTAGE (PU)








FIGURE D-41J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-41\_744L\_Entwistle\_235S.out

CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:37  
 BRANCH FLOW (Q)



FIGURE D-41I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT ENTWISTLE 235S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-41\_744L\_Entwistle\_235S.out

CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:37  
 BRANCH FLOW (P)



FIGURE D-42B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out




FIGURE D-42D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out




FIGURE D-42A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out








FIGURE D-42C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out






**FIGURE D-42F**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out





**FIGURE D-42H**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out




**FIGURE D-42E**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out




**FIGURE D-42G**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-42\_744L\_Pinedale\_207S.out








FIGURE D-42J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-42\_744L\_Pinedale\_207S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)



FIGURE D-42I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 27 CYCLES

FILE: D-42\_744L\_Pinedale\_207S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)





FIGURE D-43B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out




FIGURE D-43D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out




FIGURE D-43A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out




FIGURE D-43C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out






FIGURE D-43F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-43H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)




FIGURE D-43E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-43G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-43\_890L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)







FIGURE D-43J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-43\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)





FIGURE D-43I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-43\_890L\_Edson\_58S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)






FIGURE D-44B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out




FIGURE D-44G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES  
 FILE: D-44\_890L\_Pinedale\_207S.out







FIGURE D-44J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-44\_890L\_Pinedale\_207S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']




WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)



FIGURE D-44I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT PINEDALE 207S  
 CLEARED IN 6 CYCLES, FAR END IN 7 CYCLES

FILE: D-44\_890L\_Pinedale\_207S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)



FIGURE D-45B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out




FIGURE D-45D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out




FIGURE D-45A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out




FIGURE D-45C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out






FIGURE D-45F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-45H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)




FIGURE D-45E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-45G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)








FIGURE D-45J  
2022SL, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
BRANCH FLOW (Q)




FIGURE D-45I  
2022SL, POST-PROJECT  
3-PHASE FAULT AT BICKERDIKE 39S  
CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
FILE: D-45\_671L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
BRANCH FLOW (P)






FIGURE D-46B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out






FIGURE D-46F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out




FIGURE D-46G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out






FIGURE D-46J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)




FIGURE D-46I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-46\_671L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)






FIGURE D-47B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out




FIGURE D-47D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out




FIGURE D-47A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out




FIGURE D-47C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out






FIGURE D-47F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-47H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)




FIGURE D-47E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-47G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)






FIGURE D-47J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)




FIGURE D-47I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-47\_740L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)






FIGURE D-48B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out








FIGURE D-48F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out




FIGURE D-48G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out








FIGURE D-48J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)



FIGURE D-48I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 6 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-48\_740L\_Edson\_58S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)



FIGURE D-49B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out




FIGURE D-49D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out




FIGURE D-49A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out




FIGURE D-49C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out






FIGURE D-49F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-49H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)




FIGURE D-49E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-49G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)








FIGURE D-49J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)





FIGURE D-49I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 5 CYCLES, FAR END IN 5 CYCLES  
 FILE: D-49\_973L\_Bickerdike\_39S.out





WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)



**FIGURE D-50B**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out





**FIGURE D-50D**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




**FIGURE D-50A**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




**FIGURE D-50C**  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




FIGURE D-50F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




FIGURE D-50H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




FIGURE D-50E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out




FIGURE D-50G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out






FIGURE D-50J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)




FIGURE D-50I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT SUNDANCE 310P  
 CLEARED IN 4 CYCLES, FAR END IN 6 CYCLES  
 FILE: D-50\_973L\_Sundance\_310P.out

WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)








FIGURE D-51B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out




FIGURE D-51D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out




FIGURE D-51A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out




FIGURE D-51C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out






FIGURE D-51F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-51H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)




FIGURE D-51E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-51G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-51\_202L\_Edson\_58S.out

WED, MAY 13 2020 23:38  
 BUS VOLTAGE (PU)








FIGURE D-51J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-51\_202L\_Edson\_58S.out





WED, MAY 13 2020 23:38  
 BRANCH FLOW (Q)



FIGURE D-51I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT EDSON 58S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-51\_202L\_Edson\_58S.out



WED, MAY 13 2020 23:38  
 BRANCH FLOW (P)



FIGURE D-52B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out




FIGURE D-52D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out




FIGURE D-52A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out




FIGURE D-52C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out






FIGURE D-52F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-52H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)




FIGURE D-52E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:38  
 MACHINE POWER (MW)




FIGURE D-52G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES  
 FILE: D-52\_202L\_Cynthia\_178S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)








FIGURE D-52J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-52\_202L\_Cynthia\_178S.out  
 CHNL# 84: [VARS 88 TO 472 CKT '50']





WED, MAY 13 2020 23:39  
 BRANCH FLOW (Q)



FIGURE D-52I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT CYNTHIA 178S  
 CLEARED IN 7.5 CYCLES, FAR END IN 28.25 CYCLES

FILE: D-52\_202L\_Cynthia\_178S.out  
 CHNL# 83: [POWR 88 TO 472 CKT '50']



WED, MAY 13 2020 23:39  
 BRANCH FLOW (P)



FIGURE D-53B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out




FIGURE D-53D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out




FIGURE D-53A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out




FIGURE D-53C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out






FIGURE D-53F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 MACHINE POWER (MW)




FIGURE D-53H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)




FIGURE D-53E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 MACHINE POWER (MW)




FIGURE D-53G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)








FIGURE D-53J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 BRANCH FLOW (Q)




FIGURE D-53I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT BICKERDIKE 39S  
 CLEARED IN 6 CYCLES, FAR END IN 32.75 CYCLES  
 FILE: D-53\_745L\_Bickerdike\_39S.out

WED, MAY 13 2020 23:39  
 BRANCH FLOW (P)






FIGURE D-54B  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out




FIGURE D-54D  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out




FIGURE D-54A  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out




FIGURE D-54C  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out






FIGURE D-54F  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:39  
 MACHINE POWER (MW)




FIGURE D-54H  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)




FIGURE D-54E  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:39  
 MACHINE POWER (MW)




FIGURE D-54G  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

WED, MAY 13 2020 23:39  
 BUS VOLTAGE (PU)







FIGURE D-54J  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

CHNL# 69: [VARS 88 TO 472 CKT '50']  
 CHNL# 71: [VARS 88 TO 913 CKT '40']  
 CHNL# 63: [VARS 20 TO 88 CKT '71']  
 CHNL# 61: [VARS 20 TO 88 CKT '40']  
 CHNL# 75: [VARS 90 TO 135 CKT '74']  
 CHNL# 73: [VARS 90 TO 135 CKT '73']




WED, MAY 13 2020 23:39  
 BRANCH FLOW (Q)



FIGURE D-54I  
 2022SL, POST-PROJECT  
 3-PHASE FAULT AT COLD CREEK 602S  
 CLEARED IN 5.75 CYCLES, FAR END IN 27 CYCLES  
 FILE: D-54\_745L\_ColdCreek\_602S.out

CHNL# 68: [POWR 88 TO 472 CKT '50']  
 CHNL# 70: [POWR 88 TO 913 CKT '40']  
 CHNL# 62: [POWR 20 TO 88 CKT '71']  
 CHNL# 60: [POWR 20 TO 88 CKT '40']  
 CHNL# 74: [POWR 90 TO 135 CKT '74']  
 CHNL# 72: [POWR 90 TO 135 CKT '73']



WED, MAY 13 2020 23:39  
 BRANCH FLOW (P)


# Attachment A5

## Dynamic Data and Assumptions



# Attachment A6

## Post-Mitigation Power Flow Diagrams




2022SP POST-PROJECT (POST-RAS)  
 CATEGORY A  
 FIG A6-1  
 WED, JUN 24 2020 13:11

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 973L  
 FIG A6-2  
 WED, JUN 24 2020 13:12

**AESO**

- Bus - Voltage (kV/pu)
- Branch - MW/Mvar
- Equipment - MW/Mvar
- 100.0% Rate %


kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000












2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 671L  
 FIG A6-7  
 WED, JUN 24 2020 13:13

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 905L  
 FIG A6-9  
 WED, JUN 24 2020 13:13

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 909L  
 FIG A6-10  
 WED, JUN 24 2020 13:13

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 854L  
 FIG A6-11  
 WED, JUN 24 2020 13:14

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 685L  
 FIG A6-12  
 WED, JUN 24 2020 13:14

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 39ST2  
 FIG A6-14  
 WED, JUN 24 2020 13:14

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000



2022SP POST-PROJECT (POST-RAS)  
 CATEGORY B: 58ST1 OR 58ST2  
 FIG A6-15  
 WED, JUN 24 2020 13:15

**AESO**


Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000










2022WP POST-PROJECT (POST-RAS)  
 CATEGORY A  
 FIG A6-18  
 WED, JUN 24 2020 13:15

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 973L  
 FIG A6-19  
 WED, JUN 24 2020 13:16

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25,000<=69,000 <=138,000 <=240,000 <=500,000-500,000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 974L  
 FIG A6-20  
 WED, JUN 24 2020 13:16

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0%Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 890L  
 FIG A6-21  
 WED, JUN 24 2020 13:16

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000





2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 720L  
 FIG A6-23  
 WED, JUN 24 2020 13:17

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %


kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000












2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 909L  
 FIG A6-27  
 WED, JUN 24 2020 13:18

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 854L  
 FIG A6-28  
 WED, JUN 24 2020 13:18

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 TOU 0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 685L  
 FIG A6-29  
 WED, JUN 24 2020 13:19

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.00<=69.00 <=138.00 <=240.00 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 39ST1  
 FIG A6-30  
 WED, JUN 24 2020 13:19

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000




2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 39ST2  
 FIG A6-31  
 WED, JUN 24 2020 13:19

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000






2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 207ST1 OR 207ST2  
 FIG A6-33  
 WED, JUN 24 2020 13:20

**AESO**

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25,000 <=69,000 <=138,000 <=240,000 <=500,000-500,000





2022WP POST-PROJECT (POST-RAS)  
 CATEGORY B: 1012ST1  
 FIG A6-34  
 WED, JUN 24 2020 13:20

Bus - Voltage (kV/pu)  
 Branch - MW/Mvar  
 Equipment - MW/Mvar  
 100.0% Rate %

kV: <=25.000<=69.000 <=138.000 <=240.000 <=500.000-500.000

# Attachment A7

## Constraint Effective Factors Table

**Table M-1: Generator Types**

<b>Plant</b>	<i>Bear Creek 1</i>	<i>Bear Creek 2</i>	<i>Brazeau Hydro</i>	<i>Cascade</i>	<i>Daishowa</i>	<i>EATL</i>	<i>Edson Gas Plant</i>	<i>Genesee 3</i>	<i>Gold Creek Facility</i>	<i>Grande Prairie EcoPower</i>	<i>H.R. Milner</i>	<i>Keephills 3</i>	<i>Northern Prairie Power Project</i>	<i>Northstone Power</i>	<i>Poplar Hill #1</i>	<i>Sundance 4</i>	<i>Valley View 1</i>	<i>Valley View 2</i>	<i>WATL</i>	<i>Weldwood</i>	<i>Weyerhaeuser</i>
<b>Type</b>	<i>Cogen</i>	<i>Cogen</i>	<i>Hydro</i>	<i>Combined Cycle</i>	<i>Biomass/ Other</i>	<i>HVDC</i>	<i>Cogen</i>	<i>Coal</i>	<i>Biomass/ Other</i>	<i>Biomass/ Other</i>	<i>Gas</i>	<i>Coal</i>	<i>Gas</i>	<i>Gas</i>	<i>Gas</i>	<i>Coal</i>	<i>Gas</i>	<i>Gas</i>	<i>HVDC</i>	<i>Biomass/ Other</i>	<i>Biomass/ Other</i>

**Table M-2: 2022SP (Post-Project), Generators Effectiveness Factors under Normal Condition (N-0)**

		<b>Plant</b>																				
<b>Contingency</b>	<b>Line</b>	<i>Bear Creek 1</i>	<i>Bear Creek 2</i>	<i>Brazeau Hydro</i>	<i>Cascade</i>	<i>Daishowa</i>	<i>EATL</i>	<i>Edson Gas Plant</i>	<i>Genesee 3</i>	<i>Gold Creek Facility</i>	<i>Grande Prairie EcoPower</i>	<i>H.R. Milner</i>	<i>Keephills 3</i>	<i>Northern Prairie Power Project</i>	<i>Northstone Power</i>	<i>Poplar Hill #1</i>	<i>Sundance 4</i>	<i>Valley View 1</i>	<i>Valley View 2</i>	<i>WATL</i>	<i>Weldwood</i>	<i>Weyerhaeuser</i>
Base Case	202L (58S Edson - 178S Cynthia)	0.047	0.047	-0.083	0.102	-0.001	-0.011	0.175	0.012	0.047	0.047	0.045	0.011	0.047	0.048	0.047	0.034	0.045	0.045	0.012	0.133	0.047
Base Case	720L (347S Fox Creek - 397S Benbow)	-0.116	-0.116	0.011	0.077	0.000	0.004	0.097	-0.004	-0.116	-0.116	-0.112	-0.004	-0.114	-0.117	-0.115	0.000	-0.112	-0.112	-0.004	0.110	-0.116
Base Case	890L (58S Edson - 207S Pinedale)	0.009	0.009	-0.001	0.069	0.000	0.003	0.133	-0.002	0.009	0.009	0.008	-0.003	0.009	0.009	0.009	0.009	0.008	0.008	-0.002	0.096	0.009

**Table M-3: 2022SP (Post- Project), Generators Effectiveness Factors under Normal Condition (N-1)**

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.112	-0.001	-0.011	0.188	0.011	0.032	0.032	0.030	0.011	0.032	0.032	0.032	0.034	0.030	0.030	0.011	0.146	0.032
1012S Deer Hill T1	740L (58S Edson - 39S Bickerdike)	0.014	0.014	-0.046	0.108	0.000	-0.004	-0.375	0.005	0.014	0.014	0.013	0.004	0.014	0.014	0.014	0.025	0.013	0.013	0.005	0.146	0.014
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.007	0.001	0.073	0.000	0.003	0.137	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.008	-0.006	-0.006	-0.003	0.102	-0.007
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	-0.007	-0.007	0.001	0.079	0.000	0.003	0.147	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.009	-0.007	-0.007	-0.003	0.110	-0.007
1046L (310P Sundance (Plant) to 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	-0.125	-0.125	0.011	0.077	0.001	0.005	0.097	-0.006	-0.126	-0.125	-0.121	-0.005	-0.124	-0.127	-0.125	0.003	-0.121	-0.121	-0.005	0.110	-0.126
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	0.007	0.007	-0.001	0.069	0.000	0.003	0.134	-0.003	0.007	0.007	0.007	-0.003	0.007	0.007	0.007	0.009	0.007	0.007	-0.003	0.096	0.007
178S Cynthia T1	720L (347S Fox Creek - 397S Benbow)	-0.109	-0.109	0.001	0.088	0.000	0.003	0.115	-0.003	-0.110	-0.109	-0.106	-0.003	-0.108	-0.111	-0.109	0.005	-0.106	-0.106	-0.003	0.124	-0.110
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.018	0.018	-0.017	0.085	0.000	0.000	0.160	0.000	0.018	0.018	0.017	0.000	0.018	0.018	0.018	0.015	0.017	0.017	0.000	0.117	0.018
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	0.019	0.019	-0.019	0.091	0.000	0.000	0.171	0.000	0.019	0.019	0.018	0.000	0.019	0.019	0.019	0.016	0.018	0.018	0.000	0.125	0.019
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	0.010	0.010	-0.005	0.069	0.000	0.003	0.129	-0.003	0.010	0.010	0.010	-0.003	0.010	0.010	0.010	0.015	0.010	0.010	-0.003	0.094	0.010
202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	0.012	0.012	-0.004	0.078	0.000	0.002	0.148	-0.002	0.012	0.012	0.011	-0.002	0.012	0.012	0.012	0.011	0.011	0.011	-0.002	0.107	0.012

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
202L (58S Edson - 178S Cynthia)	720L (347S Fox Creek - 397S Benbow)	-0.109	-0.109	0.001	0.088	0.000	0.003	0.115	-0.003	-0.110	-0.109	-0.106	-0.003	-0.108	-0.111	-0.109	0.005	-0.106	-0.106	-0.003	0.124	-0.110
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.018	0.018	-0.018	0.085	0.000	0.000	0.160	0.000	0.018	0.018	0.017	0.000	0.018	0.018	0.018	0.015	0.017	0.017	0.000	0.117	0.018
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 744AL Tap)	0.017	0.017	-0.017	0.081	0.000	0.000	0.152	0.000	0.017	0.017	0.017	0.000	0.017	0.017	0.017	0.015	0.016	0.016	0.000	0.111	0.017
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	0.019	0.019	-0.019	0.092	0.000	0.000	0.171	0.000	0.019	0.019	0.019	0.000	0.019	0.020	0.019	0.017	0.018	0.018	0.000	0.125	0.019
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.118	-0.001	-0.011	0.205	0.011	0.049	0.049	0.047	0.011	0.049	0.050	0.049	0.037	0.047	0.047	0.011	0.156	0.049
207S Pinedale T1/T2	720L (347S Fox Creek - 397S Benbow)	-0.113	-0.114	0.010	0.085	0.000	0.005	0.111	-0.005	-0.114	-0.113	-0.110	-0.004	-0.112	-0.115	-0.113	0.002	-0.110	-0.110	-0.005	0.120	-0.114
320P Keephills T1	202L (58S Edson - 178S Cynthia)	0.050	0.050	-0.093	0.101	-0.002	-0.023	0.169	0.024	0.050	0.050	0.048	0.024	0.050	0.051	0.050	0.037	0.047	0.047	0.024	0.130	0.050
39S Bickerdike T1	39S Bickerdike T2	-0.060	-0.061	-0.068	0.237	0.000	-0.004	-0.552	0.004	-0.061	-0.060	-0.059	0.004	-0.059	-0.061	-0.060	0.041	-0.059	-0.060	0.005	-0.610	-0.061
39S Bickerdike T2	39S Bickerdike T1	-0.060	-0.061	-0.068	0.237	0.000	-0.004	-0.552	0.004	-0.061	-0.060	-0.059	0.004	-0.059	-0.061	-0.060	0.041	-0.059	-0.059	0.005	-0.610	-0.061
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	-0.103	-0.104	-0.002	0.100	0.000	0.003	0.000	-0.003	-0.104	-0.103	-0.100	-0.003	-0.102	-0.105	-0.103	0.007	-0.101	-0.101	-0.003	0.141	-0.104
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	0.047	0.047	-0.083	0.102	-0.001	-0.011	0.175	0.012	0.047	0.047	0.045	0.011	0.047	0.048	0.047	0.034	0.045	0.045	0.012	0.000	0.047
602S Cold Creek T1/T2	890L (58S Edson - 207S Pinedale)	0.009	0.009	-0.001	0.069	0.000	0.003	0.133	-0.002	0.009	0.009	0.008	-0.003	0.009	0.009	0.009	0.009	0.008	0.008	-0.002	0.000	0.009
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	0.006	0.006	0.017	0.074	0.001	0.006	0.145	-0.006	0.006	0.006	0.006	-0.007	0.006	0.006	0.006	0.007	0.006	0.006	-0.006	0.104	0.006
62S Brazeau T5	202L (58S Edson - 178S Cynthia)	0.019	0.019	0.000	0.068	0.000	0.003	0.126	-0.004	0.019	0.019	0.018	-0.004	0.018	0.019	0.019	0.015	0.018	0.018	-0.004	0.093	0.019

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
	Cynthia)																					
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	0.054	0.054	-0.081	0.166	-0.001	-0.008	-0.672	0.009	0.054	0.054	0.052	0.009	0.054	0.055	0.054	0.042	0.051	0.051	0.009	0.222	0.054
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	0.061	0.061	-0.104	0.109	-0.001	-0.015	0.181	0.015	0.062	0.061	0.059	0.015	0.061	0.063	0.062	0.043	0.058	0.058	0.015	0.140	0.062
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	0.061	0.061	-0.104	0.109	-0.001	-0.015	0.181	0.015	0.062	0.061	0.059	0.015	0.061	0.063	0.062	0.043	0.058	0.058	0.015	0.140	0.062
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.112	-0.001	-0.011	0.188	0.011	0.032	0.032	0.030	0.011	0.032	0.032	0.032	0.034	0.030	0.030	0.011	0.146	0.032
685L (397S Benbow - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	0.014	0.014	-0.046	0.108	0.000	-0.004	-0.375	0.005	0.014	0.014	0.013	0.004	0.014	0.014	0.014	0.025	0.013	0.013	0.005	0.146	0.014
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.007	0.001	0.073	0.000	0.003	0.138	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.008	-0.006	-0.006	-0.003	0.102	-0.007
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	-0.007	-0.007	0.001	0.079	0.000	0.003	0.147	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.009	-0.007	-0.007	-0.003	0.110	-0.007
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.112	-0.001	-0.011	0.188	0.011	0.032	0.032	0.030	0.011	0.032	0.032	0.032	0.034	0.030	0.030	0.011	0.146	0.032
720L (347S Fox Creek - 397S Benbow)	740L (58S Edson - 39S Bickerdike)	0.014	0.014	-0.046	0.108	0.000	-0.004	-0.375	0.005	0.014	0.014	0.013	0.004	0.014	0.014	0.014	0.025	0.013	0.013	0.005	0.146	0.014
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.007	0.001	0.074	0.000	0.003	0.138	-0.003	-0.007	-0.007	-0.006	-0.003	-0.007	-0.007	-0.007	0.008	-0.006	-0.006	-0.003	0.103	-0.007
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	-0.007	-0.007	0.001	0.079	0.000	0.003	0.147	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.009	-0.007	-0.007	-0.003	0.110	-0.007

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.118	-0.001	-0.011	0.205	0.011	0.049	0.049	0.047	0.011	0.049	0.050	0.049	0.036	0.047	0.047	0.011	0.155	0.049
744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.118	-0.001	-0.011	0.205	0.011	0.049	0.049	0.047	0.011	0.049	0.050	0.049	0.036	0.047	0.047	0.011	0.156	0.049
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	0.036	0.036	-0.082	0.104	-0.001	-0.011	0.178	0.011	0.037	0.036	0.035	0.011	0.037	0.037	0.037	0.034	0.034	0.034	0.012	0.136	0.037
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	0.000	0.000	0.000	0.071	0.000	0.003	0.136	-0.003	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.009	0.000	0.000	-0.003	0.099	0.000
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	0.036	0.036	-0.082	0.104	-0.001	-0.011	0.178	0.011	0.036	0.036	0.035	0.011	0.036	0.037	0.036	0.034	0.034	0.034	0.011	0.136	0.036
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	0.000	0.000	0.000	0.071	0.000	0.003	0.136	-0.003	0.000	0.000	0.000	-0.003	0.000	0.000	0.000	0.009	0.000	0.000	-0.003	0.099	0.000
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	0.043	0.043	-0.094	0.097	-0.001	-0.014	0.166	0.015	0.043	0.043	0.042	0.014	0.043	0.044	0.043	0.032	0.041	0.041	0.015	0.126	0.043
836L (61S Lodgepole - 283S Violet Grove)	202L (58S Edson - 178S Cynthia)	0.060	0.060	-0.142	0.101	-0.002	-0.023	0.163	0.024	0.060	0.060	0.058	0.024	0.060	0.062	0.061	0.043	0.057	0.057	0.024	0.128	0.060
836L (61S Lodgepole - 283S Violet Grove)	890L (58S Edson - 207S Pinedale)	0.003	0.003	0.024	0.069	0.001	0.008	0.138	-0.008	0.003	0.003	0.003	-0.008	0.003	0.003	0.003	0.005	0.003	0.003	-0.007	0.098	0.003

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.112	-0.001	-0.011	0.188	0.011	0.032	0.032	0.030	0.011	0.032	0.032	0.032	0.034	0.030	0.030	0.011	0.146	0.032
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	740L (58S Edson - 39S Bickerdike)	0.014	0.014	-0.046	0.108	0.000	-0.004	-0.375	0.005	0.014	0.014	0.013	0.004	0.014	0.014	0.014	0.025	0.013	0.013	0.005	0.146	0.014
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.007	0.001	0.073	0.000	0.003	0.137	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.008	-0.007	-0.007	-0.003	0.102	-0.007
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	-0.007	-0.007	0.001	0.079	0.000	0.003	0.147	-0.003	-0.007	-0.007	-0.007	-0.003	-0.007	-0.007	-0.007	0.009	-0.007	-0.007	-0.003	0.110	-0.007
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.118	-0.001	-0.011	0.205	0.011	0.049	0.049	0.047	0.011	0.049	0.050	0.049	0.036	0.047	0.047	0.011	0.156	0.049
890L (58S Edson - 207S Pinedale)	720L (347S Fox Creek - 397S Benbow)	-0.113	-0.114	0.010	0.085	0.000	0.005	0.111	-0.005	-0.114	-0.113	-0.110	-0.004	-0.112	-0.115	-0.113	0.002	-0.110	-0.110	-0.005	0.120	-0.114
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.051	0.051	-0.083	0.106	-0.001	-0.009	0.178	0.009	0.052	0.051	0.050	0.009	0.051	0.052	0.052	0.041	0.049	0.049	0.009	0.136	0.052
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	0.039	0.039	-0.048	0.103	0.000	-0.001	-0.386	0.001	0.039	0.039	0.037	0.001	0.039	0.039	0.039	0.035	0.037	0.037	0.001	0.135	0.039



		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.015	0.015	-0.001	0.069	0.001	0.007	0.129	-0.006	0.015	0.015	0.015	-0.006	0.015	0.015	0.015	0.019	0.015	0.015	-0.006	0.094	0.015
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	0.014	0.014	-0.001	0.066	0.001	0.006	0.122	-0.006	0.015	0.014	0.014	-0.006	0.014	0.015	0.014	0.018	0.014	0.014	-0.006	0.089	0.015
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	0.013	0.014	0.000	0.061	0.001	0.006	0.114	-0.006	0.014	0.013	0.013	-0.006	0.013	0.014	0.013	0.017	0.013	0.013	-0.006	0.083	0.014
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	0.016	0.016	-0.001	0.075	0.001	0.007	0.138	-0.007	0.016	0.016	0.016	-0.007	0.016	0.017	0.016	0.020	0.016	0.016	-0.007	0.101	0.016
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	909L (310P Sundance (Plant) - Dome)	0.243	0.244	0.041	0.235	0.014	0.136	0.200	-0.138	0.244	0.244	0.235	-0.138	0.243	0.249	0.245	0.305	0.232	0.232	-0.138	0.221	0.244
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	0.050	0.050	-0.082	0.105	-0.001	-0.010	0.178	0.010	0.050	0.050	0.048	0.010	0.050	0.051	0.050	0.038	0.047	0.047	0.010	0.136	0.050
905L (19S Wabamun Generation Station - 37S North Calder)	909L (310P Sundance (Plant) - Dome)	0.237	0.237	0.053	0.230	0.013	0.134	0.207	-0.135	0.238	0.237	0.229	-0.134	0.237	0.242	0.238	0.286	0.226	0.226	-0.135	0.221	0.238

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	0.054	0.054	-0.081	0.108	-0.001	-0.008	0.182	0.008	0.054	0.054	0.052	0.008	0.054	0.055	0.054	0.042	0.051	0.051	0.008	0.139	0.054
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.000	0.072	0.000	0.005	0.137	-0.004	0.012	0.012	0.012	-0.004	0.012	0.012	0.012	0.013	0.012	0.012	-0.004	0.099	0.012
909L (310P Sundance (Plant) - Dome)	902L (19S Wabamun Generation Station - 310P Sundance (Plant))	0.209	0.210	0.015	0.199	0.011	0.116	0.151	-0.117	0.210	0.209	0.202	-0.117	0.209	0.214	0.210	0.283	0.199	0.199	-0.117	0.179	0.210
913L (69S North Barrhead - 338S Cherhill)	720L (347S Fox Creek - 397S Benbow)	-0.125	-0.125	0.011	0.077	0.001	0.005	0.097	-0.006	-0.126	-0.125	-0.121	-0.005	-0.124	-0.127	-0.125	0.003	-0.121	-0.121	-0.005	0.110	-0.126
913L (69S North Barrhead - 338S Cherhill)	890L (58S Edson - 207S Pinedale)	0.007	0.007	-0.001	0.069	0.000	0.003	0.134	-0.003	0.007	0.007	0.007	-0.003	0.007	0.007	0.007	0.009	0.007	0.007	-0.003	0.096	0.007
919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	-0.137	-0.137	0.010	0.076	0.001	0.005	0.095	-0.005	-0.138	-0.137	-0.133	-0.005	-0.136	-0.139	-0.137	0.003	-0.133	-0.133	-0.005	0.108	-0.138
919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	0.005	0.005	-0.001	0.069	0.000	0.003	0.133	-0.003	0.005	0.005	0.005	-0.003	0.005	0.005	0.005	0.009	0.005	0.005	-0.003	0.096	0.005
922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	0.058	0.058	-0.082	0.111	-0.002	-0.016	0.183	0.017	0.058	0.058	0.056	0.017	0.058	0.059	0.058	0.045	0.055	0.055	0.017	0.142	0.058
922L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	0.011	0.011	-0.001	0.071	0.000	0.001	0.135	-0.001	0.011	0.011	0.011	-0.001	0.011	0.011	0.011	0.012	0.011	0.011	-0.001	0.098	0.011
926L (310P	202L (58S	0.058	0.058	-0.082	0.111	-0.002	-0.016	0.183	0.017	0.058	0.058	0.056	0.017	0.058	0.059	0.058	0.045	0.055	0.055	0.017	0.142	0.058

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
Sundance (Plant) - 17S Benalto)	Edson - 178S Cynthia)																					
926L (310P Sundance (Plant) - 17S Benalto)	890L (58S Edson - 207S Pinedale)	0.011	0.011	-0.001	0.071	0.000	0.001	0.135	-0.001	0.011	0.011	0.011	-0.001	0.011	0.011	0.011	0.012	0.011	0.011	-0.001	0.098	0.011
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.050	0.051	-0.078	0.143	-0.001	-0.011	0.211	0.011	0.051	0.051	0.049	0.011	0.050	0.052	0.051	0.032	0.048	0.048	0.011	0.170	0.051
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	-0.108	-0.108	0.015	0.121	0.001	0.005	0.133	-0.005	-0.108	-0.108	-0.105	-0.004	-0.107	-0.110	-0.108	-0.002	-0.105	-0.105	-0.005	0.149	-0.108
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	0.036	0.036	-0.043	0.142	0.000	-0.005	-0.352	0.005	0.036	0.036	0.035	0.005	0.036	0.036	0.036	0.022	0.034	0.034	0.005	0.171	0.036
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.011	0.011	0.003	0.098	0.000	0.003	0.154	-0.003	0.011	0.011	0.011	-0.003	0.011	0.011	0.011	0.006	0.011	0.011	-0.003	0.120	0.011
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	0.010	0.010	0.003	0.092	0.000	0.003	0.146	-0.002	0.011	0.010	0.010	-0.003	0.010	0.011	0.010	0.006	0.010	0.010	-0.002	0.113	0.011
973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	0.010	0.010	0.003	0.084	0.000	0.002	0.136	-0.002	0.010	0.010	0.009	-0.002	0.010	0.010	0.010	0.005	0.010	0.010	-0.002	0.105	0.010
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.004	0.106	0.000	0.003	0.166	-0.003	0.012	0.012	0.012	-0.003	0.012	0.012	0.012	0.007	0.012	0.012	-0.003	0.130	0.012
973L (39S Bickerdike	974L (39S Bickerdike -	0.052	0.053	0.060	0.608	0.000	0.003	0.495	-0.004	0.053	0.052	0.051	-0.004	0.051	0.053	0.052	-0.037	0.052	0.052	-0.004	0.547	0.053

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
- 310P Sundance (Plant))	310P Sundance (Plant))																					
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.050	0.051	-0.078	0.143	-0.001	-0.011	0.211	0.011	0.051	0.051	0.049	0.011	0.050	0.052	0.051	0.032	0.048	0.048	0.011	0.170	0.051
974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	-0.108	-0.108	0.015	0.120	0.001	0.005	0.133	-0.005	-0.108	-0.108	-0.105	-0.004	-0.107	-0.110	-0.108	-0.002	-0.105	-0.105	-0.005	0.149	-0.108
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	0.036	0.036	-0.043	0.142	0.000	-0.005	-0.352	0.005	0.036	0.036	0.035	0.005	0.036	0.036	0.036	0.022	0.034	0.034	0.005	0.171	0.036
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.011	0.011	0.003	0.097	0.000	0.003	0.154	-0.003	0.011	0.011	0.011	-0.003	0.011	0.011	0.011	0.006	0.011	0.011	-0.003	0.120	0.011
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	0.010	0.010	0.003	0.092	0.000	0.003	0.146	-0.002	0.010	0.010	0.010	-0.003	0.010	0.011	0.010	0.006	0.010	0.010	-0.002	0.113	0.010
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	0.010	0.010	0.003	0.084	0.000	0.002	0.136	-0.002	0.010	0.010	0.009	-0.002	0.010	0.010	0.010	0.005	0.010	0.010	-0.002	0.105	0.010
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.004	0.106	0.000	0.003	0.166	-0.003	0.012	0.012	0.012	-0.003	0.012	0.012	0.012	0.007	0.012	0.012	-0.003	0.130	0.012
974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	0.052	0.053	0.060	0.608	0.000	0.003	0.495	-0.004	0.053	0.052	0.051	-0.004	0.051	0.053	0.052	-0.037	0.052	0.052	-0.004	0.547	0.053
989L (310P Sundance (Plant)) -	720L (347S Fox Creek - 397S Benbow)	-0.135	-0.136	0.010	0.076	0.001	0.005	0.095	-0.005	-0.136	-0.136	-0.131	-0.005	-0.134	-0.138	-0.135	0.002	-0.131	-0.131	-0.005	0.108	-0.136

		Plant																				
Contingency	Line	<i>Bear Creek 1</i>	<i>Bear Creek 2</i>	<i>Brazeau Hydro</i>	<i>Cascade</i>	<i>Daishowa</i>	<i>EATL</i>	<i>Edson Gas Plant</i>	<i>Genesee 3</i>	<i>Gold Creek Facility</i>	<i>Grande Prairie EcoPower</i>	<i>H.R. Milner</i>	<i>Keephills 3</i>	<i>Northern Prairie Power Project</i>	<i>Northstone Power</i>	<i>Poplar Hill #1</i>	<i>Sundance 4</i>	<i>Valley View 1</i>	<i>Valley View 2</i>	<i>WATL</i>	<i>Weldwood</i>	<i>Weyerhaeuser</i>
77S Sagitawah)																						
989L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	0.005	0.005	-0.001	0.069	0.000	0.003	0.133	-0.003	0.005	0.005	0.005	-0.003	0.005	0.005	0.005	0.009	0.005	0.005	-0.003	0.096	0.005

**Table M-4: 2022WP (Post- Project), Generators Effectiveness Factors under Normal Condition (N-1)**

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
1012S Deer Hill T1	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.108	-0.001	0.011	0.183	0.011	0.000	0.032	0.031	0.011	0.033	0.000	0.033	0.034	0.030	0.030	0.011	0.143	0.032
1012S Deer Hill T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.008	0.001	0.072	0.000	-0.002	0.135	-0.003	0.000	-0.008	-0.007	-0.003	-0.008	0.000	-0.008	0.008	-0.007	-0.007	-0.002	0.101	-0.008
1012S Deer Hill T1	890L (58S Edson - 207S Pinedale)	-0.008	-0.008	0.001	0.077	0.000	-0.002	0.144	-0.003	0.000	-0.008	-0.008	-0.003	-0.008	0.000	-0.008	0.009	-0.008	-0.008	-0.003	0.108	-0.008
1046L (310P Sundance (Plant) to 338S Cherhill)	202L (58S Edson - 178S Cynthia)	0.047	0.047	-0.083	0.099	-0.001	0.011	0.170	0.011	0.000	0.048	0.045	0.011	0.049	0.000	0.049	0.034	0.044	0.044	0.011	0.130	0.047
1046L (310P Sundance (Plant) to 338S Cherhill)	890L (58S Edson - 207S Pinedale)	0.007	0.007	-0.001	0.068	0.000	-0.002	0.131	-0.002	0.000	0.007	0.007	-0.002	0.007	0.000	0.007	0.009	0.007	0.007	-0.002	0.095	0.007
178S Cynthia T1	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.017	0.018	-0.018	0.083	0.000	0.001	0.156	0.000	0.000	0.018	0.017	0.000	0.018	0.000	0.018	0.015	0.017	0.017	0.000	0.115	0.018
178S Cynthia T1	890L (58S Edson - 207S Pinedale)	0.019	0.019	-0.019	0.089	0.000	0.001	0.167	0.000	0.000	0.019	0.018	0.000	0.019	0.000	0.019	0.016	0.018	0.018	0.000	0.123	0.019
19S Wabamun T10	890L (58S Edson - 207S Pinedale)	0.010	0.010	-0.005	0.068	0.000	-0.002	0.127	-0.003	0.000	0.010	0.009	-0.003	0.010	0.000	0.010	0.015	0.009	0.009	-0.003	0.093	0.010
202L (178S Cynthia - 359S Esso West Pembina - 61S Lodgepole)	890L (58S Edson - 207S Pinedale)	0.011	0.011	-0.005	0.076	0.000	-0.001	0.146	-0.002	0.000	0.011	0.011	-0.002	0.012	0.000	0.012	0.011	0.011	0.011	-0.002	0.106	0.011
202L (58S Edson - 178S Cynthia)	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.018	0.018	-0.018	0.083	0.000	0.001	0.156	0.000	0.000	0.018	0.017	0.000	0.018	0.000	0.018	0.015	0.017	0.017	0.001	0.115	0.018
202L (58S Edson - 178S Cynthia)	890L (58S Edson - 207S Pinedale)	0.019	0.019	-0.020	0.089	0.000	0.001	0.167	0.000	0.000	0.019	0.018	0.000	0.019	0.000	0.019	0.016	0.018	0.018	0.001	0.123	0.019

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
207S Pinedale T1/T2	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.115	-0.001	0.011	0.200	0.011	0.000	0.049	0.047	0.011	0.051	0.000	0.051	0.036	0.046	0.046	0.011	0.152	0.049
320P Keephills T1	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.094	0.097	-0.002	0.021	0.164	0.022	0.000	0.049	0.047	0.022	0.051	0.000	0.051	0.035	0.046	0.046	0.023	0.126	0.049
39S Bickerdike T1	39S Bickerdike T2	-0.063	-0.064	-0.069	0.231	0.000	0.006	-0.559	0.005	0.000	-0.064	-0.061	0.005	-0.064	0.000	-0.065	0.041	-0.061	-0.061	0.005	-0.616	-0.064
39S Bickerdike T2	39S Bickerdike T1	-0.063	-0.064	-0.069	0.231	0.000	0.006	-0.559	0.005	0.000	-0.064	-0.061	0.005	-0.064	0.000	-0.065	0.041	-0.061	-0.061	0.005	-0.616	-0.064
58S Edson T1/T2	720L (347S Fox Creek - 397S Benbow)	-0.106	-0.106	-0.002	0.098	0.000	-0.002	0.000	-0.002	0.000	-0.107	-0.102	-0.002	-0.108	0.000	-0.108	0.007	-0.101	-0.101	-0.002	0.139	-0.106
602S Cold Creek T1/T2	202L (58S Edson - 178S Cynthia)	0.047	0.047	-0.083	0.099	-0.001	0.011	0.170	0.011	0.000	0.048	0.045	0.011	0.049	0.000	0.049	0.033	0.044	0.044	0.011	0.000	0.047
61S Lodgepole T1/T2	890L (58S Edson - 207S Pinedale)	0.005	0.005	0.017	0.072	0.001	-0.005	0.142	-0.006	0.000	0.005	0.005	-0.006	0.005	0.000	0.005	0.007	0.005	0.005	-0.006	0.103	0.005
671L (58S Edson - 39S Bickerdike)	740L (58S Edson - 39S Bickerdike)	0.053	0.054	-0.082	0.162	-0.001	0.009	-0.678	0.009	0.000	0.054	0.051	0.009	0.055	0.000	0.055	0.041	0.050	0.050	0.009	0.218	0.054
672L (235S Entwistle - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	0.062	0.062	-0.104	0.106	-0.001	0.014	0.176	0.014	0.000	0.063	0.060	0.014	0.064	0.000	0.065	0.042	0.058	0.058	0.015	0.137	0.062
673L (283S Violet Grove - 131S Moon Lake)	202L (58S Edson - 178S Cynthia)	0.062	0.062	-0.104	0.106	-0.001	0.014	0.176	0.014	0.000	0.063	0.060	0.014	0.064	0.000	0.064	0.042	0.058	0.058	0.015	0.137	0.062
685L (397S Benbow - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.108	-0.001	0.011	0.183	0.011	0.000	0.032	0.031	0.011	0.033	0.000	0.033	0.034	0.030	0.030	0.011	0.143	0.032
685L (397S Benbow - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.008	0.001	0.072	0.000	-0.002	0.135	-0.003	0.000	-0.008	-0.007	-0.003	-0.008	0.000	-0.008	0.008	-0.007	-0.007	-0.002	0.101	-0.008
685L (397S Benbow - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	-0.008	-0.008	0.001	0.077	0.000	-0.002	0.144	-0.003	0.000	-0.008	-0.008	-0.003	-0.008	0.000	-0.008	0.009	-0.008	-0.008	-0.003	0.108	-0.008

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
720L (347S Fox Creek - 397S Benbow)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.108	-0.001	0.011	0.183	0.011	0.000	0.032	0.030	0.011	0.033	0.000	0.033	0.034	0.030	0.030	0.011	0.143	0.032
720L (347S Fox Creek - 397S Benbow)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.007	-0.007	0.001	0.072	0.000	-0.002	0.135	-0.003	0.000	-0.008	-0.007	-0.003	-0.008	0.000	-0.008	0.008	-0.007	-0.007	-0.002	0.101	-0.007
720L (347S Fox Creek - 397S Benbow)	890L (58S Edson - 207S Pinedale)	-0.008	-0.008	0.001	0.077	0.000	-0.002	0.144	-0.003	0.000	-0.008	-0.008	-0.003	-0.008	0.000	-0.008	0.009	-0.008	-0.008	-0.003	0.109	-0.008
744L (228S T.M.P.L. Niton - 106S Paddle River - 235S Entwistle)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.114	-0.001	0.011	0.200	0.011	0.000	0.049	0.047	0.011	0.050	0.000	0.051	0.036	0.046	0.046	0.011	0.152	0.049
744L (228S T.M.P.L. Niton - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.114	-0.001	0.011	0.200	0.011	0.000	0.049	0.047	0.011	0.050	0.000	0.051	0.036	0.046	0.046	0.011	0.152	0.049
7L199/199L (347S Fox Creek - 741S Fox Creek)	202L (58S Edson - 178S Cynthia)	0.037	0.037	-0.083	0.101	-0.001	0.011	0.174	0.011	0.000	0.037	0.035	0.011	0.038	0.000	0.038	0.034	0.034	0.034	0.011	0.134	0.037
7L199/199L (347S Fox Creek - 741S Fox Creek)	890L (58S Edson - 207S Pinedale)	-0.001	-0.001	-0.001	0.070	0.000	-0.002	0.134	-0.002	0.000	-0.001	-0.001	-0.002	-0.001	0.000	-0.001	0.009	-0.001	-0.001	-0.002	0.098	-0.001
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	202L (58S Edson - 178S Cynthia)	0.036	0.036	-0.082	0.101	-0.001	0.011	0.174	0.011	0.000	0.037	0.035	0.011	0.038	0.000	0.038	0.034	0.034	0.034	0.011	0.134	0.036
7L90 (347S Fox Creek - 2018S Muir - 813S Little Smoky)	890L (58S Edson - 207S Pinedale)	0.000	0.000	-0.001	0.070	0.000	-0.002	0.134	-0.002	0.000	0.000	0.000	-0.002	0.000	0.000	0.000	0.009	0.000	0.000	-0.002	0.098	0.000



		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
834L (384S Keystone - 320P Keephills)	202L (58S Edson - 178S Cynthia)	0.043	0.043	-0.094	0.094	-0.001	0.013	0.162	0.014	0.000	0.044	0.042	0.014	0.045	0.000	0.045	0.031	0.041	0.041	0.014	0.123	0.043
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	202L (58S Edson - 178S Cynthia)	0.032	0.032	-0.081	0.108	-0.001	0.011	0.183	0.011	0.000	0.032	0.031	0.011	0.033	0.000	0.033	0.034	0.030	0.030	0.011	0.143	0.032
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	744L (228S T.M.P.L. Niton - 207S Pinedale)	-0.008	-0.008	0.001	0.072	0.000	-0.002	0.135	-0.003	0.000	-0.008	-0.007	-0.003	-0.008	0.000	-0.008	0.008	-0.007	-0.007	-0.002	0.101	-0.008
854L (39S Bickerdike - 348S Marlboro - 1012S Deer Hill)	890L (58S Edson - 207S Pinedale)	-0.008	-0.008	0.001	0.077	0.000	-0.002	0.144	-0.003	0.000	-0.008	-0.008	-0.003	-0.008	0.000	-0.008	0.009	-0.008	-0.008	-0.003	0.108	-0.008
890L (58S Edson - 207S Pinedale)	202L (58S Edson - 178S Cynthia)	0.049	0.049	-0.083	0.115	-0.001	0.011	0.199	0.011	0.000	0.049	0.047	0.011	0.050	0.000	0.051	0.036	0.046	0.046	0.011	0.152	0.049
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.052	0.052	-0.083	0.103	-0.001	0.009	0.174	0.009	0.000	0.052	0.050	0.009	0.053	0.000	0.054	0.040	0.049	0.049	0.009	0.134	0.052
902L (19S Wabamun Generation Station - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.015	0.015	-0.001	0.069	0.001	-0.006	0.127	-0.006	0.000	0.015	0.015	-0.006	0.015	0.000	0.016	0.019	0.014	0.014	-0.006	0.094	0.015
902L (19S Wabamun Generation Station - 310P Sundance)	890L (58S Edson - 207S Pinedale)	0.016	0.016	-0.001	0.074	0.001	-0.006	0.136	-0.006	0.000	0.016	0.016	-0.006	0.017	0.000	0.017	0.020	0.015	0.015	-0.006	0.100	0.016

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
(Plant))																						
905L (19S Wabamun Generation Station - 37S North Calder)	202L (58S Edson - 178S Cynthia)	0.050	0.050	-0.082	0.102	-0.001	0.010	0.173	0.010	0.000	0.051	0.048	0.010	0.052	0.000	0.052	0.037	0.047	0.047	0.010	0.133	0.050
909L (310P Sundance (Plant) - Dome)	202L (58S Edson - 178S Cynthia)	0.054	0.054	-0.082	0.105	-0.001	0.008	0.177	0.008	0.000	0.055	0.052	0.008	0.056	0.000	0.056	0.041	0.051	0.051	0.008	0.137	0.054
909L (310P Sundance (Plant) - Dome)	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.000	0.071	0.000	-0.004	0.134	-0.004	0.000	0.012	0.011	-0.004	0.012	0.000	0.012	0.013	0.011	0.011	-0.004	0.098	0.012
919L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	-0.141	-0.142	0.010	0.074	0.001	-0.004	0.093	-0.005	0.000	-0.143	-0.136	-0.005	-0.145	0.000	-0.145	0.003	-0.135	-0.135	-0.005	0.106	-0.142
919L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	0.004	0.004	-0.001	0.068	0.000	-0.002	0.131	-0.002	0.000	0.004	0.004	-0.002	0.004	0.000	0.004	0.009	0.004	0.004	-0.002	0.095	0.004
922L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	0.058	0.059	-0.082	0.108	-0.002	0.016	0.179	0.017	0.000	0.059	0.056	0.016	0.060	0.000	0.061	0.044	0.055	0.055	0.017	0.139	0.059
926L (310P Sundance (Plant) - 17S Benalto)	202L (58S Edson - 178S Cynthia)	0.058	0.059	-0.082	0.108	-0.002	0.016	0.179	0.017	0.000	0.059	0.056	0.016	0.060	0.000	0.061	0.044	0.055	0.055	0.017	0.139	0.059
973L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.051	0.051	-0.078	0.139	-0.001	0.011	0.205	0.011	0.000	0.051	0.049	0.011	0.052	0.000	0.053	0.031	0.048	0.048	0.011	0.167	0.051
973L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	-0.110	-0.110	0.015	0.118	0.001	-0.003	0.131	-0.004	0.000	-0.111	-0.106	-0.004	-0.112	0.000	-0.113	-0.002	-0.105	-0.105	-0.004	0.148	-0.110

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
973L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	0.036	0.036	-0.043	0.138	0.000	0.005	-0.355	0.005	0.000	0.036	0.034	0.005	0.037	0.000	0.037	0.022	0.034	0.034	0.005	0.169	0.036
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 207S Pinedale)	0.011	0.011	0.003	0.096	0.000	-0.002	0.152	-0.002	0.000	0.011	0.010	-0.002	0.011	0.000	0.011	0.006	0.010	0.010	-0.002	0.119	0.011
973L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	0.010	0.010	0.003	0.091	0.000	-0.002	0.144	-0.002	0.000	0.010	0.010	-0.002	0.010	0.000	0.010	0.006	0.010	0.010	-0.002	0.113	0.010
973L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	0.010	0.010	0.003	0.084	0.000	-0.002	0.134	-0.002	0.000	0.010	0.009	-0.002	0.010	0.000	0.010	0.005	0.009	0.009	-0.002	0.105	0.010
973L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.003	0.104	0.000	-0.002	0.163	-0.002	0.000	0.012	0.011	-0.003	0.012	0.000	0.012	0.007	0.011	0.011	-0.002	0.128	0.012
973L (39S Bickerdike - 310P Sundance (Plant))	974L (39S Bickerdike - 310P Sundance (Plant))	0.055	0.055	0.061	0.616	0.000	-0.005	0.504	-0.004	0.000	0.055	0.053	-0.004	0.056	0.000	0.056	-0.036	0.053	0.053	-0.004	0.556	0.055
974L (39S Bickerdike - 310P Sundance (Plant))	202L (58S Edson - 178S Cynthia)	0.051	0.051	-0.078	0.139	-0.001	0.011	0.205	0.011	0.000	0.051	0.049	0.011	0.052	0.000	0.053	0.031	0.048	0.048	0.011	0.167	0.051
974L (39S Bickerdike - 310P Sundance (Plant))	720L (347S Fox Creek - 397S Benbow)	-0.110	-0.110	0.015	0.118	0.001	-0.003	0.131	-0.004	0.000	-0.111	-0.106	-0.004	-0.112	0.000	-0.113	-0.002	-0.105	-0.105	-0.004	0.148	-0.110
974L (39S Bickerdike - 310P Sundance (Plant))	740L (58S Edson - 39S Bickerdike)	0.036	0.036	-0.043	0.138	0.000	0.005	-0.355	0.005	0.000	0.036	0.034	0.005	0.037	0.000	0.037	0.022	0.034	0.034	0.005	0.169	0.036
974L (39S	744L (228S	0.011	0.011	0.003	0.096	0.000	-0.002	0.152	-0.002	0.000	0.011	0.010	-0.002	0.011	0.000	0.011	0.006	0.010	0.010	-0.002	0.119	0.011

		Plant																				
Contingency	Line	Bear Creek 1	Bear Creek 2	Brazeau Hydro	Cascade	Daishowa	EATL	Edson Gas Plant	Genesee 3	Gold Creek Facility	Grande Prairie EcoPower	H.R. Milner	Keephills 3	Northern Prairie Power Project	Northstone Power	Poplar Hill #1	Sundance 4	Valley View 1	Valley View 2	WATL	Weldwood	Weyerhaeuser
Bickerdike - 310P Sundance (Plant))	T.M.P.L. Niton - 207S Pinedale)																					
974L (39S Bickerdike - 310P Sundance (Plant))	744L (228S T.M.P.L. Niton - 744AL Tap)	0.010	0.010	0.003	0.090	0.000	-0.002	0.144	-0.002	0.000	0.010	0.010	-0.002	0.010	0.000	0.010	0.006	0.010	0.010	-0.002	0.113	0.010
974L (39S Bickerdike - 310P Sundance (Plant))	744L (235S Entwistle - 744AL Tap)	0.010	0.010	0.003	0.084	0.000	-0.002	0.134	-0.002	0.000	0.010	0.009	-0.002	0.010	0.000	0.010	0.005	0.009	0.009	-0.002	0.105	0.010
974L (39S Bickerdike - 310P Sundance (Plant))	890L (58S Edson - 207S Pinedale)	0.012	0.012	0.003	0.104	0.000	-0.002	0.163	-0.002	0.000	0.012	0.011	-0.003	0.012	0.000	0.012	0.007	0.011	0.011	-0.002	0.128	0.012
974L (39S Bickerdike - 310P Sundance (Plant))	973L (39S Bickerdike - 310P Sundance (Plant))	0.055	0.055	0.061	0.616	0.000	-0.005	0.504	-0.004	0.000	0.055	0.053	-0.004	0.056	0.000	0.056	-0.036	0.053	0.053	-0.005	0.556	0.055
989L (310P Sundance (Plant) - 77S Sagitawah)	720L (347S Fox Creek - 397S Benbow)	-0.139	-0.140	0.010	0.074	0.001	-0.004	0.093	-0.005	0.000	-0.141	-0.135	-0.004	-0.143	0.000	-0.144	0.003	-0.133	-0.133	-0.005	0.107	-0.140
989L (310P Sundance (Plant) - 77S Sagitawah)	890L (58S Edson - 207S Pinedale)	0.004	0.004	-0.001	0.068	0.000	-0.002	0.131	-0.002	0.000	0.004	0.004	-0.002	0.004	0.000	0.005	0.009	0.004	0.004	-0.002	0.095	0.004