

Need for the Carmon Creek Co-generation Connection in the Peace River Area Transmission Development Information for Stakeholders

Why is this transmission development needed?

Shell Canada Ltd. (Shell) has requested transmission system access for its proposed Carmon Creek Co-generation Facility (Facility) in the Peace River area. Shell's request can be addressed by modifying the existing Wesley Creek 834S substation and developing two new 240 kV transmission circuits to connect the Facility to the Wesley Creek 834S substation.

The Alberta Electric System Operator (AESO) is processing Shell's request, including providing information to landowners, occupants, residents and agencies in the Peace River area that may be near the proposed transmission development. The AESO intends to apply to the Alberta Utilities Commission (AUC) for approval of this need in the summer of 2014. The AESO's needs identification document (NID) application will be available on the AESO's website at www.aeso.ca/transmission/8969.html at the time of its application to the AUC.

Who is the AESO?

Alberta's transmission system, sometimes referred to as the Alberta Interconnected Electric System (AIES), is planned and operated by the AESO. The transmission system comprises the high-voltage lines, towers and equipment (generally 69 kV and above) that transmit electricity from generators to lower voltage systems that distribute electricity to cities, towns, rural areas and large industrial customers.

The AESO's role is to maintain safe, reliable and economic operation of the AIES. The AESO's planning responsibility includes determining the need for transmission system development and the manner in which that need is met. The AESO is also mandated to facilitate the interconnection of qualified market participants to the AIES. The AESO is regulated by the AUC and must apply to the AUC for approval of its NID.

How is ATCO Electric Ltd. (ATCO) involved?

ATCO is the transmission facilities owner (TFO) in the Peace River area. While the AESO is responsible for identifying that transmission system development is needed, ATCO is responsible for detailed siting and routing, constructing, operating and maintaining the associated transmission facilities. The AESO has directed ATCO to provide information to stakeholders on this need and to file a facility proposal application with the AUC which will include a detailed description and location of the proposed transmission development.

Further Information

The AESO appreciates your views on the need for transmission system development and your comments are encouraged. If you have any questions or suggestions regarding the need for the proposed transmission connection in the Peace River area or the AESO's application regarding this need, please contact:

Karlene Hartnett
AESO Stakeholder Relations
1-888-866-2959
stakeholder.relations@aeso.ca
2500, 330 – 5th Avenue SW
Calgary, Alberta T2P 0L4

The AESO is committed to protecting your personal privacy in accordance with Alberta's Personal Information Protection Act. Any personal information collected by the AESO with regard to this project may be used to provide you with further information about the project, may be disclosed to the Alberta Utilities Commission (and as a result, may become public), and may also be disclosed to ATCO as the legal owner of transmission facilities in your area. If you have any questions about how the AESO will use and disclose your personal information, please contact us at 1-888-866-2959 or at stakeholder.relations@aeso.ca