

ISO Rules

Part 500 Facilities

Division 505 Legal Owners of Generating Facilities

Section 505.4 Coordinating Operational Testing



Applicability

- 1 Section 505.4 applies to:
 - (a) the **legal owner** of a **generating unit**:
 - (i) with a rating greater than five (5) MW;
 - (ii) connected to **transmission facilities** or to an **electric distribution system**, in the **balancing authority area** of the **ISO**;
 - (iii) that is already in **commercial operation**; and
 - (iv) for which the **legal owner** intends to conduct operational testing activities;
 - (b) the **legal owner** of an **aggregated generating unit**:
 - (i) with a rating greater than five (5) MW;
 - (ii) connected to **transmission facilities** or to an **electric distribution system**, in the **balancing authority area** of the **ISO**:
 - (i) that is already in **commercial operation**; and
 - (ii) for which the **legal owner** intends to conduct operational testing activities; and
 - (c) the **ISO**.

Requirements

Plans for Operational Testing

- 2 Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** must provide final, written operational testing plans to the **ISO**:
 - (a) which the **ISO** approves as being able to be implemented without impacting the reliable operation of the **interconnected electric system**;
 - (b) detailing the proposed date and time of operational testing and expected duration;
 - (c) specifying the types of operational testing activities;
 - (d) detailing the expected output of **real power** and **reactive power** from the generating facility to the **interconnected electric system** and over what periods of time; and
 - (e) in sufficient time to allow the **ISO** to approve the operational testing plans a minimum of fifteen (15) **days** prior to the desired testing date.

Conducting Operational Testing Activities

3(1) Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** must not conduct operational testing activities on the generating facility until obtaining written confirmation from the **ISO** that the **legal owner's** final operational testing plan, required under subsection 2, is approved.

(2) Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** must, on the **day** of and no less than one (1) hour prior to conducting operational testing activities

ISO Rules

Part 500 Facilities

Division 505 Legal Owners of Generating Facilities

Section 505.4 Coordinating Operational Testing



on any generating facilities, phone the **ISO** and obtain verbal authorization from the **ISO** to conduct the activities.

(3) After receiving authorization to conduct operational testing activities on a facility, the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** may conduct the activities.

(4) Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** who desires to perform operational testing required in order to recover from an unexpected operational problem must:

- (a) contact the **ISO** by phone to request approval for the operational testing;
- (b) provide a description of the operational testing, including the expected output of **real power** and **reactive power** from the generating facility to the **interconnected electric system** and over what periods of time;
- (c) not initiate the operational testing until obtaining verbal approval from the **ISO**; and
- (d) phone the **ISO** to advise when the operational testing is complete.

Changes to Approved Testing Activities

4(1) The **ISO** may amend or suspend any operational testing activities it has already approved, based on real time **reliability** requirements of the **interconnected electric system** and necessary **ISO** operational flexibility, and it may do so by providing written or verbal notice to the **legal owner** of the generating facility.

(2) Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** may suspend its operational testing activities by giving verbal notice to the **ISO**.

(3) Each of the **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** may amend its operational testing activities by making a verbal request to the **ISO** and obtaining verbal approval from the **ISO**.

(4) A **legal owner** of a **generating unit** and the **legal owner** of an **aggregated generating facility** that has amended or suspended any previously approved operational testing activities must, if the **ISO** requests, submit a revised written operational testing plan and must do so within the timeframe the **ISO** specifies in order to proceed with the operational testing activities.

Revision History

Effective	Description
2012-12-31	Initial Release