

Settlement: 2009 Inter-Ties Loss Factors

BC Tie

Transaction Type	Loss Factor (%)	Average Loss Charge (%)	Settlement LF (%)
Import	-0.62%	0.99%	0.36%
Export	0	1.05%	1.05%

SK Tie

Transaction Type	Loss Factor (%)	Average Loss Charge (%)	Settlement LF (%)
Import	1.35%	2.50%	3.85%
Export	-	2.30%	2.30%

Notes:

- | |
|---|
| <ol style="list-style-type: none"> 1. As per the 2007 Transmission Regulation, the inter-tie losses will be included in the overall loss factor calculation 2. The losses are calculated based on the historic flows on the BC 138 kV and 500 kV inter-tie 3. The losses on the Saskatchewan inter-tie are based on the converter station at McNeill 4. For inter-tie loss details, please refer to the work provided on the AESO web site:
http://www.aeso.ca/downloads/Tie_Loss_New_T-Reg_20070927.pdf 5. Values may not add due to rounding. |
|---|

October 22, 2008