

Alberta Reliability Standard

Notifications and Information Exchange Between Reliability Coordinators

IRO-015-AB-1



1. Purpose

To ensure that the **ISO**'s operations are coordinated such that it will not have an **adverse reliability impact** on adjacent **reliability coordinator areas** and to preserve the reliability benefits of interconnected operations.

2. Applicability

This **reliability standard** applies to:

(a) the **ISO**.

3. Requirements

R1 The **ISO** must follow its operating procedures, operating processes or operating plans for making notifications and exchanging reliability-related information with adjacent **reliability coordinators**.

R1.1 The **ISO** must make notifications to adjacent **reliability coordinators** of conditions in its area that may have an **adverse reliability impact** on adjacent **reliability coordinator areas**.

R2 The **ISO** must participate in agreed upon conference calls and other communication forums with synchronously connected adjacent **reliability coordinators**.

R2.1 The frequency of these conference calls must be agreed upon by the **ISO** and all involved **reliability coordinators** and must be at least weekly.

R3 Intentionally left blank.

4. Measures

The following measures correspond to the requirements identified in section 3 of this reliability standard. For example, MR1 is the measure for requirement R1.

MR1 The **ISO** may have evidence that it has followed its operating procedures, operating processes or operating plans for notifying adjacent **reliability coordinators** of conditions in its area that may adversely impact adjacent **reliability coordinator areas** in accordance with requirement R1. Such evidence may include, but is not limited to, operator logs or other data sources.

MR2 The **ISO** may have evidence that it participated in agreed upon (at least weekly) conference calls and other communication forums with synchronously connected **reliability coordinators** in accordance with requirement R2. Such evidence may include, but is not limited to, operator logs or other data sources.

MR3 Intentionally left blank.

Revision History

Effective Date	Description
2015-04-01	Initial release.