

# ISO Rules

## Part 200 Markets

### Division 205 Ancillary Services

#### Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



#### Applicability

- 1 Section 205.5 applies to:
  - (a) a **pool participant**; and
  - (b) the **ISO**,

in relation to qualifying for, providing and utilizing **spinning reserve**.

#### Requirements

##### General

- 2 A **pool participant** that provides or anticipates providing **spinning reserve** must satisfy the technical requirements set out in this section 205.5 and must continue to satisfy such technical requirements while providing **spinning reserve**.

##### Minimum Requirements

- 3(1) A **pool participant** must ensure that each **generating unit** or load is capable of providing a minimum of ten (10) MW of **spinning reserve**.

- 3(2) A **pool participant** must ensure that each **generating unit** or load is capable of providing the amount of **real power** the **ISO** qualifies the **generating unit** or load to provide under subsection 4(1) for the period from ten (10) minutes after receiving a **directive** to provide **spinning reserve** to sixty (60) minutes after receiving a **directive** to provide **spinning reserve**.

- 3(3) A **pool participant** must ensure that each **generating unit** or load is equipped with a **governor system** that:

- (a) is responsive to both over frequency and under frequency events;
- (b) has a total deadband of equal to or less than zero point zero three six (0.036) Hertz;
- (c) has a droop setting equal to or greater than three percent (3%) but less than or equal to five percent (5%) based on:
  - (i) the maximum operating range of each **generating unit** providing **spinning reserve**; or
  - (ii) the total **real power** capacity of each load providing **spinning reserve**;
- (d) has no intentional time delays added to the control system;
- (e) has a sample rate of at least thirty (30) samples per second;
- (f) has a resolution of at least zero point zero zero four (0.004) Hertz; and
- (g) while the **pool asset** is under a **dispatch** or **directive** to provide **spinning reserve** is:
  - (i) in service at all times; and
  - (ii) without load limiters or other control systems that override or interfere with the **governor system**; and
  - (iii) for **pool assets** providing both **spinning reserve** and **regulating reserve**, the **automatic generator control** signal must not override the frequency response of the **governor system**.

- 3(4) A **pool participant** must ensure that any **pool asset** providing **spinning reserve** complies with subsections 3(1), (2) and (3) as measured at the:

# ISO Rules

## Part 200 Markets

### Division 205 Ancillary Services

#### Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



- (a) stator winding terminals of each qualified **generating unit**; or
- (b) the circuit breaker or disconnection device that is electrically closest to each qualified load.

**(5)** The requirements set out in subsections 3(3)(e) and (f) do not apply to a **pool participant** that provides **spinning reserve** with a **generating unit** that is equipped with an analog **governor system**, as of the effective date of this section 205.5, until such time as the **governor system** is replaced.

**(6)** A **pool participant** must ensure that, for the applicable minimum time period set out in Appendix 1, each **generating unit** or load providing **spinning reserve** will not trip as a result of under-frequency or over-frequency deviations when its **pool asset** is under a **dispatch** or a **directive** to provide **spinning reserve**.

#### Qualification of a Generating Unit or a Load

**4(1)** The **ISO** must, prior to any **generating unit** or load providing **spinning reserve**, assess the eligibility of each **generating unit** or load and determine the **real power** in MW it is qualified to provide.

**(2)** The **ISO** must, in determining the **real power** quantity each **generating unit** or load is qualified to provide, consider the following:

- (a) whether the **generating unit** or load participates in a **remedial action scheme**;
- (b) the total **operating reserve** that could be lost during a single **contingency**; and
- (c) the maximum **real power** capability and minimum **real power** capability of each **generating unit** or load.

**(3)** The **ISO** must advise a **pool participant** of the eligibility of each **generating unit** or load within sixty (60) **days** of the **ISO** receiving an application for **spinning reserve**.

#### Application to Provide Spinning Reserve

**5** A **pool participant** may apply to provide **spinning reserve** by completing and providing to the **ISO** the documents the **ISO** specifies and posts on the AESO website.

#### Performance Requirements to a Dispatch

**6(1)** A pool participant will not be paid for spinning reserve unless the **pool participant** ensures that:

- (a) upon receipt of a **dispatch** to provide **spinning reserve**, if the time stated in the **dispatch** for the **pool asset** to be in a position to provide the **real power** quantity indicated in the **dispatch** is:
  - (i) more than fifteen (15) minutes from the time the **pool participant** receives the **dispatch**, the **pool asset** is in position at the time stated in the **dispatch**; or
  - (ii) fifteen (15) minutes or less from the time the **pool participant** receives the **dispatch**, the **pool asset** is in position at the time stated in the **dispatch** or as soon as possible thereafter but in any event, not more than fifteen (15) minutes after receiving the **dispatch**; and
- (b) the **pool asset** maintains the ability to provide the **real power** quantity corresponding to the **dispatch** quantity, as measured in accordance with subsection 3(4):
  - (i) by the times set out in subsections 6(1)(a)(i) and (ii); and
  - (ii) within a tolerance of minus:

# ISO Rules

## Part 200 Markets

### Division 205 Ancillary Services

#### Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



- (A) one (1) MW for a **dispatch** of less than or equal to twenty (20) MW; or
- (B) five percent (5%) for a **dispatch** greater than twenty (20) MW;

for as long as the **dispatch** is in effect.

**(2)** A **pool participant** must ensure that the **pool asset** remains connected to the **interconnected electric system** and be frequency responsive, as described in subsection 3(3), while under a **dispatch** to provide **spinning reserve**.

#### Performance Requirements to a Directive

**7(1)** A **pool participant** must, within ten (10) minutes after receiving a **directive** to provide **spinning reserve**, ensure that the **pool asset** is providing a quantity of **real power** equal to the instantaneous amount of **real power** of the **pool asset** at the time of the **directive** plus the amount of **real power** set out in the **directive**, as measured in accordance with subsection 3(4).

**(2)** A **pool participant** must ensure that, from the first time the **pool asset** achieves the quantity of **real power** set out in subsection 7(1) to fifteen (15) minutes after the time of the **directive**, the average quantity of **real power** provided by the **pool asset** is equal to or more than the quantity set out in subsection 7(1), as measured in accordance with subsection 3(4).

**(3)** A **pool participant** must ensure that, for each consecutive ten (10) minute interval starting fifteen (15) minutes following the receipt of a **directive**, the average **real power** from the **pool asset** equals the quantity set out in subsection 7(1), as measured in accordance with subsection 3(4), within a tolerance of:

- (a) five (5) MW for a load **pool asset** or a generating **pool asset** with a **maximum capability** of two hundred (200) MW or less; or
- (b) ten (10) MW for a load **pool asset** or a generating **pool asset** with a **maximum capability** of greater than two hundred (200) MW.

**(4)** Notwithstanding subsection 3(2), a **pool participant** must ensure the **pool asset** continues to provide the average **real power** set out in subsection 7(3) for as long as the **directive** is in effect.

**(5)** A **pool participant** must ensure that the **pool asset** remains connected to the **interconnected electric system** and remains frequency responsive, as described in subsection 3(3), while under a **directive** to provide **spinning reserve**.

**(6)** Notwithstanding subsections 7(1) through 7(4), a **pool participant** following the receipt of a **directive** for **spinning reserve** to zero (0) MW must as soon as possible, and, in any event, not more than fifteen (15) minutes after receiving the **directive** to zero (0) MW:

- (a) ensure the generating **pool asset** is within the **allowable dispatch variance** of its current energy **dispatch**; or
- (b) ensure the load **pool asset** is in position to provide the **real power** quantity indicated in its current **dispatch** for **spinning reserve**.

#### Test Requirements

**8** The **ISO** may request that a **pool participant** test its **pool asset**'s responses to **dispatches** and **directives**:

- (a) prior to allowing the **pool asset** to provide **spinning reserve**; or
- (b) if the **ISO** provides evidence that the **spinning reserve** exhibits behaviour that is inconsistent with the requirements of this section 205.5.

# ISO Rules

## Part 200 Markets

### Division 205 Ancillary Services

#### Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



#### Maintaining Eligibility

**9(1)** The **ISO** may, if a **pool participant** refuses to comply with:

- (a) a testing request pursuant to subsection 8;
- (b) any other provision of this section 205.5; or
- (c) any other section of the **ISO rules** that affects the provision of **spinning reserve**;

provide notice to the **pool participant** that it cannot participate in the **spinning reserve** market until the **pool participant** is compliant with this section 205.5 and all other **ISO rules** that affect the provision of **spinning reserve**.

**(2)** A **pool participant** that has received a notice pursuant to subsection 9(1) must not submit an **offer** for **spinning reserve** until the **ISO** confirms that the **pool participant** is compliant with this section 205.5 and all other **ISO rules** that affect the provision of **spinning reserve**.

#### Appendices

Appendix 1 – *Frequency Ranges*

#### Revision History

Effective	Description
2014-12-23	Initial release

# ISO Rules

## Part 200 Markets

### Division 205 Ancillary Services

#### Section 205.5 Spinning Reserve Technical Requirements and Performance Standards



#### Appendix 1

#### Frequency Ranges

High Frequency Duration		Low Frequency Duration	
Frequency (Hz)	Time (Sec)	Frequency (Hz)	Time (sec)
≥61.7	Instantaneous trip	≤57.0	Instantaneous trip
≥61.6	30	≤57.3	0.75
≥60.6	180	≤57.8	7.5
<60.6	Continuous operation	≤58.4	30