

# ISO Rules

## Part 200 Markets

### Division 208 Operational Constraints

#### Section 208.1 Load Outage Reporting



#### Applicability

- 1 This section 208.1 applies to:
  - (a) a **market participant with load**; and
  - (b) the **ISO**.

#### Requirements

##### Load Outage Reporting

**2(1)** Subject to subsection 2(2), a **market participant** who has a planned decrease in its capability to consume load at a facility of forty (40) MW or greater, must comply with the outage reporting requirements of this section 208.1.

**(2)** Subsection 2(1) does not apply if the **market participant** has documented the decrease in a restated **available capability** for the facility, in accordance with section 203.3 of the **ISO rules**, *Restatements for Energy*.

**(3)** The **market participant** referred to in subsection 2(1) must submit to the **ISO** the following outage information, in a form the **ISO** approves and publishes on the AESO website:

- (a) the commencement date and time of the outage, but not where such date and time is historical;
- (b) the end date and time of the outage; and
- (c) the actual decrease, in MW, in the load capability.

**(4)** The **market participant** must submit the information to the **ISO** as soon as reasonably practicable after the **market participant** is aware of the outage information.

**(5)** Subsequent to the **ISO** receiving from **market participants** the submissions referred to in subsection 2(3), on each **business day** the **ISO** must aggregate all outage records for loads as submitted, and determine the aggregate daily outages in MW which the **ISO** will calculate as:

the sum of MWh of all submitted outages by time period;

divided by

the number of hours in the time period.

**(6)** Once the **ISO** has determined the aggregate daily outages under subsection 2(5), the **ISO** also must prepare a daily outage report and publish it each **business day** on the AESO website, which report must include:

- (a) the time and date the report was prepared; and
- (b) the daily average outage amount in MW, rounded to the nearest MW, for each **business day** of the then current **month** and the next three (3) successive **months**.

**(7)** Subject to subsection 2(8), the **ISO** must keep confidential all outage information for loads submitted to it under this section 208.1, except as otherwise required to be made public under the provisions of section 103.1 of the **ISO rules**, *Confidentiality*.

# ISO Rules

## Part 200 Markets

### Division 208 Operational Constraints

#### Section 208.1 Load Outage Reporting



(8) The **ISO** must publish on the AESO website the aggregate daily outage report in a manner that, in accordance with section 103.1 of the **ISO rules**, *Confidentiality*, seeks to preserve the confidential nature of any outage information as submitted by any one **market participant**, and precludes the identification of any one **market participant**, or other directly affected **pool participant**.

#### Revision History

Effective	Description
2011-09-30	Initial release
2013-01-08	Removed reference to section 3.5 <i>Offers and Bids</i> , and replaced with section 203.3 <i>Restatements for Energy</i> .