

ISO Rules

Part 300 System Reliability and Operations

Division 306 Outages and Disturbances

Section 306.6 Automatic Voltage Regulator and Power System Stabilizer Outage Reporting



Applicability

- 1 Section 306.6 applies to:
 - (a) the **legal owner** of a **generating unit** that has either an **automatic voltage regulator** or a power system stabilizer, or both;
 - (b) the **legal owner** of an **aggregated generating facility** that has either an **automatic voltage regulator** or a power system stabilizer, or both; and
 - (b) the **ISO**.

Requirements

- 2 Each **legal owner** of a **generating unit** that has an **automatic voltage regulator** must, by the fifth business **day** of each **month**, submit to the **ISO** in writing:
 - (a) the number of hours that the **generating unit** was online during the previous **month**; and
 - (b) the number of hours that the **generating unit** was online and the **automatic voltage regulator** was not operating in voltage control mode during the previous **month**.
- 3 Each **legal owner** of a **generating unit** that has a power system stabilizer must, by the fifth business **day** of each **month**, submit to the **ISO** in writing:
 - (a) the number of hours that the **generating unit** was online during the previous **month**; and
 - (b) the number of hours that the **generating unit** was online and the power system stabilizer was offline during the previous **month**.
- 4 Each **legal owner** of an **aggregated generating facility** that has an **automatic voltage regulator** must, by the fifth business **day** of each **month**, submit to the **ISO** in writing:
 - (a) the number of hours that the **aggregated generating facility** was online during the previous **month**; and
 - (b) the number of hours that the **aggregated generating facility** was online and the **automatic voltage regulator** was not operating in voltage control mode during the previous **month**.
- 5 Each **legal owner** of an **aggregated generating facility** that has a power system stabilizer must, by the fifth business **day** of each **month**, submit to the **ISO** in writing:
 - (a) the number of hours that the **aggregated generating facility** was online during the previous **month**; and
 - (b) the number of hours that the **aggregated generating facility** was online and the power system stabilizer was offline during the previous **month**.

Revision History

Effective	Description
2013-10-01	Initial release